

Building Inspected: Cozy Lake Elementary  
Address: 205 Cozy Lake Road  
Building Owner: Jefferson Twp. BOE

PEOSH INDOOR AIR QUALITY INSPECTION REPORT

Date: March 24, 2021  
Inspector: Dan Schlosser

<b>FUNCTIONAL SPACE</b>	<b>CO2</b>	<b>CO (PPM)</b>	<b>TEMPERATURE (F)</b>	<b>HUMIDITY (%)</b>
MAIN OFFICE	516	0	77.40	27
PRINCIPAL	551	0	77.80	25
BOILER	509	0	78.20	23
CST	453	0	78.00	27
KITCHEN	441	0	78.10	24
NURSES OFFICE	446	0	78.50	22
GYM	467	0	79.10	21
ROOM 107	435	0	79.00	22
ROOM 108	413	0	79.40	22
JANITOR CLOSET	413	0	79.50	22
JC OFFICE	448	0	79.30	22
ROOM 109	431	0	80.20	22

Building Inspected: Cozy Lake Elementary  
Address: 205 Cozy Lake Road  
Building Owner: Jefferson Twp. BOE

PEOSH INDOOR AIR QUALITY INSPECTION REPORT

Date: March 24, 2021  
Inspector: Dan Schlosser

<b>FUNCTIONAL SPACE</b>	<b>CO2</b>	<b>CO (PPM)</b>	<b>TEMPERATURE (F)</b>	<b>HUMIDITY (%)</b>
ROOM 101	440	0	82.10	21
ROOM 102	436	0	82.00	21
ROOM 111	438	0	82.10	21
ROOM 112	435	0	85.30	21
ROOM 103	426	0	79.70	20
ROOM 104	455	0	79.80	19
ROOM 113	417	0	79.90	19
ROOM 114	430	0	79.90	20
ROOM 105	447	0	78.7	21
ROOM 106	439	0	78.8	21
ROOM 115	447	0	78.7	20
ROOM 116	445	0	79.9	20

Building Inspected: Cozy Lake Elementary  
Address: 205 Cozy Lake Road  
Building Owner: Jefferson Twp. BOE

PEOSH INDOOR AIR QUALITY INSPECTION REPORT

Date: March 24, 2021  
Inspector: Dan Schlosser

<b>FUNCTIONAL SPACE</b>	<b>CO2</b>	<b>CO (PPM)</b>	<b>TEMPERATURE (F)</b>	<b>HUMIDITY (%)</b>
ROOM 117	456	0	79	20
ROOM 120	437	0	78.7	20
ROOM 119	446	0	79.9	19
ROOM 117	427	0	79	19
OUTSIDE SAMPLE	428	0	42.3	28