

Building Inspected: Aurther Stanlick Elementary
Address: 121 W. Shawnee Trail
Building Owner: Jefferson Twp. BOE

PEOSH INDOOR AIR QUALITY INSPECTION REPORT

Date: March 24, 2021
Inspector: Dan Schlosser

SAMPLE LOCATION	CO2 (PPM)	CO (PPM)	TEMPERATURE (F)	HUMIDITY (%)
MAIN OFFICE	575	0	69.4	41
PRINCIPAL	549	0	73.8	37
NURSES OFFICE	557	0	74.40	37
CST	566	0	74.50	36
KITCHEN	587	0	73.70	36
MULTI PURPOSE	552	0	73.60	36
ROOM 251	515	0	73.50	30
ROOM 109	518	0	73.60	30
ROOM 107	508	0	73.10	31
ROOM 105	512	0	73.10	31
ROOM 108	580	0	73.90	32

Building Inspected: Aurther Stanlick Elementary
Address: 121 W. Shawnee Trail
Building Owner: Jefferson Twp. BOE

PEOSH INDOOR AIR QUALITY INSPECTION REPORT

Date: March 24, 2021
Inspector: Dan Schlosser

SAMPLE LOCATION	CO2 (PPM)	CO (PPM)	TEMPERATURE (F)	HUMIDITY (%)
ROOM 106	519	0	73.70	35
ROOM 104	559	0	75.20	36
ROOM 324	532	0	73.20	31
ROOM 302	529	0	73.40	31
ROOM 301	531	0	73.20	31
ROOM 300	549	0	73.40	33
MEDIA ROOM	534	0	72.8	31
ROOM 323	527	0	71.9	31
ROOM 322	522	0	72	31
ROOM 321	533	0	71.6	30
ROOM 304	523	0	72.1	32

Building Inspected: Aurther Stanlick Elementary
Address: 121 W. Shawnee Trail
Building Owner: Jefferson Twp. BOE

PEOSH INDOOR AIR QUALITY INSPECTION REPORT

Date: March 24, 2021
Inspector: Dan Schlosser

SAMPLE LOCATION	CO2 (PPM)	CO (PPM)	TEMPERATURE (F)	HUMIDITY (%)
ROOM 320	521	0	71.2	35
ROOM 306	501	0	72	35
ROOM 307	508	0	71.3	35
ROOM 317	528	0	72.1	34
ROOM 316	514	0	71.2	33
ROOM 308	512	0	71.2	34
ROOM 309	503	0	71.2	35
ROOM 315	511	0	72.3	34
ROOM 314	512	0	72.4	33
ROOM 310	514	0	71	35
ROOM 311	530	0	71	35

Building Inspected: Aurther Stanlick Elementary
Address: 121 W. Shawnee Trail
Building Owner: Jefferson Twp. BOE

PEOSH INDOOR AIR QUALITY INSPECTION REPORT

Date: March 24, 2021
Inspector: Dan Schlosser

SAMPLE LOCATION	CO2 (PPM)	CO (PPM)	TEMPERATURE (F)	HUMIDITY (%)
ROOM 312	519	0	71.9	33
ROOM 313	537	0	70.8	35
ROOM 118	542	0	70.9	34
ROOM 119	528	0	71	33
ROOM 120	515	0	72.1	32
ROOM 115	508	0	71.8	33
ROOM 114	503	0	72	33
ROOM 113	505	0	71.7	34
GYM	505	0	71.8	34
ROOM 153	543	0	72.1	34
ROOM 154	548	0	72	34

Building Inspected: Aurther Stanlick Elementary
Address: 121 W. Shawnee Trail
Building Owner: Jefferson Twp. BOE

PEOSH INDOOR AIR QUALITY INSPECTION REPORT

Date: March 24, 2021
Inspector: Dan Schlosser

SAMPLE LOCATION	CO2 (PPM)	CO (PPM)	TEMPERATURE (F)	HUMIDITY (%)
ROOM 155	498	0	72.1	34
OUTSIDE SAMPLE	480	0	56.4	74