

Building Inspected: White Rock Elementary
Address: 2 Francine Place
Building Owner: Jefferson Twp. BOE

PEOSH INDOOR AIR QUALITY INSPECTION REPORT

Date: March 24, 2021
Inspector: Dan Schlosser

SAMPLE LOCATION	CO2 (PPM)	CO (PPM)	TEMPERATURE (F)	HUMIDITY (%)
MAIN OFFICE	501	0	72.60	25
PRINCIPAL	511	0	74.00	24
COPY	514	0	74.70	22
CONFERENCE ROOM	496	0	75.80	22
CST	473	0	76.00	22
MULTI PURPOSE ROOM	460	0	73.70	23
NURSE OFFICE	447	0	74.10	23
FACULTY ROOM	448	0	73.80	23
ROOM 14	471	0	74.20	23
JANITOR CLOSET	472	0	74.30	23
ROOM A12	470	0	74.3	28

Building Inspected: White Rock Elementary
Address: 2 Francine Place
Building Owner: Jefferson Twp. BOE

PEOSH INDOOR AIR QUALITY INSPECTION REPORT

Date: March 24, 2021
Inspector: Dan Schlosser

SAMPLE LOCATION	CO2 (PPM)	CO (PPM)	TEMPERATURE (F)	HUMIDITY (%)
ROOM A10	447	0	74.8	21
ROOM A11	452	0	74.8	21
ROOM A09	440	0	75.1	21
ROOM A08	427	0	75.5	21
ROOM A07	424	0	74	23
ROOM A05	430	0	74.1	22
ROOM A06	432	0	74.2	22
ROOM A04	476	0	74.3	22
ROOM A03	471	0	74.4	21
LIBRARY	435	0	72.9	22
ROOM A01	427	0	73.1	22

Building Inspected: White Rock Elementary
Address: 2 Francine Place
Building Owner: Jefferson Twp. BOE

PEOSH INDOOR AIR QUALITY INSPECTION REPORT

Date: March 24, 2021
Inspector: Dan Schlosser

SAMPLE LOCATION	CO2 (PPM)	CO (PPM)	TEMPERATURE (F)	HUMIDITY (%)
TECH	418	0	73.4	21
ROOM B04-B2	427	0	72.2	22
ROOM B03	424	0	72.3	21
ROOM B06	426	0	72.4	21
ROOM B5	434	0	72.4	21
ROOM B7	432	0	72.5	21
ROOM B8	422	0	73	22
ROOM B10	417	0	73.1	23
ROOM B12	426	0	73.1	23
ROOM B9	450	0	73.2	22
ROOM B14	442	0	73.3	23

Building Inspected: White Rock Elementary
Address: 2 Francine Place
Building Owner: Jefferson Twp. BOE

PEOSH INDOOR AIR QUALITY INSPECTION REPORT

Date: March 24, 2021
Inspector: Dan Schlosser

SAMPLE LOCATION	CO2 (PPM)	CO (PPM)	TEMPERATURE (F)	HUMIDITY (%)
ROOM B16	438	0	73.1	23
ROOM B 11	545	0	73	23
ROOM B13	442	0	73	23
ROOM C18	443	0	75.5	22
ROOM C16	445	0	75.6	22
S4	434	0	75.7	22
ROOM C14	435	0	75.8	22
ROOM C13	445	0	75.9	22
ROOM C12	451	0	75.9	21
ROOM C11	438	0	76	21
ROOM C9	442	0	76	21

Building Inspected: White Rock Elementary
Address: 2 Francine Place
Building Owner: Jefferson Twp. BOE

PEOSH INDOOR AIR QUALITY INSPECTION REPORT

Date: March 24, 2021
Inspector: Dan Schlosser

SAMPLE LOCATION	CO2 (PPM)	CO (PPM)	TEMPERATURE (F)	HUMIDITY (%)
ROOM C8	440	0	74.9	21
ROOM C7	455	0	74.7	21
ROOM C6	449	0	74.4	22
ROOM C4	444	0	74.2	22
ROOM C5 C3	413	0	74.1	21
GYM	545	0	72	21
OUTSIDE SAMPLE	454	0	57.7	38