

Questions and Answers for

CSP 26-003JO

2025 Access and Intrusion Upgrades 9.18.2025

1. The card reader schedule notes specific Hardware sets per door however there is no reference to what these sets. Please define the hardware sets. **Hardware Sets Are Released with Addendum #3**
2. Can the district provide Pictures of IDF Closets? **No, but these can be visited.**
3. Can the district provide Bosch zone lists for the schools with existing Bosch panels? **These are not needed for the current scope of work.**
4. Can you verify on the DPDT door contacts that you want one set tied into the Bosch panel with a popit and one set home run with 18/4 to an Open Options input panel? **That is the intended design.**
5. Revise the drawings **Unclear intent**
6. In the meeting it was stated that some of the sites on the drawings and in the RFP have already had Bosch systems completed. Can the District identify which sites are not be included and provide drawings of the school with to reflect location of the Bosch devices? **All necessary items are documented within the Contract Documents, please follow as documented.**
7. Would the district consider extending the bid due date by 1-2 weeks? **Construction is fine with this if Atlas & Paul are.**
8. I noticed the bid is written for Altronix/Mercury and Bosch, are you all open to receiving alternate solutions on this? **All deviation requests are lined out in Division 28 00 10 Section 2.2; follow that process for all alternate solutions.**
9. The upcoming PFISD projects have a mix of access control and intrusion systems overlapping in some cases, but the Door Position Switch callouts do not specify intrusion or access control. Does PFISD have a standard regarding which (or if all) doors will need to connect to both systems, or are we to assume only exterior entry ways are monitored by intrusion alongside access control? **Only the door position switches indicated on the drawings will be required to integrate to both systems.**
10. Hardware Set 3 shows a Power transfer hinge and an electric strike....These parts are not needed in conjunction with each other. Please clarify which it is? **Only provide the Strike, no Hinge is needed**
11. I noticed the bid is written for Altronix/Mercury and Bosch, are you all open to receiving alternate solutions on this? **All substitution requests shall be provided per Division 28 00 10 Section 2.2.**