eurofins | Environment Testing

ANALYTICAL REPORT

PREPARED FOR

Attn: Ian St. John
St. John Environmental Consulting
5515 Grace Ave.
Saint Louis, Missouri 63116

Generated 2/9/2024 1:19:58 AM

JOB DESCRIPTION

Lebanon RII School District - Esther

JOB NUMBER

810-92179-1

Eurofins Eaton Analytical South Bend
110 S Hill Street
South Bend IN 46617

See page two for job notes and contact information.

my EOL

Eurofins Eaton Analytical South Bend

Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and will meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All questions should be directed to the Eurofins Eaton Analytical, LLC Project Manager.

Authorization



Generated
2/9/2024 1:19:58 AM

Authorized for release by
Pamela Brown, Project Manager
Pamela.Brown@et.eurofinsus.com
(574)233-4777

Table of Contents

Cover Page 1
Table of Contents 3
Definitions/Glossary 4
Case Narrative 5
Detection Summary 7
Client Sample Results 20
QC Sample Results 44
QC Association Summary 52
Lab Chronicle 57
Certification Summary 81
Method Summary 82
Sample Summary 83
Chain of Custody 87
Receipt Checklists 103

Definitions/Glossary

Client: St. John Environmental Consulting
Job ID: 810-92179-1
Project/Site: Lebanon RII School District - Esther

Qualifiers

Metals

Qualifier	Qualifier Description
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
¤	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

Job ID: 810-92179-1 — Eurofins Eaton Analytical South Bend

Job Narrative
810-92179-1

Analytical test results meet all requirements of the associated regulatory program listed on the Accreditation/Certification Summary Page unless otherwise noted under the individual analysis. Data qualifiers are applied to indicate exceptions. Noncompliant quality control (QC) is further explained in narrative comments.

- Matrix QC may not be reported if insufficient sample or site-specific QC samples were not submitted. In these situations, to demonstrate precision and accuracy at a batch level, a LCS/LCSD may be performed, unless otherwise specified in the method.
- Surrogate and/or isotope dilution analyte recoveries (if applicable) which are outside of the QC window are confirmed unless attributed to a dilution or otherwise noted in the narrative.

Regulated compliance samples (e.g. SDWA, NPDES) must comply with the associated agency requirements/permits.

Receipt
The samples were received on 1/30/2024 9:00 AM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice.

Receipt Exceptions
No sample date/time on containers. Samples logged according to COC.

LE-1 Sink (810-92179-1), LE-2 Bubble (810-92179-2), LE-3 Bathroom Sink (810-92179-3), LE-4 Sink (810-92179-4), LE-5 Bubbler (810-92179-5), LE-6 WF (810-92179-6), LE-7 WF (810-92179-7), LE-8 WF (810-92179-8), LE-9 Sink (810-92179-9), LE-10 Bottle Filler (810-92179-10), LE-11 Sink (810-92179-11), LE-12 Sink (810-92179-12), LE-13 Sink (810-92179-13), LE-14 Sink (810-92179-14), LE-15 Sink (810-92179-15), LE-16 Sink (810-92179-16), LE-17 Sink (810-92179-17), LE-18 Sink (810-92179-18), LE-19 Sink (810-92179-19), LE-20 Bottle Filler (810-92179-20), LE-21 Sink (810-92179-21), LE-22 Sink (810-92179-22), LE-23 Sink (810-92179-23), LE-24 BF (810-92179-24), LE-25 Sink (810-92179-25), LE-26 WF (810-92179-26), LE-27 Sink (810-92179-27), LE-28 WF (810-92179-28), LE-29 Sink (810-92179-29), LE-30 Sink (810-92179-30), LE-31 Sink (810-92179-31), LE-32 Sink (810-92179-32), LE-33 Sink (810-92179-33), LE-34 Bubbler (810-92179-34), LE-35 Sink (810-92179-35), LE-36 Sink (810-92179-36), LE-37 Sink (810-92179-37), LE-38 BF (810-92179-38), LE-39 Sink (810-92179-39), LE-40 Sink (810-92179-40), LE-41 Sink (810-92179-41), LE-42 Sink (810-92179-42), LE-43 BF (810-92179-43), LE-44 BF (810-92179-44), LE-45 Sink (810-92179-45), LE-46 Sink (810-92179-46), LE-47 Sink (810-92179-47), LE-48 BF (810-92179-48), LE-49 Sink (810-92179-49), LE-50 WF (810-92179-50), LE-51 WF (810-92179-51), LE-52 Sink (810-92179-52), LE-53 Sink (810-92179-53), LE-54 Sink (810-92179-54), LE-55 Sink (810-92179-55), LE-56 Sink (810-92179-56), LE-57 Bublbler (810-92179-57), LE-58 Sink (810-92179-58), LE-59 Sink (810-92179-59), LE-60 Sink (810-92179-60), LE-61 Bubbler (810-92179-61), LE-62 Sink (810-92179-62), LE-63 Sink (810-92179-63), LE-64 Sink (810-92179-64), LE-65 Bubbler (810-92179-65), LE-66 Sink (810-92179-66), LE-67 Bubbler (810-92179-67), LE-68 Sink (810-92179-68), LE-69 WF (810-92179-69), LE-70 WF (810-92179-70), LE-71 Bubbler (810-92179-71), LE-72 Sink (810-92179-72), LE-73 Sink (810-92179-73), LE-74 Sink (810-92179-74), LE-75 Bubbler (810-92179-75), LE-76 Sink (810-92179-76), LE-77 Sink (810-92179-77), LE-78 Bubbler (810-92179-78), LE-79 Sink (810-92179-79), LE-80 Bubbler (810-92179-80), LE-81 Sink (810-92179-81), LE-82 Sink (810-92179-82), LE-83 Sink (810-92179-83), LE-84 Bubbler (810-92179-84), LE-85 Sink (810-92179-85), LE-86 WF (810-92179-86), LE-87 WF (810-92179-87), LE-88 Bubbler (810-92179-88), LE-89 Sink (810-92179-89), LE-90 Sink (810-92179-90), LE-91 Sink (810-92179-91), LE-92 Bubbler (810-92179-92), LE-93 Sink (810-92179-93), LE-94 Sink (810-92179-94), LE-95 Sink (810-92179-95), LE-96 Bubbler (810-92179-96), LE-97 Sink (810-92179-97), LE-98 Bubbler (810-92179-98), LE-99 Sink (810-92179-99), LE-100 Sink (810-92179-100), LE-101 Sink (810-92179-101), LE-102 Sink (810-92179-102), LE-103 Sink (810-92179-103), LE-104 Sink (810-92179-104), LE-105 WF (810-92179-105), LE-106 WF (810-92179-106), LE-107 Bubbler (810-92179-107), LE-108 Sink (810-92179-108), LE-109 Sink (810-92179-109), LE-110 Sink (810-92179-110), LE-111 Bubbler (810-92179-111), LE-112 Sink (810-92179-112), LE-113 WF (810-92179-113), LE-114 WF (810-92179-114), LE-115 Sink (810-92179-115), LE-116 Sink (810-92179-116), LE-117 Sink (810-92179-117), LE-118 Sink (810-92179-118), LE-119 Sink (810-92179-119), LE-120 Sink (810-92179-120), LE-121 Pot Filler (810-92179-121), LE-122 Pot Filler (810-92179-122), LE-123 Sink/Washer (810-92179-123), LE-124 Sink (810-92179-124), LE-125 Sink (810-92179-125), LE-126 Sink (810-92179-126), LE-127 Sink (810-92179-127), LE-128 Sink (810-92179-128), LE-129 Sink (810-92179-129), LE-130 WF (810-92179-130), LE-131 Sink (810-92179-131), LE-132 Sink (810-92179-132), LE-133 WF (810-92179-133), LE-134 Sink (810-92179-134), LE-135 Sink (810-92179-135), LE-136 Sink Room 511 (810-92179-136), LE-137 Sink (810-92179-137), LE-138 Sink (810-92179-138), LE-139 Sink (810-92179-139), LE-140 Bubbler (810-92179-140), LE-141 Sink (810-92179-141), LE-142 Bubbler (810-92179-142), LE-143 Sink (810-92179-143), LE-144 Bubbler (810-92179-144), LE-145 Sink (810-92179-145), LE-146 BF (810-92179-146), LE-147 Sink (810-92179-147), LE-148 BF (810-92179-148), LE-149 Sink (810-92179-149), LE-150 Sink (810-92179-150), LE-151 Sink (810-92179-151), LE-152 Sink (810-92179-152), LE-153 WF (810-92179-153), LE-154 Sink (810-92179-154), LE-155 Bubbler (810-92179-155), LE-156 Sink (810-92179-156), LE-157 Bubbler (810-92179-157), LE-158 WF

(810-92179-158), LE-159 Sink (810-92179-159), LE-160 Bubbler (810-92179-160), LE-161 Sink (810-92179-161), LE-162 Bubbler (810-92179-162), LE-163 Sink Room 610 (810-92179-163), LE-164 Sink (810-92179-164), LE-165 Bubbler (810-92179-165), LE-166 Sink (810-92179-166), LE-167 Bubbler (810-92179-167) and LE-168 Sink (810-92179-168)

Metals
No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Detection Summary

Client: St. John Environmental Consulting
Project/Site: Lebanon RII School District - Esther

Job ID: 810-92179-1

Client Sample ID: LE-1 Sink — Lab Sample ID: 810-92179-1

No Detections.

Client Sample ID: LE-2 Bubble — Lab Sample ID: 810-92179-2

No Detections.

Client Sample ID: LE-3 Bathroom Sink — Lab Sample ID: 810-92179-3

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.79		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-4 Sink — Lab Sample ID: 810-92179-4

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.55		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-5 Bubbler — Lab Sample ID: 810-92179-5

No Detections.

Client Sample ID: LE-6 WF — Lab Sample ID: 810-92179-6

No Detections.

Client Sample ID: LE-7 WF — Lab Sample ID: 810-92179-7

No Detections.

Client Sample ID: LE-8 WF — Lab Sample ID: 810-92179-8

No Detections.

Client Sample ID: LE-9 Sink — Lab Sample ID: 810-92179-9

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	3.7		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-10 Bottle Filler — Lab Sample ID: 810-92179-10

No Detections.

Client Sample ID: LE-11 Sink — Lab Sample ID: 810-92179-11

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	2.9		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-12 Sink — Lab Sample ID: 810-92179-12

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	2.3		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-13 Sink — Lab Sample ID: 810-92179-13

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	2.9		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-14 Sink — Lab Sample ID: 810-92179-14

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.95		0.50		ug/L	1		200.8	Total/NA

This Detection Summary does not include radiochemical test results.

Detection Summary

Client: St. John Environmental Consulting
Project/Site: Lebanon RII School District - Esther

Job ID: 810-92179-1

Client Sample ID: LE-15 Sink — Lab Sample ID: 810-92179-15

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.60		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-16 Sink — Lab Sample ID: 810-92179-16

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.1		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-17 Sink — Lab Sample ID: 810-92179-17

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.72		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-18 Sink — Lab Sample ID: 810-92179-18

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	4.7		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-19 Sink — Lab Sample ID: 810-92179-19

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	5.1		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-20 Bottle Filler — Lab Sample ID: 810-92179-20

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.70		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-21 Sink — Lab Sample ID: 810-92179-21

No Detections.

Client Sample ID: LE-22 Sink — Lab Sample ID: 810-92179-22

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.60		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-23 Sink — Lab Sample ID: 810-92179-23

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	2.0		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-24 BF — Lab Sample ID: 810-92179-24

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.1		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-25 Sink — Lab Sample ID: 810-92179-25

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.63		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-26 WF — Lab Sample ID: 810-92179-26

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.53		0.50		ug/L	1		200.8	Total/NA

This Detection Summary does not include radiochemical test results.

Detection Summary

Client: St. John Environmental Consulting
Job ID: 810-92179-1
Project/Site: Lebanon RII School District - Esther

Client Sample ID: LE-27 Sink — Lab Sample ID: 810-92179-27

No Detections.

Client Sample ID: LE-28 WF — Lab Sample ID: 810-92179-28

No Detections.

Client Sample ID: LE-29 Sink — Lab Sample ID: 810-92179-29

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.85		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-30 Sink — Lab Sample ID: 810-92179-30

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.5		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-31 Sink — Lab Sample ID: 810-92179-31

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.87		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-32 Sink — Lab Sample ID: 810-92179-32

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	3.2		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-33 Sink — Lab Sample ID: 810-92179-33

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.3		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-34 Bubbler — Lab Sample ID: 810-92179-34

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.7		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-35 Sink — Lab Sample ID: 810-92179-35

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.51		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-36 Sink — Lab Sample ID: 810-92179-36

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.4		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-37 Sink — Lab Sample ID: 810-92179-37

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	4.7		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-38 BF — Lab Sample ID: 810-92179-38

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	2.8		0.50		ug/L	1		200.8	Total/NA

This Detection Summary does not include radiochemical test results.

Detection Summary

Client: St. John Environmental Consulting
Project/Site: Lebanon RII School District - Esther

Job ID: 810-92179-1

Client Sample ID: LE-39 Sink — Lab Sample ID: 810-92179-39

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.5		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-40 Sink — Lab Sample ID: 810-92179-40

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.99		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-41 Sink — Lab Sample ID: 810-92179-41

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.9		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-42 Sink — Lab Sample ID: 810-92179-42

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.86		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-43 BF — Lab Sample ID: 810-92179-43

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	5.3		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-44 BF — Lab Sample ID: 810-92179-44

No Detections.

Client Sample ID: LE-45 Sink — Lab Sample ID: 810-92179-45

No Detections.

Client Sample ID: LE-46 Sink — Lab Sample ID: 810-92179-46

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.6		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-47 Sink — Lab Sample ID: 810-92179-47

No Detections.

Client Sample ID: LE-48 BF — Lab Sample ID: 810-92179-48

No Detections.

Client Sample ID: LE-49 Sink — Lab Sample ID: 810-92179-49

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.7		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-50 WF — Lab Sample ID: 810-92179-50

No Detections.

Client Sample ID: LE-51 WF — Lab Sample ID: 810-92179-51

No Detections.

This Detection Summary does not include radiochemical test results.

Detection Summary

Client: St. John Environmental Consulting
Project/Site: Lebanon RII School District - Esther

Job ID: 810-92179-1

Client Sample ID: LE-52 Sink — Lab Sample ID: 810-92179-52

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	2.9		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-53 Sink — Lab Sample ID: 810-92179-53

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.5		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-54 Sink — Lab Sample ID: 810-92179-54

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.64		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-55 Sink — Lab Sample ID: 810-92179-55

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.55		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-56 Sink — Lab Sample ID: 810-92179-56

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.6		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-57 Bublbler — Lab Sample ID: 810-92179-57

No Detections.

Client Sample ID: LE-58 Sink — Lab Sample ID: 810-92179-58

No Detections.

Client Sample ID: LE-59 Sink — Lab Sample ID: 810-92179-59

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.2		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-60 Sink — Lab Sample ID: 810-92179-60

No Detections.

Client Sample ID: LE-61 Bubbler — Lab Sample ID: 810-92179-61

No Detections.

Client Sample ID: LE-62 Sink — Lab Sample ID: 810-92179-62

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	2.0		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-63 Sink — Lab Sample ID: 810-92179-63

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	2.9		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-64 Sink — Lab Sample ID: 810-92179-64

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.76		0.50		ug/L	1		200.8	Total/NA

This Detection Summary does not include radiochemical test results.

Detection Summary

Client: St. John Environmental Consulting
Job ID: 810-92179-1
Project/Site: Lebanon RII School District - Esther

Client Sample ID: LE-65 Bubbler — Lab Sample ID: 810-92179-65

No Detections.

Client Sample ID: LE-66 Sink — Lab Sample ID: 810-92179-66

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.3		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-67 Bubbler — Lab Sample ID: 810-92179-67

No Detections.

Client Sample ID: LE-68 Sink — Lab Sample ID: 810-92179-68

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.69		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-69 WF — Lab Sample ID: 810-92179-69

No Detections.

Client Sample ID: LE-70 WF — Lab Sample ID: 810-92179-70

No Detections.

Client Sample ID: LE-71 Bubbler — Lab Sample ID: 810-92179-71

No Detections.

Client Sample ID: LE-72 Sink — Lab Sample ID: 810-92179-72

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.84		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-73 Sink — Lab Sample ID: 810-92179-73

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.89		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-74 Sink — Lab Sample ID: 810-92179-74

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.1		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-75 Bubbler — Lab Sample ID: 810-92179-75

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	2.4		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-76 Sink — Lab Sample ID: 810-92179-76

No Detections.

Client Sample ID: LE-77 Sink — Lab Sample ID: 810-92179-77

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.53		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-78 Bubbler — Lab Sample ID: 810-92179-78

No Detections.

This Detection Summary does not include radiochemical test results.

Eurofins Eaton Analytical South Bend

Detection Summary

Client: St. John Environmental Consulting
Project/Site: Lebanon RII School District - Esther

Job ID: 810-92179-1

Client Sample ID: LE-79 Sink — Lab Sample ID: 810-92179-79

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	4.3		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-80 Bubbler — Lab Sample ID: 810-92179-80

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.60		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-81 Sink — Lab Sample ID: 810-92179-81

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	2.2		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-82 Sink — Lab Sample ID: 810-92179-82

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	2.2		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-83 Sink — Lab Sample ID: 810-92179-83

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.63		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-84 Bubbler — Lab Sample ID: 810-92179-84

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.66		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-85 Sink — Lab Sample ID: 810-92179-85

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	2.0		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-86 WF — Lab Sample ID: 810-92179-86

No Detections.

Client Sample ID: LE-87 WF — Lab Sample ID: 810-92179-87

No Detections.

Client Sample ID: LE-88 Bubbler — Lab Sample ID: 810-92179-88

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.51		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-89 Sink — Lab Sample ID: 810-92179-89

No Detections.

Client Sample ID: LE-90 Sink — Lab Sample ID: 810-92179-90

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	2.0		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-91 Sink — Lab Sample ID: 810-92179-91

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.55		0.50		ug/L	1		200.8	Total/NA

This Detection Summary does not include radiochemical test results.

Detection Summary

Client: St. John Environmental Consulting
Job ID: 810-92179-1
Project/Site: Lebanon RII School District - Esther

Client Sample ID: LE-92 Bubbler — Lab Sample ID: 810-92179-92

No Detections.

Client Sample ID: LE-93 Sink — Lab Sample ID: 810-92179-93

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.67		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-94 Sink — Lab Sample ID: 810-92179-94

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.65		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-95 Sink — Lab Sample ID: 810-92179-95

No Detections.

Client Sample ID: LE-96 Bubbler — Lab Sample ID: 810-92179-96

No Detections.

Client Sample ID: LE-97 Sink — Lab Sample ID: 810-92179-97

No Detections.

Client Sample ID: LE-98 Bubbler — Lab Sample ID: 810-92179-98

No Detections.

Client Sample ID: LE-99 Sink — Lab Sample ID: 810-92179-99

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	2.1		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-100 Sink — Lab Sample ID: 810-92179-100

No Detections.

Client Sample ID: LE-101 Sink — Lab Sample ID: 810-92179-101

No Detections.

Client Sample ID: LE-102 Sink — Lab Sample ID: 810-92179-102

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.8		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-103 Sink — Lab Sample ID: 810-92179-103

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	2.9		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-104 Sink — Lab Sample ID: 810-92179-104

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	5.5		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-105 WF — Lab Sample ID: 810-92179-105

No Detections.

This Detection Summary does not include radiochemical test results.

Detection Summary

Client: St. John Environmental Consulting
Project/Site: Lebanon RII School District - Esther

Job ID: 810-92179-1

Client Sample ID: LE-106 WF — Lab Sample ID: 810-92179-106

No Detections.

Client Sample ID: LE-107 Bubbler — Lab Sample ID: 810-92179-107

No Detections.

Client Sample ID: LE-108 Sink — Lab Sample ID: 810-92179-108

No Detections.

Client Sample ID: LE-109 Sink — Lab Sample ID: 810-92179-109

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.78		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-110 Sink — Lab Sample ID: 810-92179-110

No Detections.

Client Sample ID: LE-111 Bubbler — Lab Sample ID: 810-92179-111

No Detections.

Client Sample ID: LE-112 Sink — Lab Sample ID: 810-92179-112

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	2.2		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-113 WF — Lab Sample ID: 810-92179-113

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.72		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-114 WF — Lab Sample ID: 810-92179-114

No Detections.

Client Sample ID: LE-115 Sink — Lab Sample ID: 810-92179-115

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.5		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-116 Sink — Lab Sample ID: 810-92179-116

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	13		0.50		ug/L	1		200.8	Total Recoverable

Client Sample ID: LE-117 Sink — Lab Sample ID: 810-92179-117

No Detections.

Client Sample ID: LE-118 Sink — Lab Sample ID: 810-92179-118

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	2.7		0.50		ug/L	1		200.8	Total/NA

This Detection Summary does not include radiochemical test results.

Detection Summary

Client: St. John Environmental Consulting
Job ID: 810-92179-1
Project/Site: Lebanon RII School District - Esther

Client Sample ID: LE-119 Sink — Lab Sample ID: 810-92179-119

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.0		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-120 Sink — Lab Sample ID: 810-92179-120

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	5.2		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-121 Pot Filler — Lab Sample ID: 810-92179-121

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.54		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-122 Pot Filler — Lab Sample ID: 810-92179-122

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.90		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-123 Sink/Washer — Lab Sample ID: 810-92179-123

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	4.8		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-124 Sink — Lab Sample ID: 810-92179-124

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	3.7		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-125 Sink — Lab Sample ID: 810-92179-125

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	3.2		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-126 Sink — Lab Sample ID: 810-92179-126

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.6		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-127 Sink — Lab Sample ID: 810-92179-127

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.0		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-128 Sink — Lab Sample ID: 810-92179-128

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.61		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-129 Sink — Lab Sample ID: 810-92179-129

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.90		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-130 WF — Lab Sample ID: 810-92179-130

No Detections.

This Detection Summary does not include radiochemical test results.

Detection Summary

Client: St. John Environmental Consulting
Project/Site: Lebanon RII School District - Esther

Job ID: 810-92179-1

Client Sample ID: LE-131 Sink — Lab Sample ID: 810-92179-131

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.6		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-132 Sink — Lab Sample ID: 810-92179-132

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.53		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-133 WF — Lab Sample ID: 810-92179-133

No Detections.

Client Sample ID: LE-134 Sink — Lab Sample ID: 810-92179-134

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.0		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-135 Sink — Lab Sample ID: 810-92179-135

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	2.5		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-136 Sink Room 511 — Lab Sample ID: 810-92179-136

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	11		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-137 Sink — Lab Sample ID: 810-92179-137

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.64		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-138 Sink — Lab Sample ID: 810-92179-138

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.1		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-139 Sink — Lab Sample ID: 810-92179-139

No Detections.

Client Sample ID: LE-140 Bubbler — Lab Sample ID: 810-92179-140

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.50		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-141 Sink — Lab Sample ID: 810-92179-141

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.4		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-142 Bubbler — Lab Sample ID: 810-92179-142

No Detections.

Client Sample ID: LE-143 Sink — Lab Sample ID: 810-92179-143

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.60		0.50		ug/L	1		200.8	Total/NA

This Detection Summary does not include radiochemical test results.

Detection Summary

Client: St. John Environmental Consulting
Project/Site: Lebanon RII School District - Esther

Job ID: 810-92179-1

Client Sample ID: LE-144 Bubbler — Lab Sample ID: 810-92179-144

No Detections.

Client Sample ID: LE-145 Sink — Lab Sample ID: 810-92179-145

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.4		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-146 BF — Lab Sample ID: 810-92179-146

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.88		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-147 Sink — Lab Sample ID: 810-92179-147

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.63		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-148 BF — Lab Sample ID: 810-92179-148

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.8		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-149 Sink — Lab Sample ID: 810-92179-149

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.1		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-150 Sink — Lab Sample ID: 810-92179-150

No Detections.

Client Sample ID: LE-151 Sink — Lab Sample ID: 810-92179-151

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.92		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-152 Sink — Lab Sample ID: 810-92179-152

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.2		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-153 WF — Lab Sample ID: 810-92179-153

No Detections.

Client Sample ID: LE-154 Sink — Lab Sample ID: 810-92179-154

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.66		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-155 Bubbler — Lab Sample ID: 810-92179-155

No Detections.

Client Sample ID: LE-156 Sink — Lab Sample ID: 810-92179-156

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.3		0.50		ug/L	1		200.8	Total/NA

This Detection Summary does not include radiochemical test results.

Detection Summary

Client: St. John Environmental Consulting
Project/Site: Lebanon RII School District - Esther

Job ID: 810-92179-1

Client Sample ID: LE-157 Bubbler — Lab Sample ID: 810-92179-157

No Detections.

Client Sample ID: LE-158 WF — Lab Sample ID: 810-92179-158

No Detections.

Client Sample ID: LE-159 Sink — Lab Sample ID: 810-92179-159

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.7		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-160 Bubbler — Lab Sample ID: 810-92179-160

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.54		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-161 Sink — Lab Sample ID: 810-92179-161

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.96		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-162 Bubbler — Lab Sample ID: 810-92179-162

No Detections.

Client Sample ID: LE-163 Sink Room 610 — Lab Sample ID: 810-92179-163

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	7.7		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-164 Sink — Lab Sample ID: 810-92179-164

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.94		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-165 Bubbler — Lab Sample ID: 810-92179-165

No Detections.

Client Sample ID: LE-166 Sink — Lab Sample ID: 810-92179-166

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.97		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LE-167 Bubbler — Lab Sample ID: 810-92179-167

No Detections.

Client Sample ID: LE-168 Sink — Lab Sample ID: 810-92179-168

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.1		0.50		ug/L	1		200.8	Total/NA

This Detection Summary does not include radiochemical test results.

Client: St. John Environmental Consulting
Project/Site: Lebanon RII School District - Esther

Job ID: 810-92179-1

Client Sample ID: LE-1 Sink
Lab Sample ID: 810-92179-1
Date Collected: 01/26/24 04:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/06/24 12:19	1

Client Sample ID: LE-2 Bubble
Lab Sample ID: 810-92179-2
Date Collected: 01/26/24 04:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/06/24 12:20	1

Client Sample ID: LE-3 Bathroom Sink
Lab Sample ID: 810-92179-3
Date Collected: 01/26/24 04:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	**0.79**		0.50		ug/L			02/06/24 12:22	1

Client Sample ID: LE-4 Sink
Lab Sample ID: 810-92179-4
Date Collected: 01/26/24 04:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	**0.55**		0.50		ug/L			02/06/24 12:23	1

Client Sample ID: LE-5 Bubbler
Lab Sample ID: 810-92179-5
Date Collected: 01/26/24 04:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/06/24 12:28	1

Client Sample ID: LE-6 WF
Lab Sample ID: 810-92179-6
Date Collected: 01/26/24 04:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/06/24 12:29	1

Client Sample ID: LE-7 WF
Lab Sample ID: 810-92179-7
Date Collected: 01/26/24 04:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/06/24 12:31	1

Client Sample ID: LE-8 WF
Lab Sample ID: 810-92179-8
Date Collected: 01/26/24 04:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/06/24 12:32	1

Client Sample ID: LE-9 Sink
Lab Sample ID: 810-92179-9
Date Collected: 01/26/24 04:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	**3.7**		0.50		ug/L			02/06/24 12:34	1

Client Sample ID: LE-10 Bottle Filler
Lab Sample ID: 810-92179-10
Date Collected: 01/26/24 04:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/06/24 12:39	1

Client Sample ID: LE-11 Sink
Lab Sample ID: 810-92179-11
Date Collected: 01/26/24 04:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	**2.9**		0.50		ug/L			02/06/24 12:40	1

Client Sample ID: LE-12 Sink
Lab Sample ID: 810-92179-12
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	**2.3**		0.50		ug/L			02/06/24 12:42	1

Client Sample ID: LE-13 Sink
Lab Sample ID: 810-92179-13
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	**2.9**		0.50		ug/L			02/06/24 12:43	1

Client Sample ID: LE-14 Sink
Lab Sample ID: 810-92179-14
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	**0.95**		0.50		ug/L			02/06/24 12:45	1

Client Sample ID: LE-15 Sink
Lab Sample ID: 810-92179-15
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.60		0.50		ug/L			02/06/24 12:52	1

Client Sample ID: LE-16 Sink
Lab Sample ID: 810-92179-16
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.1		0.50		ug/L			02/06/24 12:54	1

Client Sample ID: LE-17 Sink
Lab Sample ID: 810-92179-17
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.72		0.50		ug/L			02/06/24 12:56	1

Client Sample ID: LE-18 Sink
Lab Sample ID: 810-92179-18
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	4.7		0.50		ug/L			02/06/24 12:57	1

Client Sample ID: LE-19 Sink
Lab Sample ID: 810-92179-19
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	5.1		0.50		ug/L			02/06/24 12:59	1

Client Sample ID: LE-20 Bottle Filler
Lab Sample ID: 810-92179-20
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.70		0.50		ug/L			02/06/24 13:00	1

Client Sample ID: LE-21 Sink
Lab Sample ID: 810-92179-21
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/06/24 13:05	1

Client Sample ID: LE-22 Sink
Lab Sample ID: 810-92179-22
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.60		0.50		ug/L			02/06/24 13:06	1

Client Sample ID: LE-23 Sink
Lab Sample ID: 810-92179-23
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.0		0.50		ug/L			02/06/24 13:08	1

Client Sample ID: LE-24 BF
Lab Sample ID: 810-92179-24
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.1		0.50		ug/L			02/06/24 13:09	1

Client Sample ID: LE-25 Sink
Lab Sample ID: 810-92179-25
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.63		0.50		ug/L			02/06/24 13:14	1

Client Sample ID: LE-26 WF
Lab Sample ID: 810-92179-26
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.53		0.50		ug/L			02/06/24 13:16	1

Client Sample ID: LE-27 Sink
Lab Sample ID: 810-92179-27
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/06/24 13:17	1

Client Sample ID: LE-28 WF
Lab Sample ID: 810-92179-28
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/06/24 13:19	1

Client Sample ID: LE-29 Sink
Lab Sample ID: 810-92179-29
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.85		0.50		ug/L			02/06/24 13:20	1

Client Sample ID: LE-30 Sink
Lab Sample ID: 810-92179-30
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.5		0.50		ug/L			02/06/24 13:22	1

Client Sample ID: LE-31 Sink
Lab Sample ID: 810-92179-31
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.87		0.50		ug/L			02/06/24 13:23	1

Client Sample ID: LE-32 Sink
Lab Sample ID: 810-92179-32
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.2		0.50		ug/L			02/06/24 13:28	1

Client Sample ID: LE-33 Sink
Lab Sample ID: 810-92179-33
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.3		0.50		ug/L			02/06/24 13:30	1

Client Sample ID: LE-34 Bubbler
Lab Sample ID: 810-92179-34
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.7		0.50		ug/L			02/06/24 13:31	1

Client Sample ID: LE-35 Sink
Lab Sample ID: 810-92179-35
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.51		0.50		ug/L			02/06/24 15:49	1

Client Sample ID: LE-36 Sink
Lab Sample ID: 810-92179-36
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.4		0.50		ug/L			02/06/24 15:54	1

Client Sample ID: LE-37 Sink
Lab Sample ID: 810-92179-37
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	4.7		0.50		ug/L			02/06/24 15:56	1

Client Sample ID: LE-38 BF
Lab Sample ID: 810-92179-38
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.8		0.50		ug/L			02/06/24 15:57	1

Client Sample ID: LE-39 Sink
Lab Sample ID: 810-92179-39
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.5		0.50		ug/L			02/06/24 15:59	1

Client Sample ID: LE-40 Sink
Lab Sample ID: 810-92179-40
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.99		0.50		ug/L			02/06/24 16:00	1

Client Sample ID: LE-41 Sink
Lab Sample ID: 810-92179-41
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.9		0.50		ug/L			02/06/24 16:02	1

Client Sample ID: LE-42 Sink
Lab Sample ID: 810-92179-42
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.86		0.50		ug/L			02/06/24 16:03	1

Client Sample ID: LE-43 BF
Lab Sample ID: 810-92179-43
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	5.3		0.50		ug/L			02/06/24 16:05	1

Client Sample ID: LE-44 BF
Lab Sample ID: 810-92179-44
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/06/24 16:06	1

Client Sample ID: LE-45 Sink
Lab Sample ID: 810-92179-45
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/06/24 16:11	1

Client Sample ID: LE-46 Sink
Lab Sample ID: 810-92179-46
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.6		0.50		ug/L			02/06/24 16:13	1

Client Sample ID: LE-47 Sink
Lab Sample ID: 810-92179-47
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/06/24 16:17	1

Client Sample ID: LE-48 BF
Lab Sample ID: 810-92179-48
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/06/24 16:19	1

Client Sample ID: LE-49 Sink
Lab Sample ID: 810-92179-49
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.7		0.50		ug/L			02/06/24 16:20	1

Client Sample ID: LE-50 WF
Lab Sample ID: 810-92179-50
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/06/24 16:22	1

Client Sample ID: LE-51 WF
Lab Sample ID: 810-92179-51
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/06/24 16:23	1

Client Sample ID: LE-52 Sink
Lab Sample ID: 810-92179-52
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	**2.9**		0.50		ug/L			02/06/24 16:25	1

Client Sample ID: LE-53 Sink
Lab Sample ID: 810-92179-53
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	**1.5**		0.50		ug/L			02/06/24 16:26	1

Client Sample ID: LE-54 Sink
Lab Sample ID: 810-92179-54
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	**0.64**		0.50		ug/L			02/06/24 16:28	1

Client Sample ID: LE-55 Sink
Lab Sample ID: 810-92179-55
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	**0.55**		0.50		ug/L			02/06/24 16:36	1

Client Sample ID: LE-56 Sink
Lab Sample ID: 810-92179-56
Date Collected: 01/26/24 04:50
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	**1.6**		0.50		ug/L			02/06/24 16:37	1

Client Sample ID: LE-57 Bublbler
Lab Sample ID: 810-92179-57
Date Collected: 01/26/24 04:50
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/06/24 16:39	1

Client Sample ID: LE-58 Sink
Lab Sample ID: 810-92179-58
Date Collected: 01/26/24 04:50
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/06/24 16:43	1

Client Sample ID: LE-59 Sink
Lab Sample ID: 810-92179-59
Date Collected: 01/26/24 04:50
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	**1.2**		0.50		ug/L			02/06/24 16:45	1

Client Sample ID: LE-60 Sink
Lab Sample ID: 810-92179-60
Date Collected: 01/26/24 04:50
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/06/24 16:46	1

Client Sample ID: LE-61 Bubbler
Lab Sample ID: 810-92179-61
Date Collected: 01/26/24 04:50
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/06/24 16:48	1

Client Sample ID: LE-62 Sink
Lab Sample ID: 810-92179-62
Date Collected: 01/26/24 04:50
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	**2.0**		0.50		ug/L			02/06/24 16:50	1

Client Sample ID: LE-63 Sink
Lab Sample ID: 810-92179-63
Date Collected: 01/26/24 04:50
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	**2.9**		0.50		ug/L			02/06/24 16:51	1

Client Sample ID: LE-64 Sink
Lab Sample ID: 810-92179-64
Date Collected: 01/26/24 04:50
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.76		0.50		ug/L			02/06/24 16:53	1

Client Sample ID: LE-65 Bubbler
Lab Sample ID: 810-92179-65
Date Collected: 01/26/24 04:50
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/06/24 16:57	1

Client Sample ID: LE-66 Sink
Lab Sample ID: 810-92179-66
Date Collected: 01/26/24 04:50
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.3		0.50		ug/L			02/06/24 16:59	1

Client Sample ID: LE-67 Bubbler
Lab Sample ID: 810-92179-67
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/06/24 17:00	1

Client Sample ID: LE-68 Sink
Lab Sample ID: 810-92179-68
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.69		0.50		ug/L			02/06/24 17:02	1

Client Sample ID: LE-69 WF
Lab Sample ID: 810-92179-69
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/06/24 17:07	1

Client Sample ID: LE-70 WF
Lab Sample ID: 810-92179-70
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/06/24 17:08	1

Client Sample ID: LE-71 Bubbler
Lab Sample ID: 810-92179-71
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/06/24 17:10	1

Client Sample ID: LE-72 Sink
Lab Sample ID: 810-92179-72
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	**0.84**		0.50		ug/L			02/06/24 17:11	1

Client Sample ID: LE-73 Sink
Lab Sample ID: 810-92179-73
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	**0.89**		0.50		ug/L			02/06/24 17:13	1

Client Sample ID: LE-74 Sink
Lab Sample ID: 810-92179-74
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	**1.1**		0.50		ug/L			02/06/24 17:14	1

Client Sample ID: LE-75 Bubbler
Lab Sample ID: 810-92179-75
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	**2.4**		0.50		ug/L			02/06/24 17:22	1

Client Sample ID: LE-76 Sink
Lab Sample ID: 810-92179-76
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/06/24 17:23	1

Client Sample ID: LE-77 Sink
Lab Sample ID: 810-92179-77
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	**0.53**		0.50		ug/L			02/06/24 17:28	1

Client Sample ID: LE-78 Bubbler
Lab Sample ID: 810-92179-78
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/06/24 17:30	1

Client Sample ID: LE-79 Sink
Lab Sample ID: 810-92179-79
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	**4.3**		0.50		ug/L			02/06/24 17:31	1

Client Sample ID: LE-80 Bubbler
Lab Sample ID: 810-92179-80
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	**0.60**		0.50		ug/L			02/06/24 17:33	1

Client Sample ID: LE-81 Sink
Lab Sample ID: 810-92179-81
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	**2.2**		0.50		ug/L			02/06/24 17:34	1

Client Sample ID: LE-82 Sink
Lab Sample ID: 810-92179-82
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	**2.2**		0.50		ug/L			02/06/24 17:36	1

Client Sample ID: LE-83 Sink
Lab Sample ID: 810-92179-83
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	**0.63**		0.50		ug/L			02/06/24 17:37	1

Client Sample ID: LE-84 Bubbler
Lab Sample ID: 810-92179-84
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	**0.66**		0.50		ug/L			02/06/24 17:39	1

Client Sample ID: LE-85 Sink
Lab Sample ID: 810-92179-85
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	**2.0**		0.50		ug/L			02/06/24 17:43	1

Client Sample ID: LE-86 WF
Lab Sample ID: 810-92179-86
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/06/24 17:45	1

Client Sample ID: LE-87 WF
Lab Sample ID: 810-92179-87
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/06/24 17:47	1

Client Sample ID: LE-88 Bubbler
Lab Sample ID: 810-92179-88
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	**0.51**		0.50		ug/L			02/06/24 17:51	1

Client Sample ID: LE-89 Sink
Lab Sample ID: 810-92179-89
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/06/24 17:53	1

Client Sample ID: LE-90 Sink
Lab Sample ID: 810-92179-90
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	**2.0**		0.50		ug/L			02/06/24 17:54	1

Client Sample ID: LE-91 Sink
Lab Sample ID: 810-92179-91
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	**0.55**		0.50		ug/L			02/06/24 17:56	1

Client Sample ID: LE-92 Bubbler
Lab Sample ID: 810-92179-92
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/06/24 17:57	1

Client Sample ID: LE-93 Sink
Lab Sample ID: 810-92179-93
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	**0.67**		0.50		ug/L			02/06/24 17:59	1

Client Sample ID: LE-94 Sink
Lab Sample ID: 810-92179-94
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	**0.65**		0.50		ug/L			02/06/24 18:00	1

Client Sample ID: LE-95 Sink
Lab Sample ID: 810-92179-95
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/06/24 18:08	1

Client Sample ID: LE-96 Bubbler
Lab Sample ID: 810-92179-96
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/06/24 18:10	1

Client Sample ID: LE-97 Sink
Lab Sample ID: 810-92179-97
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/06/24 18:11	1

Client Sample ID: LE-98 Bubbler
Lab Sample ID: 810-92179-98
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/06/24 18:13	1

Client Sample ID: LE-99 Sink
Lab Sample ID: 810-92179-99
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.1		0.50		ug/L			02/06/24 18:17	1

Client Sample ID: LE-100 Sink
Lab Sample ID: 810-92179-100
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/06/24 18:19	1

Client Sample ID: LE-101 Sink
Lab Sample ID: 810-92179-101
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/06/24 18:20	1

Client Sample ID: LE-102 Sink
Lab Sample ID: 810-92179-102
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.8		0.50		ug/L			02/06/24 18:22	1

Client Sample ID: LE-103 Sink
Lab Sample ID: 810-92179-103
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.9		0.50		ug/L			02/06/24 18:23	1

Client Sample ID: LE-104 Sink
Lab Sample ID: 810-92179-104
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	5.5		0.50		ug/L			02/06/24 18:25	1

Client Sample ID: LE-105 WF
Lab Sample ID: 810-92179-105
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/06/24 18:30	1

Client: St. John Environmental Consulting
Project/Site: Lebanon RII School District - Esther

Job ID: 810-92179-1

Client Sample ID: LE-106 WF

Lab Sample ID: 810-92179-106

Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/06/24 18:31	1

Client Sample ID: LE-107 Bubbler

Lab Sample ID: 810-92179-107

Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/06/24 18:33	1

Client Sample ID: LE-108 Sink

Lab Sample ID: 810-92179-108

Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/06/24 18:34	1

Client Sample ID: LE-109 Sink

Lab Sample ID: 810-92179-109

Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	**0.78**		0.50		ug/L			02/06/24 18:36	1

Client Sample ID: LE-110 Sink

Lab Sample ID: 810-92179-110

Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/06/24 18:40	1

Client Sample ID: LE-111 Bubbler

Lab Sample ID: 810-92179-111

Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/06/24 18:42	1

Client Sample ID: LE-112 Sink

Lab Sample ID: 810-92179-112

Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	**2.2**		0.50		ug/L			02/06/24 18:43	1

Client Sample ID: LE-113 WF — **Lab Sample ID: 810-92179-113**
Date Collected: 01/26/24 05:00 — **Matrix: Drinking Water**
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.72		0.50		ug/L			02/06/24 18:45	1

Client Sample ID: LE-114 WF — **Lab Sample ID: 810-92179-114**
Date Collected: 01/26/24 05:00 — **Matrix: Drinking Water**
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/06/24 18:47	1

Client Sample ID: LE-115 Sink — **Lab Sample ID: 810-92179-115**
Date Collected: 01/26/24 05:00 — **Matrix: Drinking Water**
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.5		0.50		ug/L			02/06/24 18:54	1

Client Sample ID: LE-116 Sink — **Lab Sample ID: 810-92179-116**
Date Collected: 01/26/24 05:00 — **Matrix: Drinking Water**
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS) - Total Recoverable

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	13		0.50		ug/L		02/07/24 11:55	02/08/24 14:17	1

Client Sample ID: LE-117 Sink — **Lab Sample ID: 810-92179-117**
Date Collected: 01/26/24 05:00 — **Matrix: Drinking Water**
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/06/24 18:56	1

Client Sample ID: LE-118 Sink — **Lab Sample ID: 810-92179-118**
Date Collected: 01/26/24 05:00 — **Matrix: Drinking Water**
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.7		0.50		ug/L			02/06/24 18:57	1

Client Sample ID: LE-119 Sink — **Lab Sample ID: 810-92179-119**
Date Collected: 01/26/24 05:00 — **Matrix: Drinking Water**
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.0		0.50		ug/L			02/06/24 19:02	1

Client Sample ID: LE-120 Sink

Lab Sample ID: 810-92179-120

Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	5.2		0.50		ug/L			02/06/24 19:03	1

Client Sample ID: LE-121 Pot Filler

Lab Sample ID: 810-92179-121

Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.54		0.50		ug/L			02/06/24 19:05	1

Client Sample ID: LE-122 Pot Filler

Lab Sample ID: 810-92179-122

Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.90		0.50		ug/L			02/06/24 19:07	1

Client Sample ID: LE-123 Sink/Washer

Lab Sample ID: 810-92179-123

Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	4.8		0.50		ug/L			02/06/24 19:08	1

Client Sample ID: LE-124 Sink

Lab Sample ID: 810-92179-124

Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.7		0.50		ug/L			02/06/24 19:10	1

Client Sample ID: LE-125 Sink

Lab Sample ID: 810-92179-125

Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.2		0.50		ug/L			02/06/24 19:11	1

Client Sample ID: LE-126 Sink

Lab Sample ID: 810-92179-126

Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.6		0.50		ug/L			02/06/24 19:16	1

Client Sample ID: LE-127 Sink — **Lab Sample ID: 810-92179-127**
Date Collected: 01/26/24 05:00 — **Matrix: Drinking Water**
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.0		0.50		ug/L			02/06/24 19:17	1

Client Sample ID: LE-128 Sink — **Lab Sample ID: 810-92179-128**
Date Collected: 01/26/24 05:00 — **Matrix: Drinking Water**
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.61		0.50		ug/L			02/06/24 19:19	1

Client Sample ID: LE-129 Sink — **Lab Sample ID: 810-92179-129**
Date Collected: 01/26/24 05:00 — **Matrix: Drinking Water**
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.90		0.50		ug/L			02/06/24 19:20	1

Client Sample ID: LE-130 WF — **Lab Sample ID: 810-92179-130**
Date Collected: 01/26/24 05:00 — **Matrix: Drinking Water**
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/06/24 19:25	1

Client Sample ID: LE-131 Sink — **Lab Sample ID: 810-92179-131**
Date Collected: 01/26/24 05:00 — **Matrix: Drinking Water**
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.6		0.50		ug/L			02/06/24 19:27	1

Client Sample ID: LE-132 Sink — **Lab Sample ID: 810-92179-132**
Date Collected: 01/26/24 05:00 — **Matrix: Drinking Water**
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.53		0.50		ug/L			02/06/24 19:28	1

Client Sample ID: LE-133 WF — **Lab Sample ID: 810-92179-133**
Date Collected: 01/26/24 05:00 — **Matrix: Drinking Water**
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/06/24 19:30	1

Client Sample ID: LE-134 Sink

Lab Sample ID: 810-92179-134

Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.0		0.50		ug/L			02/06/24 19:31	1

Client Sample ID: LE-135 Sink

Lab Sample ID: 810-92179-135

Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.5		0.50		ug/L			02/06/24 19:33	1

Client Sample ID: LE-136 Sink Room 511

Lab Sample ID: 810-92179-136

Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	11		0.50		ug/L			02/06/24 19:40	1

Client Sample ID: LE-137 Sink

Lab Sample ID: 810-92179-137

Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.64		0.50		ug/L			02/06/24 19:42	1

Client Sample ID: LE-138 Sink

Lab Sample ID: 810-92179-138

Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.1		0.50		ug/L			02/06/24 19:44	1

Client Sample ID: LE-139 Sink

Lab Sample ID: 810-92179-139

Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/06/24 19:45	1

Client Sample ID: LE-140 Bubbler

Lab Sample ID: 810-92179-140

Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.50		0.50		ug/L			02/06/24 19:47	1

Client Sample ID: LE-141 Sink
Lab Sample ID: 810-92179-141
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.4		0.50		ug/L			02/06/24 19:51	1

Client Sample ID: LE-142 Bubbler
Lab Sample ID: 810-92179-142
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/06/24 19:53	1

Client Sample ID: LE-143 Sink
Lab Sample ID: 810-92179-143
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.60		0.50		ug/L			02/06/24 19:54	1

Client Sample ID: LE-144 Bubbler
Lab Sample ID: 810-92179-144
Date Collected: 01/26/24 05:10
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/06/24 19:56	1

Client Sample ID: LE-145 Sink
Lab Sample ID: 810-92179-145
Date Collected: 01/26/24 05:10
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.4		0.50		ug/L			02/06/24 19:57	1

Client Sample ID: LE-146 BF
Lab Sample ID: 810-92179-146
Date Collected: 01/26/24 05:10
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.88		0.50		ug/L			02/06/24 20:02	1

Client Sample ID: LE-147 Sink
Lab Sample ID: 810-92179-147
Date Collected: 01/26/24 05:10
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.63		0.50		ug/L			02/06/24 20:04	1

Client Sample ID: LE-148 BF
Lab Sample ID: 810-92179-148
Date Collected: 01/26/24 05:10
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.8		0.50		ug/L			02/06/24 20:05	1

Client Sample ID: LE-149 Sink
Lab Sample ID: 810-92179-149
Date Collected: 01/26/24 05:10
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.1		0.50		ug/L			02/06/24 20:07	1

Client Sample ID: LE-150 Sink
Lab Sample ID: 810-92179-150
Date Collected: 01/26/24 05:10
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/06/24 20:08	1

Client Sample ID: LE-151 Sink
Lab Sample ID: 810-92179-151
Date Collected: 01/26/24 05:10
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.92		0.50		ug/L			02/06/24 20:10	1

Client Sample ID: LE-152 Sink
Lab Sample ID: 810-92179-152
Date Collected: 01/26/24 05:10
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.2		0.50		ug/L			02/06/24 20:14	1

Client Sample ID: LE-153 WF
Lab Sample ID: 810-92179-153
Date Collected: 01/26/24 05:10
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/06/24 20:16	1

Client Sample ID: LE-154 Sink
Lab Sample ID: 810-92179-154
Date Collected: 01/26/24 05:10
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.66		0.50		ug/L			02/06/24 20:17	1

Client Sample ID: LE-155 Bubbler

Lab Sample ID: 810-92179-155

Date Collected: 01/26/24 05:20

Matrix: Drinking Water

Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/06/24 20:19	1

Client Sample ID: LE-156 Sink

Lab Sample ID: 810-92179-156

Date Collected: 01/26/24 05:20

Matrix: Drinking Water

Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	**1.3**		0.50		ug/L			02/07/24 09:30	1

Client Sample ID: LE-157 Bubbler

Lab Sample ID: 810-92179-157

Date Collected: 01/26/24 05:20

Matrix: Drinking Water

Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/07/24 09:35	1

Client Sample ID: LE-158 WF

Lab Sample ID: 810-92179-158

Date Collected: 01/26/24 05:20

Matrix: Drinking Water

Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/07/24 09:36	1

Client Sample ID: LE-159 Sink

Lab Sample ID: 810-92179-159

Date Collected: 01/26/24 05:20

Matrix: Drinking Water

Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	**1.7**		0.50		ug/L			02/07/24 09:38	1

Client Sample ID: LE-160 Bubbler

Lab Sample ID: 810-92179-160

Date Collected: 01/26/24 05:20

Matrix: Drinking Water

Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	**0.54**		0.50		ug/L			02/07/24 09:39	1

Client Sample ID: LE-161 Sink

Lab Sample ID: 810-92179-161

Date Collected: 01/26/24 05:20

Matrix: Drinking Water

Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	**0.96**		0.50		ug/L			02/07/24 09:41	1

Client Sample ID: LE-162 Bubbler
Lab Sample ID: 810-92179-162
Date Collected: 01/26/24 05:20
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/07/24 09:43	1

Client Sample ID: LE-163 Sink Room 610
Lab Sample ID: 810-92179-163
Date Collected: 01/26/24 05:20
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	**7.7**		0.50		ug/L			02/07/24 09:44	1

Client Sample ID: LE-164 Sink
Lab Sample ID: 810-92179-164
Date Collected: 01/26/24 05:20
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	**0.94**		0.50		ug/L			02/07/24 09:46	1

Client Sample ID: LE-165 Bubbler
Lab Sample ID: 810-92179-165
Date Collected: 01/26/24 05:20
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/07/24 09:47	1

Client Sample ID: LE-166 Sink
Lab Sample ID: 810-92179-166
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	**0.97**		0.50		ug/L			02/07/24 09:52	1

Client Sample ID: LE-167 Bubbler
Lab Sample ID: 810-92179-167
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/07/24 09:53	1

Client Sample ID: LE-168 Sink
Lab Sample ID: 810-92179-168
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	**1.1**		0.50		ug/L			02/07/24 09:58	1

Method: 200.8 - Metals (ICP/MS)

Lab Sample ID: MB 810-87801/11
Matrix: Drinking Water
Analysis Batch: 87801

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/06/24 08:58	1

Lab Sample ID: MB 810-87801/131
Matrix: Drinking Water
Analysis Batch: 87801

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/06/24 12:03	1

Lab Sample ID: MB 810-87801/161
Matrix: Drinking Water
Analysis Batch: 87801

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/06/24 12:49	1

Lab Sample ID: LCS 810-87801/132
Matrix: Drinking Water
Analysis Batch: 87801

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	50.0	50.9		ug/L		102	85 - 115

Lab Sample ID: LCS 810-87801/162
Matrix: Drinking Water
Analysis Batch: 87801

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	50.0	51.3		ug/L		103	85 - 115

Lab Sample ID: LLCS 810-87801/10
Matrix: Drinking Water
Analysis Batch: 87801

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LLCS Result	LLCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	0.300	0.303	J	ug/L		101	50 - 150

Lab Sample ID: 810-92179-9 MS
Matrix: Drinking Water
Analysis Batch: 87801

Client Sample ID: LE-9 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	3.7		50.0	60.8		ug/L		114	70 - 130

Lab Sample ID: 810-92179-9 MSD
Matrix: Drinking Water
Analysis Batch: 87801

Client Sample ID: LE-9 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Lead	3.7		50.0	61.0		ug/L		115	70 - 130	0	20

Method: 200.8 - Metals (ICP/MS)

Lab Sample ID: 810-92179-20 MS
Matrix: Drinking Water
Analysis Batch: 87801

Client Sample ID: LE-20 Bottle Filler
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits		
Lead	0.70		50.0	52.9		ug/L		104	70 - 130		

Lab Sample ID: 810-92179-20 MSD
Matrix: Drinking Water
Analysis Batch: 87801

Client Sample ID: LE-20 Bottle Filler
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Lead	0.70		50.0	52.6		ug/L		104	70 - 130	1	20

Lab Sample ID: 810-92179-31 MS
Matrix: Drinking Water
Analysis Batch: 87801

Client Sample ID: LE-31 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits		
Lead	0.87		50.0	52.7		ug/L		104	70 - 130		

Lab Sample ID: 810-92179-31 MSD
Matrix: Drinking Water
Analysis Batch: 87801

Client Sample ID: LE-31 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Lead	0.87		50.0	53.3		ug/L		105	70 - 130	1	20

Lab Sample ID: MB 810-87853/101
Matrix: Drinking Water
Analysis Batch: 87853

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/06/24 18:05	1

Lab Sample ID: MB 810-87853/11
Matrix: Drinking Water
Analysis Batch: 87853

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/06/24 15:46	1

Lab Sample ID: MB 810-87853/131
Matrix: Drinking Water
Analysis Batch: 87853

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/06/24 18:51	1

Lab Sample ID: MB 810-87853/161
Matrix: Drinking Water
Analysis Batch: 87853

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/06/24 19:37	1

Method: 200.8 - Metals (ICP/MS)

Lab Sample ID: MB 810-87853/41
Matrix: Drinking Water
Analysis Batch: 87853

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/06/24 16:33	1

Lab Sample ID: MB 810-87853/71
Matrix: Drinking Water
Analysis Batch: 87853

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/06/24 17:19	1

Lab Sample ID: LCS 810-87853/102
Matrix: Drinking Water
Analysis Batch: 87853

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	50.0	49.6		ug/L		99	85 - 115

Lab Sample ID: LCS 810-87853/12
Matrix: Drinking Water
Analysis Batch: 87853

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	50.0	50.5		ug/L		101	85 - 115

Lab Sample ID: LCS 810-87853/132
Matrix: Drinking Water
Analysis Batch: 87853

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	50.0	49.4		ug/L		99	85 - 115

Lab Sample ID: LCS 810-87853/162
Matrix: Drinking Water
Analysis Batch: 87853

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	50.0	52.4		ug/L		105	85 - 115

Lab Sample ID: LCS 810-87853/42
Matrix: Drinking Water
Analysis Batch: 87853

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	50.0	51.1		ug/L		102	85 - 115

Lab Sample ID: LCS 810-87853/72
Matrix: Drinking Water
Analysis Batch: 87853

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	50.0	51.5		ug/L		103	85 - 115

Method: 200.8 - Metals (ICP/MS)

Lab Sample ID: LLCS 810-87853/10
Matrix: Drinking Water
Analysis Batch: 87853

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte			Spike Added	LLCS Result	LLCS Qualifier	Unit	D	%Rec	%Rec Limits		
Lead			0.300	0.299	J	ug/L		100	50 - 150		

Lab Sample ID: 810-92179-35 MS
Matrix: Drinking Water
Analysis Batch: 87853

Client Sample ID: LE-35 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits		
Lead	0.51		50.0	50.1		ug/L		99	70 - 130		

Lab Sample ID: 810-92179-35 MSD
Matrix: Drinking Water
Analysis Batch: 87853

Client Sample ID: LE-35 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Lead	0.51		50.0	49.6		ug/L		98	70 - 130	1	20

Lab Sample ID: 810-92179-46 MS
Matrix: Drinking Water
Analysis Batch: 87853

Client Sample ID: LE-46 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits		
Lead	1.6		50.0	56.3		ug/L		109	70 - 130		

Lab Sample ID: 810-92179-46 MSD
Matrix: Drinking Water
Analysis Batch: 87853

Client Sample ID: LE-46 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Lead	1.6		50.0	55.8		ug/L		108	70 - 130	1	20

Lab Sample ID: 810-92179-57 MS
Matrix: Drinking Water
Analysis Batch: 87853

Client Sample ID: LE-57 Bublbler
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits		
Lead	<0.50		50.0	53.7		ug/L		107	70 - 130		

Lab Sample ID: 810-92179-57 MSD
Matrix: Drinking Water
Analysis Batch: 87853

Client Sample ID: LE-57 Bublbler
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Lead	<0.50		50.0	53.3		ug/L		106	70 - 130	1	20

Lab Sample ID: 810-92179-68 MS
Matrix: Drinking Water
Analysis Batch: 87853

Client Sample ID: LE-68 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits		
Lead	0.69		50.0	54.2		ug/L		107	70 - 130		

Method: 200.8 - Metals (ICP/MS)

Lab Sample ID: 810-92179-68 MSD
Matrix: Drinking Water
Analysis Batch: 87853
Client Sample ID: LE-68 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Lead	0.69		50.0	54.3		ug/L		107	70 - 130	0	20

Lab Sample ID: 810-92179-76 MS
Matrix: Drinking Water
Analysis Batch: 87853
Client Sample ID: LE-76 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	<0.50		50.0	54.1		ug/L		107	70 - 130

Lab Sample ID: 810-92179-76 MSD
Matrix: Drinking Water
Analysis Batch: 87853
Client Sample ID: LE-76 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Lead	<0.50		50.0	54.3		ug/L		108	70 - 130	0	20

Lab Sample ID: 810-92179-87 MS
Matrix: Drinking Water
Analysis Batch: 87853
Client Sample ID: LE-87 WF
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	<0.50		50.0	51.3		ug/L		102	70 - 130

Lab Sample ID: 810-92179-87 MSD
Matrix: Drinking Water
Analysis Batch: 87853
Client Sample ID: LE-87 WF
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Lead	<0.50		50.0	50.4		ug/L		100	70 - 130	2	20

Lab Sample ID: 810-92179-98 MS
Matrix: Drinking Water
Analysis Batch: 87853
Client Sample ID: LE-98 Bubbler
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	<0.50		50.0	51.1		ug/L		101	70 - 130

Lab Sample ID: 810-92179-98 MSD
Matrix: Drinking Water
Analysis Batch: 87853
Client Sample ID: LE-98 Bubbler
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Lead	<0.50		50.0	51.2		ug/L		102	70 - 130	0	20

Lab Sample ID: 810-92179-109 MS
Matrix: Drinking Water
Analysis Batch: 87853
Client Sample ID: LE-109 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	0.78		50.0	52.0		ug/L		103	70 - 130

Method: 200.8 - Metals (ICP/MS)

Lab Sample ID: 810-92179-109 MSD
Matrix: Drinking Water
Analysis Batch: 87853

Client Sample ID: LE-109 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Lead	0.78		50.0	52.0		ug/L		103	70 - 130	0	20

Lab Sample ID: 810-92179-118 MS
Matrix: Drinking Water
Analysis Batch: 87853

Client Sample ID: LE-118 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	2.7		50.0	59.2		ug/L		113	70 - 130

Lab Sample ID: 810-92179-118 MSD
Matrix: Drinking Water
Analysis Batch: 87853

Client Sample ID: LE-118 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Lead	2.7		50.0	59.4		ug/L		113	70 - 130	0	20

Lab Sample ID: 810-92179-129 MS
Matrix: Drinking Water
Analysis Batch: 87853

Client Sample ID: LE-129 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	0.90		50.0	51.3		ug/L		101	70 - 130

Lab Sample ID: 810-92179-129 MSD
Matrix: Drinking Water
Analysis Batch: 87853

Client Sample ID: LE-129 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Lead	0.90		50.0	52.4		ug/L		103	70 - 130	2	20

Lab Sample ID: 810-92179-140 MS
Matrix: Drinking Water
Analysis Batch: 87853

Client Sample ID: LE-140 Bubbler
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	0.50		50.0	49.3		ug/L		98	70 - 130

Lab Sample ID: 810-92179-140 MSD
Matrix: Drinking Water
Analysis Batch: 87853

Client Sample ID: LE-140 Bubbler
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Lead	0.50		50.0	48.8		ug/L		97	70 - 130	1	20

Lab Sample ID: 810-92179-151 MS
Matrix: Drinking Water
Analysis Batch: 87853

Client Sample ID: LE-151 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	0.92		50.0	54.7		ug/L		108	70 - 130

Method: 200.8 - Metals (ICP/MS)

Lab Sample ID: 810-92179-151 MSD
Matrix: Drinking Water
Analysis Batch: 87853

Client Sample ID: LE-151 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Lead	0.92		50.0	54.1		ug/L		106	70 - 130	1	20

Lab Sample ID: MB 810-87936/11
Matrix: Drinking Water
Analysis Batch: 87936

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/07/24 09:27	1

Lab Sample ID: LCS 810-87936/12
Matrix: Drinking Water
Analysis Batch: 87936

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	50.0	52.9		ug/L		106	85 - 115

Lab Sample ID: LLCS 810-87936/10
Matrix: Drinking Water
Analysis Batch: 87936

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LLCS Result	LLCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	0.300	0.324	J	ug/L		108	50 - 150

Lab Sample ID: 810-92179-156 MS
Matrix: Drinking Water
Analysis Batch: 87936

Client Sample ID: LE-156 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	1.3		50.0	52.4		ug/L		102	70 - 130

Lab Sample ID: 810-92179-156 MSD
Matrix: Drinking Water
Analysis Batch: 87936

Client Sample ID: LE-156 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Lead	1.3		50.0	51.9		ug/L		101	70 - 130	1	20

Lab Sample ID: 810-92179-167 MS
Matrix: Drinking Water
Analysis Batch: 87936

Client Sample ID: LE-167 Bubbler
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	<0.50		50.0	57.1		ug/L		114	70 - 130

Lab Sample ID: 810-92179-167 MSD
Matrix: Drinking Water
Analysis Batch: 87936

Client Sample ID: LE-167 Bubbler
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Lead	<0.50		50.0	56.0		ug/L		111	70 - 130	2	20

Client: St. John Environmental Consulting
Project/Site: Lebanon RII School District - Esther

Job ID: 810-92179-1

Method: 200.8 - Metals (ICP/MS)

Lab Sample ID: MB 810-87923/1-A
Matrix: Drinking Water
Analysis Batch: 88075

Client Sample ID: Method Blank
Prep Type: Total Recoverable
Prep Batch: 87923

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L		02/07/24 11:55	02/08/24 13:46	1

Lab Sample ID: LCS 810-87923/6-A
Matrix: Drinking Water
Analysis Batch: 88075

Client Sample ID: Lab Control Sample
Prep Type: Total Recoverable
Prep Batch: 87923

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	50.0	53.1		ug/L		106	85 - 115

Lab Sample ID: LLCS 810-87923/2-A
Matrix: Drinking Water
Analysis Batch: 88075

Client Sample ID: Lab Control Sample
Prep Type: Total Recoverable
Prep Batch: 87923

Analyte	Spike Added	LLCS Result	LLCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	0.300	0.312	J	ug/L		104	50 - 150

Metals

Analysis Batch: 87801

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
810-92179-1	LE-1 Sink	Total/NA	Drinking Water	200.8	
810-92179-2	LE-2 Bubble	Total/NA	Drinking Water	200.8	
810-92179-3	LE-3 Bathroom Sink	Total/NA	Drinking Water	200.8	
810-92179-4	LE-4 Sink	Total/NA	Drinking Water	200.8	
810-92179-5	LE-5 Bubbler	Total/NA	Drinking Water	200.8	
810-92179-6	LE-6 WF	Total/NA	Drinking Water	200.8	
810-92179-7	LE-7 WF	Total/NA	Drinking Water	200.8	
810-92179-8	LE-8 WF	Total/NA	Drinking Water	200.8	
810-92179-9	LE-9 Sink	Total/NA	Drinking Water	200.8	
810-92179-10	LE-10 Bottle Filler	Total/NA	Drinking Water	200.8	
810-92179-11	LE-11 Sink	Total/NA	Drinking Water	200.8	
810-92179-12	LE-12 Sink	Total/NA	Drinking Water	200.8	
810-92179-13	LE-13 Sink	Total/NA	Drinking Water	200.8	
810-92179-14	LE-14 Sink	Total/NA	Drinking Water	200.8	
810-92179-15	LE-15 Sink	Total/NA	Drinking Water	200.8	
810-92179-16	LE-16 Sink	Total/NA	Drinking Water	200.8	
810-92179-17	LE-17 Sink	Total/NA	Drinking Water	200.8	
810-92179-18	LE-18 Sink	Total/NA	Drinking Water	200.8	
810-92179-19	LE-19 Sink	Total/NA	Drinking Water	200.8	
810-92179-20	LE-20 Bottle Filler	Total/NA	Drinking Water	200.8	
810-92179-21	LE-21 Sink	Total/NA	Drinking Water	200.8	
810-92179-22	LE-22 Sink	Total/NA	Drinking Water	200.8	
810-92179-23	LE-23 Sink	Total/NA	Drinking Water	200.8	
810-92179-24	LE-24 BF	Total/NA	Drinking Water	200.8	
810-92179-25	LE-25 Sink	Total/NA	Drinking Water	200.8	
810-92179-26	LE-26 WF	Total/NA	Drinking Water	200.8	
810-92179-27	LE-27 Sink	Total/NA	Drinking Water	200.8	
810-92179-28	LE-28 WF	Total/NA	Drinking Water	200.8	
810-92179-29	LE-29 Sink	Total/NA	Drinking Water	200.8	
810-92179-30	LE-30 Sink	Total/NA	Drinking Water	200.8	
810-92179-31	LE-31 Sink	Total/NA	Drinking Water	200.8	
810-92179-32	LE-32 Sink	Total/NA	Drinking Water	200.8	
810-92179-33	LE-33 Sink	Total/NA	Drinking Water	200.8	
810-92179-34	LE-34 Bubbler	Total/NA	Drinking Water	200.8	
MB 810-87801/11	Method Blank	Total/NA	Drinking Water	200.8	
MB 810-87801/131	Method Blank	Total/NA	Drinking Water	200.8	
MB 810-87801/161	Method Blank	Total/NA	Drinking Water	200.8	
LCS 810-87801/132	Lab Control Sample	Total/NA	Drinking Water	200.8	
LCS 810-87801/162	Lab Control Sample	Total/NA	Drinking Water	200.8	
LLCS 810-87801/10	Lab Control Sample	Total/NA	Drinking Water	200.8	
810-92179-9 MS	LE-9 Sink	Total/NA	Drinking Water	200.8	
810-92179-9 MSD	LE-9 Sink	Total/NA	Drinking Water	200.8	
810-92179-20 MS	LE-20 Bottle Filler	Total/NA	Drinking Water	200.8	
810-92179-20 MSD	LE-20 Bottle Filler	Total/NA	Drinking Water	200.8	
810-92179-31 MS	LE-31 Sink	Total/NA	Drinking Water	200.8	
810-92179-31 MSD	LE-31 Sink	Total/NA	Drinking Water	200.8	

Analysis Batch: 87853

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
810-92179-35	LE-35 Sink	Total/NA	Drinking Water	200.8	
810-92179-36	LE-36 Sink	Total/NA	Drinking Water	200.8	

Metals (Continued)

Analysis Batch: 87853 (Continued)

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
810-92179-37	LE-37 Sink	Total/NA	Drinking Water	200.8	
810-92179-38	LE-38 BF	Total/NA	Drinking Water	200.8	
810-92179-39	LE-39 Sink	Total/NA	Drinking Water	200.8	
810-92179-40	LE-40 Sink	Total/NA	Drinking Water	200.8	
810-92179-41	LE-41 Sink	Total/NA	Drinking Water	200.8	
810-92179-42	LE-42 Sink	Total/NA	Drinking Water	200.8	
810-92179-43	LE-43 BF	Total/NA	Drinking Water	200.8	
810-92179-44	LE-44 BF	Total/NA	Drinking Water	200.8	
810-92179-45	LE-45 Sink	Total/NA	Drinking Water	200.8	
810-92179-46	LE-46 Sink	Total/NA	Drinking Water	200.8	
810-92179-47	LE-47 Sink	Total/NA	Drinking Water	200.8	
810-92179-48	LE-48 BF	Total/NA	Drinking Water	200.8	
810-92179-49	LE-49 Sink	Total/NA	Drinking Water	200.8	
810-92179-50	LE-50 WF	Total/NA	Drinking Water	200.8	
810-92179-51	LE-51 WF	Total/NA	Drinking Water	200.8	
810-92179-52	LE-52 Sink	Total/NA	Drinking Water	200.8	
810-92179-53	LE-53 Sink	Total/NA	Drinking Water	200.8	
810-92179-54	LE-54 Sink	Total/NA	Drinking Water	200.8	
810-92179-55	LE-55 Sink	Total/NA	Drinking Water	200.8	
810-92179-56	LE-56 Sink	Total/NA	Drinking Water	200.8	
810-92179-57	LE-57 Bublbler	Total/NA	Drinking Water	200.8	
810-92179-58	LE-58 Sink	Total/NA	Drinking Water	200.8	
810-92179-59	LE-59 Sink	Total/NA	Drinking Water	200.8	
810-92179-60	LE-60 Sink	Total/NA	Drinking Water	200.8	
810-92179-61	LE-61 Bubbler	Total/NA	Drinking Water	200.8	
810-92179-62	LE-62 Sink	Total/NA	Drinking Water	200.8	
810-92179-63	LE-63 Sink	Total/NA	Drinking Water	200.8	
810-92179-64	LE-64 Sink	Total/NA	Drinking Water	200.8	
810-92179-65	LE-65 Bubbler	Total/NA	Drinking Water	200.8	
810-92179-66	LE-66 Sink	Total/NA	Drinking Water	200.8	
810-92179-67	LE-67 Bubbler	Total/NA	Drinking Water	200.8	
810-92179-68	LE-68 Sink	Total/NA	Drinking Water	200.8	
810-92179-69	LE-69 WF	Total/NA	Drinking Water	200.8	
810-92179-70	LE-70 WF	Total/NA	Drinking Water	200.8	
810-92179-71	LE-71 Bubbler	Total/NA	Drinking Water	200.8	
810-92179-72	LE-72 Sink	Total/NA	Drinking Water	200.8	
810-92179-73	LE-73 Sink	Total/NA	Drinking Water	200.8	
810-92179-74	LE-74 Sink	Total/NA	Drinking Water	200.8	
810-92179-75	LE-75 Bubbler	Total/NA	Drinking Water	200.8	
810-92179-76	LE-76 Sink	Total/NA	Drinking Water	200.8	
810-92179-77	LE-77 Sink	Total/NA	Drinking Water	200.8	
810-92179-78	LE-78 Bubbler	Total/NA	Drinking Water	200.8	
810-92179-79	LE-79 Sink	Total/NA	Drinking Water	200.8	
810-92179-80	LE-80 Bubbler	Total/NA	Drinking Water	200.8	
810-92179-81	LE-81 Sink	Total/NA	Drinking Water	200.8	
810-92179-82	LE-82 Sink	Total/NA	Drinking Water	200.8	
810-92179-83	LE-83 Sink	Total/NA	Drinking Water	200.8	
810-92179-84	LE-84 Bubbler	Total/NA	Drinking Water	200.8	
810-92179-85	LE-85 Sink	Total/NA	Drinking Water	200.8	
810-92179-86	LE-86 WF	Total/NA	Drinking Water	200.8	
810-92179-87	LE-87 WF	Total/NA	Drinking Water	200.8	

Metals (Continued)

Analysis Batch: 87853 (Continued)

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
810-92179-88	LE-88 Bubbler	Total/NA	Drinking Water	200.8	
810-92179-89	LE-89 Sink	Total/NA	Drinking Water	200.8	
810-92179-90	LE-90 Sink	Total/NA	Drinking Water	200.8	
810-92179-91	LE-91 Sink	Total/NA	Drinking Water	200.8	
810-92179-92	LE-92 Bubbler	Total/NA	Drinking Water	200.8	
810-92179-93	LE-93 Sink	Total/NA	Drinking Water	200.8	
810-92179-94	LE-94 Sink	Total/NA	Drinking Water	200.8	
810-92179-95	LE-95 Sink	Total/NA	Drinking Water	200.8	
810-92179-96	LE-96 Bubbler	Total/NA	Drinking Water	200.8	
810-92179-97	LE-97 Sink	Total/NA	Drinking Water	200.8	
810-92179-98	LE-98 Bubbler	Total/NA	Drinking Water	200.8	
810-92179-99	LE-99 Sink	Total/NA	Drinking Water	200.8	
810-92179-100	LE-100 Sink	Total/NA	Drinking Water	200.8	
810-92179-101	LE-101 Sink	Total/NA	Drinking Water	200.8	
810-92179-102	LE-102 Sink	Total/NA	Drinking Water	200.8	
810-92179-103	LE-103 Sink	Total/NA	Drinking Water	200.8	
810-92179-104	LE-104 Sink	Total/NA	Drinking Water	200.8	
810-92179-105	LE-105 WF	Total/NA	Drinking Water	200.8	
810-92179-106	LE-106 WF	Total/NA	Drinking Water	200.8	
810-92179-107	LE-107 Bubbler	Total/NA	Drinking Water	200.8	
810-92179-108	LE-108 Sink	Total/NA	Drinking Water	200.8	
810-92179-109	LE-109 Sink	Total/NA	Drinking Water	200.8	
810-92179-110	LE-110 Sink	Total/NA	Drinking Water	200.8	
810-92179-111	LE-111 Bubbler	Total/NA	Drinking Water	200.8	
810-92179-112	LE-112 Sink	Total/NA	Drinking Water	200.8	
810-92179-113	LE-113 WF	Total/NA	Drinking Water	200.8	
810-92179-114	LE-114 WF	Total/NA	Drinking Water	200.8	
810-92179-115	LE-115 Sink	Total/NA	Drinking Water	200.8	
810-92179-117	LE-117 Sink	Total/NA	Drinking Water	200.8	
810-92179-118	LE-118 Sink	Total/NA	Drinking Water	200.8	
810-92179-119	LE-119 Sink	Total/NA	Drinking Water	200.8	
810-92179-120	LE-120 Sink	Total/NA	Drinking Water	200.8	
810-92179-121	LE-121 Pot Filler	Total/NA	Drinking Water	200.8	
810-92179-122	LE-122 Pot Filler	Total/NA	Drinking Water	200.8	
810-92179-123	LE-123 Sink/Washer	Total/NA	Drinking Water	200.8	
810-92179-124	LE-124 Sink	Total/NA	Drinking Water	200.8	
810-92179-125	LE-125 Sink	Total/NA	Drinking Water	200.8	
810-92179-126	LE-126 Sink	Total/NA	Drinking Water	200.8	
810-92179-127	LE-127 Sink	Total/NA	Drinking Water	200.8	
810-92179-128	LE-128 Sink	Total/NA	Drinking Water	200.8	
810-92179-129	LE-129 Sink	Total/NA	Drinking Water	200.8	
810-92179-130	LE-130 WF	Total/NA	Drinking Water	200.8	
810-92179-131	LE-131 Sink	Total/NA	Drinking Water	200.8	
810-92179-132	LE-132 Sink	Total/NA	Drinking Water	200.8	
810-92179-133	LE-133 WF	Total/NA	Drinking Water	200.8	
810-92179-134	LE-134 Sink	Total/NA	Drinking Water	200.8	
810-92179-135	LE-135 Sink	Total/NA	Drinking Water	200.8	
810-92179-136	LE-136 Sink Room 511	Total/NA	Drinking Water	200.8	
810-92179-137	LE-137 Sink	Total/NA	Drinking Water	200.8	
810-92179-138	LE-138 Sink	Total/NA	Drinking Water	200.8	
810-92179-139	LE-139 Sink	Total/NA	Drinking Water	200.8	

Metals (Continued)

Analysis Batch: 87853 (Continued)

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
810-92179-140	LE-140 Bubbler	Total/NA	Drinking Water	200.8	
810-92179-141	LE-141 Sink	Total/NA	Drinking Water	200.8	
810-92179-142	LE-142 Bubbler	Total/NA	Drinking Water	200.8	
810-92179-143	LE-143 Sink	Total/NA	Drinking Water	200.8	
810-92179-144	LE-144 Bubbler	Total/NA	Drinking Water	200.8	
810-92179-145	LE-145 Sink	Total/NA	Drinking Water	200.8	
810-92179-146	LE-146 BF	Total/NA	Drinking Water	200.8	
810-92179-147	LE-147 Sink	Total/NA	Drinking Water	200.8	
810-92179-148	LE-148 BF	Total/NA	Drinking Water	200.8	
810-92179-149	LE-149 Sink	Total/NA	Drinking Water	200.8	
810-92179-150	LE-150 Sink	Total/NA	Drinking Water	200.8	
810-92179-151	LE-151 Sink	Total/NA	Drinking Water	200.8	
810-92179-152	LE-152 Sink	Total/NA	Drinking Water	200.8	
810-92179-153	LE-153 WF	Total/NA	Drinking Water	200.8	
810-92179-154	LE-154 Sink	Total/NA	Drinking Water	200.8	
810-92179-155	LE-155 Bubbler	Total/NA	Drinking Water	200.8	
MB 810-87853/101	Method Blank	Total/NA	Drinking Water	200.8	
MB 810-87853/11	Method Blank	Total/NA	Drinking Water	200.8	
MB 810-87853/131	Method Blank	Total/NA	Drinking Water	200.8	
MB 810-87853/161	Method Blank	Total/NA	Drinking Water	200.8	
MB 810-87853/41	Method Blank	Total/NA	Drinking Water	200.8	
MB 810-87853/71	Method Blank	Total/NA	Drinking Water	200.8	
LCS 810-87853/102	Lab Control Sample	Total/NA	Drinking Water	200.8	
LCS 810-87853/12	Lab Control Sample	Total/NA	Drinking Water	200.8	
LCS 810-87853/132	Lab Control Sample	Total/NA	Drinking Water	200.8	
LCS 810-87853/162	Lab Control Sample	Total/NA	Drinking Water	200.8	
LCS 810-87853/42	Lab Control Sample	Total/NA	Drinking Water	200.8	
LCS 810-87853/72	Lab Control Sample	Total/NA	Drinking Water	200.8	
LLCS 810-87853/10	Lab Control Sample	Total/NA	Drinking Water	200.8	
810-92179-35 MS	LE-35 Sink	Total/NA	Drinking Water	200.8	
810-92179-35 MSD	LE-35 Sink	Total/NA	Drinking Water	200.8	
810-92179-46 MS	LE-46 Sink	Total/NA	Drinking Water	200.8	
810-92179-46 MSD	LE-46 Sink	Total/NA	Drinking Water	200.8	
810-92179-57 MS	LE-57 Bublbler	Total/NA	Drinking Water	200.8	
810-92179-57 MSD	LE-57 Bublbler	Total/NA	Drinking Water	200.8	
810-92179-68 MS	LE-68 Sink	Total/NA	Drinking Water	200.8	
810-92179-68 MSD	LE-68 Sink	Total/NA	Drinking Water	200.8	
810-92179-76 MS	LE-76 Sink	Total/NA	Drinking Water	200.8	
810-92179-76 MSD	LE-76 Sink	Total/NA	Drinking Water	200.8	
810-92179-87 MS	LE-87 WF	Total/NA	Drinking Water	200.8	
810-92179-87 MSD	LE-87 WF	Total/NA	Drinking Water	200.8	
810-92179-98 MS	LE-98 Bubbler	Total/NA	Drinking Water	200.8	
810-92179-98 MSD	LE-98 Bubbler	Total/NA	Drinking Water	200.8	
810-92179-109 MS	LE-109 Sink	Total/NA	Drinking Water	200.8	
810-92179-109 MSD	LE-109 Sink	Total/NA	Drinking Water	200.8	
810-92179-118 MS	LE-118 Sink	Total/NA	Drinking Water	200.8	
810-92179-118 MSD	LE-118 Sink	Total/NA	Drinking Water	200.8	
810-92179-129 MS	LE-129 Sink	Total/NA	Drinking Water	200.8	
810-92179-129 MSD	LE-129 Sink	Total/NA	Drinking Water	200.8	
810-92179-140 MS	LE-140 Bubbler	Total/NA	Drinking Water	200.8	
810-92179-140 MSD	LE-140 Bubbler	Total/NA	Drinking Water	200.8	

Metals (Continued)

Analysis Batch: 87853 (Continued)

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
810-92179-151 MS	LE-151 Sink	Total/NA	Drinking Water	200.8	
810-92179-151 MSD	LE-151 Sink	Total/NA	Drinking Water	200.8	

Prep Batch: 87923

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
810-92179-116	LE-116 Sink	Total Recoverable	Drinking Water	200.8	
MB 810-87923/1-A	Method Blank	Total Recoverable	Drinking Water	200.8	
LCS 810-87923/6-A	Lab Control Sample	Total Recoverable	Drinking Water	200.8	
LLCS 810-87923/2-A	Lab Control Sample	Total Recoverable	Drinking Water	200.8	

Analysis Batch: 87936

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
810-92179-156	LE-156 Sink	Total/NA	Drinking Water	200.8	
810-92179-157	LE-157 Bubbler	Total/NA	Drinking Water	200.8	
810-92179-158	LE-158 WF	Total/NA	Drinking Water	200.8	
810-92179-159	LE-159 Sink	Total/NA	Drinking Water	200.8	
810-92179-160	LE-160 Bubbler	Total/NA	Drinking Water	200.8	
810-92179-161	LE-161 Sink	Total/NA	Drinking Water	200.8	
810-92179-162	LE-162 Bubbler	Total/NA	Drinking Water	200.8	
810-92179-163	LE-163 Sink Room 610	Total/NA	Drinking Water	200.8	
810-92179-164	LE-164 Sink	Total/NA	Drinking Water	200.8	
810-92179-165	LE-165 Bubbler	Total/NA	Drinking Water	200.8	
810-92179-166	LE-166 Sink	Total/NA	Drinking Water	200.8	
810-92179-167	LE-167 Bubbler	Total/NA	Drinking Water	200.8	
810-92179-168	LE-168 Sink	Total/NA	Drinking Water	200.8	
MB 810-87936/11	Method Blank	Total/NA	Drinking Water	200.8	
LCS 810-87936/12	Lab Control Sample	Total/NA	Drinking Water	200.8	
LLCS 810-87936/10	Lab Control Sample	Total/NA	Drinking Water	200.8	
810-92179-156 MS	LE-156 Sink	Total/NA	Drinking Water	200.8	
810-92179-156 MSD	LE-156 Sink	Total/NA	Drinking Water	200.8	
810-92179-167 MS	LE-167 Bubbler	Total/NA	Drinking Water	200.8	
810-92179-167 MSD	LE-167 Bubbler	Total/NA	Drinking Water	200.8	

Analysis Batch: 88075

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
810-92179-116	LE-116 Sink	Total Recoverable	Drinking Water	200.8	87923
MB 810-87923/1-A	Method Blank	Total Recoverable	Drinking Water	200.8	87923
LCS 810-87923/6-A	Lab Control Sample	Total Recoverable	Drinking Water	200.8	87923
LLCS 810-87923/2-A	Lab Control Sample	Total Recoverable	Drinking Water	200.8	87923

Lab Chronicle

Client: St. John Environmental Consulting
Job ID: 810-92179-1
Project/Site: Lebanon RII School District - Esther

Client Sample ID: LE-1 Sink
Lab Sample ID: 810-92179-1
Date Collected: 01/26/24 04:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87801	CA	EA SB	02/06/24 12:19

Client Sample ID: LE-2 Bubble
Lab Sample ID: 810-92179-2
Date Collected: 01/26/24 04:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87801	CA	EA SB	02/06/24 12:20

Client Sample ID: LE-3 Bathroom Sink
Lab Sample ID: 810-92179-3
Date Collected: 01/26/24 04:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87801	CA	EA SB	02/06/24 12:22

Client Sample ID: LE-4 Sink
Lab Sample ID: 810-92179-4
Date Collected: 01/26/24 04:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87801	CA	EA SB	02/06/24 12:23

Client Sample ID: LE-5 Bubbler
Lab Sample ID: 810-92179-5
Date Collected: 01/26/24 04:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87801	CA	EA SB	02/06/24 12:28

Client Sample ID: LE-6 WF
Lab Sample ID: 810-92179-6
Date Collected: 01/26/24 04:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87801	CA	EA SB	02/06/24 12:29

Client Sample ID: LE-7 WF
Lab Sample ID: 810-92179-7
Date Collected: 01/26/24 04:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87801	CA	EA SB	02/06/24 12:31

Lab Chronicle

Client: St. John Environmental Consulting
Job ID: 810-92179-1
Project/Site: Lebanon RII School District - Esther

Client Sample ID: LE-8 WF
Lab Sample ID: 810-92179-8
Date Collected: 01/26/24 04:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87801	CA	EA SB	02/06/24 12:32

Client Sample ID: LE-9 Sink
Lab Sample ID: 810-92179-9
Date Collected: 01/26/24 04:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87801	CA	EA SB	02/06/24 12:34

Client Sample ID: LE-10 Bottle Filler
Lab Sample ID: 810-92179-10
Date Collected: 01/26/24 04:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87801	CA	EA SB	02/06/24 12:39

Client Sample ID: LE-11 Sink
Lab Sample ID: 810-92179-11
Date Collected: 01/26/24 04:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87801	CA	EA SB	02/06/24 12:40

Client Sample ID: LE-12 Sink
Lab Sample ID: 810-92179-12
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87801	CA	EA SB	02/06/24 12:42

Client Sample ID: LE-13 Sink
Lab Sample ID: 810-92179-13
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87801	CA	EA SB	02/06/24 12:43

Client Sample ID: LE-14 Sink
Lab Sample ID: 810-92179-14
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87801	CA	EA SB	02/06/24 12:45

Lab Chronicle

Client: St. John Environmental Consulting
Job ID: 810-92179-1
Project/Site: Lebanon RII School District - Esther

Client Sample ID: LE-15 Sink
Lab Sample ID: 810-92179-15
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87801	CA	EA SB	02/06/24 12:52

Client Sample ID: LE-16 Sink
Lab Sample ID: 810-92179-16
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87801	CA	EA SB	02/06/24 12:54

Client Sample ID: LE-17 Sink
Lab Sample ID: 810-92179-17
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87801	CA	EA SB	02/06/24 12:56

Client Sample ID: LE-18 Sink
Lab Sample ID: 810-92179-18
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87801	CA	EA SB	02/06/24 12:57

Client Sample ID: LE-19 Sink
Lab Sample ID: 810-92179-19
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87801	CA	EA SB	02/06/24 12:59

Client Sample ID: LE-20 Bottle Filler
Lab Sample ID: 810-92179-20
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87801	CA	EA SB	02/06/24 13:00

Client Sample ID: LE-21 Sink
Lab Sample ID: 810-92179-21
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87801	CA	EA SB	02/06/24 13:05

Lab Chronicle

Client: St. John Environmental Consulting
Project/Site: Lebanon RII School District - Esther

Job ID: 810-92179-1

Client Sample ID: LE-22 Sink
Lab Sample ID: 810-92179-22
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87801	CA	EA SB	02/06/24 13:06

Client Sample ID: LE-23 Sink
Lab Sample ID: 810-92179-23
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87801	CA	EA SB	02/06/24 13:08

Client Sample ID: LE-24 BF
Lab Sample ID: 810-92179-24
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87801	CA	EA SB	02/06/24 13:09

Client Sample ID: LE-25 Sink
Lab Sample ID: 810-92179-25
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87801	CA	EA SB	02/06/24 13:14

Client Sample ID: LE-26 WF
Lab Sample ID: 810-92179-26
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87801	CA	EA SB	02/06/24 13:16

Client Sample ID: LE-27 Sink
Lab Sample ID: 810-92179-27
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87801	CA	EA SB	02/06/24 13:17

Client Sample ID: LE-28 WF
Lab Sample ID: 810-92179-28
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87801	CA	EA SB	02/06/24 13:19

Lab Chronicle

Client: St. John Environmental Consulting
Job ID: 810-92179-1
Project/Site: Lebanon RII School District - Esther

Client Sample ID: LE-29 Sink
Lab Sample ID: 810-92179-29
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87801	CA	EA SB	02/06/24 13:20

Client Sample ID: LE-30 Sink
Lab Sample ID: 810-92179-30
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87801	CA	EA SB	02/06/24 13:22

Client Sample ID: LE-31 Sink
Lab Sample ID: 810-92179-31
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87801	CA	EA SB	02/06/24 13:23

Client Sample ID: LE-32 Sink
Lab Sample ID: 810-92179-32
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87801	CA	EA SB	02/06/24 13:28

Client Sample ID: LE-33 Sink
Lab Sample ID: 810-92179-33
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87801	CA	EA SB	02/06/24 13:30

Client Sample ID: LE-34 Bubbler
Lab Sample ID: 810-92179-34
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87801	CA	EA SB	02/06/24 13:31

Client Sample ID: LE-35 Sink
Lab Sample ID: 810-92179-35
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 15:49

Lab Chronicle

Client: St. John Environmental Consulting
Project/Site: Lebanon RII School District - Esther

Job ID: 810-92179-1

Client Sample ID: LE-36 Sink
Date Collected: 01/26/24 04:45
Date Received: 01/30/24 09:00

Lab Sample ID: 810-92179-36
Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 15:54

Client Sample ID: LE-37 Sink
Date Collected: 01/26/24 04:45
Date Received: 01/30/24 09:00

Lab Sample ID: 810-92179-37
Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 15:56

Client Sample ID: LE-38 BF
Date Collected: 01/26/24 04:45
Date Received: 01/30/24 09:00

Lab Sample ID: 810-92179-38
Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 15:57

Client Sample ID: LE-39 Sink
Date Collected: 01/26/24 04:45
Date Received: 01/30/24 09:00

Lab Sample ID: 810-92179-39
Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 15:59

Client Sample ID: LE-40 Sink
Date Collected: 01/26/24 04:45
Date Received: 01/30/24 09:00

Lab Sample ID: 810-92179-40
Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 16:00

Client Sample ID: LE-41 Sink
Date Collected: 01/26/24 04:45
Date Received: 01/30/24 09:00

Lab Sample ID: 810-92179-41
Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 16:02

Client Sample ID: LE-42 Sink
Date Collected: 01/26/24 04:45
Date Received: 01/30/24 09:00

Lab Sample ID: 810-92179-42
Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 16:03

Lab Chronicle

Client: St. John Environmental Consulting
Job ID: 810-92179-1
Project/Site: Lebanon RII School District - Esther

Client Sample ID: LE-43 BF
Lab Sample ID: 810-92179-43
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 16:05

Client Sample ID: LE-44 BF
Lab Sample ID: 810-92179-44
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 16:06

Client Sample ID: LE-45 Sink
Lab Sample ID: 810-92179-45
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 16:11

Client Sample ID: LE-46 Sink
Lab Sample ID: 810-92179-46
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 16:13

Client Sample ID: LE-47 Sink
Lab Sample ID: 810-92179-47
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 16:17

Client Sample ID: LE-48 BF
Lab Sample ID: 810-92179-48
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 16:19

Client Sample ID: LE-49 Sink
Lab Sample ID: 810-92179-49
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 16:20

Lab Chronicle

Client: St. John Environmental Consulting
Project/Site: Lebanon RII School District - Esther

Job ID: 810-92179-1

Client Sample ID: LE-50 WF
Lab Sample ID: 810-92179-50
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 16:22

Client Sample ID: LE-51 WF
Lab Sample ID: 810-92179-51
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 16:23

Client Sample ID: LE-52 Sink
Lab Sample ID: 810-92179-52
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 16:25

Client Sample ID: LE-53 Sink
Lab Sample ID: 810-92179-53
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 16:26

Client Sample ID: LE-54 Sink
Lab Sample ID: 810-92179-54
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 16:28

Client Sample ID: LE-55 Sink
Lab Sample ID: 810-92179-55
Date Collected: 01/26/24 04:45
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 16:36

Client Sample ID: LE-56 Sink
Lab Sample ID: 810-92179-56
Date Collected: 01/26/24 04:50
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 16:37

Lab Chronicle

Client: St. John Environmental Consulting
Job ID: 810-92179-1
Project/Site: Lebanon RII School District - Esther

Client Sample ID: LE-57 Bublbler
Lab Sample ID: 810-92179-57
Date Collected: 01/26/24 04:50
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 16:39

Client Sample ID: LE-58 Sink
Lab Sample ID: 810-92179-58
Date Collected: 01/26/24 04:50
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 16:43

Client Sample ID: LE-59 Sink
Lab Sample ID: 810-92179-59
Date Collected: 01/26/24 04:50
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 16:45

Client Sample ID: LE-60 Sink
Lab Sample ID: 810-92179-60
Date Collected: 01/26/24 04:50
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 16:46

Client Sample ID: LE-61 Bubbler
Lab Sample ID: 810-92179-61
Date Collected: 01/26/24 04:50
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 16:48

Client Sample ID: LE-62 Sink
Lab Sample ID: 810-92179-62
Date Collected: 01/26/24 04:50
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 16:50

Client Sample ID: LE-63 Sink
Lab Sample ID: 810-92179-63
Date Collected: 01/26/24 04:50
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 16:51

Lab Chronicle

Client: St. John Environmental Consulting
Job ID: 810-92179-1
Project/Site: Lebanon RII School District - Esther

Client Sample ID: LE-64 Sink
Lab Sample ID: 810-92179-64
Date Collected: 01/26/24 04:50
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 16:53

Client Sample ID: LE-65 Bubbler
Lab Sample ID: 810-92179-65
Date Collected: 01/26/24 04:50
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 16:57

Client Sample ID: LE-66 Sink
Lab Sample ID: 810-92179-66
Date Collected: 01/26/24 04:50
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 16:59

Client Sample ID: LE-67 Bubbler
Lab Sample ID: 810-92179-67
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 17:00

Client Sample ID: LE-68 Sink
Lab Sample ID: 810-92179-68
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 17:02

Client Sample ID: LE-69 WF
Lab Sample ID: 810-92179-69
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 17:07

Client Sample ID: LE-70 WF
Lab Sample ID: 810-92179-70
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 17:08

Lab Chronicle

Client: St. John Environmental Consulting
Job ID: 810-92179-1
Project/Site: Lebanon RII School District - Esther

Client Sample ID: LE-71 Bubbler
Lab Sample ID: 810-92179-71
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 17:10

Client Sample ID: LE-72 Sink
Lab Sample ID: 810-92179-72
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 17:11

Client Sample ID: LE-73 Sink
Lab Sample ID: 810-92179-73
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 17:13

Client Sample ID: LE-74 Sink
Lab Sample ID: 810-92179-74
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 17:14

Client Sample ID: LE-75 Bubbler
Lab Sample ID: 810-92179-75
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 17:22

Client Sample ID: LE-76 Sink
Lab Sample ID: 810-92179-76
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 17:23

Client Sample ID: LE-77 Sink
Lab Sample ID: 810-92179-77
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 17:28

Lab Chronicle

Client: St. John Environmental Consulting
Job ID: 810-92179-1
Project/Site: Lebanon RII School District - Esther

Client Sample ID: LE-78 Bubbler
Lab Sample ID: 810-92179-78
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 17:30

Client Sample ID: LE-79 Sink
Lab Sample ID: 810-92179-79
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 17:31

Client Sample ID: LE-80 Bubbler
Lab Sample ID: 810-92179-80
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 17:33

Client Sample ID: LE-81 Sink
Lab Sample ID: 810-92179-81
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 17:34

Client Sample ID: LE-82 Sink
Lab Sample ID: 810-92179-82
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 17:36

Client Sample ID: LE-83 Sink
Lab Sample ID: 810-92179-83
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 17:37

Client Sample ID: LE-84 Bubbler
Lab Sample ID: 810-92179-84
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 17:39

Lab Chronicle

Client: St. John Environmental Consulting
Job ID: 810-92179-1
Project/Site: Lebanon RII School District - Esther

Client Sample ID: LE-85 Sink
Lab Sample ID: 810-92179-85
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 17:43

Client Sample ID: LE-86 WF
Lab Sample ID: 810-92179-86
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 17:45

Client Sample ID: LE-87 WF
Lab Sample ID: 810-92179-87
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 17:47

Client Sample ID: LE-88 Bubbler
Lab Sample ID: 810-92179-88
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 17:51

Client Sample ID: LE-89 Sink
Lab Sample ID: 810-92179-89
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 17:53

Client Sample ID: LE-90 Sink
Lab Sample ID: 810-92179-90
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 17:54

Client Sample ID: LE-91 Sink
Lab Sample ID: 810-92179-91
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 17:56

Lab Chronicle

Client: St. John Environmental Consulting
Project/Site: Lebanon RII School District - Esther

Job ID: 810-92179-1

Client Sample ID: LE-92 Bubbler

Lab Sample ID: 810-92179-92

Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 17:57

Client Sample ID: LE-93 Sink

Lab Sample ID: 810-92179-93

Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 17:59

Client Sample ID: LE-94 Sink

Lab Sample ID: 810-92179-94

Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 18:00

Client Sample ID: LE-95 Sink

Lab Sample ID: 810-92179-95

Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 18:08

Client Sample ID: LE-96 Bubbler

Lab Sample ID: 810-92179-96

Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 18:10

Client Sample ID: LE-97 Sink

Lab Sample ID: 810-92179-97

Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 18:11

Client Sample ID: LE-98 Bubbler

Lab Sample ID: 810-92179-98

Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 18:13

Lab Chronicle

Client: St. John Environmental Consulting
Project/Site: Lebanon RII School District - Esther

Job ID: 810-92179-1

Client Sample ID: LE-99 Sink
Lab Sample ID: 810-92179-99
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 18:17

Client Sample ID: LE-100 Sink
Lab Sample ID: 810-92179-100
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 18:19

Client Sample ID: LE-101 Sink
Lab Sample ID: 810-92179-101
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 18:20

Client Sample ID: LE-102 Sink
Lab Sample ID: 810-92179-102
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 18:22

Client Sample ID: LE-103 Sink
Lab Sample ID: 810-92179-103
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 18:23

Client Sample ID: LE-104 Sink
Lab Sample ID: 810-92179-104
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 18:25

Client Sample ID: LE-105 WF
Lab Sample ID: 810-92179-105
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 18:30

Lab Chronicle

Client: St. John Environmental Consulting
Project/Site: Lebanon RII School District - Esther

Job ID: 810-92179-1

Client Sample ID: LE-106 WF
Lab Sample ID: 810-92179-106
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 18:31

Client Sample ID: LE-107 Bubbler
Lab Sample ID: 810-92179-107
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 18:33

Client Sample ID: LE-108 Sink
Lab Sample ID: 810-92179-108
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 18:34

Client Sample ID: LE-109 Sink
Lab Sample ID: 810-92179-109
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 18:36

Client Sample ID: LE-110 Sink
Lab Sample ID: 810-92179-110
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 18:40

Client Sample ID: LE-111 Bubbler
Lab Sample ID: 810-92179-111
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 18:42

Client Sample ID: LE-112 Sink
Lab Sample ID: 810-92179-112
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 18:43

Lab Chronicle

Client: St. John Environmental Consulting
Job ID: 810-92179-1
Project/Site: Lebanon RII School District - Esther

Client Sample ID: LE-113 WF
Lab Sample ID: 810-92179-113
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 18:45

Client Sample ID: LE-114 WF
Lab Sample ID: 810-92179-114
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 18:47

Client Sample ID: LE-115 Sink
Lab Sample ID: 810-92179-115
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 18:54

Client Sample ID: LE-116 Sink
Lab Sample ID: 810-92179-116
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total Recoverable	Prep	200.8			87923	NB	EA SB	02/07/24 11:55
Total Recoverable	Analysis	200.8		1	88075	NB	EA SB	02/08/24 14:17

Client Sample ID: LE-117 Sink
Lab Sample ID: 810-92179-117
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 18:56

Client Sample ID: LE-118 Sink
Lab Sample ID: 810-92179-118
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 18:57

Client Sample ID: LE-119 Sink
Lab Sample ID: 810-92179-119
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 19:02

Lab Chronicle

Client: St. John Environmental Consulting
Job ID: 810-92179-1
Project/Site: Lebanon RII School District - Esther

Client Sample ID: LE-120 Sink
Lab Sample ID: 810-92179-120
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 19:03

Client Sample ID: LE-121 Pot Filler
Lab Sample ID: 810-92179-121
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 19:05

Client Sample ID: LE-122 Pot Filler
Lab Sample ID: 810-92179-122
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 19:07

Client Sample ID: LE-123 Sink/Washer
Lab Sample ID: 810-92179-123
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 19:08

Client Sample ID: LE-124 Sink
Lab Sample ID: 810-92179-124
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 19:10

Client Sample ID: LE-125 Sink
Lab Sample ID: 810-92179-125
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 19:11

Client Sample ID: LE-126 Sink
Lab Sample ID: 810-92179-126
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 19:16

Lab Chronicle

Client: St. John Environmental Consulting
Job ID: 810-92179-1
Project/Site: Lebanon RII School District - Esther

Client Sample ID: LE-127 Sink
Lab Sample ID: 810-92179-127
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 19:17

Client Sample ID: LE-128 Sink
Lab Sample ID: 810-92179-128
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 19:19

Client Sample ID: LE-129 Sink
Lab Sample ID: 810-92179-129
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 19:20

Client Sample ID: LE-130 WF
Lab Sample ID: 810-92179-130
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 19:25

Client Sample ID: LE-131 Sink
Lab Sample ID: 810-92179-131
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 19:27

Client Sample ID: LE-132 Sink
Lab Sample ID: 810-92179-132
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 19:28

Client Sample ID: LE-133 WF
Lab Sample ID: 810-92179-133
Date Collected: 01/26/24 05:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 19:30

Lab Chronicle

Client: St. John Environmental Consulting
Project/Site: Lebanon RII School District - Esther

Job ID: 810-92179-1

Client Sample ID: LE-134 Sink
Date Collected: 01/26/24 05:00
Date Received: 01/30/24 09:00

Lab Sample ID: 810-92179-134
Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 19:31

Client Sample ID: LE-135 Sink
Date Collected: 01/26/24 05:00
Date Received: 01/30/24 09:00

Lab Sample ID: 810-92179-135
Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 19:33

Client Sample ID: LE-136 Sink Room 511
Date Collected: 01/26/24 05:00
Date Received: 01/30/24 09:00

Lab Sample ID: 810-92179-136
Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 19:40

Client Sample ID: LE-137 Sink
Date Collected: 01/26/24 05:00
Date Received: 01/30/24 09:00

Lab Sample ID: 810-92179-137
Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 19:42

Client Sample ID: LE-138 Sink
Date Collected: 01/26/24 05:00
Date Received: 01/30/24 09:00

Lab Sample ID: 810-92179-138
Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 19:44

Client Sample ID: LE-139 Sink
Date Collected: 01/26/24 05:00
Date Received: 01/30/24 09:00

Lab Sample ID: 810-92179-139
Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 19:45

Client Sample ID: LE-140 Bubbler
Date Collected: 01/26/24 05:00
Date Received: 01/30/24 09:00

Lab Sample ID: 810-92179-140
Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 19:47

Lab Chronicle

Client: St. John Environmental Consulting
Project/Site: Lebanon RII School District - Esther

Job ID: 810-92179-1

Client Sample ID: LE-141 Sink
Date Collected: 01/26/24 05:00
Date Received: 01/30/24 09:00

Lab Sample ID: 810-92179-141
Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 19:51

Client Sample ID: LE-142 Bubbler
Date Collected: 01/26/24 05:00
Date Received: 01/30/24 09:00

Lab Sample ID: 810-92179-142
Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 19:53

Client Sample ID: LE-143 Sink
Date Collected: 01/26/24 05:00
Date Received: 01/30/24 09:00

Lab Sample ID: 810-92179-143
Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 19:54

Client Sample ID: LE-144 Bubbler
Date Collected: 01/26/24 05:10
Date Received: 01/30/24 09:00

Lab Sample ID: 810-92179-144
Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 19:56

Client Sample ID: LE-145 Sink
Date Collected: 01/26/24 05:10
Date Received: 01/30/24 09:00

Lab Sample ID: 810-92179-145
Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 19:57

Client Sample ID: LE-146 BF
Date Collected: 01/26/24 05:10
Date Received: 01/30/24 09:00

Lab Sample ID: 810-92179-146
Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 20:02

Client Sample ID: LE-147 Sink
Date Collected: 01/26/24 05:10
Date Received: 01/30/24 09:00

Lab Sample ID: 810-92179-147
Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 20:04

Lab Chronicle

Client: St. John Environmental Consulting
Project/Site: Lebanon RII School District - Esther

Job ID: 810-92179-1

Client Sample ID: LE-148 BF
Lab Sample ID: 810-92179-148
Date Collected: 01/26/24 05:10
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 20:05

Client Sample ID: LE-149 Sink
Lab Sample ID: 810-92179-149
Date Collected: 01/26/24 05:10
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 20:07

Client Sample ID: LE-150 Sink
Lab Sample ID: 810-92179-150
Date Collected: 01/26/24 05:10
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 20:08

Client Sample ID: LE-151 Sink
Lab Sample ID: 810-92179-151
Date Collected: 01/26/24 05:10
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 20:10

Client Sample ID: LE-152 Sink
Lab Sample ID: 810-92179-152
Date Collected: 01/26/24 05:10
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 20:14

Client Sample ID: LE-153 WF
Lab Sample ID: 810-92179-153
Date Collected: 01/26/24 05:10
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 20:16

Client Sample ID: LE-154 Sink
Lab Sample ID: 810-92179-154
Date Collected: 01/26/24 05:10
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 20:17

Lab Chronicle

Client: St. John Environmental Consulting
Project/Site: Lebanon RII School District - Esther

Job ID: 810-92179-1

Client Sample ID: LE-155 Bubbler
Lab Sample ID: 810-92179-155
Date Collected: 01/26/24 05:20
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87853	NB	EA SB	02/06/24 20:19

Client Sample ID: LE-156 Sink
Lab Sample ID: 810-92179-156
Date Collected: 01/26/24 05:20
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87936	CA	EA SB	02/07/24 09:30

Client Sample ID: LE-157 Bubbler
Lab Sample ID: 810-92179-157
Date Collected: 01/26/24 05:20
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87936	CA	EA SB	02/07/24 09:35

Client Sample ID: LE-158 WF
Lab Sample ID: 810-92179-158
Date Collected: 01/26/24 05:20
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87936	CA	EA SB	02/07/24 09:36

Client Sample ID: LE-159 Sink
Lab Sample ID: 810-92179-159
Date Collected: 01/26/24 05:20
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87936	CA	EA SB	02/07/24 09:38

Client Sample ID: LE-160 Bubbler
Lab Sample ID: 810-92179-160
Date Collected: 01/26/24 05:20
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87936	CA	EA SB	02/07/24 09:39

Client Sample ID: LE-161 Sink
Lab Sample ID: 810-92179-161
Date Collected: 01/26/24 05:20
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87936	CA	EA SB	02/07/24 09:41

Lab Chronicle

Client: St. John Environmental Consulting
Project/Site: Lebanon RII School District - Esther

Job ID: 810-92179-1

Client Sample ID: LE-162 Bubbler
Date Collected: 01/26/24 05:20
Date Received: 01/30/24 09:00

Lab Sample ID: 810-92179-162
Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87936	CA	EA SB	02/07/24 09:43

Client Sample ID: LE-163 Sink Room 610
Date Collected: 01/26/24 05:20
Date Received: 01/30/24 09:00

Lab Sample ID: 810-92179-163
Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87936	CA	EA SB	02/07/24 09:44

Client Sample ID: LE-164 Sink
Date Collected: 01/26/24 05:20
Date Received: 01/30/24 09:00

Lab Sample ID: 810-92179-164
Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87936	CA	EA SB	02/07/24 09:46

Client Sample ID: LE-165 Bubbler
Date Collected: 01/26/24 05:20
Date Received: 01/30/24 09:00

Lab Sample ID: 810-92179-165
Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87936	CA	EA SB	02/07/24 09:47

Client Sample ID: LE-166 Sink
Date Collected: 01/26/24 04:45
Date Received: 01/30/24 09:00

Lab Sample ID: 810-92179-166
Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87936	CA	EA SB	02/07/24 09:52

Client Sample ID: LE-167 Bubbler
Date Collected: 01/26/24 04:45
Date Received: 01/30/24 09:00

Lab Sample ID: 810-92179-167
Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87936	CA	EA SB	02/07/24 09:53

Client Sample ID: LE-168 Sink
Date Collected: 01/26/24 04:45
Date Received: 01/30/24 09:00

Lab Sample ID: 810-92179-168
Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87936	CA	EA SB	02/07/24 09:58

Laboratory References:

EA SB = Eurofins Eaton Analytical South Bend, 110 S Hill Street, South Bend, IN 46617, TEL (574)233-4777

Accreditation/Certification Summary

Client: St. John Environmental Consulting
Job ID: 810-92179-1
Project/Site: Lebanon RII School District - Esther

Laboratory: Eurofins Eaton Analytical South Bend

The accreditations/certifications listed below are applicable to this report.

Authority	Program	Identification Number	Expiration Date
Missouri	State	880	09-30-24

Method Summary

Client: St. John Environmental Consulting
Job ID: 810-92179-1
Project/Site: Lebanon RII School District - Esther

Method	Method Description	Protocol	Laboratory
200.8	Metals (ICP/MS)	EPA	EA SB
200.8	Preparation, Total Recoverable Metals	EPA	EA SB

Protocol References:

EPA = US Environmental Protection Agency

Laboratory References:

EA SB = Eurofins Eaton Analytical South Bend, 110 S Hill Street, South Bend, IN 46617, TEL (574)233-4777

Sample Summary

Client: St. John Environmental Consulting
Job ID: 810-92179-1
Project/Site: Lebanon RII School District - Esther

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
810-92179-1	LE-1 Sink	Drinking Water	01/26/24 04:30	01/30/24 09:00
810-92179-2	LE-2 Bubble	Drinking Water	01/26/24 04:30	01/30/24 09:00
810-92179-3	LE-3 Bathroom Sink	Drinking Water	01/26/24 04:30	01/30/24 09:00
810-92179-4	LE-4 Sink	Drinking Water	01/26/24 04:30	01/30/24 09:00
810-92179-5	LE-5 Bubbler	Drinking Water	01/26/24 04:30	01/30/24 09:00
810-92179-6	LE-6 WF	Drinking Water	01/26/24 04:30	01/30/24 09:00
810-92179-7	LE-7 WF	Drinking Water	01/26/24 04:30	01/30/24 09:00
810-92179-8	LE-8 WF	Drinking Water	01/26/24 04:30	01/30/24 09:00
810-92179-9	LE-9 Sink	Drinking Water	01/26/24 04:30	01/30/24 09:00
810-92179-10	LE-10 Bottle Filler	Drinking Water	01/26/24 04:30	01/30/24 09:00
810-92179-11	LE-11 Sink	Drinking Water	01/26/24 04:30	01/30/24 09:00
810-92179-12	LE-12 Sink	Drinking Water	01/26/24 04:45	01/30/24 09:00
810-92179-13	LE-13 Sink	Drinking Water	01/26/24 04:45	01/30/24 09:00
810-92179-14	LE-14 Sink	Drinking Water	01/26/24 04:45	01/30/24 09:00
810-92179-15	LE-15 Sink	Drinking Water	01/26/24 04:45	01/30/24 09:00
810-92179-16	LE-16 Sink	Drinking Water	01/26/24 04:45	01/30/24 09:00
810-92179-17	LE-17 Sink	Drinking Water	01/26/24 04:45	01/30/24 09:00
810-92179-18	LE-18 Sink	Drinking Water	01/26/24 04:45	01/30/24 09:00
810-92179-19	LE-19 Sink	Drinking Water	01/26/24 04:45	01/30/24 09:00
810-92179-20	LE-20 Bottle Filler	Drinking Water	01/26/24 04:45	01/30/24 09:00
810-92179-21	LE-21 Sink	Drinking Water	01/26/24 04:45	01/30/24 09:00
810-92179-22	LE-22 Sink	Drinking Water	01/26/24 04:45	01/30/24 09:00
810-92179-23	LE-23 Sink	Drinking Water	01/26/24 04:45	01/30/24 09:00
810-92179-24	LE-24 BF	Drinking Water	01/26/24 04:45	01/30/24 09:00
810-92179-25	LE-25 Sink	Drinking Water	01/26/24 04:45	01/30/24 09:00
810-92179-26	LE-26 WF	Drinking Water	01/26/24 04:45	01/30/24 09:00
810-92179-27	LE-27 Sink	Drinking Water	01/26/24 04:45	01/30/24 09:00
810-92179-28	LE-28 WF	Drinking Water	01/26/24 04:45	01/30/24 09:00
810-92179-29	LE-29 Sink	Drinking Water	01/26/24 04:45	01/30/24 09:00
810-92179-30	LE-30 Sink	Drinking Water	01/26/24 04:45	01/30/24 09:00
810-92179-31	LE-31 Sink	Drinking Water	01/26/24 04:45	01/30/24 09:00
810-92179-32	LE-32 Sink	Drinking Water	01/26/24 04:45	01/30/24 09:00
810-92179-33	LE-33 Sink	Drinking Water	01/26/24 04:45	01/30/24 09:00
810-92179-34	LE-34 Bubbler	Drinking Water	01/26/24 04:45	01/30/24 09:00
810-92179-35	LE-35 Sink	Drinking Water	01/26/24 04:45	01/30/24 09:00
810-92179-36	LE-36 Sink	Drinking Water	01/26/24 04:45	01/30/24 09:00
810-92179-37	LE-37 Sink	Drinking Water	01/26/24 04:45	01/30/24 09:00
810-92179-38	LE-38 BF	Drinking Water	01/26/24 04:45	01/30/24 09:00
810-92179-39	LE-39 Sink	Drinking Water	01/26/24 04:45	01/30/24 09:00
810-92179-40	LE-40 Sink	Drinking Water	01/26/24 04:45	01/30/24 09:00
810-92179-41	LE-41 Sink	Drinking Water	01/26/24 04:45	01/30/24 09:00
810-92179-42	LE-42 Sink	Drinking Water	01/26/24 04:45	01/30/24 09:00
810-92179-43	LE-43 BF	Drinking Water	01/26/24 04:45	01/30/24 09:00
810-92179-44	LE-44 BF	Drinking Water	01/26/24 04:45	01/30/24 09:00
810-92179-45	LE-45 Sink	Drinking Water	01/26/24 04:45	01/30/24 09:00
810-92179-46	LE-46 Sink	Drinking Water	01/26/24 04:45	01/30/24 09:00
810-92179-47	LE-47 Sink	Drinking Water	01/26/24 04:45	01/30/24 09:00
810-92179-48	LE-48 BF	Drinking Water	01/26/24 04:45	01/30/24 09:00
810-92179-49	LE-49 Sink	Drinking Water	01/26/24 04:45	01/30/24 09:00
810-92179-50	LE-50 WF	Drinking Water	01/26/24 04:45	01/30/24 09:00
810-92179-51	LE-51 WF	Drinking Water	01/26/24 04:45	01/30/24 09:00
810-92179-52	LE-52 Sink	Drinking Water	01/26/24 04:45	01/30/24 09:00
810-92179-53	LE-53 Sink	Drinking Water	01/26/24 04:45	01/30/24 09:00
810-92179-54	LE-54 Sink	Drinking Water	01/26/24 04:45	01/30/24 09:00

Sample Summary

Client: St. John Environmental Consulting
Project/Site: Lebanon RII School District - Esther

Job ID: 810-92179-1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
810-92179-55	LE-55 Sink	Drinking Water	01/26/24 04:45	01/30/24 09:00
810-92179-56	LE-56 Sink	Drinking Water	01/26/24 04:50	01/30/24 09:00
810-92179-57	LE-57 Bublbler	Drinking Water	01/26/24 04:50	01/30/24 09:00
810-92179-58	LE-58 Sink	Drinking Water	01/26/24 04:50	01/30/24 09:00
810-92179-59	LE-59 Sink	Drinking Water	01/26/24 04:50	01/30/24 09:00
810-92179-60	LE-60 Sink	Drinking Water	01/26/24 04:50	01/30/24 09:00
810-92179-61	LE-61 Bubbler	Drinking Water	01/26/24 04:50	01/30/24 09:00
810-92179-62	LE-62 Sink	Drinking Water	01/26/24 04:50	01/30/24 09:00
810-92179-63	LE-63 Sink	Drinking Water	01/26/24 04:50	01/30/24 09:00
810-92179-64	LE-64 Sink	Drinking Water	01/26/24 04:50	01/30/24 09:00
810-92179-65	LE-65 Bubbler	Drinking Water	01/26/24 04:50	01/30/24 09:00
810-92179-66	LE-66 Sink	Drinking Water	01/26/24 04:50	01/30/24 09:00
810-92179-67	LE-67 Bubbler	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-68	LE-68 Sink	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-69	LE-69 WF	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-70	LE-70 WF	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-71	LE-71 Bubbler	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-72	LE-72 Sink	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-73	LE-73 Sink	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-74	LE-74 Sink	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-75	LE-75 Bubbler	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-76	LE-76 Sink	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-77	LE-77 Sink	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-78	LE-78 Bubbler	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-79	LE-79 Sink	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-80	LE-80 Bubbler	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-81	LE-81 Sink	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-82	LE-82 Sink	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-83	LE-83 Sink	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-84	LE-84 Bubbler	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-85	LE-85 Sink	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-86	LE-86 WF	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-87	LE-87 WF	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-88	LE-88 Bubbler	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-89	LE-89 Sink	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-90	LE-90 Sink	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-91	LE-91 Sink	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-92	LE-92 Bubbler	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-93	LE-93 Sink	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-94	LE-94 Sink	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-95	LE-95 Sink	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-96	LE-96 Bubbler	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-97	LE-97 Sink	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-98	LE-98 Bubbler	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-99	LE-99 Sink	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-100	LE-100 Sink	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-101	LE-101 Sink	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-102	LE-102 Sink	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-103	LE-103 Sink	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-104	LE-104 Sink	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-105	LE-105 WF	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-106	LE-106 WF	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-107	LE-107 Bubbler	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-108	LE-108 Sink	Drinking Water	01/26/24 05:00	01/30/24 09:00

Sample Summary

Client: St. John Environmental Consulting
Project/Site: Lebanon RII School District - Esther

Job ID: 810-92179-1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
810-92179-109	LE-109 Sink	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-110	LE-110 Sink	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-111	LE-111 Bubbler	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-112	LE-112 Sink	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-113	LE-113 WF	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-114	LE-114 WF	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-115	LE-115 Sink	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-116	LE-116 Sink	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-117	LE-117 Sink	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-118	LE-118 Sink	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-119	LE-119 Sink	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-120	LE-120 Sink	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-121	LE-121 Pot Filler	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-122	LE-122 Pot Filler	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-123	LE-123 Sink/Washer	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-124	LE-124 Sink	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-125	LE-125 Sink	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-126	LE-126 Sink	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-127	LE-127 Sink	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-128	LE-128 Sink	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-129	LE-129 Sink	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-130	LE-130 WF	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-131	LE-131 Sink	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-132	LE-132 Sink	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-133	LE-133 WF	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-134	LE-134 Sink	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-135	LE-135 Sink	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-136	LE-136 Sink Room 511	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-137	LE-137 Sink	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-138	LE-138 Sink	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-139	LE-139 Sink	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-140	LE-140 Bubbler	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-141	LE-141 Sink	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-142	LE-142 Bubbler	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-143	LE-143 Sink	Drinking Water	01/26/24 05:00	01/30/24 09:00
810-92179-144	LE-144 Bubbler	Drinking Water	01/26/24 05:10	01/30/24 09:00
810-92179-145	LE-145 Sink	Drinking Water	01/26/24 05:10	01/30/24 09:00
810-92179-146	LE-146 BF	Drinking Water	01/26/24 05:10	01/30/24 09:00
810-92179-147	LE-147 Sink	Drinking Water	01/26/24 05:10	01/30/24 09:00
810-92179-148	LE-148 BF	Drinking Water	01/26/24 05:10	01/30/24 09:00
810-92179-149	LE-149 Sink	Drinking Water	01/26/24 05:10	01/30/24 09:00
810-92179-150	LE-150 Sink	Drinking Water	01/26/24 05:10	01/30/24 09:00
810-92179-151	LE-151 Sink	Drinking Water	01/26/24 05:10	01/30/24 09:00
810-92179-152	LE-152 Sink	Drinking Water	01/26/24 05:10	01/30/24 09:00
810-92179-153	LE-153 WF	Drinking Water	01/26/24 05:10	01/30/24 09:00
810-92179-154	LE-154 Sink	Drinking Water	01/26/24 05:10	01/30/24 09:00
810-92179-155	LE-155 Bubbler	Drinking Water	01/26/24 05:20	01/30/24 09:00
810-92179-156	LE-156 Sink	Drinking Water	01/26/24 05:20	01/30/24 09:00
810-92179-157	LE-157 Bubbler	Drinking Water	01/26/24 05:20	01/30/24 09:00
810-92179-158	LE-158 WF	Drinking Water	01/26/24 05:20	01/30/24 09:00
810-92179-159	LE-159 Sink	Drinking Water	01/26/24 05:20	01/30/24 09:00
810-92179-160	LE-160 Bubbler	Drinking Water	01/26/24 05:20	01/30/24 09:00
810-92179-161	LE-161 Sink	Drinking Water	01/26/24 05:20	01/30/24 09:00
810-92179-162	LE-162 Bubbler	Drinking Water	01/26/24 05:20	01/30/24 09:00

Sample Summary

Client: St. John Environmental Consulting
Project/Site: Lebanon RII School District - Esther

Job ID: 810-92179-1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
810-92179-163	LE-163 Sink Room 610	Drinking Water	01/26/24 05:20	01/30/24 09:00
810-92179-164	LE-164 Sink	Drinking Water	01/26/24 05:20	01/30/24 09:00
810-92179-165	LE-165 Bubbler	Drinking Water	01/26/24 05:20	01/30/24 09:00
810-92179-166	LE-166 Sink	Drinking Water	01/26/24 04:45	01/30/24 09:00
810-92179-167	LE-167 Bubbler	Drinking Water	01/26/24 04:45	01/30/24 09:00
810-92179-168	LE-168 Sink	Drinking Water	01/26/24 04:45	01/30/24 09:00

810-92179 Chain of Custody

Chain of Custody Record

eurofins | Environment Testing America

	Sampler: Ian St. John	Lab PM:	Carrier Tracking No(s):	COC No:
Jeff Morgan	Phone: 314-853-4668	E-Mail: ian@stjohnenv.com	State of Origin: MO	Page: Page 1 of 16
Company: Lebanon RIII School District	PWSID:			Job #:

Address: 224 W. Commercial Street	Due Date Requested:	Analysis Requested
City: Lebanon	TAT Requested (days): Standard	
State, Zip: MO 65536	Compliance Project: Δ Yes Δ No	
Phone: 417-849-3330	PO #:	
Email: Jeff.morgan@lebanon.k12.mo.us	WO #:	
Project Name: Lebanon RIII School District	Project #:	
Site: Lebanon Esther	SSOW#:	

Preservation Codes:

A - HCL, B - NaOH, C - Zn Acetate, D - Nitric Acid, E - NaHSO4, F - MeOH, G - Amchlor, H - Ascorbic Acid, I - Ice, J - DI Water, K - EDTA, L - EDA, M - Hexane, N - None, O - AsNaO2, P - Na2O4S, Q - Na2SO3, R - Na2S2O3, S - H2SO4, T - TSP Dodecahydrate, U - Acetone, V - MCAA, W - pH 4-5, Y - Trizma, Z - other (specify)

Other:

Sample Identification	Sample Date	Sample Time	Sample Type (C=Comp, G=grab)	Matrix (W=water, S=solid, O=waste/oil, BT=Tissue, A=Air)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Lead In Drinking Water	Total Number of containers	Special Instructions/Note:
			Preservation Code:						
LE - 1 Sink	1/24/24	0430	G	W			X		
LE - 2 Bubbler									
LE - 3 Bathroom Sink									
LE - 4 Sink									
LE - 5 Bubbler									
LE - 6 WF									
LE - 7 WF									
LE - 8 WF									
LE - 9 Sink									
LE - 10 Bottle Filler									
LE - 11 Sink									

Possible Hazard Identification

☐ Non-Hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☒ Unknown ☐ Radiological

Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)

☐ Return To Client ☒ Disposal By Lab ☐ Archive For _____ Months

Deliverable Requested: I, II, III, IV, Other (specify) No date/time on bottles PW 01/30/24

Special Instructions/QC Requirements:

Empty Kit Relinquished by:	Date:	Time:	Method of Shipment:

Relinquished by: Ian St. John	Date/Time: 1/26/24	Company	Received by: Rushed Affixed	Date/Time: 1-30-24 4°C	Company
Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company
Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company

Custody Seals Intact: Δ Yes Δ No	Custody Seal No.:	Cooler Temperature(s) °C and Other Remarks: Ambient

Ver: 02/24/23

2/9/2024

Eurofins Eaton Analyitcal: South Bend
110 South Hill Street
South Bend, IN 46617
Phone (574) 233-4777

Chain of Custody Record

eurofins | Environment Testing America

Client Information	Sampler: Ian St. John	Lab PM:	Carrier Tracking No(s):	COC No:
Client Contact: Jeff Morgan	Phone: 314-853-4668	E-Mail: ian@stjohnenv.com	State of Origin: MO	Page: Page 2 of 16
Company: Lebanon RIII School District	PWSID:			Job #:

Address: 224 W. Commercial Street	Due Date Requested:	Analysis Requested	Preservation Codes:
City: Lebanon	TAT Requested (days): Standard		A - HCL, B - NaOH, C - Zn Acetate, D - Nitric Acid, E - NaHSO4, F - MeOH, G - Amchlor, H - Ascorbic Acid, I - Ice, J - DI Water, K - EDTA, L - EDA, M - Hexane, N - None, O - AsNaO2, P - Na2O4S, Q - Na2SO3, R - Na2S2O3, S - H2SO4, T - TSP Dodecahydrate, U - Acetone, V - MCAA, W - pH 4-5, Y - Trizma, Z - other (specify)
State, Zip: MO 65536	Compliance Project: Δ Yes Δ No		
Phone: 417-849-3330	PO #:		Other:
Email: Jeff.morgan@lebanon.k12.mo.us	WO #:		
Project Name: Lebanon RIII School District	Project #:		
Site: Lebanon Esther	SSOW#:		

Sample Identification	Sample Date	Sample Time	Sample Type (C=comp, G=grab)	Matrix (W=water, S=solid, O=waste/oil, BT=Tissue, A=Air)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Lead In Drinking Water	Total Number of containers	Special Instructions/Note:
			Preservation Code:						
LE - 12 Sink	1/26/24	0445	G	W			X		
LE - 13 Sink									
LE - 14 Sink									
LE - 15 Sink									
LE - 16 Sink									
LE - 17 Sink									
LE - 18 Sink									
LE - 19 Sink									
LE - 20 Bottle Filler									
LE - 21 Sink									
LE - 22 Sink									

Possible Hazard Identification
☐ Non-Hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☒ Unknown ☐ Radiological

Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)
☐ Return To Client ☒ Disposal By Lab ☐ Archive For _____ Months

Deliverable Requested: I, II, III, IV, Other (specify)

Special Instructions/QC Requirements:

Empty Kit Relinquished by:	Date:	Time:	Method of Shipment:

	Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company
1	Ian St. John	1/26/24		[illegible]	1-31-24 900	
2	Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company
3	Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company

Custody Seals Intact: Δ Yes Δ No	Custody Seal No.:	Cooler Temperature(s) °C and Other Remarks:

Ver: 02/24/23

Eurofins Eaton Analyitcal: South Bend
110 South Hill Street
South Bend, IN 46617
Phone (574) 233-4777

Chain of Custody Record

eurofins | Environment Testing America

7/25

2/9/2024

Client Information	Sampler: Ian St. John	Lab PM:	Carrier Tracking No(s):	COC No:
Client Contact: Jeff Morgan	Phone: 314-853-4668	E-Mail: ian@stjohnenv.com	State of Origin: MO	Page: Page 3 of 16
Company: Lebanon RIII School District	PWSID:	Analysis Requested		Job #:
Address: 224 W. Commercial Street	Due Date Requested:			Preservation Codes: A - HCL, B - NaOH, C - Zn Acetate, D - Nitric Acid, E - NaHSO4, F - MeOH, G - Amchlor, H - Ascorbic Acid, I - Ice, J - DI Water, K - EDTA, L - EDA, M - Hexane, N - None, O - AsNaO2, P - Na2O4S, Q - Na2SO3, R - Na2S2O3, S - H2SO4, T - TSP Dodecahydrate, U - Acetone, V - MCAA, W - pH 4-5, Y - Trizma, Z - other (specify), Other:
City: Lebanon	TAT Requested (days): Standard			
State, Zip: MO 65536	Compliance Project: Δ Yes Δ No			
Phone: 417-849-3330	PO #:			
Email: Jeff.morgan@lebanon.k12.mo.us	WO #:			
Project Name: Lebanon RIII School District	Project #:			
Site: Lebanon Esther	SSOW#:			

Sample Identification	Sample Date	Sample Time	Sample Type (C=Comp, G=grab)	Matrix (W=water, S=solid, O=waste/oil, BT=Tissue, A=Air)	Field Filtered Sample (Yes or No)	MS/MSD (Yes or No)	Lead In Drinking Water	Total Number of containers	Special Instructions/Note:
			Preservation Code:						
LE - 23 Sink	1/26/24	0445	G	W			X		
LE - 24 BF									
LE - 25 Sink									
LE - 26 WF									
LE - 27 Sink									
LE - 28 WF									
LE - 29 Sink									
LE - 30									
LE - 31									
LE - 32									
LE - 33									

Possible Hazard Identification
☐ Non-Hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☒ Unknown ☐ Radiological

Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)
☐ Return To Client ☒ Disposal By Lab ☐ Archive For _____ Months

Deliverable Requested: I, II, III, IV, Other (specify)

Special Instructions/QC Requirements:

Empty Kit Relinquished by:	Date:	Time:	Method of Shipment:

	Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company
	Ian St. John	1/26/24		Robin Hilfred	1.30.24 909	
	Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company
	Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company

Custody Seals Intact: Δ Yes Δ No	Custody Seal No.:	Cooler Temperature(s) °C and Other Remarks:

Ver: 02/24/23

Eurofins Eaton Analyitcal: South Bend
110 South Hill Street
South Bend, IN 46617
Phone (574) 233-4777

Chain of Custody Record

eurofins | Environment Testing America

7123

2/9/2024

Client Information	Sampler: Ian St. John	Lab PM:	Carrier Tracking No(s):	COC No:
Client Contact: Jeff Morgan	Phone: 314-853-4668	E-Mail: ian@stjohnenv.com	State of Origin: MO	Page: Page 4 of 16
Company: Lebanon RIII School District	PWSID:			Job #:
Address: 224 W. Commercial Street	Due Date Requested:			
City: Lebanon	TAT Requested (days): Standard			
State, Zip: MO 65536	Compliance Project: Δ Yes Δ No			
Phone: 417-849-3330	PO #:			
Email: Jeff.morgan@lebanon.k12.mo.us	WO #:			
Project Name: Lebanon RIII School District	Project #:			
Site: Lebanon Esther	SSOW#:			

Analysis Requested

Preservation Codes:
A - HCL, B - NaOH, C - Zn Acetate, D - Nitric Acid, E - NaHSO4, F - MeOH, G - Amchlor, H - Ascorbic Acid, I - Ice, J - DI Water, K - EDTA, L - EDA, M - Hexane, N - None, O - AsNaO2, P - Na2O4S, Q - Na2SO3, R - Na2S2O3, S - H2SO4, T - TSP Dodecahydrate, U - Acetone, V - MCAA, W - pH 4-5, Y - Trizma, Z - other (specify)
Other:

Sample Identification	Sample Date	Sample Time	Sample Type (C=Comp, G=grab)	Matrix (W=water, S=solid, O=waste/oil, BT=Tissue, A=Air)	Field Filtered Sample (Yes or No)	Perform MS/ (Yes or No)	Lead In Drinking Water	Total Number of containers	Special Instructions/Note:
			Preservation Code:						
LE -34 Bubbler	1/26/24	0445	G	W			X		
LE -35 Sink									
LE -36 Sink									
LE -37 Sink									
LE -38 BF									
LE -39 Sink									
LE -40 Sink									
LE -41 Sink									
LE -42 Sink									
LE -43 BF									
LE- 44 BF									

Possible Hazard Identification
☐ Non-Hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☒ Unknown ☐ Radiological

Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)
☐ Return To Client ☒ Disposal By Lab ☐ Archive For _____ Months

Deliverable Requested: I, II, III, IV, Other (specify)

Special Instructions/QC Requirements:

Empty Kit Relinquished by:	Date:	Time:	Method of Shipment:

	Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company
1	Ian St. John	1/26/24		[illegible] Affairs	1-30-24 900	
2	Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company
3	Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company

Custody Seals Intact: Δ Yes Δ No | Custody Seal No.: | Cooler Temperature(s) °C and Other Remarks:

Ver: 02/24/23

Eurofins Eaton Analyitcal: South Bend
110 South Hill Street
South Bend, IN 46617
Phone (574) 233-4777

Chain of Custody Record

eurofins | Environment Testing America

7/25

2/9/2024

Client Information	Sampler: Ian St. John	Lab PM:	Carrier Tracking No(s):	COC No:
Client Contact: Jeff Morgan	Phone: 314-853-4668	E-Mail: ian@stjohnenv.com	State of Origin: MO	Page: Page 5 of 16
Company: Lebanon RIII School District	PWSID:			Job #:
Address: 224 W. Commercial Street	Due Date Requested:			
City: Lebanon	TAT Requested (days): Standard			
State, Zip: MO 65536	Compliance Project: Δ Yes Δ No			
Phone: 417-849-3330	PO #:			
Email: Jeff.morgan@lebanon.k12.mo.us	WO #:			
Project Name: Lebanon RIII School District	Project #:			
Site: Lebanon Esther	SSOW#:			

Analysis Requested

Preservation Codes:
A - HCL, B - NaOH, C - Zn Acetate, D - Nitric Acid, E - NaHSO4, F - MeOH, G - Amchlor, H - Ascorbic Acid, I - Ice, J - DI Water, K - EDTA, L - EDA, M - Hexane, N - None, O - AsNaO2, P - Na2O4S, Q - Na2SO3, R - Na2S2O3, S - H2SO4, T - TSP Dodecahydrate, U - Acetone, V - MCAA, W - pH 4-5, Y - Trizma, Z - other (specify)
Other:

Sample Identification	Sample Date	Sample Time	Sample Type (C=Comp, G=grab)	Matrix (W=water, S=solid, O=waste/oil, BT=Tissue, A=Air)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Lead In Drinking Water	Total Number of containers	Special Instructions/Note:
			Preservation Code:						
LE - 45 Sink	1/26/24	0445	G	W			X		
LE - 46 Sink									
LE - 47 Sink									
LE - 48 BF									
LE - 49 Sink									
LE - 50 WF									
LE - 51 WF									
LE - 52 Sink									
LE - 53									
LE - 54									
LE - 55									

Possible Hazard Identification
☐ Non-Hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☒ Unknown ☐ Radiological

Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)
☐ Return To Client ☒ Disposal By Lab ☐ Archive For _____ Months

Deliverable Requested: I, II, III, IV, Other (specify)

Special Instructions/QC Requirements:

Empty Kit Relinquished by:	Date:	Time:	Method of Shipment:

	Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company
1	Ian St. John	1/26/24		Cabbini Alfred	1-30-24 900	
2	Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company
3	Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company

Custody Seals Intact: Δ Yes Δ No	Custody Seal No.:	Cooler Temperature(s) °C and Other Remarks:

Ver: 02/24/23

Eurofins Eaton Analyitcal: South Bend
110 South Hill Street
South Bend, IN 46617
Phone (574) 233-4777

Chain of Custody Record

eurofins | Environment Testing America

7/25

2/9/2024

Client Information	Sampler: Ian St. John	Lab PM:	Carrier Tracking No(s):	COC No:
Client Contact: Jeff Morgan	Phone: 314-853-4668	E-Mail: ian@stjohnenv.com	State of Origin: MO	Page: Page 6 of 16
Company: Lebanon RIII School District	PWSID:			Job #:
Address: 224 W. Commercial Street	Due Date Requested:			
City: Lebanon	TAT Requested (days): Standard			
State, Zip: MO 65536	Compliance Project: Δ Yes Δ No			
Phone: 417-849-3330	PO #:			
Email: Jeff.morgan@lebanon.k12.mo.us	WO #:			
Project Name: Lebanon RIII School District	Project #:			
Site: Lebanon Esther	SSOW#:			

Analysis Requested

Preservation Codes:
A - HCL, B - NaOH, C - Zn Acetate, D - Nitric Acid, E - NaHSO4, F - MeOH, G - Amchlor, H - Ascorbic Acid, I - Ice, J - DI Water, K - EDTA, L - EDA, M - Hexane, N - None, O - AsNaO2, P - Na2O4S, Q - Na2SO3, R - Na2S2O3, S - H2SO4, T - TSP Dodecahydrate, U - Acetone, V - MCAA, W - pH 4-5, Y - Trizma, Z - other (specify)
Other:

Sample Identification	Sample Date	Sample Time	Sample Type (C=comp, G=grab)	Matrix (W=water, S=solid, O=waste/oil, BT=Tissue, A=Air)	Field Filtered Sample (Yes or No)	Perform MS/ (Yes or No)	Lead In Drinking Water	Total Number of containers	Special Instructions/Note:
			Preservation Code:						
LE -56 Sink	1/26/24	0450	G	W			X		
LE - 57 Bubbler									
LE - 58 Sink									
LE - 59 Sink									
LE - 60 Sink									
LE - 61 Bubbler									
LE - 62 Sink									
LE - 63 ↓									
LE - 64 ↓									
LE - 65 Bubbler									
LE - 66 Sink									

Possible Hazard Identification
☐ Non-Hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☒ Unknown ☐ Radiological

Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)
☐ Return To Client ☒ Disposal By Lab ☐ Archive For _____ Months

Deliverable Requested: I, II, III, IV, Other (specify)

Special Instructions/QC Requirements:

Empty Kit Relinquished by:	Date:	Time:	Method of Shipment:

	Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company
1	Ian St. John	1/26/24		Libbie Allred	1.30.24 908	
2	Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company
3	Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company

Custody Seals Intact: Δ Yes Δ No	Custody Seal No.:	Cooler Temperature(s) °C and Other Remarks:

Ver: 02/24/23

Eurofins Eaton Analyitcal: South Bend
110 South Hill Street
South Bend, IN 46617
Phone (574) 233-4777

Chain of Custody Record

eurofins | Environment Testing America

7107

Client Information	Sampler: Ian St. John	Lab PM:	Carrier Tracking No(s):	COC No:
Client Contact: Jeff Morgan	Phone: 314-853-4668	E-Mail: ian@stjohnenv.com	State of Origin: MO	Page: Page 1 of 16
Company: Lebanon RIII School District	PWSID:			Job #:
Address: 224 W. Commercial Street	Due Date Requested:			
City: Lebanon	TAT Requested (days): Standard			
State, Zip: MO 65536	Compliance Project: Δ Yes Δ No			
Phone: 417-849-3330	PO #:			
Email: Jeff.morgan@lebanon.k12.mo.us	WO #:			
Project Name: Lebanon RIII School District	Project #:			
Site: Lebanon Esther	SSOW#:			

Analysis Requested

Preservation Codes:
A - HCL, B - NaOH, C - Zn Acetate, D - Nitric Acid, E - NaHSO4, F - MeOH, G - Amchlor, H - Ascorbic Acid, I - Ice, J - DI Water, K - EDTA, L - EDA, M - Hexane, N - None, O - AsNaO2, P - Na2O4S, Q - Na2SO3, R - Na2S2O3, S - H2SO4, T - TSP Dodecahydrate, U - Acetone, V - MCAA, W - pH 4-5, Y - Trizma, Z - other (specify)
Other:

Sample Identification	Sample Date	Sample Time	Sample Type (C=Comp, G=grab)	Matrix (W=water, S=solid, O=waste/oil, BT=Tissue, A=Air)	Field Filtered Sample (Yes or No)	MS/MSD (Yes or No)	Lead In Drinking Water	Total Number of containers	Special Instructions/Note:
			Preservation Code:						
LE - 67 Bubbler	1/26/24	0500	G	W			X		
LE - 68 Sink									
LE - 69 WF									
LE - 70 WF									
LE - 71 Bubbler									
LE - 72 Sink									
LE - 73 Sink									
LE - 74 Sink									
LE - 75 Bubbler									
LE - 76 Sink									
LE - 77 Sink									

Possible Hazard Identification
☐ Non-Hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☒ Unknown ☐ Radiological

Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)
☐ Return To Client ☒ Disposal By Lab ☐ Archive For _____ Months

Deliverable Requested: I, II, III, IV, Other (specify)

Special Instructions/QC Requirements:

Empty Kit Relinquished by:	Date:	Time:	Method of Shipment:

	Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company
	Ian St. John	1/26/24		Robbin Hilfers	1:30.24 900	
	Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company
	Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company

Custody Seals Intact: Δ Yes Δ No | Custody Seal No.: | Cooler Temperature(s) °C and Other Remarks:

Ver: 02/24/23

2/9/2024

Eurofins Eaton Analyitcal: South Bend
110 South Hill Street
South Bend, IN 46617
Phone (574) 233-4777

Chain of Custody Record

eurofins | Environment Testing America

11 of 13

2/9/2024

Client Information	Sampler: Ian St. John	Lab PM:	Carrier Tracking No(s):	COC No:
Client Contact: Jeff Morgan	Phone: 314-853-4668	E-Mail: ian@stjohnenv.com	State of Origin: MO	Page: Page 8 of 11a
Company: Lebanon RIII School District	PWSID:			Job #:

Address: 224 W. Commercial Street	Due Date Requested:
City: Lebanon	TAT Requested (days): Standard
State, Zip: MO 65536	Compliance Project: Δ Yes Δ No
Phone: 417-849-3330	PO #:
Email: Jeff.morgan@lebanon.k12.mo.us	WO #:
Project Name: Lebanon RIII School District	Project #:
Site: Lebanon Esther	SSOW#:

Analysis Requested

Preservation Codes:
A - HCL, B - NaOH, C - Zn Acetate, D - Nitric Acid, E - NaHSO4, F - MeOH, G - Amchlor, H - Ascorbic Acid, I - Ice, J - DI Water, K - EDTA, L - EDA, M - Hexane, N - None, O - AsNaO2, P - Na2O4S, Q - Na2SO3, R - Na2S2O3, S - H2SO4, T - TSP Dodecahydrate, U - Acetone, V - MCAA, W - pH 4-5, Y - Trizma, Z - other (specify)
Other:

Sample Identification	Sample Date	Sample Time	Sample Type (C=comp, G=grab)	Matrix (W=water, S=solid, O=waste/oil, BT=Tissue, A=Air)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Lead In Drinking Water	Total Number of containers	Special Instructions/Note:
			Preservation Code:						
LE - 78 Bubbler	1/26/24	0530	G	W			X		
LE - 79 Sink									
LE - 80 Bubbler									
LE - 81 Sink									
LE - 82 Sink									
LE - 83 Sink									
LE - 84 Bubbler									
LE - 85 Sink									
LE - 86 WF									
LE - 87 WF									
LE - 88 Bubbler									

Possible Hazard Identification
☐ Non-Hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☒ Unknown ☐ Radiological

Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)
☐ Return To Client ☒ Disposal By Lab ☐ Archive For _____ Months

Deliverable Requested: I, II, III, IV, Other (specify)

Special Instructions/QC Requirements:

Empty Kit Relinquished by:	Date:	Time:	Method of Shipment:

Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company
Ian St. John	1/26/24		[illegible]	1-30-24 9??	
Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company
Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company

Custody Seals Intact: Δ Yes Δ No | Custody Seal No.: | Cooler Temperature(s) °C and Other Remarks:

Ver: 02/24/23

Eurofins Eaton Analyitcal: South Bend
110 South Hill Street
South Bend, IN 46617
Phone (574) 233-4777

Chain of Custody Record

eurofins | Environment Testing America

Client Information	Sampler: Ian St. John	Lab PM:	Carrier Tracking No(s):	COC No:
Client Contact: Jeff Morgan	Phone: 314-853-4668	E-Mail: ian@stjohnenv.com	State of Origin: MO	Page: Page 9 of 16
Company: Lebanon RIII School District	PWSID:			Job #:
Address: 224 W. Commercial Street	Due Date Requested:			
City: Lebanon	TAT Requested (days): Standard			
State, Zip: MO 65536	Compliance Project: Δ Yes Δ No			
Phone: 417-849-3330	PO #:			
Email: Jeff.morgan@lebanon.k12.mo.us	WO #:			
Project Name: Lebanon RIII School District	Project #:			
Site: Lebanon Esther	SSOW#:			

Analysis Requested

Preservation Codes:
A - HCL, B - NaOH, C - Zn Acetate, D - Nitric Acid, E - NaHSO4, F - MeOH, G - Amchlor, H - Ascorbic Acid, I - Ice, J - DI Water, K - EDTA, L - EDA, M - Hexane, N - None, O - AsNaO2, P - Na2O4S, Q - Na2SO3, R - Na2S2O3, S - H2SO4, T - TSP Dodecahydrate, U - Acetone, V - MCAA, W - pH 4-5, Y - Trizma, Z - other (specify)
Other:

Sample Identification	Sample Date	Sample Time	Sample Type (C=comp, G=grab)	Matrix (W=water, S=solid, O=waste/oil, BT=Tissue, A=Air)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Lead In Drinking Water	Total Number of containers	Special Instructions/Note:
			Preservation Code:						
LE - 89 Sink	1/26/24	0500	G	W			X		
LE - 90 Sink									
LE - 91 Sink									
LE - 92 Bubbler									
LE - 93 Sink									
LE - 94									
LE - 95									
LE - 96 Bubbler									
LE - 97 Sink									
LE - 98 Bubbler									
LE - 99 Sink									

Possible Hazard Identification
☐ Non-Hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☒ Unknown ☐ Radiological

Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)
☐ Return To Client ☒ Disposal By Lab ☐ Archive For _____ Months

Deliverable Requested: I, II, III, IV, Other (specify)

Special Instructions/QC Requirements:

Empty Kit Relinquished by:	Date:	Time:	Method of Shipment:

	Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company
1	Ian St. John	1/26/24		[illegible]	1.30-24 908	
2						
3						

Custody Seals Intact: Δ Yes Δ No | Custody Seal No.: | Cooler Temperature(s) °C and Other Remarks:

Ver: 02/24/23

2/9/2024

Eurofins Eaton Analyitcal: South Bend
110 South Hill Street
South Bend, IN 46617
Phone (574) 233-4777

Chain of Custody Record

eurofins | Environment Testing America

Client Information	Sampler: Ian St. John	Lab PM:	Carrier Tracking No(s):	COC No:
Client Contact: Jeff Morgan	Phone: 314-853-4668	E-Mail: ian@stjohnenv.com	State of Origin: MO	Page: Page 10 of 16
Company: Lebanon RIII School District	PWSID:	Analysis Requested		Job #:
Address: 224 W. Commercial Street	Due Date Requested:			Preservation Codes:
City: Lebanon	TAT Requested (days): Standard			A - HCL, B - NaOH, C - Zn Acetate, D - Nitric Acid, E - NaHSO4, F - MeOH, G - Amchlor, H - Ascorbic Acid, I - Ice, J - DI Water, K - EDTA, L - EDA, M - Hexane, N - None, O - AsNaO2, P - Na2O4S, Q - Na2SO3, R - Na2S2O3, S - H2SO4, T - TSP Dodecahydrate, U - Acetone, V - MCAA, W - pH 4-5, Y - Trizma, Z - other (specify)
State, Zip: MO 65536	Compliance Project: Δ Yes Δ No			
Phone: 417-849-3330	PO #:			Other:
Email: Jeff.morgan@lebanon.k12.mo.us	WO #:			
Project Name: Lebanon RIII School District	Project #:			
Site: Lebanon Esther	SSOW#:			

Sample Identification	Sample Date	Sample Time	Sample Type (C=comp, G=grab)	Matrix (W=water, S=solid, O=waste/oil, BT=Tissue, A=Air)	Field Filtered Sample (Yes or No)	Perform MS/ (Yes or No)	Lead In Drinking Water	Total Number of containers	Special Instructions/Note:
			Preservation Code:						
LE - 100 Sink	1/26/24	0500	G	W			X		
LE - 101									
LE - 102									
LE - 103									
LE - 104 Sink									
LE - 105 WF									
LE - 106 WF									
LE - 107 Bubbler									
LE - 108 Sink									
LE - 109 Sink									
LE - 110 Sink									

Possible Hazard Identification
☐ Non-Hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☒ Unknown ☐ Radiological

Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)
☐ Return To Client ☒ Disposal By Lab ☐ Archive For _____ Months

Deliverable Requested: I, II, III, IV, Other (specify)

Special Instructions/QC Requirements:

Empty Kit Relinquished by:	Date:	Time:	Method of Shipment:

Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company
Ian St. John	1/26/24		Unsigned Attached	1.30.24 909	
Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company
Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company

Custody Seals Intact: Δ Yes Δ No	Custody Seal No.:	Cooler Temperature(s) °C and Other Remarks:

Ver: 02/24/23

2/9/2024

Eurofins Eaton Analyitcal: South Bend
110 South Hill Street
South Bend, IN 46617
Phone (574) 233-4777

Chain of Custody Record

eurofins | Environment Testing America

Client Information	Sampler: Ian St. John	Lab PM:	Carrier Tracking No(s):	COC No:
Client Contact: Jeff Morgan	Phone: 314-853-4668	E-Mail: ian@stjohnenv.com	State of Origin: MO	Page: Page 11 of 16
Company: Lebanon RIII School District	PWSID:			Job #:

Address: 224 W. Commercial Street	Due Date Requested:	
City: Lebanon	TAT Requested (days): Standard	
State, Zip: MO 65536	Compliance Project: Δ Yes Δ No	
Phone: 417-849-3330	PO #:	
Email: Jeff.morgan@lebanon.k12.mo.us	WO #:	
Project Name: Lebanon RIII School District	Project #:	
Site: Lebanon Esther	SSOW#:	

Analysis Requested

Preservation Codes:

A - HCL, B - NaOH, C - Zn Acetate, D - Nitric Acid, E - NaHSO4, F - MeOH, G - Amchlor, H - Ascorbic Acid, I - Ice, J - DI Water, K - EDTA, L - EDA, M - Hexane, N - None, O - AsNaO2, P - Na2O4S, Q - Na2SO3, R - Na2S2O3, S - H2SO4, T - TSP Dodecahydrate, U - Acetone, V - MCAA, W - pH 4-5, Y - Trizma, Z - other (specify)

Other:

Sample Identification	Sample Date	Sample Time	Sample Type (C=comp, G=grab)	Matrix (W=water, S=solid, O=waste/oil, BT=Tissue, A=Air)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Lead In Drinking Water	Total Number of containers	Special Instructions/Note:
			Preservation Code:						
LE-111 Bubbler	1/26/24	0500	G	W			X		
LE-112 Sink									
LE-113 WF									
LE-114 WF									
LE-115 Sink									
LE-116									Top writing "117" labeled "116" ppw 01/30/24
LE-117									
LE-118									
LE-119 Sink									
LE-120 Sink									
LE-121 Ref Filler									

Possible Hazard Identification
☐ Non-Hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☒ Unknown ☐ Radiological

Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)
☐ Return To Client ☒ Disposal By Lab ☐ Archive For _____ Months

Deliverable Requested: I, II, III, IV, Other (specify)

Special Instructions/QC Requirements:

Empty Kit Relinquished by:	Date:	Time:	Method of Shipment:
Relinquished by: Ian St. John	Date/Time: 1/26/24	Company	Received by: Robin Peters Date/Time: 1-30-24 908 Company
Relinquished by:	Date/Time:	Company	Received by: Date/Time: Company
Relinquished by:	Date/Time:	Company	Received by: Date/Time: Company

Custody Seals Intact: Δ Yes Δ No | Custody Seal No.: | Cooler Temperature(s) °C and Other Remarks:

Ver: 02/24/23

2/9/2024

Eurofins Eaton Analyitcal: South Bend
110 South Hill Street
South Bend, IN 46617
Phone (574) 233-4777

Chain of Custody Record

eurofins | Environment Testing America

Client Information	Sampler: Ian St. John	Lab PM:	Carrier Tracking No(s):	COC No:
Client Contact: Jeff Morgan	Phone: 314-853-4668	E-Mail: ian@stjohnenv.com	State of Origin: MO	Page: Page 16 of 16
Company: Lebanon RIII School District	PWSID:			Job #:
Address: 224 W. Commercial Street	Due Date Requested:			
City: Lebanon	TAT Requested (days): Standard			
State, Zip: MO 65536	Compliance Project: Δ Yes Δ No			
Phone: 417-849-3330	PO #:			
Email: Jeff.morgan@lebanon.k12.mo.us	WO #:			
Project Name: Lebanon RIII School District	Project #:			
Site: Lebanon Esther	SSOW#:			

Analysis Requested

Preservation Codes:
A - HCL, B - NaOH, C - Zn Acetate, D - Nitric Acid, E - NaHSO4, F - MeOH, G - Amchlor, H - Ascorbic Acid, I - Ice, J - DI Water, K - EDTA, L - EDA, M - Hexane, N - None, O - AsNaO2, P - Na2O4S, Q - Na2SO3, R - Na2S2O3, S - H2SO4, T - TSP Dodecahydrate, U - Acetone, V - MCAA, W - pH 4-5, Y - Trizma, Z - other (specify)
Other:

Sample Identification	Sample Date	Sample Time	Sample Type (C=comp, G=grab)	Matrix (W=water, S=solid, O=waste/oil, BT=Tissue, A=Air)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Lead In Drinking Water	Total Number of containers	Special Instructions/Note:
			Preservation Code:						
LE - 122 Pot Filler	1/26/24	0580	G	W			X		
LE - 123 SINK / Washer									
LE - 124 Sink									
LE - 125									
LE - 126									
LE - 127									
LE - 128									
LE - 129									
LE - 130 WF									
LE - 131 Sink									
LE - 132 Sink									

Possible Hazard Identification
☐ Non-Hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☒ Unknown ☐ Radiological

Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)
☐ Return To Client ☒ Disposal By Lab ☐ Archive For _____ Months

Deliverable Requested: I, II, III, IV, Other (specify)

Special Instructions/QC Requirements:

Empty Kit Relinquished by:	Date:	Time:	Method of Shipment:

	Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company
1	Ian St. John	1/26/24		[illegible]	1.30.24 9pp	
2	Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company
3	Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company

Custody Seals Intact: Δ Yes Δ No | Custody Seal No.: | Cooler Temperature(s) °C and Other Remarks:

Ver: 02/24/23

Eurofins Eaton Analyitcal: South Bend
110 South Hill Street
South Bend, IN 46617
Phone (574) 233-4777

Chain of Custody Record

eurofins | Environment Testing America

Client Information	Sampler: Ian St. John	Lab PM:	Carrier Tracking No(s):	COC No:
Client Contact: Jeff Morgan	Phone: 314-853-4668	E-Mail: ian@stjohnenv.com	State of Origin: MO	Page: Page 13 of 16
Company: Lebanon RIII School District	PWSID:	Analysis Requested		Job #:
Address: 224 W. Commercial Street	Due Date Requested:			Preservation Codes:
City: Lebanon	TAT Requested (days): Standard			A - HCL, B - NaOH, C - Zn Acetate, D - Nitric Acid, E - NaHSO4, F - MeOH, G - Amchlor, H - Ascorbic Acid, I - Ice, J - DI Water, K - EDTA, L - EDA, M - Hexane, N - None, O - AsNaO2, P - Na2O4S, Q - Na2SO3, R - Na2S2O3, S - H2SO4, T - TSP Dodecahydrate, U - Acetone, V - MCAA, W - pH 4-5, Y - Trizma, Z - other (specify)
State, Zip: MO 65536	Compliance Project: Δ Yes Δ No			
Phone: 417-849-3330	PO #:			Other:
Email: Jeff.morgan@lebanon.k12.mo.us	WO #:			
Project Name: Lebanon RIII School District	Project #:			
Site: Lebanon Esther	SSOW#:			

Sample Identification	Sample Date	Sample Time	Sample Type (C=Comp, G=grab)	Matrix (W=water, S=solid, O=waste/oil, BT=Tissue, A=Air)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Lead In Drinking Water	Total Number of containers	Special Instructions/Note:
			Preservation Code:						
LE - 133 GF	1/26/24	0500	G	W			X		
LE - 134 Sink									
LE - 135									
LE - 136 Room 511									
LE - 137 Sink									
LE - 138 Sink									
LE - 139 Sink									
LE - 140 Bubbler									
LE - 141 Sink									
LE - 142 Bubbler									
LE - 143 Sink									

Possible Hazard Identification
☐ Non-Hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☒ Unknown ☐ Radiological

Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)
☐ Return To Client ☒ Disposal By Lab ☐ Archive For _____ Months

Deliverable Requested: I, II, III, IV, Other (specify)

Special Instructions/QC Requirements:

Empty Kit Relinquished by:	Date:	Time:	Method of Shipment:

	Relinquished by	Date/Time	Company	Received by	Date/Time	Company
1	Ian St. John	1/26/24		[signature]	1.30.24 900	
2						
3						

Custody Seals Intact: Δ Yes Δ No | Custody Seal No.: | Cooler Temperature(s) °C and Other Remarks:

Ver: 02/24/23

2/9/2024

Eurofins Eaton Analyitcal: South Bend
110 South Hill Street
South Bend, IN 46617
Phone (574) 233-4777

Chain of Custody Record

Cross Offs on COC by Client

7/25

eurofins | Environment Testing America

2/9/2024

Client Information	Sampler: Ian St. John	Lab PM:	Carrier Tracking No(s):	COC No:
Client Contact: Jeff Morgan	Phone: 314-853-4668	E-Mail: ian@stjohnenv.com	State of Origin: MO	Page: Page 14 of 16
Company: Lebanon RIII School District	PWSID:			Job #:
Address: 224 W. Commercial Street	Due Date Requested:			
City: Lebanon	TAT Requested (days): Standard			
State, Zip: MO 65536	Compliance Project: Δ Yes Δ No			
Phone: 417-849-3330	PO #:			
Email: Jeff.morgan@lebanon.k12.mo.us	WO #:			
Project Name: Lebanon RIII School District	Project #:			
Site: Lebanon Esther	SSOW#:			

Analysis Requested

Preservation Codes:
A - HCL, B - NaOH, C - Zn Acetate, D - Nitric Acid, E - NaHSO4, F - MeOH, G - Amchlor, H - Ascorbic Acid, I - Ice, J - DI Water, K - EDTA, L - EDA, M - Hexane, N - None, O - AsNaO2, P - Na2O4S, Q - Na2SO3, R - Na2S2O3, S - H2SO4, T - TSP Dodecahydrate, U - Acetone, V - MCAA, W - pH 4-5, Y - Trizma, Z - other (specify)
Other:

Sample Identification	Sample Date	Sample Time	Sample Type (C=Comp, G=grab)	Matrix (W=water, S=solid, O=waste/oil, BT=Tissue, A=Air)	Field Filtered Sample (Yes or No)	Perform MS/ (es or No	Lead In Drinking Water	Total Number of containers	Special Instructions/Note:
			Preservation Code:						
LE-144 Bubbler	1/26/24	6510	G	W			X		
LE-145 SINK	↓	↓	↓	↓			↓		
LE-146 BF									
LE-147 SINK									
LE-148 BF									
LE-149 SINK									
LE-150									
LE-151									
LE-152									
LE-153 WF									
LE-154 SINK	↓	↓	↓	↓			↓		

Possible Hazard Identification
☐ Non-Hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☒ Unknown ☐ Radiological

Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)
☐ Return To Client ☒ Disposal By Lab ☐ Archive For _____ Months

Deliverable Requested: I, II, III, IV, Other (specify)

Special Instructions/QC Requirements:

Empty Kit Relinquished by:	Date:	Time:	Method of Shipment:

	Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company
1	Ian St. John	1/26/24		[signature]	1-30-24 900	
2	Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company
3	Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company

Custody Seals Intact: Δ Yes Δ No	Custody Seal No.:	Cooler Temperature(s) °C and Other Remarks:

Ver: 02/24/23

Eurofins Eaton Analyitcal: South Bend
110 South Hill Street
South Bend, IN 46617
Phone (574) 233-4777

Chain of Custody Record

eurofins | Environment Testing America

7 / 25

2/9/2024

Client Information	Sampler: Ian St. John	Lab PM:	Carrier Tracking No(s):	COC No:
Client Contact: Jeff Morgan	Phone: 314-853-4668	E-Mail: ian@stjohnenv.com	State of Origin: MO	Page: Page 15 of 16
Company: Lebanon RIII School District	PWSID:			Job #:
Address: 224 W. Commercial Street	Due Date Requested:			
City: Lebanon	TAT Requested (days): Standard			
State, Zip: MO 65536	Compliance Project: Δ Yes Δ No			
Phone: 417-849-3330	PO #:			
Email: Jeff.morgan@lebanon.k12.mo.us	WO #:			
Project Name: Lebanon RIII School District	Project #:			
Site: Lebanon Esther	SSOW#:			

Analysis Requested

Preservation Codes:
A - HCL, B - NaOH, C - Zn Acetate, D - Nitric Acid, E - NaHSO4, F - MeOH, G - Amchlor, H - Ascorbic Acid, I - Ice, J - DI Water, K - EDTA, L - EDA, M - Hexane, N - None, O - AsNaO2, P - Na2O4S, Q - Na2SO3, R - Na2S2O3, S - H2SO4, T - TSP Dodecahydrate, U - Acetone, V - MCAA, W - pH 4-5, Y - Trizma, Z - other (specify)
Other:

Sample Identification	Sample Date	Sample Time	Sample Type (C=Comp, G=grab)	Matrix (W=water, S=solid, O=waste/oil, BT=Tissue, A=Air)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Lead In Drinking Water	Total Number of containers	Special Instructions/Note:
			Preservation Code:						
LE-155 Bubbler	1/26/24	0520	G	W			X		
LE-156 Sink									
LE-157 Bubbler									
LE-158 WF									
LE-159 Sink									
LE-160 Bubbler									
LE-161 Sink									
LE-162 Bubbler									
LE-163 Sink Room 610									
LE-164 Sink									
LE-165 Bubbler									

Possible Hazard Identification
☐ Non-Hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☒ Unknown ☐ Radiological

Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)
☐ Return To Client ☒ Disposal By Lab ☐ Archive For _____ Months

Deliverable Requested: I, II, III, IV, Other (specify)

Special Instructions/QC Requirements:

Empty Kit Relinquished by:	Date:	Time:	Method of Shipment:

	Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company
1	Ian St. John	1/26/24		[illegible]	1-30-24 0950	
2	Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company
3	Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company

Custody Seals Intact: Δ Yes Δ No	Custody Seal No.:	Cooler Temperature(s) °C and Other Remarks:

Ver: 02/24/23

Eurofins Eaton Analyitcal: South Bend
110 South Hill Street
South Bend, IN 46617
Phone (574) 233-4777

Cross Offs on COC by Client

7/25

Chain of Custody Record

Eurofins | Environment Testing America

2/9/2024

Client Information	Sampler: Ian St. John	Lab PM:	Carrier Tracking No(s):	COC No:
Client Contact: Jeff Morgan	Phone: 314-853-4668	E-Mail: ian@stjohnenv.com	State of Origin: MO	Page: Page 16 of 110
Company: Lebanon RIII School District	PWSID:			Job #:
Address: 224 W. Commercial Street	Due Date Requested:			
City: Lebanon	TAT Requested (days): Standard			
State, Zip: MO 65536	Compliance Project: Δ Yes Δ No			
Phone: 417-849-3330	PO #:			
Email: Jeff.morgan@lebanon.k12.mo.us	WO #:			
Project Name: Lebanon RIII School District	Project #:			
Site: Lebanon Esther	SSOW#:			

Analysis Requested

Preservation Codes:

A - HCL, B - NaOH, C - Zn Acetate, D - Nitric Acid, E - NaHSO4, F - MeOH, G - Amchlor, H - Ascorbic Acid, I - Ice, J - DI Water, K - EDTA, L - EDA, M - Hexane, N - None, O - AsNaO2, P - Na2O4S, Q - Na2SO3, R - Na2S2O3, S - H2SO4, T - TSP Dodecahydrate, U - Acetone, V - MCAA, W - pH 4-5, Y - Trizma, Z - other (specify)

Other:

Sample Identification	Sample Date	Sample Time	Sample Type (C=comp, G=grab)	Matrix (W=water, S=solid, O=waste/oil, BT=Tissue, A=Air)	Field Filtered Sample (Yes or No)	Perform MS/ (Yes or No)	Lead In Drinking Water	Total Number of containers	Special Instructions/Note:
			Preservation Code:						
LE-166 Sink	1/26/24	0445	G	W			X		
LE-167 Bubbler									
LE-168 Sink									
LE-169									
LE-170									
LE-171									
LE-172									
LE-173									
LE-174									
LE-175									
LE-176									

Possible Hazard Identification
☐ Non-Hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☒ Unknown ☐ Radiological

Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)
☐ Return To Client ☒ Disposal By Lab ☐ Archive For _____ Months

Deliverable Requested: I, II, III, IV, Other (specify)

Special Instructions/QC Requirements:

Empty Kit Relinquished by:	Date:	Time:	Method of Shipment:

	Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company
1	Ian St. John	1/26/24		Fubbing Affeld	1-30-24 500	
2	Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company
3	Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company

Custody Seals Intact: Δ Yes Δ No | Custody Seal No.: | Cooler Temperature(s) °C and Other Remarks:

Ver: 02/24/23

Login Sample Receipt Checklist

Client: St. John Environmental Consulting

Job Number: 810-92179-1

Login Number: 92179

List Source: Eurofins Eaton Analytical South Bend

List Number: 1

Creator: Pehling-Wright, Penny

Question	Answer	Comment
The cooler's custody seal, if present, is intact.	True	
Sample custody seals, if present, are intact.	True	
Samples were received on ice.	False	Thermal preservation not required.
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	True	
Samples do not require splitting or compositing.	True	
Container provided by EEA	True	