eurofins | Environment Testing

ANALYTICAL REPORT

PREPARED FOR

Attn: Ian St. John
St. John Environmental Consulting
5515 Grace Ave.
Saint Louis, Missouri 63116

Generated 2/9/2024 1:18:31 AM

JOB DESCRIPTION

Lebanon RIII School District - High School

JOB NUMBER

810-91973-1

Eurofins Eaton Analytical South Bend
110 S Hill Street
South Bend IN 46617

See page two for job notes and contact information.

myEOL

Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and will meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All questions should be directed to the Eurofins Eaton Analytical, LLC Project Manager.

Authorization



Generated
2/9/2024 1:18:31 AM

Authorized for release by
Pamela Brown, Project Manager
Pamela.Brown@et.eurofinsus.com
(574)233-4777

Table of Contents

Cover Page 1
Table of Contents 3
Definitions/Glossary 4
Case Narrative 5
Detection Summary 7
Client Sample Results 21
QC Sample Results 45
QC Association Summary 53
Lab Chronicle 58
Certification Summary 82
Method Summary 83
Sample Summary 84
Chain of Custody 87
Receipt Checklists 102

Definitions/Glossary

Client: St. John Environmental Consulting
Job ID: 810-91973-1
Project/Site: Lebanon RIII School District - High School

Qualifiers

Metals

Qualifier	Qualifier Description
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
¤	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

Job ID: 810-91973-1 — Eurofins Eaton Analytical South Bend

Job Narrative
810-91973-1

Analytical test results meet all requirements of the associated regulatory program listed on the Accreditation/Certification Summary Page unless otherwise noted under the individual analysis. Data qualifiers are applied to indicate exceptions. Noncompliant quality control (QC) is further explained in narrative comments.

- Matrix QC may not be reported if insufficient sample or site-specific QC samples were not submitted. In these situations, to demonstrate precision and accuracy at a batch level, a LCS/LCSD may be performed, unless otherwise specified in the method.
- Surrogate and/or isotope dilution analyte recoveries (if applicable) which are outside of the QC window are confirmed unless attributed to a dilution or otherwise noted in the narrative.

Regulated compliance samples (e.g. SDWA, NPDES) must comply with the associated agency requirements/permits.

Receipt
The samples were received on 1/30/2024 9:00 AM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice.

Receipt Exceptions
No sample date/time on containers. Samples logged according to COC.

LHS-1 Sink (810-91973-1), LHS-2 Sink (810-91973-2), LHS-3 WF (810-91973-3), LHS-4 WF (810-91973-4), LHS-5 WF (810-91973-5), LHS-6 WF (810-91973-6), LHS-7 Sink (810-91973-7), LHS-8 Sink (810-91973-8), LHS-9 Sink (810-91973-9), LHS-10 Sink (810-91973-10), LHS-11 Sink (810-91973-11), LHS-12 Sink (810-91973-12), LHS-13 Sink (810-91973-13), LHS-14 Sink (810-91973-14), LHS-15 Sink (810-91973-15), LHS-16 Sink (810-91973-16), LHS-17 Sink (810-91973-17), LHS-18 Sink (810-91973-18), LHS-19 Sink (810-91973-19), LHS-20 Sink (810-91973-20), LHS-21 Sink (810-91973-21), LHS-22 Sink (810-91973-22), LHS-23 Sink (810-91973-23), LHS-24 WF (810-91973-24), LHS-25 WF (810-91973-25), LHS-26 WF (810-91973-26), LHS-27 Sink (810-91973-27), LHS-28 Sink (810-91973-28), LHS-29 Sink (810-91973-29), LHS-30 Sink (810-91973-30), LHS-31 Bubbler (810-91973-31), LHS-32 Sink (810-91973-32), LHS-33 Bubbler (810-91973-33), LHS-34 Sink (810-91973-34), LHS-35 Sink (810-91973-35), LHS-36 Sink (810-91973-36), LHS-37 Bubbler (810-91973-37), LHS-38 Sink (810-91973-38), LHS-39 Bubbler (810-91973-39), LHS-40 WF (810-91973-40), LHS-41 Sink (810-91973-41), LHS-42 Sink (810-91973-42), LHS-43 Bubbler (810-91973-43), LHS-44 Sink (810-91973-44), LHS-45 Sink (810-91973-45), LHS-46 Bubbler (810-91973-46), LHS-47 Sink (810-91973-47), LHS-48 Bubbler (810-91973-48), LHS-49 WF (810-91973-49), LHS-50 Sink (810-91973-50), LHS-51 Sink (810-91973-51), LHS-52 Sink (810-91973-52), LHS-53 Bubbler (810-91973-53), LHS-54 Sink (810-91973-54), LHS-55 Bubbler (810-91973-55), LHS-56 Sink (810-91973-56), LHS-57 Bubbler (810-91973-57), LHS-58 Sink (810-91973-58), LHS-59 Sink (810-91973-59), LHS-60 Sink (810-91973-60), LHS-61 Bubbler (810-91973-61), LHS-62 Sink (810-91973-62), LHS-63 Bubbler (810-91973-63), LHS-64 Sink (810-91973-64), LHS-65 Sink (810-91973-65), LHS-66 Sink (810-91973-66), LHS-67 Sink (810-91973-68), LHS-68 Sink (810-91973-69), LHS-69 Bubbler (810-91973-70), LHS-70 WF (810-91973-71), LHS-71 WF (810-91973-72), LHS-72 Sink (810-91973-73), LHS-73 Sink (810-91973-74), LHS-74 Sink (810-91973-75), LHS-75 Sink (810-91973-76), LHS-76 Sink (810-91973-77), LHS-77 Sink (810-91973-78), LHS-78 Sink (810-91973-79), LHS-79 WF (810-91973-80), LHS-80 WF (810-91973-81), LHS-81 Sink (810-91973-82), LHS-82 Sink (810-91973-83), LHS-83 Sink (810-91973-84), LHS-84 Sink (810-91973-85), LHS-85 Sink (810-91973-86), LHS-86 Sink (810-91973-87), LHS-87 Sink (810-91973-88), LHS-88 Sink (810-91973-89), LHS-89 Sink (810-91973-90), LHS-90 Sink (810-91973-91), LHS-91 Sink (810-91973-92), LHS-92 Sink (810-91973-93), LHS-93 Sink (810-91973-94), LHS-94 Sink (810-91973-95), LHS-95 Sink (810-91973-96), LHS-96 Sink (810-91973-97), LHS-97 Sink (810-91973-98), LHS-98 Sink (810-91973-99), LHS-99 Sink (810-91973-100), LHS-100 Sink (810-91973-101), LHS-101 Sink (810-91973-102), LHS-102 Sink (810-91973-103), LHS-103 Sink (810-91973-104), LHS-104 Sink (810-91973-105), LHS-105 Sink (810-91973-106), LHS-106 Sink (810-91973-107), LHS-107 Sink (810-91973-108), LHS-108 WF (810-91973-109), LHS-109 Sink (810-91973-110), LHS-110 Sink (810-91973-111), LHS-111 Sink (810-91973-112), LHS-112 Sink (810-91973-113), LHS-113 Sink (810-91973-114), LHS-114 Sink (810-91973-115), LHS-115 Sink (810-91973-116), LHS-116 Sink (810-91973-117), LHS-117 Sink (810-91973-118), LHS-118 Sink (810-91973-119), LHS-119 Sink (810-91973-120), LHS-120 Sink (810-91973-121), LHS-121 Sink (810-91973-122), LHS-122 Sink (810-91973-123), LHS-123 Sink (810-91973-124), LHS-124 Sink (810-91973-125), LHS-125 Sink (810-91973-126), LHS-126 Sink (810-91973-127), LHS-127 WF (810-91973-128), LHAS-128 Sink (810-91973-129), LHS-129 Sink (810-91973-130), LHS-130 Sink (810-91973-131), LHS-131 Sink (810-91973-132), LHS-132 Sink (810-91973-133), LHS-133 Sink (810-91973-134), LHS-134 Sink (810-91973-135), LHS-135 Sink (810-91973-136), LHS-136 Sink (810-91973-137), LHS-137 BF (810-91973-138), LHS-138 Sink (810-91973-139), LHS-139 Sink (810-91973-140), LHS-140 WF (810-91973-141), LHS-141 Sink (810-91973-142), LHS-142 Sink (810-91973-143), LHS-143 Sink (810-91973-144), LHS-144 WF (810-91973-145), LHS-145 WF (810-91973-146), LHS-146 Sink (810-91973-147), LHS-147 Sink (810-91973-148), LHS-148 Sink (810-91973-149), LHS-149 Sink (810-91973-150), LHS-150 Sink (810-91973-151), LHS-151 Sink (810-91973-152), LHS-152 Sink (810-91973-153), LHS-153 Sink (810-91973-154), LHS-154 WF (810-91973-155), LHS-155 WF (810-91973-156), LHS-156 Sink (810-91973-157), LHS-157 WF (810-91973-158), LHS-158 WF

(810-91973-159), LHS-159 Sink (810-91973-160), LHS-160 Sink (810-91973-161), LHS-161 ICE (810-91973-162) and LHS-162 ICE (810-91973-163)

Metals
No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Detection Summary

Client: St. John Environmental Consulting
Job ID: 810-91973-1
Project/Site: Lebanon RIII School District - High School

Client Sample ID: LHS-1 Sink — Lab Sample ID: 810-91973-1

No Detections.

Client Sample ID: LHS-2 Sink — Lab Sample ID: 810-91973-2

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	3.1		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-3 WF — Lab Sample ID: 810-91973-3

No Detections.

Client Sample ID: LHS-4 WF — Lab Sample ID: 810-91973-4

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.51		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-5 WF — Lab Sample ID: 810-91973-5

No Detections.

Client Sample ID: LHS-6 WF — Lab Sample ID: 810-91973-6

No Detections.

Client Sample ID: LHS-7 Sink — Lab Sample ID: 810-91973-7

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.7		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-8 Sink — Lab Sample ID: 810-91973-8

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.3		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-9 Sink — Lab Sample ID: 810-91973-9

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	2.3		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-10 Sink — Lab Sample ID: 810-91973-10

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	4.2		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-11 Sink — Lab Sample ID: 810-91973-11

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	2.0		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-12 Sink — Lab Sample ID: 810-91973-12

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	2.3		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-13 Sink — Lab Sample ID: 810-91973-13

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.6		0.50		ug/L	1		200.8	Total/NA

This Detection Summary does not include radiochemical test results.

Detection Summary

Client: St. John Environmental Consulting
Job ID: 810-91973-1
Project/Site: Lebanon RIII School District - High School

Client Sample ID: LHS-14 Sink — Lab Sample ID: 810-91973-14

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.66		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-15 Sink — Lab Sample ID: 810-91973-15

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.2		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-16 Sink — Lab Sample ID: 810-91973-16

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.92		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-17 Sink — Lab Sample ID: 810-91973-17

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.6		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-18 Sink — Lab Sample ID: 810-91973-18

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	9.3		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-19 Sink — Lab Sample ID: 810-91973-19

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.0		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-20 Sink — Lab Sample ID: 810-91973-20

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.0		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-21 Sink — Lab Sample ID: 810-91973-21

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.1		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-22 Sink — Lab Sample ID: 810-91973-22

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	3.8		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-23 Sink — Lab Sample ID: 810-91973-23

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	5.8		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-24 WF — Lab Sample ID: 810-91973-24

No Detections.

Client Sample ID: LHS-25 WF — Lab Sample ID: 810-91973-25

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.79		0.50		ug/L	1		200.8	Total/NA

This Detection Summary does not include radiochemical test results.

Detection Summary

Client: St. John Environmental Consulting
Job ID: 810-91973-1
Project/Site: Lebanon RIII School District - High School

Client Sample ID: LHS-26 WF — Lab Sample ID: 810-91973-26

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.77		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-27 Sink — Lab Sample ID: 810-91973-27

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	6.3		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-28 Sink — Lab Sample ID: 810-91973-28

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	3.3		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-29 Sink — Lab Sample ID: 810-91973-29

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	5.6		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-30 Sink — Lab Sample ID: 810-91973-30

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	29		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-31 Bubbler — Lab Sample ID: 810-91973-31

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	11		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-32 Sink — Lab Sample ID: 810-91973-32

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	27		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-33 Bubbler — Lab Sample ID: 810-91973-33

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	16		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-34 Sink — Lab Sample ID: 810-91973-34

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	5.3		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-35 Sink — Lab Sample ID: 810-91973-35

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	10		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-36 Sink — Lab Sample ID: 810-91973-36

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	23		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-37 Bubbler — Lab Sample ID: 810-91973-37

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	13		0.50		ug/L	1		200.8	Total/NA

This Detection Summary does not include radiochemical test results.

Detection Summary

Client: St. John Environmental Consulting
Job ID: 810-91973-1
Project/Site: Lebanon RIII School District - High School

Client Sample ID: LHS-38 Sink — Lab Sample ID: 810-91973-38

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	25		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-39 Bubbler — Lab Sample ID: 810-91973-39

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	15		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-40 WF — Lab Sample ID: 810-91973-40

No Detections.

Client Sample ID: LHS-41 Sink — Lab Sample ID: 810-91973-41

No Detections.

Client Sample ID: LHS-42 Sink — Lab Sample ID: 810-91973-42

No Detections.

Client Sample ID: LHS-43 Bubbler — Lab Sample ID: 810-91973-43

No Detections.

Client Sample ID: LHS-44 Sink — Lab Sample ID: 810-91973-44

No Detections.

Client Sample ID: LHS-45 Sink — Lab Sample ID: 810-91973-45

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	2.1		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-46 Bubbler — Lab Sample ID: 810-91973-46

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.0		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-47 Sink — Lab Sample ID: 810-91973-47

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	15		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-48 Bubbler — Lab Sample ID: 810-91973-48

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.2		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-49 WF — Lab Sample ID: 810-91973-49

No Detections.

Client Sample ID: LHS-50 Sink — Lab Sample ID: 810-91973-50

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	3.9		0.50		ug/L	1		200.8	Total/NA

This Detection Summary does not include radiochemical test results.

Detection Summary

Client: St. John Environmental Consulting
Job ID: 810-91973-1
Project/Site: Lebanon RIII School District - High School

Client Sample ID: LHS-51 Sink — Lab Sample ID: 810-91973-51

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	2.6		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-52 Sink — Lab Sample ID: 810-91973-52

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	17		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-53 Bubbler — Lab Sample ID: 810-91973-53

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	3.9		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-54 Sink — Lab Sample ID: 810-91973-54

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	3.2		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-55 Bubbler — Lab Sample ID: 810-91973-55

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.99		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-56 Sink — Lab Sample ID: 810-91973-56

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	9.4		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-57 Bubbler — Lab Sample ID: 810-91973-57

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	2.5		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-58 Sink — Lab Sample ID: 810-91973-58

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.61		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-59 Sink — Lab Sample ID: 810-91973-59

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.2		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-60 Sink — Lab Sample ID: 810-91973-60

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	28		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-61 Bubbler — Lab Sample ID: 810-91973-61

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	19		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-62 Sink — Lab Sample ID: 810-91973-62

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	14		0.50		ug/L	1		200.8	Total/NA

This Detection Summary does not include radiochemical test results.

Eurofins Eaton Analytical South Bend

Detection Summary

Client: St. John Environmental Consulting
Job ID: 810-91973-1
Project/Site: Lebanon RIII School District - High School

Client Sample ID: LHS-63 Bubbler — Lab Sample ID: 810-91973-63

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	10		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-64 Sink — Lab Sample ID: 810-91973-64

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	4.8		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-65 Sink — Lab Sample ID: 810-91973-65

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	3.7		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-66 Sink — Lab Sample ID: 810-91973-66

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	8.6		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-67 Sink — Lab Sample ID: 810-91973-68

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	3.8		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-68 Sink — Lab Sample ID: 810-91973-69

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	24		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-69 Bubbler — Lab Sample ID: 810-91973-70

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	12		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-70 WF — Lab Sample ID: 810-91973-71

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	4.2		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-71 WF — Lab Sample ID: 810-91973-72

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	8.5		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-72 Sink — Lab Sample ID: 810-91973-73

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	3.7		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-73 Sink — Lab Sample ID: 810-91973-74

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	9.7		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-74 Sink — Lab Sample ID: 810-91973-75

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	3.7		0.50		ug/L	1		200.8	Total/NA

This Detection Summary does not include radiochemical test results.

Eurofins Eaton Analytical South Bend

Detection Summary

Client: St. John Environmental Consulting
Job ID: 810-91973-1
Project/Site: Lebanon RIII School District - High School

Client Sample ID: LHS-75 Sink — Lab Sample ID: 810-91973-76

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	7.2		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-76 Sink — Lab Sample ID: 810-91973-77

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	6.6		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-77 Sink — Lab Sample ID: 810-91973-78

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	7.1		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-78 Sink — Lab Sample ID: 810-91973-79

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	13		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-79 WF — Lab Sample ID: 810-91973-80

No Detections.

Client Sample ID: LHS-80 WF — Lab Sample ID: 810-91973-81

No Detections.

Client Sample ID: LHS-81 Sink — Lab Sample ID: 810-91973-82

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	5.6		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-82 Sink — Lab Sample ID: 810-91973-83

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	5.5		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-83 Sink — Lab Sample ID: 810-91973-84

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	5.0		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-84 Sink — Lab Sample ID: 810-91973-85

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	4.9		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-85 Sink — Lab Sample ID: 810-91973-86

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	6.2		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-86 Sink — Lab Sample ID: 810-91973-87

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	2.4		0.50		ug/L	1		200.8	Total/NA

This Detection Summary does not include radiochemical test results.

Detection Summary

Client: St. John Environmental Consulting
Job ID: 810-91973-1
Project/Site: Lebanon RIII School District - High School

Client Sample ID: LHS-87 Sink — Lab Sample ID: 810-91973-88

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	2.9		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-88 Sink — Lab Sample ID: 810-91973-89

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	3.4		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-89 Sink — Lab Sample ID: 810-91973-90

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	3.2		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-90 Sink — Lab Sample ID: 810-91973-91

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	3.9		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-91 Sink — Lab Sample ID: 810-91973-92

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	23		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-92 Sink — Lab Sample ID: 810-91973-93

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	22		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-93 Sink — Lab Sample ID: 810-91973-94

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	21		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-94 Sink — Lab Sample ID: 810-91973-95

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	11		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-95 Sink — Lab Sample ID: 810-91973-96

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	3.3		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-96 Sink — Lab Sample ID: 810-91973-97

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	2.4		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-97 Sink — Lab Sample ID: 810-91973-98

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	3.3		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-98 Sink — Lab Sample ID: 810-91973-99

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.64		0.50		ug/L	1		200.8	Total/NA

This Detection Summary does not include radiochemical test results.

Eurofins Eaton Analytical South Bend

Detection Summary

Client: St. John Environmental Consulting
Job ID: 810-91973-1
Project/Site: Lebanon RIII School District - High School

Client Sample ID: LHS-99 Sink — Lab Sample ID: 810-91973-100

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.1		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-100 Sink — Lab Sample ID: 810-91973-101

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	11		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-101 Sink — Lab Sample ID: 810-91973-102

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	4.9		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-102 Sink — Lab Sample ID: 810-91973-103

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	16		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-103 Sink — Lab Sample ID: 810-91973-104

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	4.1		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-104 Sink — Lab Sample ID: 810-91973-105

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	3.5		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-105 Sink — Lab Sample ID: 810-91973-106

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	2.1		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-106 Sink — Lab Sample ID: 810-91973-107

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	12		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-107 Sink — Lab Sample ID: 810-91973-108

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	2.1		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-108 WF — Lab Sample ID: 810-91973-109

No Detections.

Client Sample ID: LHS-109 Sink — Lab Sample ID: 810-91973-110

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	45		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-110 Sink — Lab Sample ID: 810-91973-111

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	4.3		0.50		ug/L	1		200.8	Total/NA

This Detection Summary does not include radiochemical test results.

Detection Summary

Client: St. John Environmental Consulting
Job ID: 810-91973-1
Project/Site: Lebanon RIII School District - High School

Client Sample ID: LHS-111 Sink — Lab Sample ID: 810-91973-112

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	6.0		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-112 Sink — Lab Sample ID: 810-91973-113

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	18		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-113 Sink — Lab Sample ID: 810-91973-114

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	2.2		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-114 Sink — Lab Sample ID: 810-91973-115

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	14		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-115 Sink — Lab Sample ID: 810-91973-116

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	6.9		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-116 Sink — Lab Sample ID: 810-91973-117

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	16		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-117 Sink — Lab Sample ID: 810-91973-118

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	4.6		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-118 Sink — Lab Sample ID: 810-91973-119

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	2.1		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-119 Sink — Lab Sample ID: 810-91973-120

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	6.1		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-120 Sink — Lab Sample ID: 810-91973-121

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	6.1		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-121 Sink — Lab Sample ID: 810-91973-122

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	4.5		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-122 Sink — Lab Sample ID: 810-91973-123

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.9		0.50		ug/L	1		200.8	Total/NA

This Detection Summary does not include radiochemical test results.

Eurofins Eaton Analytical South Bend

Detection Summary

Client: St. John Environmental Consulting
Job ID: 810-91973-1
Project/Site: Lebanon RIII School District - High School

Client Sample ID: LHS-123 Sink — Lab Sample ID: 810-91973-124

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	2.8		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-124 Sink — Lab Sample ID: 810-91973-125

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	2.1		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-125 Sink — Lab Sample ID: 810-91973-126

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.9		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-126 Sink — Lab Sample ID: 810-91973-127

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	5.9		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-127 WF — Lab Sample ID: 810-91973-128

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	4.4		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHAS-128 Sink — Lab Sample ID: 810-91973-129

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	20		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-129 Sink — Lab Sample ID: 810-91973-130

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	18		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-130 Sink — Lab Sample ID: 810-91973-131

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	16		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-131 Sink — Lab Sample ID: 810-91973-132

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	15		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-132 Sink — Lab Sample ID: 810-91973-133

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	22		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-133 Sink — Lab Sample ID: 810-91973-134

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	25		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-134 Sink — Lab Sample ID: 810-91973-135

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	15		0.50		ug/L	1		200.8	Total/NA

This Detection Summary does not include radiochemical test results.

Eurofins Eaton Analytical South Bend

Detection Summary

Client: St. John Environmental Consulting
Job ID: 810-91973-1
Project/Site: Lebanon RIII School District - High School

Client Sample ID: LHS-135 Sink — Lab Sample ID: 810-91973-136

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	28		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-136 Sink — Lab Sample ID: 810-91973-137

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	11		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-137 BF — Lab Sample ID: 810-91973-138

No Detections.

Client Sample ID: LHS-138 Sink — Lab Sample ID: 810-91973-139

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	9.3		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-139 Sink — Lab Sample ID: 810-91973-140

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	28		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-140 WF — Lab Sample ID: 810-91973-141

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	5.2		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-141 Sink — Lab Sample ID: 810-91973-142

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	7.9		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-142 Sink — Lab Sample ID: 810-91973-143

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	3.3		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-143 Sink — Lab Sample ID: 810-91973-144

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	5.1		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-144 WF — Lab Sample ID: 810-91973-145

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	8.1		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-145 WF — Lab Sample ID: 810-91973-146

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	3.3		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-146 Sink — Lab Sample ID: 810-91973-147

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	2.2		0.50		ug/L	1		200.8	Total/NA

This Detection Summary does not include radiochemical test results.

Detection Summary

Client: St. John Environmental Consulting
Job ID: 810-91973-1
Project/Site: Lebanon RIII School District - High School

Client Sample ID: LHS-147 Sink — Lab Sample ID: 810-91973-148

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	3.3		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-148 Sink — Lab Sample ID: 810-91973-149

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.81		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-149 Sink — Lab Sample ID: 810-91973-150

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	2.1		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-150 Sink — Lab Sample ID: 810-91973-151

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.1		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-151 Sink — Lab Sample ID: 810-91973-152

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	3.9		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-152 Sink — Lab Sample ID: 810-91973-153

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.7		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-153 Sink — Lab Sample ID: 810-91973-154

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	2.3		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-154 WF — Lab Sample ID: 810-91973-155

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.74		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-155 WF — Lab Sample ID: 810-91973-156

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.66		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-156 Sink — Lab Sample ID: 810-91973-157

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	2.4		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-157 WF — Lab Sample ID: 810-91973-158

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.70		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-158 WF — Lab Sample ID: 810-91973-159

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	2.2		0.50		ug/L	1		200.8	Total/NA

This Detection Summary does not include radiochemical test results.

Detection Summary

Client: St. John Environmental Consulting
Job ID: 810-91973-1
Project/Site: Lebanon RIII School District - High School

Client Sample ID: LHS-159 Sink — Lab Sample ID: 810-91973-160

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	2.6		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-160 Sink — Lab Sample ID: 810-91973-161

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	7.1		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LHS-161 ICE — Lab Sample ID: 810-91973-162

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.1		0.50		ug/L	1		200.8	Total Recoverable

Client Sample ID: LHS-162 ICE — Lab Sample ID: 810-91973-163

No Detections.

This Detection Summary does not include radiochemical test results.

Client: St. John Environmental Consulting
Job ID: 810-91973-1
Project/Site: Lebanon RIII School District - High School

Client Sample ID: LHS-1 Sink
Lab Sample ID: 810-91973-1
Date Collected: 01/26/24 07:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/05/24 11:22	1

Client Sample ID: LHS-2 Sink
Lab Sample ID: 810-91973-2
Date Collected: 01/26/24 07:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	**3.1**		0.50		ug/L			02/05/24 11:24	1

Client Sample ID: LHS-3 WF
Lab Sample ID: 810-91973-3
Date Collected: 01/26/24 07:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/05/24 11:25	1

Client Sample ID: LHS-4 WF
Lab Sample ID: 810-91973-4
Date Collected: 01/26/24 07:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	**0.51**		0.50		ug/L			02/05/24 11:27	1

Client Sample ID: LHS-5 WF
Lab Sample ID: 810-91973-5
Date Collected: 01/26/24 07:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/05/24 11:32	1

Client Sample ID: LHS-6 WF
Lab Sample ID: 810-91973-6
Date Collected: 01/26/24 07:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/05/24 11:33	1

Client Sample ID: LHS-7 Sink
Lab Sample ID: 810-91973-7
Date Collected: 01/26/24 07:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	**1.7**		0.50		ug/L			02/05/24 11:35	1

Client: St. John Environmental Consulting
Job ID: 810-91973-1
Project/Site: Lebanon RIII School District - High School

Client Sample ID: LHS-8 Sink
Lab Sample ID: 810-91973-8
Date Collected: 01/26/24 07:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.3		0.50		ug/L			02/05/24 11:36	1

Client Sample ID: LHS-9 Sink
Lab Sample ID: 810-91973-9
Date Collected: 01/26/24 07:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.3		0.50		ug/L			02/05/24 11:38	1

Client Sample ID: LHS-10 Sink
Lab Sample ID: 810-91973-10
Date Collected: 01/26/24 07:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	4.2		0.50		ug/L			02/05/24 11:39	1

Client Sample ID: LHS-11 Sink
Lab Sample ID: 810-91973-11
Date Collected: 01/26/24 07:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.0		0.50		ug/L			02/05/24 11:44	1

Client Sample ID: LHS-12 Sink
Lab Sample ID: 810-91973-12
Date Collected: 01/26/24 07:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.3		0.50		ug/L			02/05/24 11:45	1

Client Sample ID: LHS-13 Sink
Lab Sample ID: 810-91973-13
Date Collected: 01/26/24 07:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.6		0.50		ug/L			02/05/24 11:47	1

Client Sample ID: LHS-14 Sink
Lab Sample ID: 810-91973-14
Date Collected: 01/26/24 07:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.66		0.50		ug/L			02/05/24 11:49	1

Client Sample ID: LHS-15 Sink
Lab Sample ID: 810-91973-15
Date Collected: 01/26/24 07:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.2		0.50		ug/L			02/05/24 11:11	1

Client Sample ID: LHS-16 Sink
Lab Sample ID: 810-91973-16
Date Collected: 01/26/24 07:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.92		0.50		ug/L			02/05/24 11:14	1

Client Sample ID: LHS-17 Sink
Lab Sample ID: 810-91973-17
Date Collected: 01/26/24 07:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.6		0.50		ug/L			02/05/24 11:17	1

Client Sample ID: LHS-18 Sink
Lab Sample ID: 810-91973-18
Date Collected: 01/26/24 07:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	9.3		0.50		ug/L			02/05/24 11:20	1

Client Sample ID: LHS-19 Sink
Lab Sample ID: 810-91973-19
Date Collected: 01/26/24 07:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.0		0.50		ug/L			02/05/24 11:28	1

Client Sample ID: LHS-20 Sink
Lab Sample ID: 810-91973-20
Date Collected: 01/26/24 07:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.0		0.50		ug/L			02/05/24 11:31	1

Client Sample ID: LHS-21 Sink
Lab Sample ID: 810-91973-21
Date Collected: 01/26/24 07:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.1		0.50		ug/L			02/05/24 11:39	1

Client: St. John Environmental Consulting
Job ID: 810-91973-1
Project/Site: Lebanon RIII School District - High School

Client Sample ID: LHS-22 Sink
Lab Sample ID: 810-91973-22
Date Collected: 01/26/24 07:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.8		0.50		ug/L			02/05/24 11:42	1

Client Sample ID: LHS-23 Sink
Lab Sample ID: 810-91973-23
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	5.8		0.50		ug/L			02/05/24 11:45	1

Client Sample ID: LHS-24 WF
Lab Sample ID: 810-91973-24
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/05/24 11:48	1

Client Sample ID: LHS-25 WF
Lab Sample ID: 810-91973-25
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.79		0.50		ug/L			02/05/24 11:51	1

Client Sample ID: LHS-26 WF
Lab Sample ID: 810-91973-26
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.77		0.50		ug/L			02/05/24 11:54	1

Client Sample ID: LHS-27 Sink
Lab Sample ID: 810-91973-27
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	6.3		0.50		ug/L			02/05/24 11:56	1

Client Sample ID: LHS-28 Sink
Lab Sample ID: 810-91973-28
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.3		0.50		ug/L			02/05/24 11:59	1

Client: St. John Environmental Consulting
Job ID: 810-91973-1
Project/Site: Lebanon RIII School District - High School

Client Sample ID: LHS-29 Sink
Lab Sample ID: 810-91973-29
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	5.6		0.50		ug/L			02/05/24 12:15	1

Client Sample ID: LHS-30 Sink
Lab Sample ID: 810-91973-30
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	29		0.50		ug/L			02/05/24 12:19	1

Client Sample ID: LHS-31 Bubbler
Lab Sample ID: 810-91973-31
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	11		0.50		ug/L			02/05/24 12:21	1

Client Sample ID: LHS-32 Sink
Lab Sample ID: 810-91973-32
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	27		0.50		ug/L			02/05/24 12:22	1

Client Sample ID: LHS-33 Bubbler
Lab Sample ID: 810-91973-33
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	16		0.50		ug/L			02/05/24 12:24	1

Client Sample ID: LHS-34 Sink
Lab Sample ID: 810-91973-34
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	5.3		0.50		ug/L			02/05/24 12:25	1

Client Sample ID: LHS-35 Sink
Lab Sample ID: 810-91973-35
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	10		0.50		ug/L			02/05/24 12:27	1

Client: St. John Environmental Consulting
Job ID: 810-91973-1
Project/Site: Lebanon RIII School District - High School

Client Sample ID: LHS-36 Sink
Lab Sample ID: 810-91973-36
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	23		0.50		ug/L			02/05/24 12:28	1

Client Sample ID: LHS-37 Bubbler
Lab Sample ID: 810-91973-37
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	13		0.50		ug/L			02/05/24 12:30	1

Client Sample ID: LHS-38 Sink
Lab Sample ID: 810-91973-38
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	25		0.50		ug/L			02/05/24 12:32	1

Client Sample ID: LHS-39 Bubbler
Lab Sample ID: 810-91973-39
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	15		0.50		ug/L			02/05/24 12:36	1

Client Sample ID: LHS-40 WF
Lab Sample ID: 810-91973-40
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/05/24 12:38	1

Client Sample ID: LHS-41 Sink
Lab Sample ID: 810-91973-41
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/05/24 12:42	1

Client Sample ID: LHS-42 Sink
Lab Sample ID: 810-91973-42
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/05/24 12:44	1

Client: St. John Environmental Consulting
Job ID: 810-91973-1
Project/Site: Lebanon RIII School District - High School

Client Sample ID: LHS-43 Bubbler
Lab Sample ID: 810-91973-43
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/05/24 12:45	1

Client Sample ID: LHS-44 Sink
Lab Sample ID: 810-91973-44
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/05/24 12:47	1

Client Sample ID: LHS-45 Sink
Lab Sample ID: 810-91973-45
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	**2.1**		0.50		ug/L			02/05/24 12:49	1

Client Sample ID: LHS-46 Bubbler
Lab Sample ID: 810-91973-46
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	**1.0**		0.50		ug/L			02/05/24 12:50	1

Client Sample ID: LHS-47 Sink
Lab Sample ID: 810-91973-47
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	**15**		0.50		ug/L			02/05/24 12:52	1

Client Sample ID: LHS-48 Bubbler
Lab Sample ID: 810-91973-48
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	**1.2**		0.50		ug/L			02/05/24 12:53	1

Client Sample ID: LHS-49 WF
Lab Sample ID: 810-91973-49
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/05/24 13:01	1

Client: St. John Environmental Consulting
Job ID: 810-91973-1
Project/Site: Lebanon RIII School District - High School

Client Sample ID: LHS-50 Sink
Lab Sample ID: 810-91973-50
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.9		0.50		ug/L			02/05/24 13:02	1

Client Sample ID: LHS-51 Sink
Lab Sample ID: 810-91973-51
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.6		0.50		ug/L			02/05/24 13:04	1

Client Sample ID: LHS-52 Sink
Lab Sample ID: 810-91973-52
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	17		0.50		ug/L			02/05/24 13:09	1

Client Sample ID: LHS-53 Bubbler
Lab Sample ID: 810-91973-53
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.9		0.50		ug/L			02/05/24 13:10	1

Client Sample ID: LHS-54 Sink
Lab Sample ID: 810-91973-54
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.2		0.50		ug/L			02/05/24 13:12	1

Client Sample ID: LHS-55 Bubbler
Lab Sample ID: 810-91973-55
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.99		0.50		ug/L			02/05/24 13:13	1

Client Sample ID: LHS-56 Sink
Lab Sample ID: 810-91973-56
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	9.4		0.50		ug/L			02/05/24 13:15	1

Client: St. John Environmental Consulting
Job ID: 810-91973-1
Project/Site: Lebanon RIII School District - High School

Client Sample ID: LHS-57 Bubbler
Lab Sample ID: 810-91973-57
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.5		0.50		ug/L			02/05/24 13:16	1

Client Sample ID: LHS-58 Sink
Lab Sample ID: 810-91973-58
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.61		0.50		ug/L			02/05/24 13:18	1

Client Sample ID: LHS-59 Sink
Lab Sample ID: 810-91973-59
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.2		0.50		ug/L			02/05/24 13:22	1

Client Sample ID: LHS-60 Sink
Lab Sample ID: 810-91973-60
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	28		0.50		ug/L			02/05/24 13:24	1

Client Sample ID: LHS-61 Bubbler
Lab Sample ID: 810-91973-61
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	19		0.50		ug/L			02/05/24 13:25	1

Client Sample ID: LHS-62 Sink
Lab Sample ID: 810-91973-62
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	14		0.50		ug/L			02/05/24 13:27	1

Client Sample ID: LHS-63 Bubbler
Lab Sample ID: 810-91973-63
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	10		0.50		ug/L			02/05/24 13:32	1

Client Sample ID: LHS-64 Sink
Lab Sample ID: 810-91973-64
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	4.8		0.50		ug/L			02/05/24 13:33	1

Client Sample ID: LHS-65 Sink
Lab Sample ID: 810-91973-65
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.7		0.50		ug/L			02/05/24 13:35	1

Client Sample ID: LHS-66 Sink
Lab Sample ID: 810-91973-66
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	8.6		0.50		ug/L			02/05/24 13:36	1

Client Sample ID: LHS-67 Sink
Lab Sample ID: 810-91973-68
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.8		0.50		ug/L			02/05/24 13:38	1

Client Sample ID: LHS-68 Sink
Lab Sample ID: 810-91973-69
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	24		0.50		ug/L			02/05/24 13:39	1

Client Sample ID: LHS-69 Bubbler
Lab Sample ID: 810-91973-70
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	12		0.50		ug/L			02/05/24 12:46	1

Client Sample ID: LHS-70 WF
Lab Sample ID: 810-91973-71
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	4.2		0.50		ug/L			02/05/24 12:48	1

Client: St. John Environmental Consulting
Job ID: 810-91973-1
Project/Site: Lebanon RIII School District - High School

Client Sample ID: LHS-71 WF
Lab Sample ID: 810-91973-72
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	8.5		0.50		ug/L			02/05/24 12:51	1

Client Sample ID: LHS-72 Sink
Lab Sample ID: 810-91973-73
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.7		0.50		ug/L			02/05/24 12:59	1

Client Sample ID: LHS-73 Sink
Lab Sample ID: 810-91973-74
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	9.7		0.50		ug/L			02/05/24 13:01	1

Client Sample ID: LHS-74 Sink
Lab Sample ID: 810-91973-75
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.7		0.50		ug/L			02/05/24 13:04	1

Client Sample ID: LHS-75 Sink
Lab Sample ID: 810-91973-76
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	7.2		0.50		ug/L			02/05/24 13:07	1

Client Sample ID: LHS-76 Sink
Lab Sample ID: 810-91973-77
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	6.6		0.50		ug/L			02/05/24 13:09	1

Client Sample ID: LHS-77 Sink
Lab Sample ID: 810-91973-78
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	7.1		0.50		ug/L			02/05/24 13:12	1

Client: St. John Environmental Consulting
Job ID: 810-91973-1
Project/Site: Lebanon RIII School District - High School

Client Sample ID: LHS-78 Sink
Lab Sample ID: 810-91973-79
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	13		0.50		ug/L			02/05/24 13:14	1

Client Sample ID: LHS-79 WF
Lab Sample ID: 810-91973-80
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/05/24 13:22	1

Client Sample ID: LHS-80 WF
Lab Sample ID: 810-91973-81
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/05/24 13:25	1

Client Sample ID: LHS-81 Sink
Lab Sample ID: 810-91973-82
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	5.6		0.50		ug/L			02/05/24 13:28	1

Client Sample ID: LHS-82 Sink
Lab Sample ID: 810-91973-83
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	5.5		0.50		ug/L			02/05/24 13:30	1

Client Sample ID: LHS-83 Sink
Lab Sample ID: 810-91973-84
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	5.0		0.50		ug/L			02/05/24 13:38	1

Client Sample ID: LHS-84 Sink
Lab Sample ID: 810-91973-85
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	4.9		0.50		ug/L			02/05/24 13:41	1

Client Sample ID: LHS-85 Sink
Lab Sample ID: 810-91973-86
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	6.2		0.50		ug/L			02/05/24 13:43	1

Client Sample ID: LHS-86 Sink
Lab Sample ID: 810-91973-87
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.4		0.50		ug/L			02/05/24 13:46	1

Client Sample ID: LHS-87 Sink
Lab Sample ID: 810-91973-88
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.9		0.50		ug/L			02/05/24 13:49	1

Client Sample ID: LHS-88 Sink
Lab Sample ID: 810-91973-89
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.4		0.50		ug/L			02/05/24 13:51	1

Client Sample ID: LHS-89 Sink
Lab Sample ID: 810-91973-90
Date Collected: 01/26/24 08:10
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.2		0.50		ug/L			02/05/24 14:04	1

Client Sample ID: LHS-90 Sink
Lab Sample ID: 810-91973-91
Date Collected: 01/26/24 08:10
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.9		0.50		ug/L			02/05/24 14:07	1

Client Sample ID: LHS-91 Sink
Lab Sample ID: 810-91973-92
Date Collected: 01/26/24 08:10
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	23		0.50		ug/L			02/05/24 14:09	1

Client: St. John Environmental Consulting
Job ID: 810-91973-1
Project/Site: Lebanon RIII School District - High School

Client Sample ID: LHS-92 Sink
Lab Sample ID: 810-91973-93
Date Collected: 01/26/24 08:10
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	22		0.50		ug/L			02/05/24 14:12	1

Client Sample ID: LHS-93 Sink
Lab Sample ID: 810-91973-94
Date Collected: 01/26/24 08:10
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	21		0.50		ug/L			02/05/24 14:15	1

Client Sample ID: LHS-94 Sink
Lab Sample ID: 810-91973-95
Date Collected: 01/26/24 08:10
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	11		0.50		ug/L			02/05/24 14:23	1

Client Sample ID: LHS-95 Sink
Lab Sample ID: 810-91973-96
Date Collected: 01/26/24 08:10
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.3		0.50		ug/L			02/05/24 14:25	1

Client Sample ID: LHS-96 Sink
Lab Sample ID: 810-91973-97
Date Collected: 01/26/24 08:10
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.4		0.50		ug/L			02/05/24 14:28	1

Client Sample ID: LHS-97 Sink
Lab Sample ID: 810-91973-98
Date Collected: 01/26/24 08:10
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.3		0.50		ug/L			02/05/24 14:30	1

Client Sample ID: LHS-98 Sink
Lab Sample ID: 810-91973-99
Date Collected: 01/26/24 08:10
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.64		0.50		ug/L			02/05/24 14:33	1

Client Sample ID: LHS-99 Sink
Lab Sample ID: 810-91973-100
Date Collected: 01/26/24 08:10
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.1		0.50		ug/L			02/05/24 14:41	1

Client Sample ID: LHS-100 Sink
Lab Sample ID: 810-91973-101
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	11		0.50		ug/L			02/05/24 14:44	1

Client Sample ID: LHS-101 Sink
Lab Sample ID: 810-91973-102
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	4.9		0.50		ug/L			02/05/24 14:46	1

Client Sample ID: LHS-102 Sink
Lab Sample ID: 810-91973-103
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	16		0.50		ug/L			02/05/24 14:49	1

Client Sample ID: LHS-103 Sink
Lab Sample ID: 810-91973-104
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	4.1		0.50		ug/L			02/05/24 14:51	1

Client Sample ID: LHS-104 Sink
Lab Sample ID: 810-91973-105
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.5		0.50		ug/L			02/05/24 14:54	1

Client Sample ID: LHS-105 Sink
Lab Sample ID: 810-91973-106
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.1		0.50		ug/L			02/05/24 15:02	1

Client: St. John Environmental Consulting
Job ID: 810-91973-1
Project/Site: Lebanon RIII School District - High School

Client Sample ID: LHS-106 Sink
Lab Sample ID: 810-91973-107
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	12		0.50		ug/L			02/05/24 15:05	1

Client Sample ID: LHS-107 Sink
Lab Sample ID: 810-91973-108
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.1		0.50		ug/L			02/05/24 15:07	1

Client Sample ID: LHS-108 WF
Lab Sample ID: 810-91973-109
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/05/24 15:10	1

Client Sample ID: LHS-109 Sink
Lab Sample ID: 810-91973-110
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	45		0.50		ug/L			02/05/24 15:23	1

Client Sample ID: LHS-110 Sink
Lab Sample ID: 810-91973-111
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	4.3		0.50		ug/L			02/05/24 15:26	1

Client Sample ID: LHS-111 Sink
Lab Sample ID: 810-91973-112
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	6.0		0.50		ug/L			02/05/24 15:28	1

Client Sample ID: LHS-112 Sink
Lab Sample ID: 810-91973-113
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	18		0.50		ug/L			02/05/24 15:31	1

Client Sample ID: LHS-113 Sink
Lab Sample ID: 810-91973-114
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.2		0.50		ug/L			02/05/24 15:33	1

Client Sample ID: LHS-114 Sink
Lab Sample ID: 810-91973-115
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	14		0.50		ug/L			02/05/24 15:36	1

Client Sample ID: LHS-115 Sink
Lab Sample ID: 810-91973-116
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	6.9		0.50		ug/L			02/05/24 15:39	1

Client Sample ID: LHS-116 Sink
Lab Sample ID: 810-91973-117
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	16		0.50		ug/L			02/05/24 15:47	1

Client Sample ID: LHS-117 Sink
Lab Sample ID: 810-91973-118
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	4.6		0.50		ug/L			02/05/24 15:49	1

Client Sample ID: LHS-118 Sink
Lab Sample ID: 810-91973-119
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.1		0.50		ug/L			02/05/24 15:52	1

Client Sample ID: LHS-119 Sink
Lab Sample ID: 810-91973-120
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	6.1		0.50		ug/L			02/05/24 16:00	1

Client Sample ID: LHS-120 Sink
Lab Sample ID: 810-91973-121
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	6.1		0.50		ug/L			02/05/24 16:02	1

Client Sample ID: LHS-121 Sink
Lab Sample ID: 810-91973-122
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	4.5		0.50		ug/L			02/05/24 16:05	1

Client Sample ID: LHS-122 Sink
Lab Sample ID: 810-91973-123
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.9		0.50		ug/L			02/05/24 16:08	1

Client Sample ID: LHS-123 Sink
Lab Sample ID: 810-91973-124
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.8		0.50		ug/L			02/05/24 16:10	1

Client Sample ID: LHS-124 Sink
Lab Sample ID: 810-91973-125
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.1		0.50		ug/L			02/05/24 16:13	1

Client Sample ID: LHS-125 Sink
Lab Sample ID: 810-91973-126
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.9		0.50		ug/L			02/05/24 16:16	1

Client Sample ID: LHS-126 Sink
Lab Sample ID: 810-91973-127
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	5.9		0.50		ug/L			02/05/24 16:18	1

Client: St. John Environmental Consulting
Job ID: 810-91973-1
Project/Site: Lebanon RIII School District - High School

Client Sample ID: LHS-127 WF
Lab Sample ID: 810-91973-128
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	4.4		0.50		ug/L			02/05/24 16:26	1

Client Sample ID: LHAS-128 Sink
Lab Sample ID: 810-91973-129
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	20		0.50		ug/L			02/05/24 16:29	1

Client Sample ID: LHS-129 Sink
Lab Sample ID: 810-91973-130
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	18		0.50		ug/L			02/05/24 13:47	1

Client Sample ID: LHS-130 Sink
Lab Sample ID: 810-91973-131
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	16		0.50		ug/L			02/05/24 13:49	1

Client Sample ID: LHS-131 Sink
Lab Sample ID: 810-91973-132
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	15		0.50		ug/L			02/05/24 13:53	1

Client Sample ID: LHS-132 Sink
Lab Sample ID: 810-91973-133
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	22		0.50		ug/L			02/05/24 13:55	1

Client Sample ID: LHS-133 Sink
Lab Sample ID: 810-91973-134
Date Collected: 01/26/24 08:40
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	25		0.50		ug/L			02/05/24 13:56	1

Client: St. John Environmental Consulting
Job ID: 810-91973-1
Project/Site: Lebanon RIII School District - High School

Client Sample ID: LHS-134 Sink
Lab Sample ID: 810-91973-135
Date Collected: 01/26/24 08:40
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	15		0.50		ug/L			02/05/24 13:58	1

Client Sample ID: LHS-135 Sink
Lab Sample ID: 810-91973-136
Date Collected: 01/26/24 08:40
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	28		0.50		ug/L			02/05/24 13:59	1

Client Sample ID: LHS-136 Sink
Lab Sample ID: 810-91973-137
Date Collected: 01/26/24 08:40
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	11		0.50		ug/L			02/05/24 14:01	1

Client Sample ID: LHS-137 BF
Lab Sample ID: 810-91973-138
Date Collected: 01/26/24 08:40
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/05/24 14:02	1

Client Sample ID: LHS-138 Sink
Lab Sample ID: 810-91973-139
Date Collected: 01/26/24 08:40
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	9.3		0.50		ug/L			02/05/24 14:04	1

Client Sample ID: LHS-139 Sink
Lab Sample ID: 810-91973-140
Date Collected: 01/26/24 08:40
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	28		0.50		ug/L			02/05/24 14:09	1

Client Sample ID: LHS-140 WF
Lab Sample ID: 810-91973-141
Date Collected: 01/26/24 08:40
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	5.2		0.50		ug/L			02/05/24 14:10	1

Client: St. John Environmental Consulting
Job ID: 810-91973-1
Project/Site: Lebanon RIII School District - High School

Client Sample ID: LHS-141 Sink
Lab Sample ID: 810-91973-142
Date Collected: 01/26/24 08:40
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	7.9		0.50		ug/L			02/05/24 14:12	1

Client Sample ID: LHS-142 Sink
Lab Sample ID: 810-91973-143
Date Collected: 01/26/24 08:40
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.3		0.50		ug/L			02/05/24 14:16	1

Client Sample ID: LHS-143 Sink
Lab Sample ID: 810-91973-144
Date Collected: 01/26/24 08:40
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	5.1		0.50		ug/L			02/05/24 15:19	1

Client Sample ID: LHS-144 WF
Lab Sample ID: 810-91973-145
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	8.1		0.50		ug/L			02/05/24 15:21	1

Client Sample ID: LHS-145 WF
Lab Sample ID: 810-91973-146
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.3		0.50		ug/L			02/05/24 15:22	1

Client Sample ID: LHS-146 Sink
Lab Sample ID: 810-91973-147
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.2		0.50		ug/L			02/05/24 15:27	1

Client Sample ID: LHS-147 Sink
Lab Sample ID: 810-91973-148
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.3		0.50		ug/L			02/05/24 15:29	1

Client Sample ID: LHS-148 Sink
Lab Sample ID: 810-91973-149
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.81		0.50		ug/L			02/05/24 15:30	1

Client Sample ID: LHS-149 Sink
Lab Sample ID: 810-91973-150
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.1		0.50		ug/L			02/05/24 15:32	1

Client Sample ID: LHS-150 Sink
Lab Sample ID: 810-91973-151
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.1		0.50		ug/L			02/05/24 15:33	1

Client Sample ID: LHS-151 Sink
Lab Sample ID: 810-91973-152
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.9		0.50		ug/L			02/05/24 15:35	1

Client Sample ID: LHS-152 Sink
Lab Sample ID: 810-91973-153
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.7		0.50		ug/L			02/05/24 15:36	1

Client Sample ID: LHS-153 Sink
Lab Sample ID: 810-91973-154
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.3		0.50		ug/L			02/05/24 15:41	1

Client Sample ID: LHS-154 WF
Lab Sample ID: 810-91973-155
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.74		0.50		ug/L			02/05/24 15:42	1

Client: St. John Environmental Consulting
Job ID: 810-91973-1
Project/Site: Lebanon RIII School District - High School

Client Sample ID: LHS-155 WF
Lab Sample ID: 810-91973-156
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.66		0.50		ug/L			02/05/24 15:44	1

Client Sample ID: LHS-156 Sink
Lab Sample ID: 810-91973-157
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.4		0.50		ug/L			02/05/24 15:46	1

Client Sample ID: LHS-157 WF
Lab Sample ID: 810-91973-158
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.70		0.50		ug/L			02/05/24 15:50	1

Client Sample ID: LHS-158 WF
Lab Sample ID: 810-91973-159
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.2		0.50		ug/L			02/05/24 15:52	1

Client Sample ID: LHS-159 Sink
Lab Sample ID: 810-91973-160
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.6		0.50		ug/L			02/05/24 15:53	1

Client Sample ID: LHS-160 Sink
Lab Sample ID: 810-91973-161
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	7.1		0.50		ug/L			02/05/24 15:55	1

Client Sample ID: LHS-161 ICE
Lab Sample ID: 810-91973-162
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS) - Total Recoverable

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.1		0.50		ug/L		02/07/24 11:55	02/08/24 14:15	1

Client Sample Results

Client: St. John Environmental Consulting
Job ID: 810-91973-1
Project/Site: Lebanon RIII School District - High School

Client Sample ID: LHS-162 ICE
Lab Sample ID: 810-91973-163
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/05/24 15:56	1

Method: 200.8 - Metals (ICP/MS)

Lab Sample ID: MB 810-87664/11
Matrix: Drinking Water
Analysis Batch: 87664

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/05/24 07:14	1

Lab Sample ID: MB 810-87664/162
Matrix: Drinking Water
Analysis Batch: 87664

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/05/24 11:07	1

Lab Sample ID: LCS 810-87664/163
Matrix: Drinking Water
Analysis Batch: 87664

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	50.0	53.5		ug/L		107	85 - 115

Lab Sample ID: LLCS 810-87664/10
Matrix: Drinking Water
Analysis Batch: 87664

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LLCS Result	LLCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	0.300	0.310	J	ug/L		103	50 - 150

Lab Sample ID: 810-91973-10 MS
Matrix: Drinking Water
Analysis Batch: 87664

Client Sample ID: LHS-10 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	4.2		50.0	55.4		ug/L		102	70 - 130

Lab Sample ID: 810-91973-10 MSD
Matrix: Drinking Water
Analysis Batch: 87664

Client Sample ID: LHS-10 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Lead	4.2		50.0	55.2		ug/L		102	70 - 130	0	20

Lab Sample ID: MB 810-87667/12
Matrix: Drinking Water
Analysis Batch: 87667

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/05/24 09:21	1

Lab Sample ID: MB 810-87667/42
Matrix: Drinking Water
Analysis Batch: 87667

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/05/24 10:44	1

Method: 200.8 - Metals (ICP/MS)

Lab Sample ID: LCS 810-87667/43
Matrix: Drinking Water
Analysis Batch: 87667

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte			Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits		
Lead			50.0	48.2		ug/L		96	85 - 115		

Lab Sample ID: LLCS 810-87667/11
Matrix: Drinking Water
Analysis Batch: 87667

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte			Spike Added	LLCS Result	LLCS Qualifier	Unit	D	%Rec	%Rec Limits		
Lead			0.300	0.300	J	ug/L		100	50 - 150		

Lab Sample ID: 810-91973-20 MS
Matrix: Drinking Water
Analysis Batch: 87667

Client Sample ID: LHS-20 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits		
Lead	1.0		50.0	49.1		ug/L		96	70 - 130		

Lab Sample ID: 810-91973-20 MSD
Matrix: Drinking Water
Analysis Batch: 87667

Client Sample ID: LHS-20 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Lead	1.0		50.0	49.6		ug/L		97	70 - 130	1	20

Lab Sample ID: MB 810-87687/12
Matrix: Drinking Water
Analysis Batch: 87687

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/05/24 12:40	1

Lab Sample ID: MB 810-87687/42
Matrix: Drinking Water
Analysis Batch: 87687

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/05/24 13:59	1

Lab Sample ID: MB 810-87687/72
Matrix: Drinking Water
Analysis Batch: 87687

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/05/24 15:18	1

Lab Sample ID: LCS 810-87687/13
Matrix: Drinking Water
Analysis Batch: 87687

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte			Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits		
Lead			50.0	49.3		ug/L		99	85 - 115		

Method: 200.8 - Metals (ICP/MS)

Lab Sample ID: LCS 810-87687/43
Matrix: Drinking Water
Analysis Batch: 87687

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	50.0	49.8		ug/L		100	85 - 115

Lab Sample ID: LCS 810-87687/73
Matrix: Drinking Water
Analysis Batch: 87687

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	50.0	49.8		ug/L		100	85 - 115

Lab Sample ID: LLCS 810-87687/11
Matrix: Drinking Water
Analysis Batch: 87687

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LLCS Result	LLCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	0.300	0.273	J	ug/L		91	50 - 150

Lab Sample ID: 810-91973-72 MS
Matrix: Drinking Water
Analysis Batch: 87687

Client Sample ID: LHS-71 WF
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	8.5		50.0	57.1		ug/L		97	70 - 130

Lab Sample ID: 810-91973-72 MSD
Matrix: Drinking Water
Analysis Batch: 87687

Client Sample ID: LHS-71 WF
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Lead	8.5		50.0	56.6		ug/L		96	70 - 130	1	20

Lab Sample ID: 810-91973-83 MS
Matrix: Drinking Water
Analysis Batch: 87687

Client Sample ID: LHS-82 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	5.5		50.0	55.3		ug/L		100	70 - 130

Lab Sample ID: 810-91973-83 MSD
Matrix: Drinking Water
Analysis Batch: 87687

Client Sample ID: LHS-82 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Lead	5.5		50.0	55.7		ug/L		100	70 - 130	1	20

Lab Sample ID: 810-91973-94 MS
Matrix: Drinking Water
Analysis Batch: 87687

Client Sample ID: LHS-93 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	21		50.0	72.8		ug/L		103	70 - 130

Method: 200.8 - Metals (ICP/MS)

Lab Sample ID: 810-91973-94 MSD
Matrix: Drinking Water
Analysis Batch: 87687
Client Sample ID: LHS-93 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Lead	21		50.0	72.5		ug/L		103	70 - 130	0	20

Lab Sample ID: 810-91973-105 MS
Matrix: Drinking Water
Analysis Batch: 87687
Client Sample ID: LHS-104 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	3.5		50.0	55.2		ug/L		104	70 - 130

Lab Sample ID: 810-91973-105 MSD
Matrix: Drinking Water
Analysis Batch: 87687
Client Sample ID: LHS-104 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Lead	3.5		50.0	55.5		ug/L		104	70 - 130	0	20

Lab Sample ID: 810-91973-116 MS
Matrix: Drinking Water
Analysis Batch: 87687
Client Sample ID: LHS-115 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	6.9		50.0	56.7		ug/L		100	70 - 130

Lab Sample ID: 810-91973-116 MSD
Matrix: Drinking Water
Analysis Batch: 87687
Client Sample ID: LHS-115 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Lead	6.9		50.0	57.9		ug/L		102	70 - 130	2	20

Lab Sample ID: 810-91973-127 MS
Matrix: Drinking Water
Analysis Batch: 87687
Client Sample ID: LHS-126 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	5.9		50.0	55.4		ug/L		99	70 - 130

Lab Sample ID: 810-91973-127 MSD
Matrix: Drinking Water
Analysis Batch: 87687
Client Sample ID: LHS-126 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Lead	5.9		50.0	55.5		ug/L		99	70 - 130	0	20

Lab Sample ID: MB 810-87688/11
Matrix: Drinking Water
Analysis Batch: 87688
Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/05/24 12:12	1

Method: 200.8 - Metals (ICP/MS)

Lab Sample ID: MB 810-87688/131
Matrix: Drinking Water
Analysis Batch: 87688

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/05/24 15:16	1

Lab Sample ID: MB 810-87688/41
Matrix: Drinking Water
Analysis Batch: 87688

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/05/24 12:58	1

Lab Sample ID: MB 810-87688/71
Matrix: Drinking Water
Analysis Batch: 87688

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/05/24 13:44	1

Lab Sample ID: LCS 810-87688/12
Matrix: Drinking Water
Analysis Batch: 87688

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	50.0	52.7		ug/L		105	85 - 115

Lab Sample ID: LCS 810-87688/132
Matrix: Drinking Water
Analysis Batch: 87688

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	50.0	50.3		ug/L		101	85 - 115

Lab Sample ID: LCS 810-87688/42
Matrix: Drinking Water
Analysis Batch: 87688

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	50.0	52.2		ug/L		104	85 - 115

Lab Sample ID: LCS 810-87688/72
Matrix: Drinking Water
Analysis Batch: 87688

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	50.0	51.4		ug/L		103	85 - 115

Lab Sample ID: LLCS 810-87688/10
Matrix: Drinking Water
Analysis Batch: 87688

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LLCS Result	LLCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	0.300	0.310	J	ug/L		103	50 - 150

Method: 200.8 - Metals (ICP/MS)

Lab Sample ID: 810-91973-29 MS
Matrix: Drinking Water
Analysis Batch: 87688
Client Sample ID: LHS-29 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	5.6		50.0	58.6		ug/L		106	70 - 130

Lab Sample ID: 810-91973-29 MSD
Matrix: Drinking Water
Analysis Batch: 87688
Client Sample ID: LHS-29 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Lead	5.6		50.0	59.0		ug/L		107	70 - 130	1	20

Lab Sample ID: 810-91973-40 MS
Matrix: Drinking Water
Analysis Batch: 87688
Client Sample ID: LHS-40 WF
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	<0.50		50.0	55.1		ug/L		109	70 - 130

Lab Sample ID: 810-91973-40 MSD
Matrix: Drinking Water
Analysis Batch: 87688
Client Sample ID: LHS-40 WF
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Lead	<0.50		50.0	58.2		ug/L		116	70 - 130	5	20

Lab Sample ID: 810-91973-51 MS
Matrix: Drinking Water
Analysis Batch: 87688
Client Sample ID: LHS-51 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	2.6		50.0	54.3		ug/L		103	70 - 130

Lab Sample ID: 810-91973-51 MSD
Matrix: Drinking Water
Analysis Batch: 87688
Client Sample ID: LHS-51 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Lead	2.6		50.0	54.4		ug/L		103	70 - 130	0	20

Lab Sample ID: 810-91973-62 MS
Matrix: Drinking Water
Analysis Batch: 87688
Client Sample ID: LHS-62 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	14		50.0	70.5		ug/L		114	70 - 130

Lab Sample ID: 810-91973-62 MSD
Matrix: Drinking Water
Analysis Batch: 87688
Client Sample ID: LHS-62 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Lead	14		50.0	69.6		ug/L		112	70 - 130	1	20

Method: 200.8 - Metals (ICP/MS)

Lab Sample ID: 810-91973-131 MS
Matrix: Drinking Water
Analysis Batch: 87688

Client Sample ID: LHS-130 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	16		50.0	66.5		ug/L		102	70 - 130

Lab Sample ID: 810-91973-131 MSD
Matrix: Drinking Water
Analysis Batch: 87688

Client Sample ID: LHS-130 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Lead	16		50.0	65.2		ug/L		99	70 - 130	2	20

Lab Sample ID: 810-91973-142 MS
Matrix: Drinking Water
Analysis Batch: 87688

Client Sample ID: LHS-141 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	7.9		50.0	57.8		ug/L		100	70 - 130

Lab Sample ID: 810-91973-142 MSD
Matrix: Drinking Water
Analysis Batch: 87688

Client Sample ID: LHS-141 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Lead	7.9		50.0	57.1		ug/L		98	70 - 130	1	20

Lab Sample ID: 810-91973-146 MS
Matrix: Drinking Water
Analysis Batch: 87688

Client Sample ID: LHS-145 WF
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	3.3		50.0	56.1		ug/L		106	70 - 130

Lab Sample ID: 810-91973-146 MSD
Matrix: Drinking Water
Analysis Batch: 87688

Client Sample ID: LHS-145 WF
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Lead	3.3		50.0	57.3		ug/L		108	70 - 130	2	20

Lab Sample ID: 810-91973-157 MS
Matrix: Drinking Water
Analysis Batch: 87688

Client Sample ID: LHS-156 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	2.4		50.0	55.8		ug/L		107	70 - 130

Lab Sample ID: 810-91973-157 MSD
Matrix: Drinking Water
Analysis Batch: 87688

Client Sample ID: LHS-156 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Lead	2.4		50.0	55.5		ug/L		106	70 - 130	0	20

Client: St. John Environmental Consulting
Job ID: 810-91973-1
Project/Site: Lebanon RIII School District - High School

Method: 200.8 - Metals (ICP/MS)

Lab Sample ID: MB 810-87923/1-A
Matrix: Drinking Water
Analysis Batch: 88075

Client Sample ID: Method Blank
Prep Type: Total Recoverable
Prep Batch: 87923

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L		02/07/24 11:55	02/08/24 13:46	1

Lab Sample ID: LCS 810-87923/6-A
Matrix: Drinking Water
Analysis Batch: 88075

Client Sample ID: Lab Control Sample
Prep Type: Total Recoverable
Prep Batch: 87923

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	50.0	53.1		ug/L		106	85 - 115

Lab Sample ID: LLCS 810-87923/2-A
Matrix: Drinking Water
Analysis Batch: 88075

Client Sample ID: Lab Control Sample
Prep Type: Total Recoverable
Prep Batch: 87923

Analyte	Spike Added	LLCS Result	LLCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	0.300	0.312	J	ug/L		104	50 - 150

Metals

Analysis Batch: 87664

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
810-91973-1	LHS-1 Sink	Total/NA	Drinking Water	200.8	
810-91973-2	LHS-2 Sink	Total/NA	Drinking Water	200.8	
810-91973-3	LHS-3 WF	Total/NA	Drinking Water	200.8	
810-91973-4	LHS-4 WF	Total/NA	Drinking Water	200.8	
810-91973-5	LHS-5 WF	Total/NA	Drinking Water	200.8	
810-91973-6	LHS-6 WF	Total/NA	Drinking Water	200.8	
810-91973-7	LHS-7 Sink	Total/NA	Drinking Water	200.8	
810-91973-8	LHS-8 Sink	Total/NA	Drinking Water	200.8	
810-91973-9	LHS-9 Sink	Total/NA	Drinking Water	200.8	
810-91973-10	LHS-10 Sink	Total/NA	Drinking Water	200.8	
810-91973-11	LHS-11 Sink	Total/NA	Drinking Water	200.8	
810-91973-12	LHS-12 Sink	Total/NA	Drinking Water	200.8	
810-91973-13	LHS-13 Sink	Total/NA	Drinking Water	200.8	
810-91973-14	LHS-14 Sink	Total/NA	Drinking Water	200.8	
MB 810-87664/11	Method Blank	Total/NA	Drinking Water	200.8	
MB 810-87664/162	Method Blank	Total/NA	Drinking Water	200.8	
LCS 810-87664/163	Lab Control Sample	Total/NA	Drinking Water	200.8	
LLCS 810-87664/10	Lab Control Sample	Total/NA	Drinking Water	200.8	
810-91973-10 MS	LHS-10 Sink	Total/NA	Drinking Water	200.8	
810-91973-10 MSD	LHS-10 Sink	Total/NA	Drinking Water	200.8	

Analysis Batch: 87667

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
810-91973-15	LHS-15 Sink	Total/NA	Drinking Water	200.8	
810-91973-16	LHS-16 Sink	Total/NA	Drinking Water	200.8	
810-91973-17	LHS-17 Sink	Total/NA	Drinking Water	200.8	
810-91973-18	LHS-18 Sink	Total/NA	Drinking Water	200.8	
810-91973-19	LHS-19 Sink	Total/NA	Drinking Water	200.8	
810-91973-20	LHS-20 Sink	Total/NA	Drinking Water	200.8	
810-91973-21	LHS-21 Sink	Total/NA	Drinking Water	200.8	
810-91973-22	LHS-22 Sink	Total/NA	Drinking Water	200.8	
810-91973-23	LHS-23 Sink	Total/NA	Drinking Water	200.8	
810-91973-24	LHS-24 WF	Total/NA	Drinking Water	200.8	
810-91973-25	LHS-25 WF	Total/NA	Drinking Water	200.8	
810-91973-26	LHS-26 WF	Total/NA	Drinking Water	200.8	
810-91973-27	LHS-27 Sink	Total/NA	Drinking Water	200.8	
810-91973-28	LHS-28 Sink	Total/NA	Drinking Water	200.8	
MB 810-87667/12	Method Blank	Total/NA	Drinking Water	200.8	
MB 810-87667/42	Method Blank	Total/NA	Drinking Water	200.8	
LCS 810-87667/43	Lab Control Sample	Total/NA	Drinking Water	200.8	
LLCS 810-87667/11	Lab Control Sample	Total/NA	Drinking Water	200.8	
810-91973-20 MS	LHS-20 Sink	Total/NA	Drinking Water	200.8	
810-91973-20 MSD	LHS-20 Sink	Total/NA	Drinking Water	200.8	

Analysis Batch: 87687

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
810-91973-70	LHS-69 Bubbler	Total/NA	Drinking Water	200.8	
810-91973-71	LHS-70 WF	Total/NA	Drinking Water	200.8	
810-91973-72	LHS-71 WF	Total/NA	Drinking Water	200.8	
810-91973-73	LHS-72 Sink	Total/NA	Drinking Water	200.8	
810-91973-74	LHS-73 Sink	Total/NA	Drinking Water	200.8	

Metals (Continued)

Analysis Batch: 87687 (Continued)

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
810-91973-75	LHS-74 Sink	Total/NA	Drinking Water	200.8	
810-91973-76	LHS-75 Sink	Total/NA	Drinking Water	200.8	
810-91973-77	LHS-76 Sink	Total/NA	Drinking Water	200.8	
810-91973-78	LHS-77 Sink	Total/NA	Drinking Water	200.8	
810-91973-79	LHS-78 Sink	Total/NA	Drinking Water	200.8	
810-91973-80	LHS-79 WF	Total/NA	Drinking Water	200.8	
810-91973-81	LHS-80 WF	Total/NA	Drinking Water	200.8	
810-91973-82	LHS-81 Sink	Total/NA	Drinking Water	200.8	
810-91973-83	LHS-82 Sink	Total/NA	Drinking Water	200.8	
810-91973-84	LHS-83 Sink	Total/NA	Drinking Water	200.8	
810-91973-85	LHS-84 Sink	Total/NA	Drinking Water	200.8	
810-91973-86	LHS-85 Sink	Total/NA	Drinking Water	200.8	
810-91973-87	LHS-86 Sink	Total/NA	Drinking Water	200.8	
810-91973-88	LHS-87 Sink	Total/NA	Drinking Water	200.8	
810-91973-89	LHS-88 Sink	Total/NA	Drinking Water	200.8	
810-91973-90	LHS-89 Sink	Total/NA	Drinking Water	200.8	
810-91973-91	LHS-90 Sink	Total/NA	Drinking Water	200.8	
810-91973-92	LHS-91 Sink	Total/NA	Drinking Water	200.8	
810-91973-93	LHS-92 Sink	Total/NA	Drinking Water	200.8	
810-91973-94	LHS-93 Sink	Total/NA	Drinking Water	200.8	
810-91973-95	LHS-94 Sink	Total/NA	Drinking Water	200.8	
810-91973-96	LHS-95 Sink	Total/NA	Drinking Water	200.8	
810-91973-97	LHS-96 Sink	Total/NA	Drinking Water	200.8	
810-91973-98	LHS-97 Sink	Total/NA	Drinking Water	200.8	
810-91973-99	LHS-98 Sink	Total/NA	Drinking Water	200.8	
810-91973-100	LHS-99 Sink	Total/NA	Drinking Water	200.8	
810-91973-101	LHS-100 Sink	Total/NA	Drinking Water	200.8	
810-91973-102	LHS-101 Sink	Total/NA	Drinking Water	200.8	
810-91973-103	LHS-102 Sink	Total/NA	Drinking Water	200.8	
810-91973-104	LHS-103 Sink	Total/NA	Drinking Water	200.8	
810-91973-105	LHS-104 Sink	Total/NA	Drinking Water	200.8	
810-91973-106	LHS-105 Sink	Total/NA	Drinking Water	200.8	
810-91973-107	LHS-106 Sink	Total/NA	Drinking Water	200.8	
810-91973-108	LHS-107 Sink	Total/NA	Drinking Water	200.8	
810-91973-109	LHS-108 WF	Total/NA	Drinking Water	200.8	
810-91973-110	LHS-109 Sink	Total/NA	Drinking Water	200.8	
810-91973-111	LHS-110 Sink	Total/NA	Drinking Water	200.8	
810-91973-112	LHS-111 Sink	Total/NA	Drinking Water	200.8	
810-91973-113	LHS-112 Sink	Total/NA	Drinking Water	200.8	
810-91973-114	LHS-113 Sink	Total/NA	Drinking Water	200.8	
810-91973-115	LHS-114 Sink	Total/NA	Drinking Water	200.8	
810-91973-116	LHS-115 Sink	Total/NA	Drinking Water	200.8	
810-91973-117	LHS-116 Sink	Total/NA	Drinking Water	200.8	
810-91973-118	LHS-117 Sink	Total/NA	Drinking Water	200.8	
810-91973-119	LHS-118 Sink	Total/NA	Drinking Water	200.8	
810-91973-120	LHS-119 Sink	Total/NA	Drinking Water	200.8	
810-91973-121	LHS-120 Sink	Total/NA	Drinking Water	200.8	
810-91973-122	LHS-121 Sink	Total/NA	Drinking Water	200.8	
810-91973-123	LHS-122 Sink	Total/NA	Drinking Water	200.8	
810-91973-124	LHS-123 Sink	Total/NA	Drinking Water	200.8	
810-91973-125	LHS-124 Sink	Total/NA	Drinking Water	200.8	

Metals (Continued)

Analysis Batch: 87687 (Continued)

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
810-91973-126	LHS-125 Sink	Total/NA	Drinking Water	200.8	
810-91973-127	LHS-126 Sink	Total/NA	Drinking Water	200.8	
810-91973-128	LHS-127 WF	Total/NA	Drinking Water	200.8	
810-91973-129	LHAS-128 Sink	Total/NA	Drinking Water	200.8	
MB 810-87687/12	Method Blank	Total/NA	Drinking Water	200.8	
MB 810-87687/42	Method Blank	Total/NA	Drinking Water	200.8	
MB 810-87687/72	Method Blank	Total/NA	Drinking Water	200.8	
LCS 810-87687/13	Lab Control Sample	Total/NA	Drinking Water	200.8	
LCS 810-87687/43	Lab Control Sample	Total/NA	Drinking Water	200.8	
LCS 810-87687/73	Lab Control Sample	Total/NA	Drinking Water	200.8	
LLCS 810-87687/11	Lab Control Sample	Total/NA	Drinking Water	200.8	
810-91973-72 MS	LHS-71 WF	Total/NA	Drinking Water	200.8	
810-91973-72 MSD	LHS-71 WF	Total/NA	Drinking Water	200.8	
810-91973-83 MS	LHS-82 Sink	Total/NA	Drinking Water	200.8	
810-91973-83 MSD	LHS-82 Sink	Total/NA	Drinking Water	200.8	
810-91973-94 MS	LHS-93 Sink	Total/NA	Drinking Water	200.8	
810-91973-94 MSD	LHS-93 Sink	Total/NA	Drinking Water	200.8	
810-91973-105 MS	LHS-104 Sink	Total/NA	Drinking Water	200.8	
810-91973-105 MSD	LHS-104 Sink	Total/NA	Drinking Water	200.8	
810-91973-116 MS	LHS-115 Sink	Total/NA	Drinking Water	200.8	
810-91973-116 MSD	LHS-115 Sink	Total/NA	Drinking Water	200.8	
810-91973-127 MS	LHS-126 Sink	Total/NA	Drinking Water	200.8	
810-91973-127 MSD	LHS-126 Sink	Total/NA	Drinking Water	200.8	

Analysis Batch: 87688

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
810-91973-29	LHS-29 Sink	Total/NA	Drinking Water	200.8	
810-91973-30	LHS-30 Sink	Total/NA	Drinking Water	200.8	
810-91973-31	LHS-31 Bubbler	Total/NA	Drinking Water	200.8	
810-91973-32	LHS-32 Sink	Total/NA	Drinking Water	200.8	
810-91973-33	LHS-33 Bubbler	Total/NA	Drinking Water	200.8	
810-91973-34	LHS-34 Sink	Total/NA	Drinking Water	200.8	
810-91973-35	LHS-35 Sink	Total/NA	Drinking Water	200.8	
810-91973-36	LHS-36 Sink	Total/NA	Drinking Water	200.8	
810-91973-37	LHS-37 Bubbler	Total/NA	Drinking Water	200.8	
810-91973-38	LHS-38 Sink	Total/NA	Drinking Water	200.8	
810-91973-39	LHS-39 Bubbler	Total/NA	Drinking Water	200.8	
810-91973-40	LHS-40 WF	Total/NA	Drinking Water	200.8	
810-91973-41	LHS-41 Sink	Total/NA	Drinking Water	200.8	
810-91973-42	LHS-42 Sink	Total/NA	Drinking Water	200.8	
810-91973-43	LHS-43 Bubbler	Total/NA	Drinking Water	200.8	
810-91973-44	LHS-44 Sink	Total/NA	Drinking Water	200.8	
810-91973-45	LHS-45 Sink	Total/NA	Drinking Water	200.8	
810-91973-46	LHS-46 Bubbler	Total/NA	Drinking Water	200.8	
810-91973-47	LHS-47 Sink	Total/NA	Drinking Water	200.8	
810-91973-48	LHS-48 Bubbler	Total/NA	Drinking Water	200.8	
810-91973-49	LHS-49 WF	Total/NA	Drinking Water	200.8	
810-91973-50	LHS-50 Sink	Total/NA	Drinking Water	200.8	
810-91973-51	LHS-51 Sink	Total/NA	Drinking Water	200.8	
810-91973-52	LHS-52 Sink	Total/NA	Drinking Water	200.8	
810-91973-53	LHS-53 Bubbler	Total/NA	Drinking Water	200.8	

Metals (Continued)

Analysis Batch: 87688 (Continued)

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
810-91973-54	LHS-54 Sink	Total/NA	Drinking Water	200.8	
810-91973-55	LHS-55 Bubbler	Total/NA	Drinking Water	200.8	
810-91973-56	LHS-56 Sink	Total/NA	Drinking Water	200.8	
810-91973-57	LHS-57 Bubbler	Total/NA	Drinking Water	200.8	
810-91973-58	LHS-58 Sink	Total/NA	Drinking Water	200.8	
810-91973-59	LHS-59 Sink	Total/NA	Drinking Water	200.8	
810-91973-60	LHS-60 Sink	Total/NA	Drinking Water	200.8	
810-91973-61	LHS-61 Bubbler	Total/NA	Drinking Water	200.8	
810-91973-62	LHS-62 Sink	Total/NA	Drinking Water	200.8	
810-91973-63	LHS-63 Bubbler	Total/NA	Drinking Water	200.8	
810-91973-64	LHS-64 Sink	Total/NA	Drinking Water	200.8	
810-91973-65	LHS-65 Sink	Total/NA	Drinking Water	200.8	
810-91973-66	LHS-66 Sink	Total/NA	Drinking Water	200.8	
810-91973-68	LHS-67 Sink	Total/NA	Drinking Water	200.8	
810-91973-69	LHS-68 Sink	Total/NA	Drinking Water	200.8	
810-91973-130	LHS-129 Sink	Total/NA	Drinking Water	200.8	
810-91973-131	LHS-130 Sink	Total/NA	Drinking Water	200.8	
810-91973-132	LHS-131 Sink	Total/NA	Drinking Water	200.8	
810-91973-133	LHS-132 Sink	Total/NA	Drinking Water	200.8	
810-91973-134	LHS-133 Sink	Total/NA	Drinking Water	200.8	
810-91973-135	LHS-134 Sink	Total/NA	Drinking Water	200.8	
810-91973-136	LHS-135 Sink	Total/NA	Drinking Water	200.8	
810-91973-137	LHS-136 Sink	Total/NA	Drinking Water	200.8	
810-91973-138	LHS-137 BF	Total/NA	Drinking Water	200.8	
810-91973-139	LHS-138 Sink	Total/NA	Drinking Water	200.8	
810-91973-140	LHS-139 Sink	Total/NA	Drinking Water	200.8	
810-91973-141	LHS-140 WF	Total/NA	Drinking Water	200.8	
810-91973-142	LHS-141 Sink	Total/NA	Drinking Water	200.8	
810-91973-143	LHS-142 Sink	Total/NA	Drinking Water	200.8	
810-91973-144	LHS-143 Sink	Total/NA	Drinking Water	200.8	
810-91973-145	LHS-144 WF	Total/NA	Drinking Water	200.8	
810-91973-146	LHS-145 WF	Total/NA	Drinking Water	200.8	
810-91973-147	LHS-146 Sink	Total/NA	Drinking Water	200.8	
810-91973-148	LHS-147 Sink	Total/NA	Drinking Water	200.8	
810-91973-149	LHS-148 Sink	Total/NA	Drinking Water	200.8	
810-91973-150	LHS-149 Sink	Total/NA	Drinking Water	200.8	
810-91973-151	LHS-150 Sink	Total/NA	Drinking Water	200.8	
810-91973-152	LHS-151 Sink	Total/NA	Drinking Water	200.8	
810-91973-153	LHS-152 Sink	Total/NA	Drinking Water	200.8	
810-91973-154	LHS-153 Sink	Total/NA	Drinking Water	200.8	
810-91973-155	LHS-154 WF	Total/NA	Drinking Water	200.8	
810-91973-156	LHS-155 WF	Total/NA	Drinking Water	200.8	
810-91973-157	LHS-156 Sink	Total/NA	Drinking Water	200.8	
810-91973-158	LHS-157 WF	Total/NA	Drinking Water	200.8	
810-91973-159	LHS-158 WF	Total/NA	Drinking Water	200.8	
810-91973-160	LHS-159 Sink	Total/NA	Drinking Water	200.8	
810-91973-161	LHS-160 Sink	Total/NA	Drinking Water	200.8	
810-91973-163	LHS-162 ICE	Total/NA	Drinking Water	200.8	
MB 810-87688/11	Method Blank	Total/NA	Drinking Water	200.8	
MB 810-87688/131	Method Blank	Total/NA	Drinking Water	200.8	
MB 810-87688/41	Method Blank	Total/NA	Drinking Water	200.8	

Metals (Continued)

Analysis Batch: 87688 (Continued)

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
MB 810-87688/71	Method Blank	Total/NA	Drinking Water	200.8	
LCS 810-87688/12	Lab Control Sample	Total/NA	Drinking Water	200.8	
LCS 810-87688/132	Lab Control Sample	Total/NA	Drinking Water	200.8	
LCS 810-87688/42	Lab Control Sample	Total/NA	Drinking Water	200.8	
LCS 810-87688/72	Lab Control Sample	Total/NA	Drinking Water	200.8	
LLCS 810-87688/10	Lab Control Sample	Total/NA	Drinking Water	200.8	
810-91973-29 MS	LHS-29 Sink	Total/NA	Drinking Water	200.8	
810-91973-29 MSD	LHS-29 Sink	Total/NA	Drinking Water	200.8	
810-91973-40 MS	LHS-40 WF	Total/NA	Drinking Water	200.8	
810-91973-40 MSD	LHS-40 WF	Total/NA	Drinking Water	200.8	
810-91973-51 MS	LHS-51 Sink	Total/NA	Drinking Water	200.8	
810-91973-51 MSD	LHS-51 Sink	Total/NA	Drinking Water	200.8	
810-91973-62 MS	LHS-62 Sink	Total/NA	Drinking Water	200.8	
810-91973-62 MSD	LHS-62 Sink	Total/NA	Drinking Water	200.8	
810-91973-131 MS	LHS-130 Sink	Total/NA	Drinking Water	200.8	
810-91973-131 MSD	LHS-130 Sink	Total/NA	Drinking Water	200.8	
810-91973-142 MS	LHS-141 Sink	Total/NA	Drinking Water	200.8	
810-91973-142 MSD	LHS-141 Sink	Total/NA	Drinking Water	200.8	
810-91973-146 MS	LHS-145 WF	Total/NA	Drinking Water	200.8	
810-91973-146 MSD	LHS-145 WF	Total/NA	Drinking Water	200.8	
810-91973-157 MS	LHS-156 Sink	Total/NA	Drinking Water	200.8	
810-91973-157 MSD	LHS-156 Sink	Total/NA	Drinking Water	200.8	

Prep Batch: 87923

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
810-91973-162	LHS-161 ICE	Total Recoverable	Drinking Water	200.8	
MB 810-87923/1-A	Method Blank	Total Recoverable	Drinking Water	200.8	
LCS 810-87923/6-A	Lab Control Sample	Total Recoverable	Drinking Water	200.8	
LLCS 810-87923/2-A	Lab Control Sample	Total Recoverable	Drinking Water	200.8	

Analysis Batch: 88075

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
810-91973-162	LHS-161 ICE	Total Recoverable	Drinking Water	200.8	87923
MB 810-87923/1-A	Method Blank	Total Recoverable	Drinking Water	200.8	87923
LCS 810-87923/6-A	Lab Control Sample	Total Recoverable	Drinking Water	200.8	87923
LLCS 810-87923/2-A	Lab Control Sample	Total Recoverable	Drinking Water	200.8	87923

Lab Chronicle

Client: St. John Environmental Consulting
Job ID: 810-91973-1
Project/Site: Lebanon RIII School District - High School

Client Sample ID: LHS-1 Sink
Lab Sample ID: 810-91973-1
Date Collected: 01/26/24 07:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87664	NB	EA SB	02/05/24 11:22

Client Sample ID: LHS-2 Sink
Lab Sample ID: 810-91973-2
Date Collected: 01/26/24 07:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87664	NB	EA SB	02/05/24 11:24

Client Sample ID: LHS-3 WF
Lab Sample ID: 810-91973-3
Date Collected: 01/26/24 07:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87664	NB	EA SB	02/05/24 11:25

Client Sample ID: LHS-4 WF
Lab Sample ID: 810-91973-4
Date Collected: 01/26/24 07:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87664	NB	EA SB	02/05/24 11:27

Client Sample ID: LHS-5 WF
Lab Sample ID: 810-91973-5
Date Collected: 01/26/24 07:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87664	NB	EA SB	02/05/24 11:32

Client Sample ID: LHS-6 WF
Lab Sample ID: 810-91973-6
Date Collected: 01/26/24 07:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87664	NB	EA SB	02/05/24 11:33

Client Sample ID: LHS-7 Sink
Lab Sample ID: 810-91973-7
Date Collected: 01/26/24 07:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87664	NB	EA SB	02/05/24 11:35

Lab Chronicle

Client: St. John Environmental Consulting
Job ID: 810-91973-1
Project/Site: Lebanon RIII School District - High School

Client Sample ID: LHS-8 Sink
Lab Sample ID: 810-91973-8
Date Collected: 01/26/24 07:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87664	NB	EA SB	02/05/24 11:36

Client Sample ID: LHS-9 Sink
Lab Sample ID: 810-91973-9
Date Collected: 01/26/24 07:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87664	NB	EA SB	02/05/24 11:38

Client Sample ID: LHS-10 Sink
Lab Sample ID: 810-91973-10
Date Collected: 01/26/24 07:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87664	NB	EA SB	02/05/24 11:39

Client Sample ID: LHS-11 Sink
Lab Sample ID: 810-91973-11
Date Collected: 01/26/24 07:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87664	NB	EA SB	02/05/24 11:44

Client Sample ID: LHS-12 Sink
Lab Sample ID: 810-91973-12
Date Collected: 01/26/24 07:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87664	NB	EA SB	02/05/24 11:45

Client Sample ID: LHS-13 Sink
Lab Sample ID: 810-91973-13
Date Collected: 01/26/24 07:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87664	NB	EA SB	02/05/24 11:47

Client Sample ID: LHS-14 Sink
Lab Sample ID: 810-91973-14
Date Collected: 01/26/24 07:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87664	NB	EA SB	02/05/24 11:49

Lab Chronicle

Client: St. John Environmental Consulting
Job ID: 810-91973-1
Project/Site: Lebanon RIII School District - High School

Client Sample ID: LHS-15 Sink
Lab Sample ID: 810-91973-15
Date Collected: 01/26/24 07:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87667	CA	EA SB	02/05/24 11:11

Client Sample ID: LHS-16 Sink
Lab Sample ID: 810-91973-16
Date Collected: 01/26/24 07:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87667	CA	EA SB	02/05/24 11:14

Client Sample ID: LHS-17 Sink
Lab Sample ID: 810-91973-17
Date Collected: 01/26/24 07:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87667	CA	EA SB	02/05/24 11:17

Client Sample ID: LHS-18 Sink
Lab Sample ID: 810-91973-18
Date Collected: 01/26/24 07:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87667	CA	EA SB	02/05/24 11:20

Client Sample ID: LHS-19 Sink
Lab Sample ID: 810-91973-19
Date Collected: 01/26/24 07:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87667	CA	EA SB	02/05/24 11:28

Client Sample ID: LHS-20 Sink
Lab Sample ID: 810-91973-20
Date Collected: 01/26/24 07:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87667	CA	EA SB	02/05/24 11:31

Client Sample ID: LHS-21 Sink
Lab Sample ID: 810-91973-21
Date Collected: 01/26/24 07:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87667	CA	EA SB	02/05/24 11:39

Lab Chronicle

Client: St. John Environmental Consulting
Job ID: 810-91973-1
Project/Site: Lebanon RIII School District - High School

Client Sample ID: LHS-22 Sink
Lab Sample ID: 810-91973-22
Date Collected: 01/26/24 07:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87667	CA	EA SB	02/05/24 11:42

Client Sample ID: LHS-23 Sink
Lab Sample ID: 810-91973-23
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87667	CA	EA SB	02/05/24 11:45

Client Sample ID: LHS-24 WF
Lab Sample ID: 810-91973-24
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87667	CA	EA SB	02/05/24 11:48

Client Sample ID: LHS-25 WF
Lab Sample ID: 810-91973-25
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87667	CA	EA SB	02/05/24 11:51

Client Sample ID: LHS-26 WF
Lab Sample ID: 810-91973-26
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87667	CA	EA SB	02/05/24 11:54

Client Sample ID: LHS-27 Sink
Lab Sample ID: 810-91973-27
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87667	CA	EA SB	02/05/24 11:56

Client Sample ID: LHS-28 Sink
Lab Sample ID: 810-91973-28
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87667	CA	EA SB	02/05/24 11:59

Lab Chronicle

Client: St. John Environmental Consulting
Job ID: 810-91973-1
Project/Site: Lebanon RIII School District - High School

Client Sample ID: LHS-29 Sink
Lab Sample ID: 810-91973-29
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 12:15

Client Sample ID: LHS-30 Sink
Lab Sample ID: 810-91973-30
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 12:19

Client Sample ID: LHS-31 Bubbler
Lab Sample ID: 810-91973-31
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 12:21

Client Sample ID: LHS-32 Sink
Lab Sample ID: 810-91973-32
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 12:22

Client Sample ID: LHS-33 Bubbler
Lab Sample ID: 810-91973-33
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 12:24

Client Sample ID: LHS-34 Sink
Lab Sample ID: 810-91973-34
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 12:25

Client Sample ID: LHS-35 Sink
Lab Sample ID: 810-91973-35
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 12:27

Lab Chronicle

Client: St. John Environmental Consulting
Job ID: 810-91973-1
Project/Site: Lebanon RIII School District - High School

Client Sample ID: LHS-36 Sink
Lab Sample ID: 810-91973-36
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 12:28

Client Sample ID: LHS-37 Bubbler
Lab Sample ID: 810-91973-37
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 12:30

Client Sample ID: LHS-38 Sink
Lab Sample ID: 810-91973-38
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 12:32

Client Sample ID: LHS-39 Bubbler
Lab Sample ID: 810-91973-39
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 12:36

Client Sample ID: LHS-40 WF
Lab Sample ID: 810-91973-40
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 12:38

Client Sample ID: LHS-41 Sink
Lab Sample ID: 810-91973-41
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 12:42

Client Sample ID: LHS-42 Sink
Lab Sample ID: 810-91973-42
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 12:44

Lab Chronicle

Client: St. John Environmental Consulting
Job ID: 810-91973-1
Project/Site: Lebanon RIII School District - High School

Client Sample ID: LHS-43 Bubbler
Lab Sample ID: 810-91973-43
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 12:45

Client Sample ID: LHS-44 Sink
Lab Sample ID: 810-91973-44
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 12:47

Client Sample ID: LHS-45 Sink
Lab Sample ID: 810-91973-45
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 12:49

Client Sample ID: LHS-46 Bubbler
Lab Sample ID: 810-91973-46
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 12:50

Client Sample ID: LHS-47 Sink
Lab Sample ID: 810-91973-47
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 12:52

Client Sample ID: LHS-48 Bubbler
Lab Sample ID: 810-91973-48
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 12:53

Client Sample ID: LHS-49 WF
Lab Sample ID: 810-91973-49
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 13:01

Lab Chronicle

Client: St. John Environmental Consulting
Job ID: 810-91973-1
Project/Site: Lebanon RIII School District - High School

Client Sample ID: LHS-50 Sink
Lab Sample ID: 810-91973-50
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 13:02

Client Sample ID: LHS-51 Sink
Lab Sample ID: 810-91973-51
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 13:04

Client Sample ID: LHS-52 Sink
Lab Sample ID: 810-91973-52
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 13:09

Client Sample ID: LHS-53 Bubbler
Lab Sample ID: 810-91973-53
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 13:10

Client Sample ID: LHS-54 Sink
Lab Sample ID: 810-91973-54
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 13:12

Client Sample ID: LHS-55 Bubbler
Lab Sample ID: 810-91973-55
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 13:13

Client Sample ID: LHS-56 Sink
Lab Sample ID: 810-91973-56
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 13:15

Client Sample ID: LHS-57 Bubbler
Lab Sample ID: 810-91973-57
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 13:16

Client Sample ID: LHS-58 Sink
Lab Sample ID: 810-91973-58
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 13:18

Client Sample ID: LHS-59 Sink
Lab Sample ID: 810-91973-59
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 13:22

Client Sample ID: LHS-60 Sink
Lab Sample ID: 810-91973-60
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 13:24

Client Sample ID: LHS-61 Bubbler
Lab Sample ID: 810-91973-61
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 13:25

Client Sample ID: LHS-62 Sink
Lab Sample ID: 810-91973-62
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 13:27

Client Sample ID: LHS-63 Bubbler
Lab Sample ID: 810-91973-63
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 13:32

Lab Chronicle

Client: St. John Environmental Consulting
Job ID: 810-91973-1
Project/Site: Lebanon RIII School District - High School

Client Sample ID: LHS-64 Sink
Lab Sample ID: 810-91973-64
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 13:33

Client Sample ID: LHS-65 Sink
Lab Sample ID: 810-91973-65
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 13:35

Client Sample ID: LHS-66 Sink
Lab Sample ID: 810-91973-66
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 13:36

Client Sample ID: LHS-67 Sink
Lab Sample ID: 810-91973-68
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 13:38

Client Sample ID: LHS-68 Sink
Lab Sample ID: 810-91973-69
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 13:39

Client Sample ID: LHS-69 Bubbler
Lab Sample ID: 810-91973-70
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87687	CA	EA SB	02/05/24 12:46

Client Sample ID: LHS-70 WF
Lab Sample ID: 810-91973-71
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87687	CA	EA SB	02/05/24 12:48

Lab Chronicle

Client: St. John Environmental Consulting
Job ID: 810-91973-1
Project/Site: Lebanon RIII School District - High School

Client Sample ID: LHS-71 WF
Lab Sample ID: 810-91973-72
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87687	CA	EA SB	02/05/24 12:51

Client Sample ID: LHS-72 Sink
Lab Sample ID: 810-91973-73
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87687	CA	EA SB	02/05/24 12:59

Client Sample ID: LHS-73 Sink
Lab Sample ID: 810-91973-74
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87687	CA	EA SB	02/05/24 13:01

Client Sample ID: LHS-74 Sink
Lab Sample ID: 810-91973-75
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87687	CA	EA SB	02/05/24 13:04

Client Sample ID: LHS-75 Sink
Lab Sample ID: 810-91973-76
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87687	CA	EA SB	02/05/24 13:07

Client Sample ID: LHS-76 Sink
Lab Sample ID: 810-91973-77
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87687	CA	EA SB	02/05/24 13:09

Client Sample ID: LHS-77 Sink
Lab Sample ID: 810-91973-78
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87687	CA	EA SB	02/05/24 13:12

Lab Chronicle

Client: St. John Environmental Consulting
Job ID: 810-91973-1
Project/Site: Lebanon RIII School District - High School

Client Sample ID: LHS-78 Sink
Lab Sample ID: 810-91973-79
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87687	CA	EA SB	02/05/24 13:14

Client Sample ID: LHS-79 WF
Lab Sample ID: 810-91973-80
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87687	CA	EA SB	02/05/24 13:22

Client Sample ID: LHS-80 WF
Lab Sample ID: 810-91973-81
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87687	CA	EA SB	02/05/24 13:25

Client Sample ID: LHS-81 Sink
Lab Sample ID: 810-91973-82
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87687	CA	EA SB	02/05/24 13:28

Client Sample ID: LHS-82 Sink
Lab Sample ID: 810-91973-83
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87687	CA	EA SB	02/05/24 13:30

Client Sample ID: LHS-83 Sink
Lab Sample ID: 810-91973-84
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87687	CA	EA SB	02/05/24 13:38

Client Sample ID: LHS-84 Sink
Lab Sample ID: 810-91973-85
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87687	CA	EA SB	02/05/24 13:41

Lab Chronicle

Client: St. John Environmental Consulting
Job ID: 810-91973-1
Project/Site: Lebanon RIII School District - High School

Client Sample ID: LHS-85 Sink
Lab Sample ID: 810-91973-86
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87687	CA	EA SB	02/05/24 13:43

Client Sample ID: LHS-86 Sink
Lab Sample ID: 810-91973-87
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87687	CA	EA SB	02/05/24 13:46

Client Sample ID: LHS-87 Sink
Lab Sample ID: 810-91973-88
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87687	CA	EA SB	02/05/24 13:49

Client Sample ID: LHS-88 Sink
Lab Sample ID: 810-91973-89
Date Collected: 01/26/24 08:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87687	CA	EA SB	02/05/24 13:51

Client Sample ID: LHS-89 Sink
Lab Sample ID: 810-91973-90
Date Collected: 01/26/24 08:10
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87687	CA	EA SB	02/05/24 14:04

Client Sample ID: LHS-90 Sink
Lab Sample ID: 810-91973-91
Date Collected: 01/26/24 08:10
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87687	CA	EA SB	02/05/24 14:07

Client Sample ID: LHS-91 Sink
Lab Sample ID: 810-91973-92
Date Collected: 01/26/24 08:10
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87687	CA	EA SB	02/05/24 14:09

Lab Chronicle

Client: St. John Environmental Consulting
Job ID: 810-91973-1
Project/Site: Lebanon RIII School District - High School

Client Sample ID: LHS-92 Sink
Lab Sample ID: 810-91973-93
Date Collected: 01/26/24 08:10
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87687	CA	EA SB	02/05/24 14:12

Client Sample ID: LHS-93 Sink
Lab Sample ID: 810-91973-94
Date Collected: 01/26/24 08:10
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87687	CA	EA SB	02/05/24 14:15

Client Sample ID: LHS-94 Sink
Lab Sample ID: 810-91973-95
Date Collected: 01/26/24 08:10
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87687	CA	EA SB	02/05/24 14:23

Client Sample ID: LHS-95 Sink
Lab Sample ID: 810-91973-96
Date Collected: 01/26/24 08:10
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87687	CA	EA SB	02/05/24 14:25

Client Sample ID: LHS-96 Sink
Lab Sample ID: 810-91973-97
Date Collected: 01/26/24 08:10
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87687	CA	EA SB	02/05/24 14:28

Client Sample ID: LHS-97 Sink
Lab Sample ID: 810-91973-98
Date Collected: 01/26/24 08:10
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87687	CA	EA SB	02/05/24 14:30

Client Sample ID: LHS-98 Sink
Lab Sample ID: 810-91973-99
Date Collected: 01/26/24 08:10
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87687	CA	EA SB	02/05/24 14:33

Lab Chronicle

Client: St. John Environmental Consulting
Job ID: 810-91973-1
Project/Site: Lebanon RIII School District - High School

Client Sample ID: LHS-99 Sink
Lab Sample ID: 810-91973-100
Date Collected: 01/26/24 08:10
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87687	CA	EA SB	02/05/24 14:41

Client Sample ID: LHS-100 Sink
Lab Sample ID: 810-91973-101
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87687	CA	EA SB	02/05/24 14:44

Client Sample ID: LHS-101 Sink
Lab Sample ID: 810-91973-102
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87687	CA	EA SB	02/05/24 14:46

Client Sample ID: LHS-102 Sink
Lab Sample ID: 810-91973-103
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87687	CA	EA SB	02/05/24 14:49

Client Sample ID: LHS-103 Sink
Lab Sample ID: 810-91973-104
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87687	CA	EA SB	02/05/24 14:51

Client Sample ID: LHS-104 Sink
Lab Sample ID: 810-91973-105
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87687	CA	EA SB	02/05/24 14:54

Client Sample ID: LHS-105 Sink
Lab Sample ID: 810-91973-106
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87687	CA	EA SB	02/05/24 15:02

Lab Chronicle

Client: St. John Environmental Consulting
Job ID: 810-91973-1
Project/Site: Lebanon RIII School District - High School

Client Sample ID: LHS-106 Sink
Lab Sample ID: 810-91973-107
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87687	CA	EA SB	02/05/24 15:05

Client Sample ID: LHS-107 Sink
Lab Sample ID: 810-91973-108
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87687	CA	EA SB	02/05/24 15:07

Client Sample ID: LHS-108 WF
Lab Sample ID: 810-91973-109
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87687	CA	EA SB	02/05/24 15:10

Client Sample ID: LHS-109 Sink
Lab Sample ID: 810-91973-110
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87687	CA	EA SB	02/05/24 15:23

Client Sample ID: LHS-110 Sink
Lab Sample ID: 810-91973-111
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87687	CA	EA SB	02/05/24 15:26

Client Sample ID: LHS-111 Sink
Lab Sample ID: 810-91973-112
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87687	CA	EA SB	02/05/24 15:28

Client Sample ID: LHS-112 Sink
Lab Sample ID: 810-91973-113
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87687	CA	EA SB	02/05/24 15:31

Lab Chronicle

Client: St. John Environmental Consulting
Job ID: 810-91973-1
Project/Site: Lebanon RIII School District - High School

Client Sample ID: LHS-113 Sink
Lab Sample ID: 810-91973-114
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87687	CA	EA SB	02/05/24 15:33

Client Sample ID: LHS-114 Sink
Lab Sample ID: 810-91973-115
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87687	CA	EA SB	02/05/24 15:36

Client Sample ID: LHS-115 Sink
Lab Sample ID: 810-91973-116
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87687	CA	EA SB	02/05/24 15:39

Client Sample ID: LHS-116 Sink
Lab Sample ID: 810-91973-117
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87687	CA	EA SB	02/05/24 15:47

Client Sample ID: LHS-117 Sink
Lab Sample ID: 810-91973-118
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87687	CA	EA SB	02/05/24 15:49

Client Sample ID: LHS-118 Sink
Lab Sample ID: 810-91973-119
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87687	CA	EA SB	02/05/24 15:52

Client Sample ID: LHS-119 Sink
Lab Sample ID: 810-91973-120
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87687	CA	EA SB	02/05/24 16:00

Lab Chronicle

Client: St. John Environmental Consulting
Job ID: 810-91973-1
Project/Site: Lebanon RIII School District - High School

Client Sample ID: LHS-120 Sink
Lab Sample ID: 810-91973-121
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87687	CA	EA SB	02/05/24 16:02

Client Sample ID: LHS-121 Sink
Lab Sample ID: 810-91973-122
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87687	CA	EA SB	02/05/24 16:05

Client Sample ID: LHS-122 Sink
Lab Sample ID: 810-91973-123
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87687	CA	EA SB	02/05/24 16:08

Client Sample ID: LHS-123 Sink
Lab Sample ID: 810-91973-124
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87687	CA	EA SB	02/05/24 16:10

Client Sample ID: LHS-124 Sink
Lab Sample ID: 810-91973-125
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87687	CA	EA SB	02/05/24 16:13

Client Sample ID: LHS-125 Sink
Lab Sample ID: 810-91973-126
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87687	CA	EA SB	02/05/24 16:16

Client Sample ID: LHS-126 Sink
Lab Sample ID: 810-91973-127
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87687	CA	EA SB	02/05/24 16:18

Lab Chronicle

Client: St. John Environmental Consulting
Job ID: 810-91973-1
Project/Site: Lebanon RIII School District - High School

Client Sample ID: LHS-127 WF
Lab Sample ID: 810-91973-128
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87687	CA	EA SB	02/05/24 16:26

Client Sample ID: LHAS-128 Sink
Lab Sample ID: 810-91973-129
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87687	CA	EA SB	02/05/24 16:29

Client Sample ID: LHS-129 Sink
Lab Sample ID: 810-91973-130
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 13:47

Client Sample ID: LHS-130 Sink
Lab Sample ID: 810-91973-131
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 13:49

Client Sample ID: LHS-131 Sink
Lab Sample ID: 810-91973-132
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 13:53

Client Sample ID: LHS-132 Sink
Lab Sample ID: 810-91973-133
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 13:55

Client Sample ID: LHS-133 Sink
Lab Sample ID: 810-91973-134
Date Collected: 01/26/24 08:40
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 13:56

Lab Chronicle

Client: St. John Environmental Consulting
Job ID: 810-91973-1
Project/Site: Lebanon RIII School District - High School

Client Sample ID: LHS-134 Sink
Lab Sample ID: 810-91973-135
Date Collected: 01/26/24 08:40
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 13:58

Client Sample ID: LHS-135 Sink
Lab Sample ID: 810-91973-136
Date Collected: 01/26/24 08:40
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 13:59

Client Sample ID: LHS-136 Sink
Lab Sample ID: 810-91973-137
Date Collected: 01/26/24 08:40
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 14:01

Client Sample ID: LHS-137 BF
Lab Sample ID: 810-91973-138
Date Collected: 01/26/24 08:40
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 14:02

Client Sample ID: LHS-138 Sink
Lab Sample ID: 810-91973-139
Date Collected: 01/26/24 08:40
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 14:04

Client Sample ID: LHS-139 Sink
Lab Sample ID: 810-91973-140
Date Collected: 01/26/24 08:40
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 14:09

Client Sample ID: LHS-140 WF
Lab Sample ID: 810-91973-141
Date Collected: 01/26/24 08:40
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 14:10

Lab Chronicle

Client: St. John Environmental Consulting
Job ID: 810-91973-1
Project/Site: Lebanon RIII School District - High School

Client Sample ID: LHS-141 Sink
Lab Sample ID: 810-91973-142
Date Collected: 01/26/24 08:40
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 14:12

Client Sample ID: LHS-142 Sink
Lab Sample ID: 810-91973-143
Date Collected: 01/26/24 08:40
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 14:16

Client Sample ID: LHS-143 Sink
Lab Sample ID: 810-91973-144
Date Collected: 01/26/24 08:40
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 15:19

Client Sample ID: LHS-144 WF
Lab Sample ID: 810-91973-145
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 15:21

Client Sample ID: LHS-145 WF
Lab Sample ID: 810-91973-146
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 15:22

Client Sample ID: LHS-146 Sink
Lab Sample ID: 810-91973-147
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 15:27

Client Sample ID: LHS-147 Sink
Lab Sample ID: 810-91973-148
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 15:29

Lab Chronicle

Client: St. John Environmental Consulting
Job ID: 810-91973-1
Project/Site: Lebanon RIII School District - High School

Client Sample ID: LHS-148 Sink
Lab Sample ID: 810-91973-149
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 15:30

Client Sample ID: LHS-149 Sink
Lab Sample ID: 810-91973-150
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 15:32

Client Sample ID: LHS-150 Sink
Lab Sample ID: 810-91973-151
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 15:33

Client Sample ID: LHS-151 Sink
Lab Sample ID: 810-91973-152
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 15:35

Client Sample ID: LHS-152 Sink
Lab Sample ID: 810-91973-153
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 15:36

Client Sample ID: LHS-153 Sink
Lab Sample ID: 810-91973-154
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 15:41

Client Sample ID: LHS-154 WF
Lab Sample ID: 810-91973-155
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 15:42

Lab Chronicle

Client: St. John Environmental Consulting
Job ID: 810-91973-1
Project/Site: Lebanon RIII School District - High School

Client Sample ID: LHS-155 WF
Lab Sample ID: 810-91973-156
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 15:44

Client Sample ID: LHS-156 Sink
Lab Sample ID: 810-91973-157
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 15:46

Client Sample ID: LHS-157 WF
Lab Sample ID: 810-91973-158
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 15:50

Client Sample ID: LHS-158 WF
Lab Sample ID: 810-91973-159
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 15:52

Client Sample ID: LHS-159 Sink
Lab Sample ID: 810-91973-160
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 15:53

Client Sample ID: LHS-160 Sink
Lab Sample ID: 810-91973-161
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 15:55

Client Sample ID: LHS-161 ICE
Lab Sample ID: 810-91973-162
Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total Recoverable	Prep	200.8			87923	NB	EA SB	02/07/24 11:55
Total Recoverable	Analysis	200.8		1	88075	NB	EA SB	02/08/24 14:15

Lab Chronicle

Client: St. John Environmental Consulting
Job ID: 810-91973-1
Project/Site: Lebanon RIII School District - High School

Client Sample ID: LHS-162 ICE
Lab Sample ID: 810-91973-163

Date Collected: 01/26/24 08:30
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87688	CA	EA SB	02/05/24 15:56

Laboratory References:

EA SB = Eurofins Eaton Analytical South Bend, 110 S Hill Street, South Bend, IN 46617, TEL (574)233-4777

Accreditation/Certification Summary

Client: St. John Environmental Consulting
Job ID: 810-91973-1
Project/Site: Lebanon RIII School District - High School

Laboratory: Eurofins Eaton Analytical South Bend

The accreditations/certifications listed below are applicable to this report.

Authority	Program	Identification Number	Expiration Date
Missouri	State	880	09-30-24

Method Summary

Client: St. John Environmental Consulting
Job ID: 810-91973-1
Project/Site: Lebanon RIII School District - High School

Method	Method Description	Protocol	Laboratory
200.8	Metals (ICP/MS)	EPA	EA SB
200.8	Preparation, Total Recoverable Metals	EPA	EA SB

Protocol References:

EPA = US Environmental Protection Agency

Laboratory References:

EA SB = Eurofins Eaton Analytical South Bend, 110 S Hill Street, South Bend, IN 46617, TEL (574)233-4777

Sample Summary

Client: St. John Environmental Consulting
Job ID: 810-91973-1
Project/Site: Lebanon RIII School District - High School

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
810-91973-1	LHS-1 Sink	Drinking Water	01/26/24 07:30	01/30/24 09:00
810-91973-2	LHS-2 Sink	Drinking Water	01/26/24 07:30	01/30/24 09:00
810-91973-3	LHS-3 WF	Drinking Water	01/26/24 07:30	01/30/24 09:00
810-91973-4	LHS-4 WF	Drinking Water	01/26/24 07:30	01/30/24 09:00
810-91973-5	LHS-5 WF	Drinking Water	01/26/24 07:30	01/30/24 09:00
810-91973-6	LHS-6 WF	Drinking Water	01/26/24 07:30	01/30/24 09:00
810-91973-7	LHS-7 Sink	Drinking Water	01/26/24 07:30	01/30/24 09:00
810-91973-8	LHS-8 Sink	Drinking Water	01/26/24 07:30	01/30/24 09:00
810-91973-9	LHS-9 Sink	Drinking Water	01/26/24 07:30	01/30/24 09:00
810-91973-10	LHS-10 Sink	Drinking Water	01/26/24 07:30	01/30/24 09:00
810-91973-11	LHS-11 Sink	Drinking Water	01/26/24 07:30	01/30/24 09:00
810-91973-12	LHS-12 Sink	Drinking Water	01/26/24 07:30	01/30/24 09:00
810-91973-13	LHS-13 Sink	Drinking Water	01/26/24 07:30	01/30/24 09:00
810-91973-14	LHS-14 Sink	Drinking Water	01/26/24 07:30	01/30/24 09:00
810-91973-15	LHS-15 Sink	Drinking Water	01/26/24 07:30	01/30/24 09:00
810-91973-16	LHS-16 Sink	Drinking Water	01/26/24 07:30	01/30/24 09:00
810-91973-17	LHS-17 Sink	Drinking Water	01/26/24 07:30	01/30/24 09:00
810-91973-18	LHS-18 Sink	Drinking Water	01/26/24 07:30	01/30/24 09:00
810-91973-19	LHS-19 Sink	Drinking Water	01/26/24 07:30	01/30/24 09:00
810-91973-20	LHS-20 Sink	Drinking Water	01/26/24 07:30	01/30/24 09:00
810-91973-21	LHS-21 Sink	Drinking Water	01/26/24 07:30	01/30/24 09:00
810-91973-22	LHS-22 Sink	Drinking Water	01/26/24 07:30	01/30/24 09:00
810-91973-23	LHS-23 Sink	Drinking Water	01/26/24 08:00	01/30/24 09:00
810-91973-24	LHS-24 WF	Drinking Water	01/26/24 08:00	01/30/24 09:00
810-91973-25	LHS-25 WF	Drinking Water	01/26/24 08:00	01/30/24 09:00
810-91973-26	LHS-26 WF	Drinking Water	01/26/24 08:00	01/30/24 09:00
810-91973-27	LHS-27 Sink	Drinking Water	01/26/24 08:00	01/30/24 09:00
810-91973-28	LHS-28 Sink	Drinking Water	01/26/24 08:00	01/30/24 09:00
810-91973-29	LHS-29 Sink	Drinking Water	01/26/24 08:00	01/30/24 09:00
810-91973-30	LHS-30 Sink	Drinking Water	01/26/24 08:00	01/30/24 09:00
810-91973-31	LHS-31 Bubbler	Drinking Water	01/26/24 08:00	01/30/24 09:00
810-91973-32	LHS-32 Sink	Drinking Water	01/26/24 08:00	01/30/24 09:00
810-91973-33	LHS-33 Bubbler	Drinking Water	01/26/24 08:00	01/30/24 09:00
810-91973-34	LHS-34 Sink	Drinking Water	01/26/24 08:00	01/30/24 09:00
810-91973-35	LHS-35 Sink	Drinking Water	01/26/24 08:00	01/30/24 09:00
810-91973-36	LHS-36 Sink	Drinking Water	01/26/24 08:00	01/30/24 09:00
810-91973-37	LHS-37 Bubbler	Drinking Water	01/26/24 08:00	01/30/24 09:00
810-91973-38	LHS-38 Sink	Drinking Water	01/26/24 08:00	01/30/24 09:00
810-91973-39	LHS-39 Bubbler	Drinking Water	01/26/24 08:00	01/30/24 09:00
810-91973-40	LHS-40 WF	Drinking Water	01/26/24 08:00	01/30/24 09:00
810-91973-41	LHS-41 Sink	Drinking Water	01/26/24 08:00	01/30/24 09:00
810-91973-42	LHS-42 Sink	Drinking Water	01/26/24 08:00	01/30/24 09:00
810-91973-43	LHS-43 Bubbler	Drinking Water	01/26/24 08:00	01/30/24 09:00
810-91973-44	LHS-44 Sink	Drinking Water	01/26/24 08:00	01/30/24 09:00
810-91973-45	LHS-45 Sink	Drinking Water	01/26/24 08:00	01/30/24 09:00
810-91973-46	LHS-46 Bubbler	Drinking Water	01/26/24 08:00	01/30/24 09:00
810-91973-47	LHS-47 Sink	Drinking Water	01/26/24 08:00	01/30/24 09:00
810-91973-48	LHS-48 Bubbler	Drinking Water	01/26/24 08:00	01/30/24 09:00
810-91973-49	LHS-49 WF	Drinking Water	01/26/24 08:00	01/30/24 09:00
810-91973-50	LHS-50 Sink	Drinking Water	01/26/24 08:00	01/30/24 09:00
810-91973-51	LHS-51 Sink	Drinking Water	01/26/24 08:00	01/30/24 09:00
810-91973-52	LHS-52 Sink	Drinking Water	01/26/24 08:00	01/30/24 09:00
810-91973-53	LHS-53 Bubbler	Drinking Water	01/26/24 08:00	01/30/24 09:00
810-91973-54	LHS-54 Sink	Drinking Water	01/26/24 08:00	01/30/24 09:00

Sample Summary

Client: St. John Environmental Consulting
Job ID: 810-91973-1
Project/Site: Lebanon RIII School District - High School

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
810-91973-55	LHS-55 Bubbler	Drinking Water	01/26/24 08:00	01/30/24 09:00
810-91973-56	LHS-56 Sink	Drinking Water	01/26/24 08:00	01/30/24 09:00
810-91973-57	LHS-57 Bubbler	Drinking Water	01/26/24 08:00	01/30/24 09:00
810-91973-58	LHS-58 Sink	Drinking Water	01/26/24 08:00	01/30/24 09:00
810-91973-59	LHS-59 Sink	Drinking Water	01/26/24 08:00	01/30/24 09:00
810-91973-60	LHS-60 Sink	Drinking Water	01/26/24 08:00	01/30/24 09:00
810-91973-61	LHS-61 Bubbler	Drinking Water	01/26/24 08:00	01/30/24 09:00
810-91973-62	LHS-62 Sink	Drinking Water	01/26/24 08:00	01/30/24 09:00
810-91973-63	LHS-63 Bubbler	Drinking Water	01/26/24 08:00	01/30/24 09:00
810-91973-64	LHS-64 Sink	Drinking Water	01/26/24 08:00	01/30/24 09:00
810-91973-65	LHS-65 Sink	Drinking Water	01/26/24 08:00	01/30/24 09:00
810-91973-66	LHS-66 Sink	Drinking Water	01/26/24 08:00	01/30/24 09:00
810-91973-68	LHS-67 Sink	Drinking Water	01/26/24 08:00	01/30/24 09:00
810-91973-69	LHS-68 Sink	Drinking Water	01/26/24 08:00	01/30/24 09:00
810-91973-70	LHS-69 Bubbler	Drinking Water	01/26/24 08:00	01/30/24 09:00
810-91973-71	LHS-70 WF	Drinking Water	01/26/24 08:00	01/30/24 09:00
810-91973-72	LHS-71 WF	Drinking Water	01/26/24 08:00	01/30/24 09:00
810-91973-73	LHS-72 Sink	Drinking Water	01/26/24 08:00	01/30/24 09:00
810-91973-74	LHS-73 Sink	Drinking Water	01/26/24 08:00	01/30/24 09:00
810-91973-75	LHS-74 Sink	Drinking Water	01/26/24 08:00	01/30/24 09:00
810-91973-76	LHS-75 Sink	Drinking Water	01/26/24 08:00	01/30/24 09:00
810-91973-77	LHS-76 Sink	Drinking Water	01/26/24 08:00	01/30/24 09:00
810-91973-78	LHS-77 Sink	Drinking Water	01/26/24 08:00	01/30/24 09:00
810-91973-79	LHS-78 Sink	Drinking Water	01/26/24 08:00	01/30/24 09:00
810-91973-80	LHS-79 WF	Drinking Water	01/26/24 08:00	01/30/24 09:00
810-91973-81	LHS-80 WF	Drinking Water	01/26/24 08:00	01/30/24 09:00
810-91973-82	LHS-81 Sink	Drinking Water	01/26/24 08:00	01/30/24 09:00
810-91973-83	LHS-82 Sink	Drinking Water	01/26/24 08:00	01/30/24 09:00
810-91973-84	LHS-83 Sink	Drinking Water	01/26/24 08:00	01/30/24 09:00
810-91973-85	LHS-84 Sink	Drinking Water	01/26/24 08:00	01/30/24 09:00
810-91973-86	LHS-85 Sink	Drinking Water	01/26/24 08:00	01/30/24 09:00
810-91973-87	LHS-86 Sink	Drinking Water	01/26/24 08:00	01/30/24 09:00
810-91973-88	LHS-87 Sink	Drinking Water	01/26/24 08:00	01/30/24 09:00
810-91973-89	LHS-88 Sink	Drinking Water	01/26/24 08:00	01/30/24 09:00
810-91973-90	LHS-89 Sink	Drinking Water	01/26/24 08:10	01/30/24 09:00
810-91973-91	LHS-90 Sink	Drinking Water	01/26/24 08:10	01/30/24 09:00
810-91973-92	LHS-91 Sink	Drinking Water	01/26/24 08:10	01/30/24 09:00
810-91973-93	LHS-92 Sink	Drinking Water	01/26/24 08:10	01/30/24 09:00
810-91973-94	LHS-93 Sink	Drinking Water	01/26/24 08:10	01/30/24 09:00
810-91973-95	LHS-94 Sink	Drinking Water	01/26/24 08:10	01/30/24 09:00
810-91973-96	LHS-95 Sink	Drinking Water	01/26/24 08:10	01/30/24 09:00
810-91973-97	LHS-96 Sink	Drinking Water	01/26/24 08:10	01/30/24 09:00
810-91973-98	LHS-97 Sink	Drinking Water	01/26/24 08:10	01/30/24 09:00
810-91973-99	LHS-98 Sink	Drinking Water	01/26/24 08:10	01/30/24 09:00
810-91973-100	LHS-99 Sink	Drinking Water	01/26/24 08:10	01/30/24 09:00
810-91973-101	LHS-100 Sink	Drinking Water	01/26/24 08:30	01/30/24 09:00
810-91973-102	LHS-101 Sink	Drinking Water	01/26/24 08:30	01/30/24 09:00
810-91973-103	LHS-102 Sink	Drinking Water	01/26/24 08:30	01/30/24 09:00
810-91973-104	LHS-103 Sink	Drinking Water	01/26/24 08:30	01/30/24 09:00
810-91973-105	LHS-104 Sink	Drinking Water	01/26/24 08:30	01/30/24 09:00
810-91973-106	LHS-105 Sink	Drinking Water	01/26/24 08:30	01/30/24 09:00
810-91973-107	LHS-106 Sink	Drinking Water	01/26/24 08:30	01/30/24 09:00
810-91973-108	LHS-107 Sink	Drinking Water	01/26/24 08:30	01/30/24 09:00
810-91973-109	LHS-108 WF	Drinking Water	01/26/24 08:30	01/30/24 09:00

Sample Summary

Client: St. John Environmental Consulting
Job ID: 810-91973-1
Project/Site: Lebanon RIII School District - High School

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
810-91973-110	LHS-109 Sink	Drinking Water	01/26/24 08:30	01/30/24 09:00
810-91973-111	LHS-110 Sink	Drinking Water	01/26/24 08:30	01/30/24 09:00
810-91973-112	LHS-111 Sink	Drinking Water	01/26/24 08:30	01/30/24 09:00
810-91973-113	LHS-112 Sink	Drinking Water	01/26/24 08:30	01/30/24 09:00
810-91973-114	LHS-113 Sink	Drinking Water	01/26/24 08:30	01/30/24 09:00
810-91973-115	LHS-114 Sink	Drinking Water	01/26/24 08:30	01/30/24 09:00
810-91973-116	LHS-115 Sink	Drinking Water	01/26/24 08:30	01/30/24 09:00
810-91973-117	LHS-116 Sink	Drinking Water	01/26/24 08:30	01/30/24 09:00
810-91973-118	LHS-117 Sink	Drinking Water	01/26/24 08:30	01/30/24 09:00
810-91973-119	LHS-118 Sink	Drinking Water	01/26/24 08:30	01/30/24 09:00
810-91973-120	LHS-119 Sink	Drinking Water	01/26/24 08:30	01/30/24 09:00
810-91973-121	LHS-120 Sink	Drinking Water	01/26/24 08:30	01/30/24 09:00
810-91973-122	LHS-121 Sink	Drinking Water	01/26/24 08:30	01/30/24 09:00
810-91973-123	LHS-122 Sink	Drinking Water	01/26/24 08:30	01/30/24 09:00
810-91973-124	LHS-123 Sink	Drinking Water	01/26/24 08:30	01/30/24 09:00
810-91973-125	LHS-124 Sink	Drinking Water	01/26/24 08:30	01/30/24 09:00
810-91973-126	LHS-125 Sink	Drinking Water	01/26/24 08:30	01/30/24 09:00
810-91973-127	LHS-126 Sink	Drinking Water	01/26/24 08:30	01/30/24 09:00
810-91973-128	LHS-127 WF	Drinking Water	01/26/24 08:30	01/30/24 09:00
810-91973-129	LHAS-128 Sink	Drinking Water	01/26/24 08:30	01/30/24 09:00
810-91973-130	LHS-129 Sink	Drinking Water	01/26/24 08:30	01/30/24 09:00
810-91973-131	LHS-130 Sink	Drinking Water	01/26/24 08:30	01/30/24 09:00
810-91973-132	LHS-131 Sink	Drinking Water	01/26/24 08:30	01/30/24 09:00
810-91973-133	LHS-132 Sink	Drinking Water	01/26/24 08:30	01/30/24 09:00
810-91973-134	LHS-133 Sink	Drinking Water	01/26/24 08:40	01/30/24 09:00
810-91973-135	LHS-134 Sink	Drinking Water	01/26/24 08:40	01/30/24 09:00
810-91973-136	LHS-135 Sink	Drinking Water	01/26/24 08:40	01/30/24 09:00
810-91973-137	LHS-136 Sink	Drinking Water	01/26/24 08:40	01/30/24 09:00
810-91973-138	LHS-137 BF	Drinking Water	01/26/24 08:40	01/30/24 09:00
810-91973-139	LHS-138 Sink	Drinking Water	01/26/24 08:40	01/30/24 09:00
810-91973-140	LHS-139 Sink	Drinking Water	01/26/24 08:40	01/30/24 09:00
810-91973-141	LHS-140 WF	Drinking Water	01/26/24 08:40	01/30/24 09:00
810-91973-142	LHS-141 Sink	Drinking Water	01/26/24 08:40	01/30/24 09:00
810-91973-143	LHS-142 Sink	Drinking Water	01/26/24 08:40	01/30/24 09:00
810-91973-144	LHS-143 Sink	Drinking Water	01/26/24 08:40	01/30/24 09:00
810-91973-145	LHS-144 WF	Drinking Water	01/26/24 08:30	01/30/24 09:00
810-91973-146	LHS-145 WF	Drinking Water	01/26/24 08:30	01/30/24 09:00
810-91973-147	LHS-146 Sink	Drinking Water	01/26/24 08:30	01/30/24 09:00
810-91973-148	LHS-147 Sink	Drinking Water	01/26/24 08:30	01/30/24 09:00
810-91973-149	LHS-148 Sink	Drinking Water	01/26/24 08:30	01/30/24 09:00
810-91973-150	LHS-149 Sink	Drinking Water	01/26/24 08:30	01/30/24 09:00
810-91973-151	LHS-150 Sink	Drinking Water	01/26/24 08:30	01/30/24 09:00
810-91973-152	LHS-151 Sink	Drinking Water	01/26/24 08:30	01/30/24 09:00
810-91973-153	LHS-152 Sink	Drinking Water	01/26/24 08:30	01/30/24 09:00
810-91973-154	LHS-153 Sink	Drinking Water	01/26/24 08:30	01/30/24 09:00
810-91973-155	LHS-154 WF	Drinking Water	01/26/24 08:30	01/30/24 09:00
810-91973-156	LHS-155 WF	Drinking Water	01/26/24 08:30	01/30/24 09:00
810-91973-157	LHS-156 Sink	Drinking Water	01/26/24 08:30	01/30/24 09:00
810-91973-158	LHS-157 WF	Drinking Water	01/26/24 08:30	01/30/24 09:00
810-91973-159	LHS-158 WF	Drinking Water	01/26/24 08:30	01/30/24 09:00
810-91973-160	LHS-159 Sink	Drinking Water	01/26/24 08:30	01/30/24 09:00
810-91973-161	LHS-160 Sink	Drinking Water	01/26/24 08:30	01/30/24 09:00
810-91973-162	LHS-161 ICE	Drinking Water	01/26/24 08:30	01/30/24 09:00
810-91973-163	LHS-162 ICE	Drinking Water	01/26/24 08:30	01/30/24 09:00

Chain of Custody Record

Cross Offs on COC by Client

eurofins | Environment Testing America

810-91973 COC

Client Contact: Jeff Morgan	Sampler: Ian St. John	Lab PM:	Carrier Tracking No(s):
Company: Lebanon RIII School District	Phone: 314-853-4668	E-Mail: ian@stjohnenv.com	State of Origin: MO
Address: 224 W. Commercial Street	PWSID:		COC No:
City: Lebanon	Due Date Requested:		Page: Page 1 of 15
State, Zip: MO 65536	TAT Requested (days): Standard		Job #:
Phone: 417-849-3330	Compliance Project: Δ Yes Δ No		
Email: Jeff.morgan@lebanon.k12.mo.us	PO #:		
Project Name: Lebanon RIII School District	WO #:		
Site: Lebanon Highschool	Project #:		
	SSOW#:		

Analysis Requested

Preservation Codes:

A - HCL, B - NaOH, C - Zn Acetate, D - Nitric Acid, E - NaHSO4, F - MeOH, G - Amchlor, H - Ascorbic Acid, I - Ice, J - DI Water, K - EDTA, L - EDA, M - Hexane, N - None, O - AsNaO2, P - Na2O4S, Q - Na2SO3, R - Na2S2O3, S - H2SO4, T - TSP Dodecahydrate, U - Acetone, V - MCAA, W - pH 4-5, Y - Trizma, Z - other (specify)

Other:

Sample Identification	Sample Date	Sample Time	Sample Type (C=Comp, G=grab)	Matrix (W=water, S=solid, O=waste/oil, BT=Tissue, A=Air)	Lead In Drinking Water	Total Number of containers	Special Instructions/Note:
			Preservation Code:				
LHS-1 Sink	1/26/24	0730	G	W	X		
LHS-2 Sink							
LHS-3 WF							
LHS-4							
LHS-5							
LHS-6							
LHS-7 Sink							
LHS-8							
LHS-9							
LHS-10							
LHS-11							

Possible Hazard Identification

☐ Non-Hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☒ Unknown ☐ Radiological

Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)

☐ Return To Client ☒ Disposal By Lab ☐ Archive For _____ Months

Deliverable Requested: I, II, III, IV, Other (specify) No date/time on bottles 01/30/24

Special Instructions/QC Requirements:

Empty Kit Relinquished by:	Date:	Time:	Method of Shipment:
Relinquished by: Ian St. John	Date/Time: 1/26/24	Company	Received by: Penny Pehling Wright
Relinquished by:	Date/Time:	Company	Received by:
Relinquished by:	Date/Time:	Company	Received by:

Date/Time: 01/30/24 0900	Company FEA		
Date/Time:	Company		
Date/Time:	Company		

Custody Seals Intact: Δ Yes Δ No | Custody Seal No.:

Cooler Temperature(s) °C and Other Remarks: Ambient

Ver: 02/24/23

Eurofins Eaton Analyitcal: South Bend
110 South Hill Street
South Bend, IN 46617
Phone (574) 233-4777

Chain of Custody Record Cross Offs on COC by Client

eurofins | Environment Testing America

Client Information	Sampler: Ian St. John	Lab PM:	Carrier Tracking No(s):	COC No:
Client Contact: Jeff Morgan	Phone: 314-853-4668	E-Mail: ian@stjohnenv.com	State of Origin: MO	Page: Page 2 of 3 15
Company: Lebanon RIII School District	PWSID:			Job #:
Address: 224 W. Commercial Street	Due Date Requested:			
City: Lebanon	TAT Requested (days): Standard			
State, Zip: MO 65536	Compliance Project: Δ Yes Δ No			
Phone: 417-849-3330	PO #:			
Email: Jeff.morgan@lebanon.k12.mo.us	WO #:			
Project Name: Lebanon RIII School District	Project #:			
Site: Lebanon Highschool	SSOW#:			

Analysis Requested

Preservation Codes:
A - HCL, B - NaOH, C - Zn Acetate, D - Nitric Acid, E - NaHSO4, F - MeOH, G - Amchlor, H - Ascorbic Acid, I - Ice, J - DI Water, K - EDTA, L - EDA, M - Hexane, N - None, O - AsNaO2, P - Na2O4S, Q - Na2SO3, R - Na2S2O3, S - H2SO4, T - TSP Dodecahydrate, U - Acetone, V - MCAA, W - pH 4-5, Y - Trizma, Z - other (specify)
Other:

Sample Identification	Sample Date	Sample Time	Sample Type (C=Comp, G=grab)	Matrix (W=water, S=solid, O=waste/oil, BT=Tissue, A=Air)	Lead In Drinking Water	Total Number of containers	Special Instructions/Note:
			Preservation Code:				
LHS - 12 Sink	1/26/24	0730	G	W	X		
LHS - 13							
LHS - 14							
LHS - 15							
LHS - 16							
LHS - 17							
LHS - 18							
LHS - 19							
LHS - 20							
LHS - 21							
LHS - 22 Sink							

Possible Hazard Identification
☐ Non-Hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☒ Unknown ☐ Radiological

Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)
☐ Return To Client ☒ Disposal By Lab ☐ Archive For _____ Months

Deliverable Requested: I, II, III, IV, Other (specify)

Special Instructions/QC Requirements:

Empty Kit Relinquished by:	Date:	Time:	Method of Shipment:

	Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company
1	Ian St. John	1/26/24		Penny Pelling Wright	01/30/24 0900	EEA
2	Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company
3	Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company

Custody Seals Intact: Δ Yes Δ No | Custody Seal No.: | Cooler Temperature(s) °C and Other Remarks:

Ver: 02/24/23

Eurofins Eaton Analyitcal: South Bend
110 South Hill Street
South Bend, IN 46617
Phone (574) 233-4777

Chain of Custody Record

Cross Ons on COC by Cli

eurofins | Environment Testing America

Client Information	Sampler: Ian St. John	Lab PM:	Carrier Tracking No(s):	COC No:
Client Contact: Jeff Morgan	Phone: 314-853-4668	E-Mail: ian@stjohnenv.com	State of Origin: MO	Page: Page 3 of 15
Company: Lebanon RIII School District	PWSID:			Job #:
Address: 224 W. Commercial Street	Due Date Requested:			
City: Lebanon	TAT Requested (days): Standard			
State, Zip: MO 65536	Compliance Project: Δ Yes Δ No			
Phone: 417-849-3330	PO #:			
Email: Jeff.morgan@lebanon.k12.mo.us	WO #:			
Project Name: Lebanon RIII School District	Project #:			
Site: Lebanon Highschool	SSOW#:			

Analysis Requested

Preservation Codes:
A - HCL, B - NaOH, C - Zn Acetate, D - Nitric Acid, E - NaHSO4, F - MeOH, G - Amchlor, H - Ascorbic Acid, I - Ice, J - DI Water, K - EDTA, L - EDA, M - Hexane, N - None, O - AsNaO2, P - Na2O4S, Q - Na2SO3, R - Na2S2O3, S - H2SO4, T - TSP Dodecahydrate, U - Acetone, V - MCAA, W - pH 4-5, Y - Trizma, Z - other (specify)
Other:

Sample Identification	Sample Date	Sample Time	Sample Type (C=Comp, G=grab)	Matrix (W=water, S=solid, O=waste/oil, BT=Tissue, A=Air)	Lead In Drinking Water	Total Number of containers	Special Instructions/Note:
			Preservation Code:				
LHS-23 Sink	1/26/24	0800	G	W	X		
LHS-24 WF							
LHS-25							
LHS-26							
LHS-27 Sink							
LHS-28							
LHS-29							
LHS-30							
LHS-31 Bubbler							
LHS-32 Sink							
LHS-33 Bubbler							

Possible Hazard Identification
☐ Non-Hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☒ Unknown ☐ Radiological

Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)
☐ Return To Client ☒ Disposal By Lab ☐ Archive For _____ Months

Deliverable Requested: I, II, III, IV, Other (specify)

Special Instructions/QC Requirements:

Empty Kit Relinquished by:	Date:	Time:	Method of Shipment:

Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company
Ian St. John	1/26/24		Penny Pilling Wright	01/30/24 0900	EEA
Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company
Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company

Custody Seals Intact: Δ Yes Δ No | Custody Seal No.: | Cooler Temperature(s) °C and Other Remarks:

Ver: 02/24/23

Eurofins Eaton Analyitcal: South Bend
110 South Hill Street
South Bend, IN 46617
Phone (574) 233-4777

Chain of Custody Record

Cross Offs on COC by Client

eurofins | Environment Testing America

Client Information	Sampler: Ian St. John	Lab PM:	Carrier Tracking No(s):	COC No:
Client Contact: Jeff Morgan	Phone: 314-853-4668	E-Mail: ian@stjohnenv.com	State of Origin: MO	Page: Page 1 of 15
Company: Lebanon RIII School District	PWSID:	Analysis Requested		Job #:
Address: 224 W. Commercial Street	Due Date Requested:			Preservation Codes: A - HCL, B - NaOH, C - Zn Acetate, D - Nitric Acid, E - NaHSO4, F - MeOH, G - Amchlor, H - Ascorbic Acid, I - Ice, J - DI Water, K - EDTA, L - EDA, M - Hexane, N - None, O - AsNaO2, P - Na2O4S, Q - Na2SO3, R - Na2S2O3, S - H2SO4, T - TSP Dodecahydrate, U - Acetone, V - MCAA, W - pH 4-5, Y - Trizma, Z - other (specify)
City: Lebanon	TAT Requested (days): Standard			
State, Zip: MO 65536	Compliance Project: Δ Yes Δ No			
Phone: 417-849-3330	PO #:			Other:
Email: Jeff.morgan@lebanon.k12.mo.us	WO #:			
Project Name: Lebanon RIII School District	Project #:			
Site: Lebanon Highschool	SSOW#:			

Sample Identification	Sample Date	Sample Time	Sample Type (C=comp, G=grab)	Matrix (W=water, S=solid, O=waste/oil, BT=Tissue, A=Air)	Lead In Drinking Water	Total Number of containers	Special Instructions/Note:
			Preservation Code:				
LHS-34 Sink	1/26/24	0900	G	W	X		
LHS-35							
LHS-36							
LHS-37 Bubbler							
LHS-38 Sink							
LHS-39 Bubbler							
LHS-40 WF							
LHS-41 Sink							
LHS-42 Sink							
LHS-43 Bubbler							
LHS-44 Sink							

Possible Hazard Identification
☐ Non-Hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☒ Unknown ☐ Radiological

Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)
☐ Return To Client ☒ Disposal By Lab ☐ Archive For _____ Months

Deliverable Requested: I, II, III, IV, Other (specify)

Special Instructions/QC Requirements:

Empty Kit Relinquished by:	Date:	Time:	Method of Shipment:

Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company
Ian St. John	1/26/24		Penny Pelling Wright	01 30 24 0900	EEA
Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company
Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company

Custody Seals Intact: Δ Yes Δ No	Custody Seal No.:	Cooler Temperature(s) °C and Other Remarks:

Ver: 02/24/23

Eurofins Eaton Analyitcal: South Bend
110 South Hill Street
South Bend, IN 46617
Phone (574) 233-4777

Chain of Custody Record Cross Offs on COC by Client

eurofins Environment Testing America

Client Information	Sampler: Ian St. John	Lab PM:	Carrier Tracking No(s):	COC No:
Client Contact: Jeff Morgan	Phone: 314-853-4668	E-Mail: ian@stjohnenv.com	State of Origin: MO	Page: Page 5 of 15
Company: Lebanon RIII School District	PWSID:			Job #:
Address: 224 W. Commercial Street	Due Date Requested:			
City: Lebanon	TAT Requested (days): Standard			
State, Zip: MO 65536	Compliance Project: Δ Yes Δ No			
Phone: 417-849-3330	PO #:			
Email: Jeff.morgan@lebanon.k12.mo.us	WO #:			
Project Name: Lebanon RIII School District	Project #:			
Site: Lebanon Highschool	SSOW#:			

Analysis Requested

Preservation Codes:
A - HCL, B - NaOH, C - Zn Acetate, D - Nitric Acid, E - NaHSO4, F - MeOH, G - Amchlor, H - Ascorbic Acid, I - Ice, J - DI Water, K - EDTA, L - EDA, M - Hexane, N - None, O - AsNaO2, P - Na2O4S, Q - Na2SO3, R - Na2S2O3, S - H2SO4, T - TSP Dodecahydrate, U - Acetone, V - MCAA, W - pH 4-5, Y - Trizma, Z - other (specify)
Other:

Sample Identification	Sample Date	Sample Time	Sample Type (C=Comp, G=grab)	Matrix (W=water, S=solid, O=waste/oil, BT=Tissue, A=Air)	Lead In Drinking Water	Total Number of containers	Special Instructions/Note:
			Preservation Code:				
LHS-45 Sink	1/26/24	0800	G	W	X		
LHS-46 Bubbler							
LHS-47 Sink							
LHS-48 Bubbler							
LHS-49 ~~46~~ WF							
LHS-50 Sink							
LHS-51 Sink							
LHS-52 Sink							
LHS-53 Bubbler							
LHS-54 Sink							
LHS-55 Bubbler							

Possible Hazard Identification
☐ Non-Hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☒ Unknown ☐ Radiological

Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)
☐ Return To Client ☒ Disposal By Lab ☐ Archive For _____ Months

Deliverable Requested: I, II, III, IV, Other (specify)

Special Instructions/QC Requirements:

Empty Kit Relinquished by:	Date:	Time:	Method of Shipment:

	Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company
1	Ian St. John	1/26/24		Penny Pilling/Wyatt	01130 24 1900	EEA
2	Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company
3	Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company

Custody Seals Intact: Δ Yes Δ No | Custody Seal No.: | Cooler Temperature(s) °C and Other Remarks:

Ver: 02/24/23

Eurofins Eaton Analyitcal: South Bend
110 South Hill Street
South Bend, IN 46617
Phone (574) 233-4777

Chain of Custody Record

eurofins | Environment Testing America

Cross Offs on COC by Client

Client Information	Sampler: Ian St. John	Lab PM:	Carrier Tracking No(s):	COC No:
Client Contact: Jeff Morgan	Phone: 314-853-4668	E-Mail: ian@stjohnenv.com	State of Origin: MO	Page: Page 6 of 15
Company: Lebanon RIII School District	PWSID:			Job #:
Address: 224 W. Commercial Street	Due Date Requested:			
City: Lebanon	TAT Requested (days): Standard			
State, Zip: MO 65536	Compliance Project: Δ Yes Δ No			
Phone: 417-849-3330	PO #:			
Email: Jeff.morgan@lebanon.k12.mo.us	WO #:			
Project Name: Lebanon RIII School District	Project #:			
Site: Lebanon Highschool	SSOW#:			

Analysis Requested

Preservation Codes:
A - HCL, B - NaOH, C - Zn Acetate, D - Nitric Acid, E - NaHSO4, F - MeOH, G - Amchlor, H - Ascorbic Acid, I - Ice, J - DI Water, K - EDTA, L - EDA, M - Hexane, N - None, O - AsNaO2, P - Na2O4S, Q - Na2SO3, R - Na2S2O3, S - H2SO4, T - TSP Dodecahydrate, U - Acetone, V - MCAA, W - pH 4-5, Y - Trizma, Z - other (specify)
Other:

Sample Identification	Sample Date	Sample Time	Sample Type (C=comp, G=grab)	Matrix (W=water, S=solid, O=waste/oil, BT=Tissue, A=Air)	Lead In Drinking Water	Total Number of containers	Special Instructions/Note:
			Preservation Code:				
LHS - 56 Sink	1/26/24	0900	G	W	X		
LHS - 57 Bubbler							
LHS - 58 Sink							
LHS - 59 Sink							
LHS - 60 Sink							
LHS - 61 Bubbler							
LHS - 62 Sink							
LHS - 63 Bubbler							
LHS - 64 Sink							
LHS - 65							
LHS - 66							

Possible Hazard Identification
☐ Non-Hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☒ Unknown ☐ Radiological

Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)
☐ Return To Client ☒ Disposal By Lab ☐ Archive For _____ Months

Deliverable Requested: I, II, III, IV, Other (specify)

Special Instructions/QC Requirements:

Empty Kit Relinquished by:	Date:	Time:	Method of Shipment:

	Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company
1	Ian St. John	1/26/24		Penny Pehling Wright	01/30/24 0900	EEA
2	Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company
3	Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company

Custody Seals Intact: Δ Yes Δ No | Custody Seal No.: | Cooler Temperature(s) °C and Other Remarks:

Ver: 02/24/23

Eurofins Eaton Analyitcal: South Bend
110 South Hill Street
South Bend, IN 46617
Phone (574) 233-4777

Chain of Custody Record

Cross Offs on [illegible]

eurofins | Environment Testing America

Client Information	Sampler: Ian St. John	Lab PM:	Carrier Tracking No(s):	COC No:
Client Contact: Jeff Morgan	Phone: 314-853-4668	E-Mail: ian@stjohnenv.com	State of Origin: MO	Page: Page 7 of 15
Company: Lebanon RIII School District	PWSID:	Analysis Requested		Job #:
Address: 224 W. Commercial Street	Due Date Requested:			Preservation Codes: A - HCL, B - NaOH, C - Zn Acetate, D - Nitric Acid, E - NaHSO4, F - MeOH, G - Amchlor, H - Ascorbic Acid, I - Ice, J - DI Water, K - EDTA, L - EDA, M - Hexane, N - None, O - AsNaO2, P - Na2O4S, Q - Na2SO3, R - Na2S2O3, S - H2SO4, T - TSP Dodecahydrate, U - Acetone, V - MCAA, W - pH 4-5, Y - Trizma, Z - other (specify); Other:
City: Lebanon	TAT Requested (days): Standard			
State, Zip: MO 65536	Compliance Project: Δ Yes Δ No			
Phone: 417-849-3330	PO #:			
Email: Jeff.morgan@lebanon.k12.mo.us	WO #:			
Project Name: Lebanon RIII School District	Project #:			
Site: Lebanon Highschool	SSOW#:			

Sample Identification	Sample Date	Sample Time	Sample Type (C=comp, G=grab)	Matrix (W=water, S=solid, O=waste/oil, BT=Tissue, A=Air)	Lead In Drinking Water	Total Number of containers	Special Instructions/Note:
			Preservation Code:				
LHS - 67 Sink	1/26/24	0800	G	W	X		
LHS - 68 Sink							
LHS - 69 Bubbler							
LHS - 70 WF							
LHS - 71 WF							
LHS - 72 Sink							
LHS - 73 Sink							
LHS - 74 Sink							
LHS - 75 Sink							
LHS - 76							
LHS - 77							

Possible Hazard Identification
☐ Non-Hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☒ Unknown ☐ Radiological

Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)
☐ Return To Client ☒ Disposal By Lab ☐ Archive For _____ Months

Deliverable Requested: I, II, III, IV, Other (specify)

Special Instructions/QC Requirements:

Empty Kit Relinquished by:	Date:	Time:	Method of Shipment:

Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company
Ian St. John	1/26/24		Penny Pehling Wright	01 30 24 0700	EEA
Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company
Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company

Custody Seals Intact: Δ Yes Δ No | Custody Seal No.: | Cooler Temperature(s) °C and Other Remarks:

Ver: 02/24/23

Eurofins Eaton Analyitcal: South Bend
110 South Hill Street
South Bend, IN 46617
Phone (574) 233-4777

Chain of Custody Record

eurofins | Environment Testing America

Client Information	Sampler: Ian St. John	Lab PM:	Carrier Tracking No(s):	COC No:
Client Contact: Jeff Morgan	Phone: 314-853-4668	E-Mail: ian@stjohnenv.com	State of Origin: MO	Page: Page 8 of 15
Company: Lebanon RIII School District	PWSID:			Job #:
Address: 224 W. Commercial Street	Due Date Requested:			
City: Lebanon	TAT Requested (days): Standard			
State, Zip: MO 65536	Compliance Project: Δ Yes Δ No			
Phone: 417-849-3330	PO #:			
Email: Jeff.morgan@lebanon.k12.mo.us	WO #:			
Project Name: Lebanon RIII School District	Project #:			
Site: Lebanon Highschool	SSOW#:			

Analysis Requested

Preservation Codes:
A - HCL, B - NaOH, C - Zn Acetate, D - Nitric Acid, E - NaHSO4, F - MeOH, G - Amchlor, H - Ascorbic Acid, I - Ice, J - DI Water, K - EDTA, L - EDA, M - Hexane, N - None, O - AsNaO2, P - Na2O4S, Q - Na2SO3, R - Na2S2O3, S - H2SO4, T - TSP Dodecahydrate, U - Acetone, V - MCAA, W - pH 4-5, Y - Trizma, Z - other (specify)
Other:

Sample Identification	Sample Date	Sample Time	Sample Type (C=Comp, G=grab)	Matrix (W=water, S=solid, O=wastoil, BT=Tissue, A=Air)	Lead In Drinking Water	Total Number of containers	Special Instructions/Note:
			Preservation Code:				
LHS - 78 Sink	1/26/24	0800	G	W	X		
LHS - 79 WF							
LHS - 80 WF							
LHS - 81 Sink							
LHS - 82							
LHS - 83							
LHS - 84							
LHS - 85							
LHS - 86							
LHS - 87							
LHS - 88							

Possible Hazard Identification
☐ Non-Hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☒ Unknown ☐ Radiological

Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)
☐ Return To Client ☒ Disposal By Lab ☐ Archive For _____ Months

Deliverable Requested: I, II, III, IV, Other (specify)

Special Instructions/QC Requirements:

Empty Kit Relinquished by:	Date:	Time:	Method of Shipment:

	Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company
1	Ian St. John	1/26/24		Penny Perkins Wright	1/27/24 0900	EEA
2	Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company
3	Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company

Custody Seals Intact: Δ Yes Δ No | Custody Seal No.: | Cooler Temperature(s) °C and Other Remarks:

Ver: 02/24/23

Eurofins Eaton Analyitcal: South Bend
110 South Hill Street
South Bend, IN 46617
Phone (574) 233-4777

Chain of Custody Record

eurofins | Environment Testing America

Cross Offs on COC by Client

Client Information	Sampler: Ian St. John	Lab PM:	Carrier Tracking No(s):	COC No:
Client Contact: Jeff Morgan	Phone: 314-853-4668	E-Mail: ian@stjohnenv.com	State of Origin: MO	Page: Page 9 of 15
Company: Lebanon RIII School District	PWSID:			Job #:
Address: 224 W. Commercial Street	Due Date Requested:			
City: Lebanon	TAT Requested (days): Standard			
State, Zip: MO 65536	Compliance Project: Δ Yes Δ No			
Phone: 417-849-3330	PO #:			
Email: Jeff.morgan@lebanon.k12.mo.us	WO #:			
Project Name: Lebanon RIII School District	Project #:			
Site: Lebanon Highschool	SSOW#:			

Analysis Requested

Preservation Codes:
A - HCL, B - NaOH, C - Zn Acetate, D - Nitric Acid, E - NaHSO4, F - MeOH, G - Amchlor, H - Ascorbic Acid, I - Ice, J - DI Water, K - EDTA, L - EDA, M - Hexane, N - None, O - AsNaO2, P - Na2O4S, Q - Na2SO3, R - Na2S2O3, S - H2SO4, T - TSP Dodecahydrate, U - Acetone, V - MCAA, W - pH 4-5, Y - Trizma, Z - other (specify)
Other:

Sample Identification	Sample Date	Sample Time	Sample Type (C=comp, G=grab)	Matrix (W=water, S=solid, O=waste/oil, BT=Tissue, A=Air)	Lead In Drinking Water	Total Number of containers	Special Instructions/Note:
			Preservation Code:				
LHS-89 Sink	1/26/24	0810	G	W	X		
LHS-90 Sink							
LHS-91							
LHS-92							
LHS-93							
LHS-94 Sink							
LHS-95							
LHS-96							
LHS-97							
LHS-98 Sink							
LHS-99 Sink							

Possible Hazard Identification
☐ Non-Hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☒ Unknown ☐ Radiological

Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)
☐ Return To Client ☒ Disposal By Lab ☐ Archive For _____ Months

Deliverable Requested: I, II, III, IV, Other (specify)

Special Instructions/QC Requirements:

Empty Kit Relinquished by:	Date:	Time:	Method of Shipment:

	Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company
1	Ian St. John	1/26/24		Kinsey Pehling Wright	01/30/24 0900	LEA
2						
3						

Custody Seals Intact: Δ Yes Δ No	Custody Seal No.:	Cooler Temperature(s) °C and Other Remarks:

Ver: 02/24/23

Eurofins Eaton Analyitcal: South Bend
110 South Hill Street
South Bend, IN 46617
Phone (574) 233-4777

Chain of Custody Record

eurofins | Environment Testing America

Client Information	Sampler: Ian St. John	Lab PM:	Carrier Tracking No(s):	COC No:
Client Contact: Jeff Morgan	Phone: 314-853-4668	E-Mail: ian@stjohnenv.com	State of Origin: MO	Page: Page 10 of 15
Company: Lebanon RIII School District	PWSID:	Analysis Requested		Job #:
Address: 224 W. Commercial Street	Due Date Requested:			Preservation Codes: A - HCL, B - NaOH, C - Zn Acetate, D - Nitric Acid, E - NaHSO4, F - MeOH, G - Amchlor, H - Ascorbic Acid, I - Ice, J - DI Water, K - EDTA, L - EDA, M - Hexane, N - None, O - AsNaO2, P - Na2O4S, Q - Na2SO3, R - Na2S2O3, S - H2SO4, T - TSP Dodecahydrate, U - Acetone, V - MCAA, W - pH 4-5, Y - Trizma, Z - other (specify), Other:
City: Lebanon	TAT Requested (days): Standard			
State, Zip: MO 65536	Compliance Project: Δ Yes Δ No			
Phone: 417-849-3330	PO #:			
Email: Jeff.morgan@lebanon.k12.mo.us	WO #:			
Project Name: Lebanon RIII School District	Project #:			
Site: Lebanon Highschool	SSOW#:			

Sample Identification	Sample Date	Sample Time	Sample Type (C=Comp, G=grab)	Matrix (W=water, S=solid, O=waste/oil, BT=Tissue, A=Air)	Lead In Drinking Water	Total Number of containers	Special Instructions/Note:
			Preservation Code:				
LHS - 100 Sink	1/26/24	0830	G	W	X		
LHS - 101							
LHS - 102							
LHS - 103 Sink							
LHS - 104							
LHS - 105							
LHS - 106							
LHS - 107 Sink							
LHS - 108 WF							
LHS - 109 Sink							
LHS - 110 Sink							

Possible Hazard Identification
☐ Non-Hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☒ Unknown ☐ Radiological

Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)
☐ Return To Client ☒ Disposal By Lab ☐ Archive For _____ Months

Deliverable Requested: I, II, III, IV, Other (specify)

Special Instructions/QC Requirements:

Empty Kit Relinquished by:	Date:	Time:	Method of Shipment:
Relinquished by: Ian St. John	Date/Time: 1/26/24	Company	Received by: Penny Pilkey Wright
Relinquished by:	Date/Time:	Company	Received by:
Relinquished by:	Date/Time:	Company	Received by:

Date/Time: 1/30/24 0900 Company: EEA
Date/Time: Company
Date/Time: Company

Custody Seals Intact: Δ Yes Δ No | Custody Seal No.:

Cooler Temperature(s) °C and Other Remarks:

Ver: 02/24/23

Eurofins Eaton Analyitcal: South Bend
110 South Hill Street
South Bend, IN 46617
Phone (574) 233-4777

Chain of Custody Record

eurofins | Environment Testing America

Client Information	Sampler: Ian St. John	Lab PM:	Carrier Tracking No(s):	COC No:
Client Contact: Jeff Morgan	Phone: 314-853-4668	E-Mail: ian@stjohnenv.com	State of Origin: MO	Page: Page 14 of 15
Company: Lebanon RIII School District	PWSID:	Analysis Requested		Job #:
Address: 224 W. Commercial Street	Due Date Requested:			Preservation Codes: A - HCL, B - NaOH, C - Zn Acetate, D - Nitric Acid, E - NaHSO4, F - MeOH, G - Amchlor, H - Ascorbic Acid, I - Ice, J - DI Water, K - EDTA, L - EDA, M - Hexane, N - None, O - AsNaO2, P - Na2O4S, Q - Na2SO3, R - Na2S2O3, S - H2SO4, T - TSP Dodecahydrate, U - Acetone, V - MCAA, W - pH 4-5, Y - Trizma, Z - other (specify)
City: Lebanon	TAT Requested (days): Standard			
State, Zip: MO 65536	Compliance Project: Δ Yes Δ No			
Phone: 417-849-3330	PO #:			Other:
Email: Jeff.morgan@lebanon.k12.mo.us	WO #:			
Project Name: Lebanon RIII School District	Project #:			
Site: Lebanon Highschool	SSOW#:			

Sample Identification	Sample Date	Sample Time	Sample Type (C=comp, G=grab)	Matrix (W=water, S=solid, O=wasteoil, BT=Tissue, A=Air)	Lead In Drinking Water	Total Number of containers	Special Instructions/Note:
			Preservation Code:				
LHS - 111 Sink	1/26/24	0830	G	W	X		
LHS - 112 Sink							
LHS - 113 Sink							
LHS - 114							
LHS - 115							
LHS - 116							
LHS - 117							
LHS - 118 Sink							
LHS - 119							
LHS - 120							
LHS - 121							

Possible Hazard Identification
☐ Non-Hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☒ Unknown ☐ Radiological

Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)
☐ Return To Client ☒ Disposal By Lab ☐ Archive For _____ Months

Deliverable Requested: I, II, III, IV, Other (specify)

Special Instructions/QC Requirements:

Empty Kit Relinquished by:	Date:	Time:	Method of Shipment:

Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company
Ian St. John	1/26/24		Penny Pebley Wright	01/30/24 0900	EEA
Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company
Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company

Custody Seals Intact: Δ Yes Δ No	Custody Seal No.:	Cooler Temperature(s) °C and Other Remarks:

Ver: 02/24/23

Eurofins Eaton Analyitcal: South Bend
110 South Hill Street
South Bend, IN 46617
Phone (574) 233-4777

Chain of Custody Record

Cross Offs on COC by Client

eurofins | Environment Testing America

Client Information	Sampler: Ian St. John	Lab PM:	Carrier Tracking No(s):	COC No:
Client Contact: Jeff Morgan	Phone: 314-853-4668	E-Mail: ian@stjohnenv.com	State of Origin: MO	Page: Page 2 of 5
Company: Lebanon RIII School District	PWSID:			Job #:
Address: 224 W. Commercial Street	Due Date Requested:			
City: Lebanon	TAT Requested (days): Standard			
State, Zip: MO 65536	Compliance Project: Δ Yes Δ No			
Phone: 417-849-3330	PO #:			
Email: Jeff.morgan@lebanon.k12.mo.us	WO #:			
Project Name: Lebanon RIII School District	Project #:			
Site: Lebanon Highschool	SSOW#:			

Analysis Requested

Preservation Codes:
A - HCL, B - NaOH, C - Zn Acetate, D - Nitric Acid, E - NaHSO4, F - MeOH, G - Amchlor, H - Ascorbic Acid, I - Ice, J - DI Water, K - EDTA, L - EDA, M - Hexane, N - None, O - AsNaO2, P - Na2O4S, Q - Na2SO3, R - Na2S2O3, S - H2SO4, T - TSP Dodecahydrate, U - Acetone, V - MCAA, W - pH 4-5, Y - Trizma, Z - other (specify)
Other:

Sample Identification	Sample Date	Sample Time	Sample Type (C=comp, G=grab)	Matrix (W=water, S=solid, O=waste/oil, BT=Tissue, A=Air)	Lead In Drinking Water	Total Number of containers	Special Instructions/Note:
			Preservation Code:				
LHS - 122 Sink	1/26/24	0830	G	W	X		
LHS - 123							
LHS - 124							
LHS - 125							
LHS - 126 Sink							
LHS - 127 WF							
LHS - 128 Sink							
LHS - 129							
LHS - 130							
LHS - 131							
LHS - 132							

Possible Hazard Identification
☐ Non-Hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☒ Unknown ☐ Radiological

Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)
☐ Return To Client ☒ Disposal By Lab ☐ Archive For _____ Months

Deliverable Requested: I, II, III, IV, Other (specify)

Special Instructions/QC Requirements:

Empty Kit Relinquished by:	Date:	Time:	Method of Shipment:

Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company
Ian St. John	1/26/24		Kelly Pohling Wright	01/30/24 0900	EEA
Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company
Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company

Custody Seals Intact: Δ Yes Δ No | Custody Seal No.: | Cooler Temperature(s) °C and Other Remarks:

Ver: 02/24/23

Eurofins Eaton Analyitcal: South Bend
110 South Hill Street
South Bend, IN 46617
Phone (574) 233-4777

Chain of Custody Record

eurofins | Environment Testing America

Cross Offs on COC by Client

Client Information	Sampler: Ian St. John	Lab PM:	Carrier Tracking No(s):	COC No:
Client Contact: Jeff Morgan	Phone: 314-853-4668	E-Mail: ian@stjohnenv.com	State of Origin: MO	Page: Page 13 of 15
Company: Lebanon RIII School District	PWSID:			Job #:
Address: 224 W. Commercial Street	Due Date Requested:			
City: Lebanon	TAT Requested (days): Standard			
State, Zip: MO 65536	Compliance Project: Δ Yes Δ No			
Phone: 417-849-3330	PO #:			
Email: Jeff.morgan@lebanon.k12.mo.us	WO #:			
Project Name: Lebanon RIII School District	Project #:			
Site: Lebanon Highschool	SSOW#:			

Analysis Requested

Preservation Codes:
A - HCL, B - NaOH, C - Zn Acetate, D - Nitric Acid, E - NaHSO4, F - MeOH, G - Amchlor, H - Ascorbic Acid, I - Ice, J - DI Water, K - EDTA, L - EDA, M - Hexane, N - None, O - AsNaO2, P - Na2O4S, Q - Na2SO3, R - Na2S2O3, S - H2SO4, T - TSP Dodecahydrate, U - Acetone, V - MCAA, W - pH 4-5, Y - Trizma, Z - other (specify)
Other:

Sample Identification	Sample Date	Sample Time	Sample Type (C=comp, G=grab)	Matrix (W=water, S=solid, O=waste/oil, BT=Tissue, A=Air)	Lead In Drinking Water	Total Number of containers	Special Instructions/Note:
			Preservation Code:				
LHS - 133 Sink	1/26/24	0840	G	W	X		
LHS - 134							
LHS - 135							
LHS - 136 Sink							
LHS - 137 BF							
LHS - 138 Sink							
LHS - 139 Sink							
LHS - 140 WF							
LHS - 141 Sink							
LHS - 142							
LHS - 143							

Possible Hazard Identification
☐ Non-Hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☒ Unknown ☐ Radiological

Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)
☐ Return To Client ☒ Disposal By Lab ☐ Archive For _____ Months

Deliverable Requested: I, II, III, IV, Other (specify)

Special Instructions/QC Requirements:

Empty Kit Relinquished by:	Date:	Time:	Method of Shipment:

	Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company
1	Ian St. John	1/26/24		Penny Pehling Wright	01/30/24 0900	EEA
2						
3						

Custody Seals Intact: Δ Yes Δ No | Custody Seal No.: | Cooler Temperature(s) °C and Other Remarks:

Ver: 02/24/23

Eurofins Eaton Analyitcal: South Bend
110 South Hill Street
South Bend, IN 46617
Phone (574) 233-4777

Chain of Custody Record Cross Offs on COC by Client

eurofins | Environment Testing America

Client Information	Sampler: Ian St. John	Lab PM:	Carrier Tracking No(s):	COC No:
Client Contact: Jeff Morgan	Phone: 314-853-4668	E-Mail: ian@stjohnenv.com	State of Origin: MO	Page: Page 14 of 15
Company: Lebanon RIII School District	PWSID:			Job #:
Address: 224 W. Commercial Street	Due Date Requested:			
City: Lebanon	TAT Requested (days): Standard			
State, Zip: MO 65536	Compliance Project: Δ Yes Δ No			
Phone: 417-849-3330	PO #:			
Email: Jeff.morgan@lebanon.k12.mo.us	WO #:			
Project Name: Lebanon RIII School District	Project #:			
Site: Lebanon Highschool	SSOW#:			

Analysis Requested

Preservation Codes:
A - HCL, B - NaOH, C - Zn Acetate, D - Nitric Acid, E - NaHSO4, F - MeOH, G - Amchlor, H - Ascorbic Acid, I - Ice, J - DI Water, K - EDTA, L - EDA, M - Hexane, N - None, O - AsNaO2, P - Na2O4S, Q - Na2SO3, R - Na2S2O3, S - H2SO4, T - TSP Dodecahydrate, U - Acetone, V - MCAA, W - pH 4-5, Y - Trizma, Z - other (specify)
Other:

Sample Identification	Sample Date	Sample Time	Sample Type (C=Comp, G=grab)	Matrix (W=water, S=solid, O=waste/oil, BT=Tissue, A=Air)	Lead In Drinking Water	Total Number of containers	Special Instructions/Note:
			Preservation Code:				
LHS-144 WF	1/26/24	0830	G	W	X		
LHS-145 ~~Sink~~ WF							
LHS-146 Sink							
LHS-147 Sink							
LHS-148							
LHS-149							
LHS-150							
LHS-151 Sink							
LHS-152							
LHS-153							
LHS-154 WF							

Possible Hazard Identification
☐ Non-Hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☒ Unknown ☐ Radiological

Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)
☐ Return To Client ☒ Disposal By Lab ☐ Archive For _____ Months

Deliverable Requested: I, II, III, IV, Other (specify)

Special Instructions/QC Requirements:

Empty Kit Relinquished by:	Date:	Time:	Method of Shipment:

Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company
Ian St. John	1/26/24		Penny Pehling Wright	01/30/24 0900	EEA
Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company
Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company

Custody Seals Intact: Δ Yes Δ No | Custody Seal No.: | Cooler Temperature(s) °C and Other Remarks:

Ver: 02/24/23

Eurofins Eaton Analyitcal: South Bend
110 South Hill Street
South Bend, IN 46617
Phone (574) 233-4777

Chain of Custody Record

Cross Offs on COC by Client

Eurofins | Environment Testing America

Client Information	Sampler: Ian St. John	Lab PM:	Carrier Tracking No(s):	COC No:
Client Contact: Jeff Morgan	Phone: 314-853-4668	E-Mail: ian@stjohnenv.com	State of Origin: MO	Page: Page 15 of 15
Company: Lebanon RIII School District	PWSID:			Job #:
Address: 224 W. Commercial Street	Due Date Requested:			
City: Lebanon	TAT Requested (days): Standard			
State, Zip: MO 65536	Compliance Project: Δ Yes Δ No			
Phone: 417-849-3330	PO #:			
Email: Jeff.morgan@lebanon.k12.mo.us	WO #:			
Project Name: Lebanon RIII School District	Project #:			
Site: Lebanon Highschool	SSOW#:			

Analysis Requested

Preservation Codes:

A - HCL, B - NaOH, C - Zn Acetate, D - Nitric Acid, E - NaHSO4, F - MeOH, G - Amchlor, H - Ascorbic Acid, I - Ice, J - DI Water, K - EDTA, L - EDA, M - Hexane, N - None, O - AsNaO2, P - Na2O4S, Q - Na2SO3, R - Na2S2O3, S - H2SO4, T - TSP Dodecahydrate, U - Acetone, V - MCAA, W - pH 4-5, Y - Trizma, Z - other (specify)

Other:

Sample Identification	Sample Date	Sample Time	Sample Type (C=Comp, G=grab)	Matrix (W=water, S=solid, O=waste/oil, BT=Tissue, A=Air)	Lead In Drinking Water	Total Number of containers	Special Instructions/Note:
			Preservation Code:				
LHS-155 WF	1/26/24	0830	G	W	X		
LHS-156 SINK	↓	↓	↓	↓	↓		
LHS-157 WF	↓	↓	↓	↓	↓		
LHS-158 WF	↓	↓	↓	↓	↓		
LHS-159 SINK	↓	↓	↓	↓	↓		
LHS-160 SINK	↓	↓	↓	↓	↓		
LHS-161 ICE	↓	↓	↓	↓	↓		
LHS-162 ICE	↓	↓	↓	↓	↓		

Possible Hazard Identification
☐ Non-Hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☒ Unknown ☐ Radiological

Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)
☐ Return To Client ☒ Disposal By Lab ☐ Archive For _____ Months

Deliverable Requested: I, II, III, IV, Other (specify)

Special Instructions/QC Requirements:

Empty Kit Relinquished by:	Date:	Time:	Method of Shipment:

Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company
Ian St. John	1/26/24		Penny Pebley Wright	01/30/24 0900	EEA
Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company
Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company

Custody Seals Intact: Δ Yes Δ No | Custody Seal No.: | Cooler Temperature(s) °C and Other Remarks:

Ver: 02/24/23

Login Sample Receipt Checklist

Client: St. John Environmental Consulting

Job Number: 810-91973-1

Login Number: 91973

List Source: Eurofins Eaton Analytical South Bend

List Number: 1

Creator: Pehling-Wright, Penny

Question	Answer	Comment
The cooler's custody seal, if present, is intact.	True	
Sample custody seals, if present, are intact.	True	
Samples were received on ice.	False	Thermal preservation not required.
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	True	
Samples do not require splitting or compositing.	True	
Container provided by EEA	True	