eurofins | Environment Testing

ANALYTICAL REPORT

PREPARED FOR

Attn: Ian St. John
St. John Environmental Consulting
5515 Grace Ave.
Saint Louis, Missouri 63116

Generated 2/5/2024 11:28:17 PM

JOB DESCRIPTION

Lebanon RIII School Dist.-Labanon Tech&Career Cntr

JOB NUMBER

810-92069-1

Eurofins Eaton Analytical South Bend
110 S Hill Street
South Bend IN 46617

See page two for job notes and contact information.

myEOL

Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and will meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All questions should be directed to the Eurofins Eaton Analytical, LLC Project Manager.

Authorization



Generated
2/5/2024 11:28:17 PM

Authorized for release by
Pamela Brown, Project Manager
Pamela.Brown@et.eurofinsus.com
(574)233-4777

Table of Contents

Cover Page 1
Table of Contents 3
Definitions/Glossary 4
Case Narrative 5
Detection Summary 6
Client Sample Results 10
QC Sample Results 17
QC Association Summary 21
Lab Chronicle 23
Certification Summary 30
Method Summary 31
Sample Summary 32
Chain of Custody 33
Receipt Checklists 38

Definitions/Glossary

Client: St. John Environmental Consulting
Job ID: 810-92069-1
Project/Site: Lebanon RIII School Dist.-Labanon Tech&Career Cntr

Qualifiers

Metals

Qualifier	Qualifier Description
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
¤	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

Job ID: 810-92069-1 Eurofins Eaton Analytical South Bend

Job Narrative
810-92069-1

Analytical test results meet all requirements of the associated regulatory program listed on the Accreditation/Certification Summary Page unless otherwise noted under the individual analysis. Data qualifiers are applied to indicate exceptions. Noncompliant quality control (QC) is further explained in narrative comments.

- Matrix QC may not be reported if insufficient sample or site-specific QC samples were not submitted. In these situations, to demonstrate precision and accuracy at a batch level, a LCS/LCSD may be performed, unless otherwise specified in the method.
- Surrogate and/or isotope dilution analyte recoveries (if applicable) which are outside of the QC window are confirmed unless attributed to a dilution or otherwise noted in the narrative.

Regulated compliance samples (e.g. SDWA, NPDES) must comply with the associated agency requirements/permits.

Receipt
The samples were received on 1/30/2024 9:00 AM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice.

Metals
No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Detection Summary

Client: St. John Environmental Consulting
Project/Site: Lebanon RIII School Dist.-Labanon Tech&Career Cntr

Job ID: 810-92069-1

Client Sample ID: LTCC-1 Sink — Lab Sample ID: 810-92069-1

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.7		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LTCC-2 Sink — Lab Sample ID: 810-92069-2

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.1		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LTCC-3 Sink — Lab Sample ID: 810-92069-3

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	75		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LTCC-4 Sink — Lab Sample ID: 810-92069-4

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	8.2		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LTCC-5 Sink — Lab Sample ID: 810-92069-5

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.4		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LTCC-6 Sink — Lab Sample ID: 810-92069-6

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	2.1		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LTCC-7 WF — Lab Sample ID: 810-92069-7

No Detections.

Client Sample ID: LTCC-8 WF — Lab Sample ID: 810-92069-8

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.0		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LTCC-9 Sink — Lab Sample ID: 810-92069-9

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	3.2		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LTCC-10 Sink — Lab Sample ID: 810-92069-10

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	3.3		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LTCC-11 Sink — Lab Sample ID: 810-92069-11

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	22		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LTCC-12 Sink — Lab Sample ID: 810-92069-12

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	6.0		0.50		ug/L	1		200.8	Total/NA

This Detection Summary does not include radiochemical test results.

Detection Summary

Client: St. John Environmental Consulting
Project/Site: Lebanon RIII School Dist.-Labanon Tech&Career Cntr

Job ID: 810-92069-1

Client Sample ID: LTCC-13 Sink — Lab Sample ID: 810-92069-13

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	4.0		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LTCC-14 Sink — Lab Sample ID: 810-92069-14

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.9		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LTCC-15 Sink — Lab Sample ID: 810-92069-15

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	5.2		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LTCC-16 Sink — Lab Sample ID: 810-92069-16

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	2.6		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LTCC-17 WF — Lab Sample ID: 810-92069-17

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	5.3		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LTCC-18 Sink — Lab Sample ID: 810-92069-18

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	12		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LTCC-19 Sink — Lab Sample ID: 810-92069-19

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	5.7		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LTCC-20 Sink — Lab Sample ID: 810-92069-20

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	9.5		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LTCC-21 Sink — Lab Sample ID: 810-92069-21

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	4.5		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LTCC-22 Sink — Lab Sample ID: 810-92069-22

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	17		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LTCC-23 Sink — Lab Sample ID: 810-92069-23

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	4.7		0.50		ug/L	1		200.8	Total/NA

This Detection Summary does not include radiochemical test results.

Detection Summary

Client: St. John Environmental Consulting
Project/Site: Lebanon RIII School Dist.-Labanon Tech&Career Cntr

Job ID: 810-92069-1

Client Sample ID: LTCC-24 Sink — Lab Sample ID: 810-92069-24

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	2.9		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LTCC-25 WF — Lab Sample ID: 810-92069-25

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.2		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LTCC-26 Sink — Lab Sample ID: 810-92069-26

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	11		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LTCC-27 Sink — Lab Sample ID: 810-92069-27

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	9.2		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LTCC-28 Sink — Lab Sample ID: 810-92069-28

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	3.9		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LTCC-29 Sink — Lab Sample ID: 810-92069-29

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	3.4		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LTCC-30 Sink — Lab Sample ID: 810-92069-30

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	16		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LTCC-31 Sink — Lab Sample ID: 810-92069-31

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	7.0		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LTCC-32 Sink — Lab Sample ID: 810-92069-32

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	12		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LTCC-33 Sink — Lab Sample ID: 810-92069-33

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.7		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LTCC-34 Sink — Lab Sample ID: 810-92069-34

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	7.1		0.50		ug/L	1		200.8	Total/NA

This Detection Summary does not include radiochemical test results.

Detection Summary

Client: St. John Environmental Consulting
Job ID: 810-92069-1
Project/Site: Lebanon RIII School Dist.-Labanon Tech&Career Cntr

Client Sample ID: LTCC-35 WF — Lab Sample ID: 810-92069-35

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	0.71		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LTCC-36 Sink — Lab Sample ID: 810-92069-36

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.8		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LTCC-37 Sink — Lab Sample ID: 810-92069-37

No Detections.

Client Sample ID: LTCC-38 Sink — Lab Sample ID: 810-92069-38

No Detections.

Client Sample ID: LTCC-39 Sink — Lab Sample ID: 810-92069-39

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.9		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LTCC-40 Sink — Lab Sample ID: 810-92069-40

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.2		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LTCC-41 Sink — Lab Sample ID: 810-92069-41

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	1.4		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LTCC-42 Sink — Lab Sample ID: 810-92069-42

No Detections.

Client Sample ID: LTCC-43 Sink — Lab Sample ID: 810-92069-43

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	2.6		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LTCC-44 Sink — Lab Sample ID: 810-92069-44

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Lead	29		0.50		ug/L	1		200.8	Total/NA

Client Sample ID: LTCC-45 Sink — Lab Sample ID: 810-92069-45

No Detections.

Client Sample ID: LTCC-46 WF — Lab Sample ID: 810-92069-46

No Detections.

Client Sample ID: LTCC-47 Sink — Lab Sample ID: 810-92069-47

No Detections.

This Detection Summary does not include radiochemical test results.

Client: St. John Environmental Consulting
Job ID: 810-92069-1
Project/Site: Lebanon RIII School Dist.-Labanon Tech&Career Cntr

Client Sample ID: LTCC-1 Sink
Lab Sample ID: 810-92069-1
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.7		0.50		ug/L			02/02/24 12:52	1

Client Sample ID: LTCC-2 Sink
Lab Sample ID: 810-92069-2
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.1		0.50		ug/L			02/02/24 12:54	1

Client Sample ID: LTCC-3 Sink
Lab Sample ID: 810-92069-3
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	75		0.50		ug/L			02/02/24 12:55	1

Client Sample ID: LTCC-4 Sink
Lab Sample ID: 810-92069-4
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	8.2		0.50		ug/L			02/02/24 12:57	1

Client Sample ID: LTCC-5 Sink
Lab Sample ID: 810-92069-5
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.4		0.50		ug/L			02/02/24 12:58	1

Client Sample ID: LTCC-6 Sink
Lab Sample ID: 810-92069-6
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.1		0.50		ug/L			02/02/24 13:00	1

Client Sample ID: LTCC-7 WF
Lab Sample ID: 810-92069-7
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/02/24 13:10	1

Client: St. John Environmental Consulting
Job ID: 810-92069-1
Project/Site: Lebanon RIII School Dist.-Labanon Tech&Career Cntr

Client Sample ID: LTCC-8 WF
Lab Sample ID: 810-92069-8
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.0		0.50		ug/L			02/02/24 13:12	1

Client Sample ID: LTCC-9 Sink
Lab Sample ID: 810-92069-9
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.2		0.50		ug/L			02/02/24 13:17	1

Client Sample ID: LTCC-10 Sink
Lab Sample ID: 810-92069-10
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.3		0.50		ug/L			02/02/24 13:18	1

Client Sample ID: LTCC-11 Sink
Lab Sample ID: 810-92069-11
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	22		0.50		ug/L			02/05/24 07:30	1

Client Sample ID: LTCC-12 Sink
Lab Sample ID: 810-92069-12
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	6.0		0.50		ug/L			02/05/24 07:31	1

Client Sample ID: LTCC-13 Sink
Lab Sample ID: 810-92069-13
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	4.0		0.50		ug/L			02/05/24 07:33	1

Client Sample ID: LTCC-14 Sink
Lab Sample ID: 810-92069-14
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.9		0.50		ug/L			02/05/24 07:34	1

Client: St. John Environmental Consulting
Job ID: 810-92069-1
Project/Site: Lebanon RIII School Dist.-Labanon Tech&Career Cntr

Client Sample ID: LTCC-15 Sink
Lab Sample ID: 810-92069-15
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	5.2		0.50		ug/L			02/05/24 07:39	1

Client Sample ID: LTCC-16 Sink
Lab Sample ID: 810-92069-16
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.6		0.50		ug/L			02/05/24 07:41	1

Client Sample ID: LTCC-17 WF
Lab Sample ID: 810-92069-17
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	5.3		0.50		ug/L			02/05/24 07:45	1

Client Sample ID: LTCC-18 Sink
Lab Sample ID: 810-92069-18
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	12		0.50		ug/L			02/05/24 07:47	1

Client Sample ID: LTCC-19 Sink
Lab Sample ID: 810-92069-19
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	5.7		0.50		ug/L			02/05/24 07:48	1

Client Sample ID: LTCC-20 Sink
Lab Sample ID: 810-92069-20
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	9.5		0.50		ug/L			02/05/24 07:50	1

Client Sample ID: LTCC-21 Sink
Lab Sample ID: 810-92069-21
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	4.5		0.50		ug/L			02/05/24 07:51	1

Client: St. John Environmental Consulting
Job ID: 810-92069-1
Project/Site: Lebanon RIII School Dist.-Labanon Tech&Career Cntr

Client Sample ID: LTCC-22 Sink
Lab Sample ID: 810-92069-22
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	17		0.50		ug/L			02/05/24 07:53	1

Client Sample ID: LTCC-23 Sink
Lab Sample ID: 810-92069-23
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	4.7		0.50		ug/L			02/05/24 07:54	1

Client Sample ID: LTCC-24 Sink
Lab Sample ID: 810-92069-24
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	2.9		0.50		ug/L			02/05/24 07:56	1

Client Sample ID: LTCC-25 WF
Lab Sample ID: 810-92069-25
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.2		0.50		ug/L			02/05/24 08:04	1

Client Sample ID: LTCC-26 Sink
Lab Sample ID: 810-92069-26
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	11		0.50		ug/L			02/05/24 08:05	1

Client Sample ID: LTCC-27 Sink
Lab Sample ID: 810-92069-27
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	9.2		0.50		ug/L			02/05/24 08:07	1

Client Sample ID: LTCC-28 Sink
Lab Sample ID: 810-92069-28
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.9		0.50		ug/L			02/05/24 08:11	1

Client: St. John Environmental Consulting
Job ID: 810-92069-1
Project/Site: Lebanon RIII School Dist.-Labanon Tech&Career Cntr

Client Sample ID: LTCC-29 Sink
Lab Sample ID: 810-92069-29
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	3.4		0.50		ug/L			02/05/24 08:13	1

Client Sample ID: LTCC-30 Sink
Lab Sample ID: 810-92069-30
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	16		0.50		ug/L			02/05/24 08:14	1

Client Sample ID: LTCC-31 Sink
Lab Sample ID: 810-92069-31
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	7.0		0.50		ug/L			02/05/24 08:16	1

Client Sample ID: LTCC-32 Sink
Lab Sample ID: 810-92069-32
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	12		0.50		ug/L			02/05/24 08:18	1

Client Sample ID: LTCC-33 Sink
Lab Sample ID: 810-92069-33
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.7		0.50		ug/L			02/05/24 08:19	1

Client Sample ID: LTCC-34 Sink
Lab Sample ID: 810-92069-34
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	7.1		0.50		ug/L			02/05/24 08:21	1

Client Sample ID: LTCC-35 WF
Lab Sample ID: 810-92069-35
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	0.71		0.50		ug/L			02/05/24 08:25	1

Client: St. John Environmental Consulting
Job ID: 810-92069-1
Project/Site: Lebanon RIII School Dist.-Labanon Tech&Career Cntr

Client Sample ID: LTCC-36 Sink
Lab Sample ID: 810-92069-36
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.8		0.50		ug/L			02/05/24 08:27	1

Client Sample ID: LTCC-37 Sink
Lab Sample ID: 810-92069-37
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/05/24 08:28	1

Client Sample ID: LTCC-38 Sink
Lab Sample ID: 810-92069-38
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/05/24 08:30	1

Client Sample ID: LTCC-39 Sink
Lab Sample ID: 810-92069-39
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.9		0.50		ug/L			02/05/24 08:34	1

Client Sample ID: LTCC-40 Sink
Lab Sample ID: 810-92069-40
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.2		0.50		ug/L			02/05/24 08:36	1

Client Sample ID: LTCC-41 Sink
Lab Sample ID: 810-92069-41
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	1.4		0.50		ug/L			02/05/24 08:38	1

Client Sample ID: LTCC-42 Sink
Lab Sample ID: 810-92069-42
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/05/24 08:39	1

Client: St. John Environmental Consulting
Job ID: 810-92069-1
Project/Site: Lebanon RIII School Dist.-Labanon Tech&Career Cntr

Client Sample ID: LTCC-43 Sink
Lab Sample ID: 810-92069-43
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	**2.6**		0.50		ug/L			02/05/24 08:41	1

Client Sample ID: LTCC-44 Sink
Lab Sample ID: 810-92069-44
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	**29**		0.50		ug/L			02/05/24 08:42	1

Client Sample ID: LTCC-45 Sink
Lab Sample ID: 810-92069-45
Date Collected: 01/26/24 09:10
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/05/24 08:50	1

Client Sample ID: LTCC-46 WF
Lab Sample ID: 810-92069-46
Date Collected: 01/26/24 09:10
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/05/24 08:51	1

Client Sample ID: LTCC-47 Sink
Lab Sample ID: 810-92069-47
Date Collected: 01/26/24 09:10
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/05/24 08:56	1

Client: St. John Environmental Consulting
Job ID: 810-92069-1
Project/Site: Lebanon RIII School Dist.-Labanon Tech&Career Cntr

Method: 200.8 - Metals (ICP/MS)

Lab Sample ID: MB 810-87581/11
Matrix: Drinking Water
Analysis Batch: 87581
Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/02/24 09:16	1

Lab Sample ID: MB 810-87581/131
Matrix: Drinking Water
Analysis Batch: 87581
Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/02/24 12:21	1

Lab Sample ID: MB 810-87581/161
Matrix: Drinking Water
Analysis Batch: 87581
Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/02/24 13:07	1

Lab Sample ID: LCS 810-87581/132
Matrix: Drinking Water
Analysis Batch: 87581
Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	50.0	51.4		ug/L		103	85 - 115

Lab Sample ID: LCS 810-87581/162
Matrix: Drinking Water
Analysis Batch: 87581
Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	50.0	51.6		ug/L		103	85 - 115

Lab Sample ID: LLCS 810-87581/10
Matrix: Drinking Water
Analysis Batch: 87581
Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LLCS Result	LLCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	0.300	0.313	J	ug/L		104	50 - 150

Lab Sample ID: 810-92069-6 MS
Matrix: Drinking Water
Analysis Batch: 87581
Client Sample ID: LTCC-6 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	2.1		50.0	54.0		ug/L		104	70 - 130

Method: 200.8 - Metals (ICP/MS) (Continued)

Lab Sample ID: 810-92069-6 MSD
Matrix: Drinking Water
Analysis Batch: 87581

Client Sample ID: LTCC-6 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Lead	2.1		50.0	54.1		ug/L		104	70 - 130	0	20

Lab Sample ID: 810-92069-8 MS
Matrix: Drinking Water
Analysis Batch: 87581

Client Sample ID: LTCC-8 WF
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	1.0		50.0	52.8		ug/L		103	70 - 130

Lab Sample ID: 810-92069-8 MSD
Matrix: Drinking Water
Analysis Batch: 87581

Client Sample ID: LTCC-8 WF
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Lead	1.0		50.0	51.9		ug/L		102	70 - 130	2	20

Lab Sample ID: MB 810-87664/11
Matrix: Drinking Water
Analysis Batch: 87664

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/05/24 07:14	1

Lab Sample ID: MB 810-87664/41
Matrix: Drinking Water
Analysis Batch: 87664

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/05/24 08:01	1

Lab Sample ID: MB 810-87664/71
Matrix: Drinking Water
Analysis Batch: 87664

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Lead	<0.50		0.50		ug/L			02/05/24 08:47	1

Lab Sample ID: LCS 810-87664/12
Matrix: Drinking Water
Analysis Batch: 87664

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	50.0	53.3		ug/L		107	85 - 115

Method: 200.8 - Metals (ICP/MS) (Continued)

Lab Sample ID: LCS 810-87664/42
Matrix: Drinking Water
Analysis Batch: 87664

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	50.0	52.4		ug/L		105	85 - 115

Lab Sample ID: LCS 810-87664/72
Matrix: Drinking Water
Analysis Batch: 87664

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	50.0	51.0		ug/L		102	85 - 115

Lab Sample ID: LLCS 810-87664/10
Matrix: Drinking Water
Analysis Batch: 87664

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LLCS Result	LLCS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	0.300	0.310	J	ug/L		103	50 - 150

Lab Sample ID: 810-92069-16 MS
Matrix: Drinking Water
Analysis Batch: 87664

Client Sample ID: LTCC-16 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	2.6		50.0	53.6		ug/L		102	70 - 130

Lab Sample ID: 810-92069-16 MSD
Matrix: Drinking Water
Analysis Batch: 87664

Client Sample ID: LTCC-16 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Lead	2.6		50.0	53.2		ug/L		101	70 - 130	1	20

Lab Sample ID: 810-92069-27 MS
Matrix: Drinking Water
Analysis Batch: 87664

Client Sample ID: LTCC-27 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Lead	9.2		50.0	59.4		ug/L		100	70 - 130

Lab Sample ID: 810-92069-27 MSD
Matrix: Drinking Water
Analysis Batch: 87664

Client Sample ID: LTCC-27 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Lead	9.2		50.0	59.6		ug/L		101	70 - 130	0	20

Client: St. John Environmental Consulting
Job ID: 810-92069-1
Project/Site: Lebanon RIII School Dist.-Labanon Tech&Career Cntr

Method: 200.8 - Metals (ICP/MS) (Continued)

Lab Sample ID: 810-92069-38 MS
Matrix: Drinking Water
Analysis Batch: 87664

Client Sample ID: LTCC-38 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits		
Lead	<0.50		50.0	51.0		ug/L		101	70 - 130		

Lab Sample ID: 810-92069-38 MSD
Matrix: Drinking Water
Analysis Batch: 87664

Client Sample ID: LTCC-38 Sink
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Lead	<0.50		50.0	51.2		ug/L		102	70 - 130	0	20

Lab Sample ID: 810-92069-46 MS
Matrix: Drinking Water
Analysis Batch: 87664

Client Sample ID: LTCC-46 WF
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits		
Lead	<0.50		50.0	51.6		ug/L		102	70 - 130		

Lab Sample ID: 810-92069-46 MSD
Matrix: Drinking Water
Analysis Batch: 87664

Client Sample ID: LTCC-46 WF
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Lead	<0.50		50.0	51.3		ug/L		102	70 - 130	1	20

Metals

Analysis Batch: 87581

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
810-92069-1	LTCC-1 Sink	Total/NA	Drinking Water	200.8	
810-92069-2	LTCC-2 Sink	Total/NA	Drinking Water	200.8	
810-92069-3	LTCC-3 Sink	Total/NA	Drinking Water	200.8	
810-92069-4	LTCC-4 Sink	Total/NA	Drinking Water	200.8	
810-92069-5	LTCC-5 Sink	Total/NA	Drinking Water	200.8	
810-92069-6	LTCC-6 Sink	Total/NA	Drinking Water	200.8	
810-92069-7	LTCC-7 WF	Total/NA	Drinking Water	200.8	
810-92069-8	LTCC-8 WF	Total/NA	Drinking Water	200.8	
810-92069-9	LTCC-9 Sink	Total/NA	Drinking Water	200.8	
810-92069-10	LTCC-10 Sink	Total/NA	Drinking Water	200.8	
MB 810-87581/11	Method Blank	Total/NA	Drinking Water	200.8	
MB 810-87581/131	Method Blank	Total/NA	Drinking Water	200.8	
MB 810-87581/161	Method Blank	Total/NA	Drinking Water	200.8	
LCS 810-87581/132	Lab Control Sample	Total/NA	Drinking Water	200.8	
LCS 810-87581/162	Lab Control Sample	Total/NA	Drinking Water	200.8	
LLCS 810-87581/10	Lab Control Sample	Total/NA	Drinking Water	200.8	
810-92069-6 MS	LTCC-6 Sink	Total/NA	Drinking Water	200.8	
810-92069-6 MSD	LTCC-6 Sink	Total/NA	Drinking Water	200.8	
810-92069-8 MS	LTCC-8 WF	Total/NA	Drinking Water	200.8	
810-92069-8 MSD	LTCC-8 WF	Total/NA	Drinking Water	200.8	

Analysis Batch: 87664

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
810-92069-11	LTCC-11 Sink	Total/NA	Drinking Water	200.8	
810-92069-12	LTCC-12 Sink	Total/NA	Drinking Water	200.8	
810-92069-13	LTCC-13 Sink	Total/NA	Drinking Water	200.8	
810-92069-14	LTCC-14 Sink	Total/NA	Drinking Water	200.8	
810-92069-15	LTCC-15 Sink	Total/NA	Drinking Water	200.8	
810-92069-16	LTCC-16 Sink	Total/NA	Drinking Water	200.8	
810-92069-17	LTCC-17 WF	Total/NA	Drinking Water	200.8	
810-92069-18	LTCC-18 Sink	Total/NA	Drinking Water	200.8	
810-92069-19	LTCC-19 Sink	Total/NA	Drinking Water	200.8	
810-92069-20	LTCC-20 Sink	Total/NA	Drinking Water	200.8	
810-92069-21	LTCC-21 Sink	Total/NA	Drinking Water	200.8	
810-92069-22	LTCC-22 Sink	Total/NA	Drinking Water	200.8	
810-92069-23	LTCC-23 Sink	Total/NA	Drinking Water	200.8	
810-92069-24	LTCC-24 Sink	Total/NA	Drinking Water	200.8	
810-92069-25	LTCC-25 WF	Total/NA	Drinking Water	200.8	
810-92069-26	LTCC-26 Sink	Total/NA	Drinking Water	200.8	
810-92069-27	LTCC-27 Sink	Total/NA	Drinking Water	200.8	
810-92069-28	LTCC-28 Sink	Total/NA	Drinking Water	200.8	
810-92069-29	LTCC-29 Sink	Total/NA	Drinking Water	200.8	
810-92069-30	LTCC-30 Sink	Total/NA	Drinking Water	200.8	
810-92069-31	LTCC-31 Sink	Total/NA	Drinking Water	200.8	
810-92069-32	LTCC-32 Sink	Total/NA	Drinking Water	200.8	
810-92069-33	LTCC-33 Sink	Total/NA	Drinking Water	200.8	
810-92069-34	LTCC-34 Sink	Total/NA	Drinking Water	200.8	
810-92069-35	LTCC-35 WF	Total/NA	Drinking Water	200.8	
810-92069-36	LTCC-36 Sink	Total/NA	Drinking Water	200.8	
810-92069-37	LTCC-37 Sink	Total/NA	Drinking Water	200.8	

Metals (Continued)

Analysis Batch: 87664 (Continued)

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
810-92069-38	LTCC-38 Sink	Total/NA	Drinking Water	200.8	
810-92069-39	LTCC-39 Sink	Total/NA	Drinking Water	200.8	
810-92069-40	LTCC-40 Sink	Total/NA	Drinking Water	200.8	
810-92069-41	LTCC-41 Sink	Total/NA	Drinking Water	200.8	
810-92069-42	LTCC-42 Sink	Total/NA	Drinking Water	200.8	
810-92069-43	LTCC-43 Sink	Total/NA	Drinking Water	200.8	
810-92069-44	LTCC-44 Sink	Total/NA	Drinking Water	200.8	
810-92069-45	LTCC-45 Sink	Total/NA	Drinking Water	200.8	
810-92069-46	LTCC-46 WF	Total/NA	Drinking Water	200.8	
810-92069-47	LTCC-47 Sink	Total/NA	Drinking Water	200.8	
MB 810-87664/11	Method Blank	Total/NA	Drinking Water	200.8	
MB 810-87664/41	Method Blank	Total/NA	Drinking Water	200.8	
MB 810-87664/71	Method Blank	Total/NA	Drinking Water	200.8	
LCS 810-87664/12	Lab Control Sample	Total/NA	Drinking Water	200.8	
LCS 810-87664/42	Lab Control Sample	Total/NA	Drinking Water	200.8	
LCS 810-87664/72	Lab Control Sample	Total/NA	Drinking Water	200.8	
LLCS 810-87664/10	Lab Control Sample	Total/NA	Drinking Water	200.8	
810-92069-16 MS	LTCC-16 Sink	Total/NA	Drinking Water	200.8	
810-92069-16 MSD	LTCC-16 Sink	Total/NA	Drinking Water	200.8	
810-92069-27 MS	LTCC-27 Sink	Total/NA	Drinking Water	200.8	
810-92069-27 MSD	LTCC-27 Sink	Total/NA	Drinking Water	200.8	
810-92069-38 MS	LTCC-38 Sink	Total/NA	Drinking Water	200.8	
810-92069-38 MSD	LTCC-38 Sink	Total/NA	Drinking Water	200.8	
810-92069-46 MS	LTCC-46 WF	Total/NA	Drinking Water	200.8	
810-92069-46 MSD	LTCC-46 WF	Total/NA	Drinking Water	200.8	

Lab Chronicle

Client: St. John Environmental Consulting
Job ID: 810-92069-1
Project/Site: Lebanon RIII School Dist.-Labanon Tech&Career Cntr

Client Sample ID: LTCC-1 Sink
Lab Sample ID: 810-92069-1
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87581	CA	EA SB	02/02/24 12:52

Client Sample ID: LTCC-2 Sink
Lab Sample ID: 810-92069-2
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87581	CA	EA SB	02/02/24 12:54

Client Sample ID: LTCC-3 Sink
Lab Sample ID: 810-92069-3
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87581	CA	EA SB	02/02/24 12:55

Client Sample ID: LTCC-4 Sink
Lab Sample ID: 810-92069-4
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87581	CA	EA SB	02/02/24 12:57

Client Sample ID: LTCC-5 Sink
Lab Sample ID: 810-92069-5
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87581	CA	EA SB	02/02/24 12:58

Client Sample ID: LTCC-6 Sink
Lab Sample ID: 810-92069-6
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87581	CA	EA SB	02/02/24 13:00

Client Sample ID: LTCC-7 WF
Lab Sample ID: 810-92069-7
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87581	CA	EA SB	02/02/24 13:10

Lab Chronicle

Client: St. John Environmental Consulting
Project/Site: Lebanon RIII School Dist.-Labanon Tech&Career Cntr

Job ID: 810-92069-1

Client Sample ID: LTCC-8 WF

Lab Sample ID: 810-92069-8
Matrix: Drinking Water
Date Collected: 01/26/24 09:00
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87581	CA	EA SB	02/02/24 13:12

Client Sample ID: LTCC-9 Sink

Lab Sample ID: 810-92069-9
Matrix: Drinking Water
Date Collected: 01/26/24 09:00
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87581	CA	EA SB	02/02/24 13:17

Client Sample ID: LTCC-10 Sink

Lab Sample ID: 810-92069-10
Matrix: Drinking Water
Date Collected: 01/26/24 09:00
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87581	CA	EA SB	02/02/24 13:18

Client Sample ID: LTCC-11 Sink

Lab Sample ID: 810-92069-11
Matrix: Drinking Water
Date Collected: 01/26/24 09:00
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87664	NB	EA SB	02/05/24 07:30

Client Sample ID: LTCC-12 Sink

Lab Sample ID: 810-92069-12
Matrix: Drinking Water
Date Collected: 01/26/24 09:00
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87664	NB	EA SB	02/05/24 07:31

Client Sample ID: LTCC-13 Sink

Lab Sample ID: 810-92069-13
Matrix: Drinking Water
Date Collected: 01/26/24 09:00
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87664	NB	EA SB	02/05/24 07:33

Client Sample ID: LTCC-14 Sink

Lab Sample ID: 810-92069-14
Matrix: Drinking Water
Date Collected: 01/26/24 09:00
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87664	NB	EA SB	02/05/24 07:34

Lab Chronicle

Client: St. John Environmental Consulting
Job ID: 810-92069-1
Project/Site: Lebanon RIII School Dist.-Labanon Tech&Career Cntr

Client Sample ID: LTCC-15 Sink
Lab Sample ID: 810-92069-15
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87664	NB	EA SB	02/05/24 07:39

Client Sample ID: LTCC-16 Sink
Lab Sample ID: 810-92069-16
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87664	NB	EA SB	02/05/24 07:41

Client Sample ID: LTCC-17 WF
Lab Sample ID: 810-92069-17
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87664	NB	EA SB	02/05/24 07:45

Client Sample ID: LTCC-18 Sink
Lab Sample ID: 810-92069-18
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87664	NB	EA SB	02/05/24 07:47

Client Sample ID: LTCC-19 Sink
Lab Sample ID: 810-92069-19
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87664	NB	EA SB	02/05/24 07:48

Client Sample ID: LTCC-20 Sink
Lab Sample ID: 810-92069-20
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87664	NB	EA SB	02/05/24 07:50

Client Sample ID: LTCC-21 Sink
Lab Sample ID: 810-92069-21
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87664	NB	EA SB	02/05/24 07:51

Lab Chronicle

Client: St. John Environmental Consulting
Project/Site: Lebanon RIII School Dist.-Labanon Tech&Career Cntr

Job ID: 810-92069-1

Client Sample ID: LTCC-22 Sink
Date Collected: 01/26/24 09:00
Date Received: 01/30/24 09:00

Lab Sample ID: 810-92069-22
Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87664	NB	EA SB	02/05/24 07:53

Client Sample ID: LTCC-23 Sink
Date Collected: 01/26/24 09:00
Date Received: 01/30/24 09:00

Lab Sample ID: 810-92069-23
Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87664	NB	EA SB	02/05/24 07:54

Client Sample ID: LTCC-24 Sink
Date Collected: 01/26/24 09:00
Date Received: 01/30/24 09:00

Lab Sample ID: 810-92069-24
Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87664	NB	EA SB	02/05/24 07:56

Client Sample ID: LTCC-25 WF
Date Collected: 01/26/24 09:00
Date Received: 01/30/24 09:00

Lab Sample ID: 810-92069-25
Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87664	NB	EA SB	02/05/24 08:04

Client Sample ID: LTCC-26 Sink
Date Collected: 01/26/24 09:00
Date Received: 01/30/24 09:00

Lab Sample ID: 810-92069-26
Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87664	NB	EA SB	02/05/24 08:05

Client Sample ID: LTCC-27 Sink
Date Collected: 01/26/24 09:00
Date Received: 01/30/24 09:00

Lab Sample ID: 810-92069-27
Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87664	NB	EA SB	02/05/24 08:07

Client Sample ID: LTCC-28 Sink
Date Collected: 01/26/24 09:00
Date Received: 01/30/24 09:00

Lab Sample ID: 810-92069-28
Matrix: Drinking Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87664	NB	EA SB	02/05/24 08:11

Lab Chronicle

Client: St. John Environmental Consulting
Project/Site: Lebanon RIII School Dist.-Labanon Tech&Career Cntr

Job ID: 810-92069-1

Client Sample ID: LTCC-29 Sink
Lab Sample ID: 810-92069-29
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87664	NB	EA SB	02/05/24 08:13

Client Sample ID: LTCC-30 Sink
Lab Sample ID: 810-92069-30
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87664	NB	EA SB	02/05/24 08:14

Client Sample ID: LTCC-31 Sink
Lab Sample ID: 810-92069-31
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87664	NB	EA SB	02/05/24 08:16

Client Sample ID: LTCC-32 Sink
Lab Sample ID: 810-92069-32
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87664	NB	EA SB	02/05/24 08:18

Client Sample ID: LTCC-33 Sink
Lab Sample ID: 810-92069-33
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87664	NB	EA SB	02/05/24 08:19

Client Sample ID: LTCC-34 Sink
Lab Sample ID: 810-92069-34
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87664	NB	EA SB	02/05/24 08:21

Client Sample ID: LTCC-35 WF
Lab Sample ID: 810-92069-35
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87664	NB	EA SB	02/05/24 08:25

Lab Chronicle

Client: St. John Environmental Consulting
Project/Site: Lebanon RIII School Dist.-Labanon Tech&Career Cntr

Job ID: 810-92069-1

Client Sample ID: LTCC-36 Sink
Lab Sample ID: 810-92069-36
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87664	NB	EA SB	02/05/24 08:27

Client Sample ID: LTCC-37 Sink
Lab Sample ID: 810-92069-37
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87664	NB	EA SB	02/05/24 08:28

Client Sample ID: LTCC-38 Sink
Lab Sample ID: 810-92069-38
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87664	NB	EA SB	02/05/24 08:30

Client Sample ID: LTCC-39 Sink
Lab Sample ID: 810-92069-39
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87664	NB	EA SB	02/05/24 08:34

Client Sample ID: LTCC-40 Sink
Lab Sample ID: 810-92069-40
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87664	NB	EA SB	02/05/24 08:36

Client Sample ID: LTCC-41 Sink
Lab Sample ID: 810-92069-41
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87664	NB	EA SB	02/05/24 08:38

Client Sample ID: LTCC-42 Sink
Lab Sample ID: 810-92069-42
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87664	NB	EA SB	02/05/24 08:39

Lab Chronicle

Client: St. John Environmental Consulting
Job ID: 810-92069-1
Project/Site: Lebanon RIII School Dist.-Labanon Tech&Career Cntr

Client Sample ID: LTCC-43 Sink
Lab Sample ID: 810-92069-43
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87664	NB	EA SB	02/05/24 08:41

Client Sample ID: LTCC-44 Sink
Lab Sample ID: 810-92069-44
Date Collected: 01/26/24 09:00
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87664	NB	EA SB	02/05/24 08:42

Client Sample ID: LTCC-45 Sink
Lab Sample ID: 810-92069-45
Date Collected: 01/26/24 09:10
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87664	NB	EA SB	02/05/24 08:50

Client Sample ID: LTCC-46 WF
Lab Sample ID: 810-92069-46
Date Collected: 01/26/24 09:10
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87664	NB	EA SB	02/05/24 08:51

Client Sample ID: LTCC-47 Sink
Lab Sample ID: 810-92069-47
Date Collected: 01/26/24 09:10
Matrix: Drinking Water
Date Received: 01/30/24 09:00

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	200.8		1	87664	NB	EA SB	02/05/24 08:56

Laboratory References:

EA SB = Eurofins Eaton Analytical South Bend, 110 S Hill Street, South Bend, IN 46617, TEL (574)233-4777

Accreditation/Certification Summary

Client: St. John Environmental Consulting
Job ID: 810-92069-1
Project/Site: Lebanon RIII School Dist.-Labanon Tech&Career Cntr

Laboratory: Eurofins Eaton Analytical South Bend

The accreditations/certifications listed below are applicable to this report.

Authority	Program	Identification Number	Expiration Date
Missouri	State	880	09-30-24

Method Summary

Client: St. John Environmental Consulting
Job ID: 810-92069-1
Project/Site: Lebanon RIII School Dist.-Labanon Tech&Career Cntr

Method	Method Description	Protocol	Laboratory
200.8	Metals (ICP/MS)	EPA	EA SB

Protocol References:

EPA = US Environmental Protection Agency

Laboratory References:

EA SB = Eurofins Eaton Analytical South Bend, 110 S Hill Street, South Bend, IN 46617, TEL (574)233-4777

Sample Summary

Client: St. John Environmental Consulting
Job ID: 810-92069-1
Project/Site: Lebanon RIII School Dist.-Labanon Tech&Career Cntr

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
810-92069-1	LTCC-1 Sink	Drinking Water	01/26/24 09:00	01/30/24 09:00
810-92069-2	LTCC-2 Sink	Drinking Water	01/26/24 09:00	01/30/24 09:00
810-92069-3	LTCC-3 Sink	Drinking Water	01/26/24 09:00	01/30/24 09:00
810-92069-4	LTCC-4 Sink	Drinking Water	01/26/24 09:00	01/30/24 09:00
810-92069-5	LTCC-5 Sink	Drinking Water	01/26/24 09:00	01/30/24 09:00
810-92069-6	LTCC-6 Sink	Drinking Water	01/26/24 09:00	01/30/24 09:00
810-92069-7	LTCC-7 WF	Drinking Water	01/26/24 09:00	01/30/24 09:00
810-92069-8	LTCC-8 WF	Drinking Water	01/26/24 09:00	01/30/24 09:00
810-92069-9	LTCC-9 Sink	Drinking Water	01/26/24 09:00	01/30/24 09:00
810-92069-10	LTCC-10 Sink	Drinking Water	01/26/24 09:00	01/30/24 09:00
810-92069-11	LTCC-11 Sink	Drinking Water	01/26/24 09:00	01/30/24 09:00
810-92069-12	LTCC-12 Sink	Drinking Water	01/26/24 09:00	01/30/24 09:00
810-92069-13	LTCC-13 Sink	Drinking Water	01/26/24 09:00	01/30/24 09:00
810-92069-14	LTCC-14 Sink	Drinking Water	01/26/24 09:00	01/30/24 09:00
810-92069-15	LTCC-15 Sink	Drinking Water	01/26/24 09:00	01/30/24 09:00
810-92069-16	LTCC-16 Sink	Drinking Water	01/26/24 09:00	01/30/24 09:00
810-92069-17	LTCC-17 WF	Drinking Water	01/26/24 09:00	01/30/24 09:00
810-92069-18	LTCC-18 Sink	Drinking Water	01/26/24 09:00	01/30/24 09:00
810-92069-19	LTCC-19 Sink	Drinking Water	01/26/24 09:00	01/30/24 09:00
810-92069-20	LTCC-20 Sink	Drinking Water	01/26/24 09:00	01/30/24 09:00
810-92069-21	LTCC-21 Sink	Drinking Water	01/26/24 09:00	01/30/24 09:00
810-92069-22	LTCC-22 Sink	Drinking Water	01/26/24 09:00	01/30/24 09:00
810-92069-23	LTCC-23 Sink	Drinking Water	01/26/24 09:00	01/30/24 09:00
810-92069-24	LTCC-24 Sink	Drinking Water	01/26/24 09:00	01/30/24 09:00
810-92069-25	LTCC-25 WF	Drinking Water	01/26/24 09:00	01/30/24 09:00
810-92069-26	LTCC-26 Sink	Drinking Water	01/26/24 09:00	01/30/24 09:00
810-92069-27	LTCC-27 Sink	Drinking Water	01/26/24 09:00	01/30/24 09:00
810-92069-28	LTCC-28 Sink	Drinking Water	01/26/24 09:00	01/30/24 09:00
810-92069-29	LTCC-29 Sink	Drinking Water	01/26/24 09:00	01/30/24 09:00
810-92069-30	LTCC-30 Sink	Drinking Water	01/26/24 09:00	01/30/24 09:00
810-92069-31	LTCC-31 Sink	Drinking Water	01/26/24 09:00	01/30/24 09:00
810-92069-32	LTCC-32 Sink	Drinking Water	01/26/24 09:00	01/30/24 09:00
810-92069-33	LTCC-33 Sink	Drinking Water	01/26/24 09:00	01/30/24 09:00
810-92069-34	LTCC-34 Sink	Drinking Water	01/26/24 09:00	01/30/24 09:00
810-92069-35	LTCC-35 WF	Drinking Water	01/26/24 09:00	01/30/24 09:00
810-92069-36	LTCC-36 Sink	Drinking Water	01/26/24 09:00	01/30/24 09:00
810-92069-37	LTCC-37 Sink	Drinking Water	01/26/24 09:00	01/30/24 09:00
810-92069-38	LTCC-38 Sink	Drinking Water	01/26/24 09:00	01/30/24 09:00
810-92069-39	LTCC-39 Sink	Drinking Water	01/26/24 09:00	01/30/24 09:00
810-92069-40	LTCC-40 Sink	Drinking Water	01/26/24 09:00	01/30/24 09:00
810-92069-41	LTCC-41 Sink	Drinking Water	01/26/24 09:00	01/30/24 09:00
810-92069-42	LTCC-42 Sink	Drinking Water	01/26/24 09:00	01/30/24 09:00
810-92069-43	LTCC-43 Sink	Drinking Water	01/26/24 09:00	01/30/24 09:00
810-92069-44	LTCC-44 Sink	Drinking Water	01/26/24 09:00	01/30/24 09:00
810-92069-45	LTCC-45 Sink	Drinking Water	01/26/24 09:10	01/30/24 09:00
810-92069-46	LTCC-46 WF	Drinking Water	01/26/24 09:10	01/30/24 09:00
810-92069-47	LTCC-47 Sink	Drinking Water	01/26/24 09:10	01/30/24 09:00

Eurofins Eaton Analyitcal: South Bend
110 South Hill Street
South Bend, IN 46617
Phone (574) 233-4777

Chain of Custody Record

eurofins | Environment Testing America

105

Client Information	Sampler: Ian St. John	Lab PM:	Carrier Tracking No(s):	COC No:
Client Contact: Jeff Morgan	Phone: 314-853-4668	E-Mail: ian@stjohnenv.com	State of Origin: MO	Page: Page 1 of 5
Company: Lebanon RIII School District	PWSID:			Job #:
Address: 224 W. Commercial Street	Due Date Requested:			
City: Lebanon	TAT Requested (days): Standard			
State, Zip: MO 65536	Compliance Project: Δ Yes Δ No			
Phone: 417-849-3330	PO #:			
Email: Jeff.morgan@lebanon.k12.mo.us	WO #:			
Project Name: Lebanon RIII School District	Project #:			
Site: Lebanon Technology and Career Cntr.	SSOW#:			

Analysis Requested

810-92069 Chain of Custody

Preservation Codes:
A - HCL, B - NaOH, C - Zn Acetate, D - Nitric Acid, E - NaHSO4, F - MeOH, G - Amchlor, H - Ascorbic Acid, I - Ice, J - DI Water, K - EDTA, L - EDA, M - Hexane, N - None, O - AsNaO2, P - Na2O4S, Q - Na2SO3, R - Na2S2O3, S - H2SO4, T - TSP Dodecahydrate, U - Acetone, V - MCAA, W - pH 4-5, Y - Trizma, Z - other (specify)
Other:

Sample Identification	Sample Date	Sample Time	Sample Type (C=comp, G=grab)	Matrix (W=water, S=solid, O=waste/oil, BT=Tissue, A=Air)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Lead In Drinking Wat	Total Number of containers	Special Instructions/Note:
			Preservation Code:						
LTCC-1 SINK	1/26/24	0900	G	W			X		
LTCC-2 SINK									
LTCC-3 SINK									
LTCC-4 SINK									
LTCC-5 SINK									
LTCC-6 SINK									
LTCC-7 WF									
LTCC-8 WF									
LTCC-9 SINK									
LTCC-10									
LTCC-11									

Possible Hazard Identification
☐ Non-Hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☒ Unknown ☐ Radiological

Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)
☐ Return To Client ☒ Disposal By Lab ☐ Archive For _____ Months

Deliverable Requested: I, II, III, IV, Other (specify)

Special Instructions/QC Requirements:

Empty Kit Relinquished by: | Date: | Time: | Method of Shipment:

Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company
Ian St. John	1/26/24		Richard Hiles	1-30-24 900	

Custody Seals Intact: Δ Yes Δ No | Custody Seal No.: | Cooler Temperature(s) °C and Other Remarks:

Ver: 02/24/23

Eurofins Eaton Analyitcal: South Bend
110 South Hill Street
South Bend, IN 46617
Phone (574) 233-4777

Chain of Custody Record

eurofins | Environment Testing America

7125

Client Information	Sampler: Ian St. John	Lab PM:	Carrier Tracking No(s):	COC No:
Client Contact: Jeff Morgan	Phone: 314-853-4668	E-Mail: ian@stjohnenv.com	State of Origin: MO	Page: Page 2 of 5
Company: Lebanon RIII School District	PWSID:			Job #:
Address: 224 W. Commercial Street	Due Date Requested:			
City: Lebanon	TAT Requested (days): Standard			
State, Zip: MO 65536	Compliance Project: Δ Yes Δ No			
Phone: 417-849-3330	PO #:			
Email: Jeff.morgan@lebanon.k12.mo.us	WO #:			
Project Name: Lebanon RIII School District	Project #:			
Site: Lebanon Technology and Career Cntr.	SSOW#:			

Analysis Requested

Preservation Codes:
A - HCL, B - NaOH, C - Zn Acetate, D - Nitric Acid, E - NaHSO4, F - MeOH, G - Amchlor, H - Ascorbic Acid, I - Ice, J - DI Water, K - EDTA, L - EDA, M - Hexane, N - None, O - AsNaO2, P - Na2O4S, Q - Na2SO3, R - Na2S2O3, S - H2SO4, T - TSP Dodecahydrate, U - Acetone, V - MCAA, W - pH 4-5, Y - Trizma, Z - other (specify)
Other:

Sample Identification	Sample Date	Sample Time	Sample Type (C=comp, G=grab)	Matrix (W=water, S=solid, O=waste/oil, BT=Tissue, A=Air)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Lead In Drinking Water	Total Number of containers	Special Instructions/Note:
			Preservation Code:						
LTCC-12 Sink	1/26/24	0900	G	W			X		
LTCC-13									
LTCC-14									
LTCC-15									
LTCC-16									
LTCC-17 WF									
LTCC-18 Sink									
LTCC-19									
LTCC-20									
LTCC-21 Sink									
LTCC-22 Sink									

Possible Hazard Identification
☐ Non-Hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☒ Unknown ☐ Radiological

Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)
☐ Return To Client ☒ Disposal By Lab ☐ Archive For _____ Months

Deliverable Requested: I, II, III, IV, Other (specify)

Special Instructions/QC Requirements:

Empty Kit Relinquished by:	Date:	Time:	Method of Shipment:

Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company
Ian St. John	1/26/24			1-30-24 900	
Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company
Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company

Custody Seals Intact: Δ Yes Δ No | Custody Seal No.: | Cooler Temperature(s) °C and Other Remarks:

Ver: 02/24/23

Eurofins Eaton Analyitcal: South Bend
110 South Hill Street
South Bend, IN 46617
Phone (574) 233-4777

Chain of Custody Record

eurofins | Environment Testing America

7/25

Client Information	Sampler: Ian St. John	Lab PM:	Carrier Tracking No(s):	COC No:
Client Contact: Jeff Morgan	Phone: 314-853-4668	E-Mail: ian@stjohnenv.com	State of Origin: MO	Page: Page 3 of 5
Company: Lebanon RIII School District	PWSID:			Job #:
Address: 224 W. Commercial Street	Due Date Requested:			
City: Lebanon	TAT Requested (days): Standard			
State, Zip: MO 65536	Compliance Project: Δ Yes Δ No			
Phone: 417-849-3330	PO #:			
Email: Jeff.morgan@lebanon.k12.mo.us	WO #:			
Project Name: Lebanon RIII School District	Project #:			
Site: Lebanon Technology and Career Cntr.	SSOW#:			

Analysis Requested

Preservation Codes:
A - HCL, B - NaOH, C - Zn Acetate, D - Nitric Acid, E - NaHSO4, F - MeOH, G - Amchlor, H - Ascorbic Acid, I - Ice, J - DI Water, K - EDTA, L - EDA, M - Hexane, N - None, O - AsNaO2, P - Na2O4S, Q - Na2SO3, R - Na2S2O3, S - H2SO4, T - TSP Dodecahydrate, U - Acetone, V - MCAA, W - pH 4-5, Y - Trizma, Z - other (specify)
Other:

Sample Identification	Sample Date	Sample Time	Sample Type (C=Comp, G=grab)	Matrix (W=water, S=solid, O=waste/oil, BT=Tissue, A=Air)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Lead In Drinking Water	Total Number of containers	Special Instructions/Note:
			Preservation Code:						
LTCC_23 Sink	1/26/24	0900	G	W			X		
LTCC-24 Sink									
LTCC-25 WF									
LTCC-26 Sink									
LTCC-27									
LTCC-28									
LTCC-29 Sink									
LTCC-30 Sink									
LTCC-31									
LTCC-32									
LTCC-33									

Possible Hazard Identification
☐ Non-Hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☒ Unknown ☐ Radiological

Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)
☐ Return To Client ☒ Disposal By Lab ☐ Archive For _____ Months

Deliverable Requested: I, II, III, IV, Other (specify)

Special Instructions/QC Requirements:

Empty Kit Relinquished by:	Date:	Time:	Method of Shipment:

	Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company
1	Ian St. John	1/26/24		[illegible]	1.30.24 900A	
2						
3						

Custody Seals Intact: Δ Yes Δ No | Custody Seal No.: | Cooler Temperature(s) °C and Other Remarks:

Ver: 02/24/23

Eurofins Eaton Analyitcal: South Bend
110 South Hill Street
South Bend, IN 46617
Phone (574) 233-4777

Chain of Custody Record

eurofins | Environment Testing America

7125

Client Information	Sampler: Ian St. John	Lab PM:	Carrier Tracking No(s):	COC No:
Client Contact: Jeff Morgan	Phone: 314-853-4668	E-Mail: ian@stjohnenv.com	State of Origin: MO	Page: Page 4 of 5
Company: Lebanon RIII School District	PWSID:			Job #:
Address: 224 W. Commercial Street	Due Date Requested:			
City: Lebanon	TAT Requested (days): Standard			
State, Zip: MO 65536	Compliance Project: Δ Yes Δ No			
Phone: 417-849-3330	PO #:			
Email: Jeff.morgan@lebanon.k12.mo.us	WO #:			
Project Name: Lebanon RIII School District	Project #:			
Site: Lebanon Technology and Career Cntr.	SSOW#:			

Analysis Requested

Preservation Codes:
A - HCL, B - NaOH, C - Zn Acetate, D - Nitric Acid, E - NaHSO4, F - MeOH, G - Amchlor, H - Ascorbic Acid, I - Ice, J - DI Water, K - EDTA, L - EDA, M - Hexane, N - None, O - AsNaO2, P - Na2O4S, Q - Na2SO3, R - Na2S2O3, S - H2SO4, T - TSP Dodecahydrate, U - Acetone, V - MCAA, W - pH 4-5, Y - Trizma, Z - other (specify)
Other:

Sample Identification	Sample Date	Sample Time	Sample Type (C=comp, G=grab)	Matrix (W=water, S=solid, O=waste/oil, BT=Tissue, A=Air)	Field Filtered Sample - Perform MS/MSD (Yes or No)	Lead In Drinking Water	Total Number of containers	Special Instructions/Note:
			Preservation Code:					
LTCC-34 Sink	1/26/24	0900	G	W		X		
LTCC 35 WF								
LTCC 36 Sink								
LTCC 37								
LTCC 38								
LTCC 39								
LTCC 40								
LTCC 41								
LTCC 42								
LTCC- 43 Sink								
LTCC- 44 Sink								

Possible Hazard Identification
☐ Non-Hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☒ Unknown ☐ Radiological

Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)
☐ Return To Client ☒ Disposal By Lab ☐ Archive For _____ Months

Deliverable Requested: I, II, III, IV, Other (specify)

Special Instructions/QC Requirements:

Empty Kit Relinquished by:	Date:	Time:	Method of Shipment:

	Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company
1	Ian St. John	1/26/24		[illegible]	1.30.24 900	
2						
3						

Custody Seals Intact: Δ Yes Δ No	Custody Seal No.:	Cooler Temperature(s) °C and Other Remarks:

Ver: 02/24/23

Eurofins Eaton Analyitcal: South Bend
110 South Hill Street
South Bend, IN 46617
Phone (574) 233-4777

Chain of Custody Record

eurofins | Environment Testing America

7/25

Client Information	Sampler: Ian St. John	Lab PM:	Carrier Tracking No(s):	COC No:
Client Contact: Jeff Morgan	Phone: 314-853-4668	E-Mail: ian@stjohnenv.com	State of Origin:	Page: Page 5 of 5
Company: Lebanon R-III School Dist.	PWSID:	Analysis Requested		Job #:
Address: 224 W. Commercial Street	Due Date Requested:			Preservation Codes:
City: Lebanon	TAT Requested (days): Standard			A - HCL; B - NaOH; C - Zn Acetate; D - Nitric Acid; E - NaHSO4; F - MeOH; G - Amchlor; H - Ascorbic Acid; I - Ice; J - DI Water; K - EDTA; L - EDA; M - Hexane; N - None; O - AsNaO2; P - Na2O4S; Q - Na2SO3; R - Na2S2O3; S - H2SO4; T - TSP Dodecahydrate; U - Acetone; V - MCAA; W - pH 4-5; Y - Trizma; Z - other (specify); Other:
State, Zip: MO	Compliance Project: Δ Yes Δ No			
Phone: 417-849-3330	PO #:			
Email:	WO #:			
Project Name: Lebanon R-III School DRT--	Project #:			
Site: Lebanon Tech & Career Cntr	SSOW#:			

Sample Identification	Sample Date	Sample Time	Sample Type (C=comp, G=grab)	Matrix (W=water, S=solid, O=waste/oil, BT=Tissue, A=Air)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Pb in Drinking Water	Total Number of containers	Special Instructions/Note:
			Preservation Code:						
LTCC-45 SINK	1/26/24	0910	G	W			X		
LTCC-46 NF	↓	↓	↓	↓			↓		
LTCC-47 SINK	↓	↓	↓	↓			↓		

Possible Hazard Identification
☐ Non-Hazard ☐ Flammable ☐ Skin Irritant ☐ Poison B ☒ Unknown ☐ Radiological

Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)
☐ Return To Client ☒ Disposal By Lab ☐ Archive For _____ Months

Deliverable Requested: I, II, III, IV, Other (specify)

Special Instructions/QC Requirements:

Empty Kit Relinquished by:	Date:	Time:	Method of Shipment:

	Relinquished by	Date/Time	Company	Received by	Date/Time	Company
1		1/26/24			1.30.24 900	
2	Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company
3	Relinquished by:	Date/Time:	Company	Received by:	Date/Time:	Company

Custody Seals Intact: Δ Yes Δ No | Custody Seal No.: | Cooler Temperature(s) °C and Other Remarks:

Ver: 02/24/23

Login Sample Receipt Checklist

Client: St. John Environmental Consulting

Job Number: 810-92069-1

Login Number: 92069

List Source: Eurofins Eaton Analytical South Bend

List Number: 1

Creator: Alfred, Robbin

Question	Answer	Comment
The cooler's custody seal, if present, is intact.	True	
Sample custody seals, if present, are intact.	True	
Samples were received on ice.	True	
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	True	
Samples do not require splitting or compositing.	True	
Container provided by EEA	True	