

Results Summary Lead in Drinking Water Samples 2024-2025 SY

Lawnside Public Schools - Lawnside School

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
S-1	12-LPS-0911-01	Kitchen sink (near window)	1.24	No
S-2	12-LPS-0911-02	Kitchen sink (near door)	ND	No
S-3	12-LPS-0911-03	Kitchen Eye Wash Sink	3.20	No
IM-1	12-LPS-0911-04	Kitchen Ice Machine	ND	No
BB-1	12-LPS-0911-05	Hallway adj. MP Room; WF - Bubbler	ND	No
BB-2	12-LPS-0911-06	Hallway adj. MP Room; WF w/bottler filler - Bubbler	ND	No
BF-1	12-LPS-0911-07	Hallway adj. MP Room; WF w/bottler filler - Bottle filler	ND	No
WC-1	12-LPS-0911-08	Staff Lounge Water Cooler	ND	No
S-4	12-LPS-0911-09	Staff Lounge Sink	ND	No
BB-3	12-LPS-0911-10	Hallway in front of Staff Lounge; WF w/ bottle filler - Bubbler	ND	No
BF-2	12-LPS-0911-11	Hallway in front of Staff Lounge; WF w/ bottle filler - Bottle filler	ND	No
BB-4	12-LPS-0911-12	Hallway in front of Staff Lounge; WF - Bubbler	ND	No
BB-5	12-LPS-0911-13	Hallway by Conference Room; WF - Bubbler	ND	No
BB-6	12-LPS-0911-14	Hallway by Nurse's Office; WF - Bubbler	ND	No
BB-7	12-LPS-0911-15	Hallway by Nurse's Office; WF - Bubbler (Hand's Free)	ND	No
S-5	12-LPS-0911-16	Nurse's Office Sink	3.37	No
BB-8	12-LPS-0911-17	Hallway between Boys and Girls (Custodian Closet 2); WF w/ bottle filler - Bubbler	ND	No
BF-3	12-LPS-0911-18	Hallway between Boys and Girls (Custodian Closet 2); WF w/ bottle filler - Bottle filler	ND	No
BB-9	12-LPS-0911-19	Hallway between Boys and Girls (Custodian Closet 2); WF - Bubbler (hands free)	ND	No
BB-10	12-LPS-0911-20	Hallway between Boys and Girls (Custodian Closet 3) WF w/ bottle filler - Bubbler	ND	No

Action Level (AL) ≥15.5 parts per billion (ppb)

Results Summary Lead in Drinking Water Samples 2024-2025 SY

Lawnside Public Schools - Lawnside School

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
BF-4	12-LPS-0911-21	Hallway between Boys and Girls (Custodian Closet 3); WF w/ bottle filler - Bottle Filler	ND	No
BB-11	12-LPS-0911-22	Hallway between Boys and Girls (Custodian Closet 3); WF - Bubbler	ND	No
BB-12	12-LPS-0911-23	Room 120; WF - Bubbler	ND	No
BB-13	12-LPS-0911-24	Room 121; WF - Bubbler	ND	No
BB-14	12-LPS-0911-25	Hallway by Faculty Restroom; WF w/ bottle filler - Bubbler	ND	No
BF-5	12-LPS-0911-26	Hallway by Faculty Restroom; WF w/ bottle filler - Bottle filler	ND	No
S-6	12-LPS-0911-27	Trailer Teacher Lounge; Sink	ND	No
BB-15	12-LPS-0911-28	Trailer Hallway; WF w/ bottle filler - Bubbler	ND	No
BF-6	12-LPS-0911-29	Trailer Hallway; WF w/ bottle filler - Bottle Filler	ND	No
S-7	12-LPS-0911-30	Room 126; Sink (nearest entrance)	ND	No
S-8	12-LPS-0911-31	Room 126; Sink (furthest entrance)	2.69	No
S-9	12-LPS-0911-32	Room 127; Sink (nearest entrance)	ND	No
S-10	12-LPS-0911-33	Room 127; Sink (furthest entrance)	2.05	No
S-11	12-LPS-0911-34	Room 128; Sink (nearest entrance)	ND	No
S-12	12-LPS-0911-35	Room 128; Sink (furthest entrance)	2.59	No
S-13	12-LPS-0911-36	Room 129; Sink (nearest entrance)	ND	No
S-14	12-LPS-0911-37	Room 129; Sink (furthest entrance)	1.15	No
S-15	12-LPS-0911-38	Room 130; Sink (nearest entrance)	ND	No
S-16	12-LPS-0911-39	Room 130; Sink (furthest entrance)	1.08	No
S-17	12-LPS-0911-40	Room 131; Sink (nearest entrance)	ND	No

Action Level (AL) ≥15.5 parts per billion (ppb)

Results Summary Lead in Drinking Water Samples 2024-2025 SY

Lawnside Public Schools - Lawnside School

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
S-18	12-LPS-0911-41	Room 131; Sink (furthest entrance)	3.05	No

Action Level (AL) ≥15.5 parts per billion (ppb)

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012534564

LIMS Reference ID: AD34564

EMSL Customer ID: EDI50

Attention: Tim Gromen

Environmental Design, Inc. [EDI50]
5434 King Avenue, Suite 101
Pennsauken, NJ 08109
(856) 616-9516
tg@editesting.com

Project Name: Lead in Drinking Water 2024-2025
SY/PR-250909-1511/426 Charleston
Ave.,Lawnside,NJ 08045

Project ID: Lead in Drinking Water 2024-2025 SY

Customer PO:

Sales Rep: Sheryl Steinmetz

Received: 09/11/2025 10:30

Reported: 09/19/2025 12:57

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 12-LPS-0911-08/Staff Lounge Cooler (Continued) Lims Reference ID: AD34564-08 Matrix: Drinking Water Sampled: 09/11/25 06:19:00									
Metals (Continued)									
Lead	ND		1	1.00	µg/L	09/17/25 11:01	09/17/25 18:40	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 12-LPS-0911-09/Staff Lounge Sink Lims Reference ID: AD34564-09 Matrix: Drinking Water Sampled: 09/11/25 06:21:00									
Metals									
Lead	ND		1	1.00	µg/L	09/17/25 11:01	09/17/25 18:42	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 12-LPS-0911-10/Hallway in Front of Staff Lounge Water Fountain (w/ bottle filler attachment) Bubbler Lims Reference ID: AD34564-10 Matrix: Drinking Water Sampled: 09/11/25 06:23:00									
Metals									
Lead	ND		1	1.00	µg/L	09/17/25 11:01	09/17/25 18:44	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 12-LPS-0911-11/Hallway in Front of Staff Lounge Water Fountain (w/ bottle filler attachment) Bottle Filler Lims Reference ID: AD34564-11 Matrix: Drinking Water Sampled: 09/11/25 06:25:00									
Metals									
Lead	ND		1	1.00	µg/L	09/17/25 11:01	09/17/25 18:46	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 12-LPS-0911-12/Hallway in Front of Staff Lounge Water Fountain Bubbler Lims Reference ID: AD34564-12 Matrix: Drinking Water Sampled: 09/11/25 06:27:00									
Metals									
Lead	ND		1	1.00	µg/L	09/17/25 11:01	09/17/25 18:52	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 12-LPS-0911-13/Hallway by Conference Room Water Fountain Bubbler Lims Reference ID: AD34564-13 Matrix: Drinking Water Sampled: 09/11/25 06:29:00									
Metals									
Lead	ND		1	1.00	µg/L	09/17/25 11:01	09/17/25 18:54	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 12-LPS-0911-14/Hallway by Nurse's Office Water Fountain Bubbler Lims Reference ID: AD34564-14 Matrix: Drinking Water Sampled: 09/11/25 06:31:00									
Metals									
Lead	ND		1	1.00	µg/L	09/17/25 11:01	09/17/25 19:00	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012534564

LIMS Reference ID: AD34564

EMSL Customer ID: EDI50

Attention: Tim Gromen

Environmental Design, Inc. [EDI50]

5434 King Avenue, Suite 101

Pennsauken, NJ 08109

(856) 616-9516

tg@editesting.com

Project Name:

Lead in Drinking Water 2024-2025
SY/PR-250909-1511/426 Charleston
Ave.,Lawnside,NJ 08045

Project ID:

Lead in Drinking Water 2024-2025 SY

Customer PO:**Sales Rep:**

Sheryl Steinmetz

Received:

09/11/2025 10:30

Reported:

09/19/2025 12:57

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
---------	--------	---	----	----	-------	-----------------------	-----------------------	---------------------	----------------------------

Sample: 12-LPS-0911-15/Hallway by Nurse's Office
Water Fountain Bubbler (Hands Free)

Lims Reference ID: AD34564-15 Matrix: Drinking Water

Sampled: 09/11/25 06:33:00

Metals

Lead	ND	1	1.00	µg/L	09/17/25 11:01	09/17/25 19:02	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: 12-LPS-0911-16/Nurse's Office Sink

Lims Reference ID: AD34564-16 Matrix: Drinking Water

Sampled: 09/11/25 06:35:00

Metals

Lead	3.37	1	1.00	µg/L	09/17/25 11:01	09/17/25 19:04	PL	EPA 200.8 (DA)/EPA 200.8
------	------	---	------	------	----------------	----------------	----	--------------------------

Sample: 12-LPS-0911-17/Hallway between Boys and
Girls (Custodian Closet 2) Water Fountain
(w/ bottle filler attachment) Bubbler

Lims Reference ID: AD34564-17 Matrix: Drinking Water

Sampled: 09/11/25 06:37:00

Metals

Lead	ND	1	1.00	µg/L	09/17/25 11:01	09/17/25 19:07	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: 12-LPS-0911-18/Hallway between Boys and
Girls (Custodian Closet 2) Water Fountain
(w/ bottle filler attachment) Bottle Filler

Lims Reference ID: AD34564-18 Matrix: Drinking Water

Sampled: 09/11/25 06:39:00

Metals

Lead	ND	1	1.00	µg/L	09/17/25 11:01	09/17/25 19:09	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: 12-LPS-0911-19/Hallway between Boys and
Girls (Custodian Closet 2) Water Fountain
Bubbler (Hands Free)

Lims Reference ID: AD34564-19 Matrix: Drinking Water

Sampled: 09/11/25 06:41:00

Metals

Lead	ND	1	1.00	µg/L	09/17/25 11:01	09/17/25 19:11	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: 12-LPS-0911-20/Hallway between Boys and
Girls (Custodian Closet 3) Water Fountain
(w/ bottle filler attachment) Bubbler

Lims Reference ID: AD34564-20 Matrix: Drinking Water

Sampled: 09/11/25 06:43:00

Metals

Lead	ND	1	1.00	µg/L	09/17/25 11:01	09/17/25 19:13	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: 12-LPS-0911-21/Hallway between Boys and
Girls (Custodian Closet 3) Water Fountain
(w/ bottle filler attachment) Bottle Filler

Lims Reference ID: AD34564-21 Matrix: Drinking Water

Sampled: 09/11/25 06:45:00

Metals

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012534564

LIMS Reference ID: AD34564

EMSL Customer ID: EDI50

Attention: Tim Gromen

Environmental Design, Inc. [EDI50]
5434 King Avenue, Suite 101
Pennsauken, NJ 08109
(856) 616-9516
tg@editesting.com

Project Name: Lead in Drinking Water 2024-2025
SY/PR-250909-1511/426 Charleston
Ave.,Lawnside,NJ 08045

Project ID: Lead in Drinking Water 2024-2025 SY

Customer PO:

Sales Rep: Sheryl Steinmetz

Received: 09/11/2025 10:30

Reported: 09/19/2025 12:57

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
---------	--------	---	----	----	-------	-----------------------	-----------------------	---------------------	----------------------------

Sample: 12-LPS-0911-21/Hallway between Boys and Girls (Custodian Closet 3) Water Fountain (w/ bottle filler attachment) Bottle Filler (Continued) Lims Reference ID: AD34564-21 Matrix: Drinking Water Sampled: 09/11/25 06:45:00

Metals (Continued)

Lead	ND	1	1.00	µg/L	09/17/25 17:18	09/17/25 17:51	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: 12-LPS-0911-22/Hallway between Boys and Girls (Custodian Closet 3) Water Fountain Bubbler Lims Reference ID: AD34564-22 Matrix: Drinking Water Sampled: 09/11/25 06:47:00

Metals

Lead	ND	1	1.00	µg/L	09/17/25 11:06	09/17/25 19:31	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: 12-LPS-0911-23/Room 120 Water Fountain Bubbler Lims Reference ID: AD34564-23 Matrix: Drinking Water Sampled: 09/11/25 06:49:00

Metals

Lead	ND	1	1.00	µg/L	09/17/25 11:06	09/17/25 19:40	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: 12-LPS-0911-24/Room 121 Water Fountain Bubbler Lims Reference ID: AD34564-24 Matrix: Drinking Water Sampled: 09/11/25 06:51:00

Metals

Lead	ND	1	1.00	µg/L	09/17/25 11:06	09/17/25 19:42	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: 12-LPS-0911-25/Hallway by Faculty Restroom Water Fountain (w/ bottle filler attachment) Bubbler Lims Reference ID: AD34564-25 Matrix: Drinking Water Sampled: 09/11/25 06:53:00

Metals

Lead	ND	1	1.00	µg/L	09/17/25 11:06	09/17/25 19:44	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: 12-LPS-0911-26/Hallway by Faculty Restroom Water Fountain (w/ bottle filler attachment) Bottle Filler Lims Reference ID: AD34564-26 Matrix: Drinking Water Sampled: 09/11/25 06:55:00

Metals

Lead	ND	1	1.00	µg/L	09/17/25 11:06	09/17/25 19:46	PL	EPA 200.8 (DA)/EPA 200.8
------	----	---	------	------	----------------	----------------	----	--------------------------

Sample: 12-LPS-0911-27/Trailer Teacher Lounge Sink Lims Reference ID: AD34564-27 Matrix: Drinking Water Sampled: 09/11/25 06:57:00

Metals



EMSL Analytical, Inc.
200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012534564
LIMS Reference ID: AD34564
EMSL Customer ID: EDI50

Attention: Tim Gromen
Environmental Design, Inc. [EDI50]
5434 King Avenue, Suite 101
Pennsauken, NJ 08109
(856) 616-9516
tg@editesting.com

Project Name: Lead in Drinking Water 2024-2025
SY/PR-250909-1511/426 Charleston
Ave,Lawnside,NJ 08045
Project ID: Lead in Drinking Water 2024-2025 SY
Customer PO:
Sales Rep: Sheryl Steinmetz
Received: 09/11/2025 10:30
Reported: 09/19/2025 12:57

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 12-LPS-0911-27/Trailer Teacher Lounge Sink (Continued) Lims Reference ID: AD34564-27 Matrix: Drinking Water Sampled: 09/11/25 06:57:00									
Metals (Continued)									
Lead	ND		1	1.00	µg/L	09/17/25 11:06	09/17/25 19:52	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 12-LPS-0911-28/Trailer Hallway Water Fountain (w/ bottle filler attachment) Bubbler Lims Reference ID: AD34564-28 Matrix: Drinking Water Sampled: 09/11/25 06:59:00									
Metals									
Lead	ND		1	1.00	µg/L	09/17/25 11:06	09/17/25 19:54	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 12-LPS-0911-29/Trailer Hallway Water Fountain (w/ bottle filler attachment) Bottle Filler Lims Reference ID: AD34564-29 Matrix: Drinking Water Sampled: 09/11/25 07:01:00									
Metals									
Lead	ND		1	1.00	µg/L	09/17/25 11:06	09/17/25 19:56	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 12-LPS-0911-30/Room 126 Sink (nearest entrance) Lims Reference ID: AD34564-30 Matrix: Drinking Water Sampled: 09/11/25 07:03:00									
Metals									
Lead	ND		1	1.00	µg/L	09/17/25 11:06	09/17/25 19:58	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 12-LPS-0911-31/Room 126 Sink (furthest entrance) Lims Reference ID: AD34564-31 Matrix: Drinking Water Sampled: 09/11/25 07:05:00									
Metals									
Lead	2.69		1	1.00	µg/L	09/17/25 11:06	09/17/25 20:00	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 12-LPS-0911-32/Room 127 Sink (nearest entrance) Lims Reference ID: AD34564-32 Matrix: Drinking Water Sampled: 09/11/25 07:07:00									
Metals									
Lead	ND		1	1.00	µg/L	09/17/25 11:06	09/17/25 20:02	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 12-LPS-0911-33/Room 127 Sink (furthest entrance) Lims Reference ID: AD34564-33 Matrix: Drinking Water Sampled: 09/11/25 07:09:00									
Metals									
Lead	2.05		1	1.00	µg/L	09/17/25 11:06	09/17/25 20:08	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012534564

LIMS Reference ID: AD34564

EMSL Customer ID: EDI50

Attention: Tim Gromen

Environmental Design, Inc. [EDI50]

5434 King Avenue, Suite 101

Pennsauken, NJ 08109

(856) 616-9516

tg@editesting.com

Project Name:

Lead in Drinking Water 2024-2025
SY/PR-250909-1511/426 Charleston
Ave.,Lawnside,NJ 08045

Project ID:

Lead in Drinking Water 2024-2025 SY

Customer PO:**Sales Rep:**

Sheryl Steinmetz

Received:

09/11/2025 10:30

Reported:

09/19/2025 12:57

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 12-LPS-0911-34/Room 128 Sink (nearest entrance) Lims Reference ID: AD34564-34 Matrix: Drinking Water Sampled: 09/11/25 07:11:00									
Metals									
Lead	ND		1	1.00	µg/L	09/17/25 11:06	09/17/25 20:10	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 12-LPS-0911-35/Room 128 Sink (furthest entrance) Lims Reference ID: AD34564-35 Matrix: Drinking Water Sampled: 09/11/25 07:13:00									
Metals									
Lead	2.59		1	1.00	µg/L	09/17/25 11:06	09/17/25 20:16	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 12-LPS-0911-36/Room 129 Sink (nearest entrance) Lims Reference ID: AD34564-36 Matrix: Drinking Water Sampled: 09/11/25 07:15:00									
Metals									
Lead	ND		1	1.00	µg/L	09/17/25 11:06	09/17/25 20:18	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 12-LPS-0911-37/Room 129 Sink (furthest entrance) Lims Reference ID: AD34564-37 Matrix: Drinking Water Sampled: 09/11/25 07:17:00									
Metals									
Lead	1.15		1	1.00	µg/L	09/17/25 11:06	09/17/25 20:20	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 12-LPS-0911-38/Room 130 Sink (nearest entrance) Lims Reference ID: AD34564-38 Matrix: Drinking Water Sampled: 09/11/25 07:19:00									
Metals									
Lead	ND		1	1.00	µg/L	09/17/25 11:06	09/17/25 20:22	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 12-LPS-0911-39/Room 130 Sink (furthest entrance) Lims Reference ID: AD34564-39 Matrix: Drinking Water Sampled: 09/11/25 07:21:00									
Metals									
Lead	1.08		1	1.00	µg/L	09/17/25 11:06	09/17/25 20:25	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 12-LPS-0911-40/Room 131 Sink (nearest entrance) Lims Reference ID: AD34564-40 Matrix: Drinking Water Sampled: 09/11/25 07:23:00									
Metals									
Lead	ND		1	1.00	µg/L	09/17/25 11:06	09/17/25 20:27	PL	EPA 200.8 (DA)/EPA 200.8



EMSL Analytical, Inc.
200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012534564
LIMS Reference ID: AD34564
EMSL Customer ID: EDI50

Attention: Tim Gromen
Environmental Design, Inc. [EDI50]
5434 King Avenue, Suite 101
Pennsauken, NJ 08109
(856) 616-9516
tg@editesting.com

Project Name: Lead in Drinking Water 2024-2025
SY/PR-250909-1511/426 Charleston
Ave,Lawnside,NJ 08045
Project ID: Lead in Drinking Water 2024-2025 SY
Customer PO:
Sales Rep: Sheryl Steinmetz
Received: 09/11/2025 10:30
Reported: 09/19/2025 12:57

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 12-LPS-0911-41/Room 131 Sink (furthest entrance) Lims Reference ID: AD34564-41 Matrix: Drinking Water Sampled: 09/11/25 07:25:00									
Metals									
Lead	3.05		1	1.00	µg/L	09/17/25 11:06	09/17/25 20:29	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012534564**LIMS Reference ID:** AD34564**EMSL Customer ID:** EDI50**Attention:** Tim Gromen

Environmental Design, Inc. [EDI50]
5434 King Avenue, Suite 101
Pennsauken, NJ 08109
(856) 616-9516
tg@editesting.com

Project Name:

Lead in Drinking Water 2024-2025
SY/PR-250909-1511/426 Charleston
Ave,Lawnside,NJ 08045

Project ID:

Lead in Drinking Water 2024-2025 SY

Customer PO:**Sales Rep:**

Sheryl Steinmetz

Received:

09/11/2025 10:30

Reported:

09/19/2025 12:57

Certified Analyses included in this Report

Analyte	Certifications
<i>EPA 200.8 in Drinking Water</i>	
Lead	NJDEP

List of Certifications

Code	Description	Number	Expires
PADEP	Pennsylvania Department of Environmental Protection	2845.25	11/30/2025
NYSDOH	New York State Department of Health ELAP	10872	04/01/2026
NJDEP	New Jersey Department of Environmental Protection	03036	06/30/2026
MADEP	Massachusetts Department of Environmental Protection	M-NJ337	06/30/2026
CTDPH	Connecticut Department of Public Health	PH-0270	06/30/2026
California ELAP	California Water Boards	1877	06/30/2026
AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC)	100194	04/01/2027
A2LA	A2LA Environmental Certificate	2845.01	07/31/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax: cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012534564**LIMS Reference ID:** AD34564**EMSL Customer ID:** EDI50**Attention:** Tim Gromen

Environmental Design, Inc. [EDI50]
5434 King Avenue, Suite 101
Pennsauken, NJ 08109
(856) 616-9516
tg@editesting.com

Project Name:

Lead in Drinking Water 2024-2025
SY/PR-250909-1511/426 Charleston
Ave., Lawnside, NJ 08045

Project ID:

Lead in Drinking Water 2024-2025 SY

Customer PO:**Sales Rep:**

Sheryl Steinmetz

Received:

09/11/2025 10:30

Reported:

09/19/2025 12:57

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

Owen McKenna Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.