

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012531010

LIMS Reference ID: AD31010

EMSL Customer ID: CLCS25

Attention: Brian Logel

Clarence Central Schools [CLCS25]
9600 Clarence Center Road
Clarence Center, NY 14032
(716) 407-9131
blogel@clarenceschools.org

Project Name: Clarence CSD - Sheridan Hill Elementary (SH)**Project ID:** _Master Project-CLCS25**Customer PO:****Sales Rep:** David Prince**Received:** 08/12/2025 10:15**Reported:** 08/26/2025 16:49**Analytical Results**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SH-001/Main Office Lav Sink Lims Reference ID: AD31010-01 Matrix: Drinking Water Sampled: 06/18/25 06:00:00									
Metals									
Lead	8.19		1	1.00	µg/L	08/14/25 11:51	08/21/25 11:55	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-002/Nurse Sink Lims Reference ID: AD31010-02 Matrix: Drinking Water Sampled: 06/18/25 06:00:00									
Metals									
Lead	1.02		1	1.00	µg/L	08/14/25 11:51	08/21/25 12:01	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-003/103 Work RM; Lav Sink Lims Reference ID: AD31010-03 Matrix: Drinking Water Sampled: 06/18/25 06:00:00									
Metals									
Lead	4.58		1	1.00	µg/L	08/14/25 11:51	08/21/25 12:03	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-004/Media Work Rm 401 Sink Lims Reference ID: AD31010-04 Matrix: Drinking Water Sampled: 06/18/25 06:00:00									
Metals									
Lead	2.66		1	1.00	µg/L	08/14/25 11:51	08/21/25 12:05	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-005/110 Sink Left Lav Lims Reference ID: AD31010-05 Matrix: Drinking Water Sampled: 06/18/25 06:00:00									
Metals									
Lead	3.84		1	1.00	µg/L	08/14/25 11:51	08/21/25 12:07	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-006/110 Sink Right Lims Reference ID: AD31010-06 Matrix: Drinking Water Sampled: 06/18/25 06:00:00									
Metals									
Lead	5.23		1	1.00	µg/L	08/14/25 11:51	08/21/25 12:13	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-007/112 Sink Left Lav Lims Reference ID: AD31010-07 Matrix: Drinking Water Sampled: 06/18/25 06:00:00									
Metals									
Lead	3.20		1	1.00	µg/L	08/14/25 11:51	08/21/25 12:14	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-008/112 Sink Right Lims Reference ID: AD31010-08 Matrix: Drinking Water Sampled: 06/18/25 06:00:00									
Metals									
Lead	5.37		1	1.00	µg/L	08/14/25 11:51	08/21/25 12:16	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-009/113 Sink Lims Reference ID: AD31010-09 Matrix: Drinking Water Sampled: 06/18/25 06:00:00									
Metals									

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012531010

LIMS Reference ID: AD31010

EMSL Customer ID: CLCS25

Attention: Brian Logel

Clarence Central Schools [CLCS25]
9600 Clarence Center Road
Clarence Center, NY 14032
(716) 407-9131
blogel@clarenceschools.org

Project Name: Clarence CSD - Sheridan Hill Elementary (SH)**Project ID:** _Master Project-CLCS25**Customer PO:****Sales Rep:** David Prince**Received:** 08/12/2025 10:15**Reported:** 08/26/2025 16:49**Analytical Results**
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
---------	--------	---	----	----	-------	--------------------	--------------------	------------------	-------------------------

Sample: SH-009/113 Sink (Continued)

Lims Reference ID: AD31010-09 Matrix: Drinking Water

Sampled: 06/18/25 06:00:00

Metals (Continued)

Lead	4.98		1	1.00	µg/L	08/13/25 16:30	08/21/25 11:06	PL	EPA 200.8 (DA)/EPA 200.8
------	------	--	---	------	------	----------------	----------------	----	--------------------------

Sample: SH-010/113 Lav Sink

Lims Reference ID: AD31010-10 Matrix: Drinking Water

Sampled: 06/18/25 06:00:00

Metals

Lead	5.75		1	1.00	µg/L	08/14/25 11:51	08/21/25 12:18	PL	EPA 200.8 (DA)/EPA 200.8
------	------	--	---	------	------	----------------	----------------	----	--------------------------

Sample: SH-011/114 Sink Left

Lims Reference ID: AD31010-11 Matrix: Drinking Water

Sampled: 06/18/25 06:30:00

Metals

Lead	4.82		1	1.00	µg/L	08/13/25 16:30	08/21/25 11:08	PL	EPA 200.8 (DA)/EPA 200.8
------	------	--	---	------	------	----------------	----------------	----	--------------------------

Sample: SH-012/114 Sink Right

Lims Reference ID: AD31010-12 Matrix: Drinking Water

Sampled: 06/18/25 06:30:00

Metals

Lead	8.41		1	1.00	µg/L	08/14/25 11:51	08/21/25 12:20	PL	EPA 200.8 (DA)/EPA 200.8
------	------	--	---	------	------	----------------	----------------	----	--------------------------

Sample: SH-013/115 Sink Left Lav

Lims Reference ID: AD31010-13 Matrix: Drinking Water

Sampled: 06/18/25 06:30:00

Metals

Lead	7.59		1	1.00	µg/L	08/14/25 11:51	08/21/25 12:22	PL	EPA 200.8 (DA)/EPA 200.8
------	------	--	---	------	------	----------------	----------------	----	--------------------------

Sample: SH-014/115 Sink Right

Lims Reference ID: AD31010-14 Matrix: Drinking Water

Sampled: 06/18/25 06:30:00

Metals

Lead	3.39		1	1.00	µg/L	08/14/25 11:51	08/21/25 12:28	PL	EPA 200.8 (DA)/EPA 200.8
------	------	--	---	------	------	----------------	----------------	----	--------------------------

Sample: SH-015/116 Sink Left

Lims Reference ID: AD31010-15 Matrix: Drinking Water

Sampled: 06/18/25 06:30:00

Metals

Lead	6.65		1	1.00	µg/L	08/14/25 11:51	08/21/25 12:29	PL	EPA 200.8 (DA)/EPA 200.8
------	------	--	---	------	------	----------------	----------------	----	--------------------------

Sample: SH-016/116 Sink Right

Lims Reference ID: AD31010-16 Matrix: Drinking Water

Sampled: 06/18/25 06:30:00

Metals

Lead	4.80		1	1.00	µg/L	08/14/25 11:51	08/21/25 12:35	PL	EPA 200.8 (DA)/EPA 200.8
------	------	--	---	------	------	----------------	----------------	----	--------------------------

Sample: SH-017/117 Sink Left Lav

Lims Reference ID: AD31010-17 Matrix: Drinking Water

Sampled: 06/18/25 06:30:00

Metals

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012531010

LIMS Reference ID: AD31010

EMSL Customer ID: CLCS25

Attention: Brian Logel

Clarence Central Schools [CLCS25]
9600 Clarence Center Road
Clarence Center, NY 14032
(716) 407-9131
blogel@clarenceschools.org

Project Name: Clarence CSD - Sheridan Hill Elementary (SH)**Project ID:** _Master Project-CLCS25**Customer PO:****Sales Rep:** David Prince**Received:** 08/12/2025 10:15**Reported:** 08/26/2025 16:49**Analytical Results**
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SH-017/117 Sink Left Lav (Continued) Lims Reference ID: AD31010-17 Matrix: Drinking Water Sampled: 06/18/25 06:30:00									
Metals (Continued)									
Lead	5.31		1	1.00	µg/L	08/14/25 11:51	08/21/25 12:37	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-018/117 Sink Right Lims Reference ID: AD31010-18 Matrix: Drinking Water Sampled: 06/18/25 06:30:00									
Metals									
Lead	7.56		1	1.00	µg/L	08/14/25 11:51	08/21/25 12:39	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-019/118 Sink Left Lav Lims Reference ID: AD31010-19 Matrix: Drinking Water Sampled: 06/18/25 06:30:00									
Metals									
Lead	3.45		1	1.00	µg/L	08/14/25 11:51	08/21/25 12:41	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-020/118 Sink Right Lims Reference ID: AD31010-20 Matrix: Drinking Water Sampled: 06/18/25 06:30:00									
Metals									
Lead	3.63		1	1.00	µg/L	08/14/25 11:51	08/21/25 12:43	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-021/119 Sink Left Lav Lims Reference ID: AD31010-21 Matrix: Drinking Water Sampled: 06/18/25 07:00:00									
Metals									
Lead	5.85		1	1.00	µg/L	08/14/25 11:51	08/21/25 12:45	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-022/119 Sink Right Lims Reference ID: AD31010-22 Matrix: Drinking Water Sampled: 06/18/25 07:00:00									
Metals									
Lead	5.31		1	1.00	µg/L	08/14/25 11:51	08/21/25 12:46	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-023/121 Sink Left Lav Lims Reference ID: AD31010-23 Matrix: Drinking Water Sampled: 06/18/25 07:00:00									
Metals									
Lead	5.82		1	1.00	µg/L	08/14/25 11:56	08/21/25 12:58	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-024/121 Sink Right Lims Reference ID: AD31010-24 Matrix: Drinking Water Sampled: 06/18/25 07:00:00									
Metals									
Lead	5.63		1	1.00	µg/L	08/14/25 11:56	08/21/25 13:03	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-025/123 Sink Lims Reference ID: AD31010-25 Matrix: Drinking Water Sampled: 06/18/25 07:00:00									
Metals									

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012531010

LIMS Reference ID: AD31010

EMSL Customer ID: CLCS25

Attention: Brian Logel

Clarence Central Schools [CLCS25]
9600 Clarence Center Road
Clarence Center, NY 14032
(716) 407-9131
blogel@clarenceschools.org

Project Name: Clarence CSD - Sheridan Hill Elementary (SH)**Project ID:** _Master Project-CLCS25**Customer PO:****Sales Rep:** David Prince**Received:** 08/12/2025 10:15**Reported:** 08/26/2025 16:49**Analytical Results**
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SH-025/123 Sink (Continued) Lims Reference ID: AD31010-25 Matrix: Drinking Water Sampled: 06/18/25 07:00:00									
Metals (Continued)									
Lead	1.28		1	1.00	µg/L	08/14/25 11:56	08/21/25 13:05	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-026/Bottle Filler by 201 Lims Reference ID: AD31010-26 Matrix: Drinking Water Sampled: 06/18/25 07:00:00									
Metals									
Lead	ND		1	1.00	µg/L	08/14/25 11:56	08/21/25 13:07	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-027/Girls Gang Lav Sink #1 Left Lims Reference ID: AD31010-27 Matrix: Drinking Water Sampled: 06/18/25 07:00:00									
Metals									
Lead	1.74		1	1.00	µg/L	08/14/25 11:56	08/21/25 13:09	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-028/Girls Gang Lav Sink #2 Lims Reference ID: AD31010-28 Matrix: Drinking Water Sampled: 06/18/25 07:00:00									
Metals									
Lead	ND		1	1.00	µg/L	08/14/25 11:56	08/21/25 13:15	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-029/Girls Gang Lav Sink #3 Lims Reference ID: AD31010-29 Matrix: Drinking Water Sampled: 06/18/25 07:00:00									
Metals									
Lead	ND		1	1.00	µg/L	08/14/25 11:56	08/21/25 13:17	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-030/Girls Gang Lav Sink #4 Right Lims Reference ID: AD31010-30 Matrix: Drinking Water Sampled: 06/18/25 07:00:00									
Metals									
Lead	ND		1	1.00	µg/L	08/14/25 11:56	08/21/25 13:19	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-031/Boys Gang Lav Sink #1 Left Lims Reference ID: AD31010-31 Matrix: Drinking Water Sampled: 06/18/25 07:30:00									
Metals									
Lead	ND		1	1.00	µg/L	08/14/25 11:56	08/21/25 13:21	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-032/Boys Gang Lav Sink #2 Lims Reference ID: AD31010-32 Matrix: Drinking Water Sampled: 06/18/25 07:30:00									
Metals									
Lead	1.05		1	1.00	µg/L	08/14/25 11:56	08/21/25 13:22	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-033/Boys Gang Lav Sink #3 Lims Reference ID: AD31010-33 Matrix: Drinking Water Sampled: 06/18/25 07:30:00									
Metals									

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012531010

LIMS Reference ID: AD31010

EMSL Customer ID: CLCS25

Attention: Brian Logel

Clarence Central Schools [CLCS25]
9600 Clarence Center Road
Clarence Center, NY 14032
(716) 407-9131
blogel@clarenceschools.org

Project Name: Clarence CSD - Sheridan Hill Elementary (SH)**Project ID:** _Master Project-CLCS25**Customer PO:****Sales Rep:** David Prince**Received:** 08/12/2025 10:15**Reported:** 08/26/2025 16:49**Analytical Results**
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SH-033/Boys Gang Lav Sink #3 (Continued) Lims Reference ID: AD31010-33 Matrix: Drinking Water Sampled: 06/18/25 07:30:00									
Metals (Continued)									
Lead	ND		1	1.00	µg/L	08/14/25 11:56	08/21/25 13:24	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-034/Boys Gang Lav Sink #4 Right Lims Reference ID: AD31010-34 Matrix: Drinking Water Sampled: 06/18/25 07:30:00									
Metals									
Lead	ND		1	1.00	µg/L	08/14/25 11:56	08/21/25 13:30	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-035/201 Sink Lims Reference ID: AD31010-35 Matrix: Drinking Water Sampled: 06/18/25 07:30:00									
Metals									
Lead	ND		1	1.00	µg/L	08/14/25 11:56	08/21/25 13:32	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-036/201 Lav Sink Lims Reference ID: AD31010-36 Matrix: Drinking Water Sampled: 06/18/25 07:30:00									
Metals									
Lead	ND		1	1.00	µg/L	08/14/25 11:56	08/21/25 13:38	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-037/205 Sink Lims Reference ID: AD31010-37 Matrix: Drinking Water Sampled: 06/18/25 07:30:00									
Metals									
Lead	ND		1	1.00	µg/L	08/14/25 11:56	08/21/25 13:39	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-038/206 Sink Lims Reference ID: AD31010-38 Matrix: Drinking Water Sampled: 06/18/25 07:30:00									
Metals									
Lead	ND		1	1.00	µg/L	08/14/25 11:56	08/21/25 13:41	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-039/208 Sink Lims Reference ID: AD31010-39 Matrix: Drinking Water Sampled: 06/18/25 07:30:00									
Metals									
Lead	ND		1	1.00	µg/L	08/14/25 11:56	08/21/25 13:43	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-040/210 Sink Lims Reference ID: AD31010-40 Matrix: Drinking Water Sampled: 06/18/25 07:30:00									
Metals									
Lead	ND		1	1.00	µg/L	08/14/25 11:56	08/21/25 13:45	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-041/207 Sink Lims Reference ID: AD31010-41 Matrix: Drinking Water Sampled: 06/18/25 08:00:00									
Metals									

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012531010

LIMS Reference ID: AD31010

EMSL Customer ID: CLCS25

Attention: Brian Logel

Clarence Central Schools [CLCS25]
9600 Clarence Center Road
Clarence Center, NY 14032
(716) 407-9131
blogel@clarenceschools.org

Project Name: Clarence CSD - Sheridan Hill Elementary (SH)**Project ID:** _Master Project-CLCS25**Customer PO:****Sales Rep:** David Prince**Received:** 08/12/2025 10:15**Reported:** 08/26/2025 16:49**Analytical Results**
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
---------	--------	---	----	----	-------	--------------------	--------------------	------------------	-------------------------

Sample: SH-041/207 Sink (Continued)

Lims Reference ID: AD31010-41 Matrix: Drinking Water

Sampled: 06/18/25 08:00:00

Metals (Continued)

Lead	1.39		1	1.00	µg/L	08/14/25 11:56	08/21/25 13:47	PL	EPA 200.8 (DA)/EPA 200.8
------	------	--	---	------	------	----------------	----------------	----	--------------------------

Sample: SH-042/209 Sink

Lims Reference ID: AD31010-42 Matrix: Drinking Water

Sampled: 06/18/25 08:00:00

Metals

Lead	ND		1	1.00	µg/L	08/14/25 11:56	08/21/25 13:49	PL	EPA 200.8 (DA)/EPA 200.8
------	----	--	---	------	------	----------------	----------------	----	--------------------------

Sample: SH-043/212 Sink

Lims Reference ID: AD31010-43 Matrix: Drinking Water

Sampled: 06/18/25 08:00:00

Metals

Lead	3.07		1	1.00	µg/L	08/18/25 10:40	08/19/25 12:51	PL	EPA 200.8 (DA)/EPA 200.8
------	------	--	---	------	------	----------------	----------------	----	--------------------------

Sample: SH-044/214 Sink

Lims Reference ID: AD31010-44 Matrix: Drinking Water

Sampled: 06/18/25 08:00:00

Metals

Lead	26.3		1	1.00	µg/L	08/18/25 13:57	08/19/25 16:47	SE	EPA 200.8 (Dig)/EPA 200.8
------	------	--	---	------	------	----------------	----------------	----	---------------------------

Sample: SH-045/216 Sink

Lims Reference ID: AD31010-45 Matrix: Drinking Water

Sampled: 06/18/25 08:00:00

Metals

Lead	1.22		1	1.00	µg/L	08/18/25 10:40	08/19/25 12:57	PL	EPA 200.8 (DA)/EPA 200.8
------	------	--	---	------	------	----------------	----------------	----	--------------------------

Sample: SH-046/218 Sink

Lims Reference ID: AD31010-46 Matrix: Drinking Water

Sampled: 06/18/25 08:00:00

Metals

Lead	14.4		1	1.00	µg/L	08/18/25 10:40	08/19/25 12:59	PL	EPA 200.8 (DA)/EPA 200.8
------	------	--	---	------	------	----------------	----------------	----	--------------------------

Sample: SH-047/213 Sink

Lims Reference ID: AD31010-47 Matrix: Drinking Water

Sampled: 06/18/25 08:00:00

Metals

Lead	35.6		1	1.00	µg/L	08/18/25 10:40	08/19/25 13:01	PL	EPA 200.8 (DA)/EPA 200.8
------	------	--	---	------	------	----------------	----------------	----	--------------------------

Sample: SH-048/women Gang Lav Sink Left

Lims Reference ID: AD31010-48 Matrix: Drinking Water

Sampled: 06/18/25 08:00:00

Metals

Lead	9.95		1	1.00	µg/L	08/18/25 10:40	08/19/25 13:03	PL	EPA 200.8 (DA)/EPA 200.8
------	------	--	---	------	------	----------------	----------------	----	--------------------------

Sample: SH-049/Women Gang Lav Sink Right

Lims Reference ID: AD31010-49 Matrix: Drinking Water

Sampled: 06/18/25 08:00:00

Metals

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012531010

LIMS Reference ID: AD31010

EMSL Customer ID: CLCS25

Attention: Brian Logel

Clarence Central Schools [CLCS25]
9600 Clarence Center Road
Clarence Center, NY 14032
(716) 407-9131
blogel@clarenceschools.org

Project Name: Clarence CSD - Sheridan Hill Elementary (SH)**Project ID:** _Master Project-CLCS25**Customer PO:****Sales Rep:** David Prince**Received:** 08/12/2025 10:15**Reported:** 08/26/2025 16:49**Analytical Results**
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SH-049/Women Gang Lav Sink Right (Continued) Lims Reference ID: AD31010-49 Matrix: Drinking Water Sampled: 06/18/25 08:00:00									
Metals (Continued)									
Lead	10.9		1	1.00	µg/L	08/18/25 10:40	08/19/25 13:08	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-050/Mens Gang Lav Sink Left Lims Reference ID: AD31010-50 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	7.39		1	1.00	µg/L	08/13/25 16:30	08/21/25 11:14	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-051/Mens Gang Lav Sink Lims Reference ID: AD31010-51 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	6.00		1	1.00	µg/L	08/13/25 16:30	08/21/25 11:16	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-052/315 Sink Left Lims Reference ID: AD31010-52 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	32.1		1	1.00	µg/L	08/13/25 16:30	08/21/25 11:18	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-053/315 Sink Right Lims Reference ID: AD31010-53 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	33.8		1	1.00	µg/L	08/13/25 16:30	08/21/25 11:20	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-054/314 Sink Left Lims Reference ID: AD31010-54 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	13.2		1	1.00	µg/L	08/13/25 16:30	08/21/25 11:21	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-055/Faculty Break Room Sink Lims Reference ID: AD31010-55 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	1.25		1	1.00	µg/L	08/13/25 16:30	08/21/25 11:23	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-056/Bottle Filler by Faculty Break Room Lims Reference ID: AD31010-56 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	ND		1	1.00	µg/L	08/13/25 16:30	08/21/25 11:29	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-057/Boys Gang Lav Sink #1 Left (by 303) Lims Reference ID: AD31010-57 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012531010

LIMS Reference ID: AD31010

EMSL Customer ID: CLCS25

Attention: Brian Logel

Clarence Central Schools [CLCS25]
9600 Clarence Center Road
Clarence Center, NY 14032
(716) 407-9131
blogel@clarenceschools.org

Project Name: Clarence CSD - Sheridan Hill Elementary (SH)**Project ID:** _Master Project-CLCS25**Customer PO:****Sales Rep:** David Prince**Received:** 08/12/2025 10:15**Reported:** 08/26/2025 16:49**Analytical Results**
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SH-057/Boys Gang Lav Sink #1 Left (by 303) Lims Reference ID: AD31010-57 Matrix: Drinking Water Sampled: 06/18/25 08:30:00 (Continued)									
Metals									
Lead	2.79		1	1.00	µg/L	08/13/25 16:30	08/21/25 11:31	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-058/Boys Gang Lav Sink #2 (by 303) Lims Reference ID: AD31010-58 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	2.04		1	1.00	µg/L	08/13/25 16:30	08/21/25 11:37	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-059/Boys Gang Lav Sink #3 (by 303) Lims Reference ID: AD31010-59 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	3.54		1	1.00	µg/L	08/13/25 16:30	08/21/25 11:38	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-060/Girls Gang Lav Sink #1 Left (by 303) Lims Reference ID: AD31010-60 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	3.07		1	1.00	µg/L	08/13/25 16:30	08/21/25 11:40	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-061/Girls Gang Lav Sink #2 (by 303) Lims Reference ID: AD31010-61 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	3.21		1	1.00	µg/L	08/13/25 16:30	08/21/25 11:42	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-062/Girls Gang Lav Sink #3 (by 303) Lims Reference ID: AD31010-62 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	5.60		1	1.00	µg/L	08/13/25 16:30	08/21/25 11:44	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-063/Staff Women Lav Sink (Single) Lims Reference ID: AD31010-63 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	4.40		1	1.00	µg/L	08/15/25 13:30	08/21/25 14:10	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-064/Staff Men Lav Sink (Single) Lims Reference ID: AD31010-64 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	7.50		1	1.00	µg/L	08/15/25 13:30	08/21/25 14:16	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-065/312 Art Sink Left Lims Reference ID: AD31010-65 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012531010

LIMS Reference ID: AD31010

EMSL Customer ID: CLCS25

Attention: Brian Logel

Clarence Central Schools [CLCS25]
9600 Clarence Center Road
Clarence Center, NY 14032
(716) 407-9131
blogel@clarenceschools.org

Project Name: Clarence CSD - Sheridan Hill Elementary (SH)**Project ID:** _Master Project-CLCS25**Customer PO:****Sales Rep:** David Prince**Received:** 08/12/2025 10:15**Reported:** 08/26/2025 16:49**Analytical Results**
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SH-065/312 Art Sink Left (Continued) Lims Reference ID: AD31010-65 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	1.33		1	1.00	µg/L	08/15/25 13:30	08/21/25 14:18	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-066/312 Art Sink Right Lims Reference ID: AD31010-66 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	1.62		1	1.00	µg/L	08/15/25 13:30	08/21/25 14:20	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-067/311 Sink Lims Reference ID: AD31010-67 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	10.9		1	1.00	µg/L	08/18/25 13:57	08/19/25 16:49	SE	EPA 200.8 (Dig)/EPA 200.8
Sample: SH-068/310 Sink Lims Reference ID: AD31010-68 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	14.1		1	1.00	µg/L	08/15/25 13:30	08/21/25 14:21	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-069/309 Sink Lims Reference ID: AD31010-69 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	14.7		1	1.00	µg/L	08/15/25 13:30	08/21/25 14:27	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-070/308 Sink Lims Reference ID: AD31010-70 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	8.34		1	1.00	µg/L	08/15/25 13:30	08/21/25 14:29	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-071/307 Sink Lims Reference ID: AD31010-71 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	11.1		1	1.00	µg/L	08/15/25 13:30	08/21/25 14:31	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-072/306 Sink Lims Reference ID: AD31010-72 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	17.0		1	1.00	µg/L	08/15/25 13:30	08/21/25 14:33	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-073/305 Sink Lims Reference ID: AD31010-73 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012531010

LIMS Reference ID: AD31010

EMSL Customer ID: CLCS25

Attention: Brian Logel

Clarence Central Schools [CLCS25]
9600 Clarence Center Road
Clarence Center, NY 14032
(716) 407-9131
blogel@clarenceschools.org

Project Name: Clarence CSD - Sheridan Hill Elementary (SH)**Project ID:** _Master Project-CLCS25**Customer PO:****Sales Rep:** David Prince**Received:** 08/12/2025 10:15**Reported:** 08/26/2025 16:49**Analytical Results**
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SH-073/305 Sink (Continued) Lims Reference ID: AD31010-73 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals (Continued)									
Lead	19.2		1	1.00	µg/L	08/15/25 13:30	08/21/25 14:35	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-074/303 Sink Lims Reference ID: AD31010-74 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	14.0		1	1.00	µg/L	08/15/25 13:30	08/21/25 14:37	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-075/301 Sink Lims Reference ID: AD31010-75 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	1.97		1	1.00	µg/L	08/15/25 13:30	08/21/25 14:42	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-076/Women Gang Lav Sink Left Lims Reference ID: AD31010-76 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	ND		1	1.00	µg/L	08/15/25 13:30	08/21/25 14:44	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-077/Women Gang Lav Sink Right Lims Reference ID: AD31010-77 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	ND		1	1.00	µg/L	08/15/25 13:30	08/21/25 14:50	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-078/Mens Gang Lav Sink Left Lims Reference ID: AD31010-78 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	ND		1	1.00	µg/L	08/15/25 13:30	08/21/25 14:52	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-079/Mens Gang Lav Sink Right Lims Reference ID: AD31010-79 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	ND		1	1.00	µg/L	08/15/25 13:30	08/21/25 14:54	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-080/217 Sink Lims Reference ID: AD31010-80 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	ND		1	1.00	µg/L	08/15/25 13:30	08/21/25 14:56	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-081/215 Sink Lims Reference ID: AD31010-81 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012531010

LIMS Reference ID: AD31010

EMSL Customer ID: CLCS25

Attention: Brian Logel

Clarence Central Schools [CLCS25]
9600 Clarence Center Road
Clarence Center, NY 14032
(716) 407-9131
blogel@clarenceschools.org

Project Name: Clarence CSD - Sheridan Hill Elementary (SH)**Project ID:** _Master Project-CLCS25**Customer PO:****Sales Rep:** David Prince**Received:** 08/12/2025 10:15**Reported:** 08/26/2025 16:49**Analytical Results**
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SH-081/215 Sink (Continued) Lims Reference ID: AD31010-81 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals (Continued)									
Lead	ND		1	1.00	µg/L	08/15/25 13:30	08/21/25 14:57	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-082/213 Sink Lims Reference ID: AD31010-82 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	ND		1	1.00	µg/L	08/15/25 13:30	08/21/25 14:59	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-083/210 Sink Lims Reference ID: AD31010-83 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	ND		1	1.00	µg/L	08/15/25 13:30	08/21/25 15:01	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-084/211 Sink Lims Reference ID: AD31010-84 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	ND		1	1.00	µg/L	08/18/25 10:40	08/19/25 13:10	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-085/208 Sink Lims Reference ID: AD31010-85 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	1.60		1	1.00	µg/L	08/18/25 10:40	08/19/25 13:12	PL	EPA 200.8 (DA)/EPA 200.8
Sample: SH-086/200 Hall Water Fountain Lims Reference ID: AD31010-86 Matrix: Drinking Water Sampled: 06/18/25 08:30:00									
Metals									
Lead	ND		1	1.00	µg/L	08/18/25 10:40	08/19/25 13:14	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012531010

LIMS Reference ID: AD31010

EMSL Customer ID: CLCS25

Attention: Brian Logel

Clarence Central Schools [CLCS25]
9600 Clarence Center Road
Clarence Center, NY 14032
(716) 407-9131
blogel@clarenceschools.org

Project Name: Clarence CSD - Sheridan Hill Elementary (SH)**Project ID:** _Master Project-CLCS25**Customer PO:****Sales Rep:** David Prince**Received:** 08/12/2025 10:15**Reported:** 08/26/2025 16:49**Certified Analyses included in this Report**

Analyte	Certifications
<i>EPA 200.8 in Drinking Water</i>	
Lead	NJDEP

List of Certifications

Code	Description	Number	Expires
PADEP	Pennsylvania Department of Environmental Protection	2845.25	11/30/2025
NYSDOH	New York State Department of Health ELAP	10872	04/01/2026
NJDEP	New Jersey Department of Environmental Protection	03036	06/30/2026
MADEP	Massachusetts Department of Environmental Protection	M-NJ337	06/30/2026
CTDPH	Connecticut Department of Public Health	PH-0270	06/30/2026
California ELAP	California Water Boards	1877	06/30/2026
AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC)	100194	04/01/2027
A2LA	A2LA Environmental Certificate	2845.01	07/31/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012531010**LIMS Reference ID:** AD31010**EMSL Customer ID:** CLCS25**Attention:** Brian Logel

Clarence Central Schools [CLCS25]
9600 Clarence Center Road
Clarence Center, NY 14032
(716) 407-9131
blogel@clarenceschools.org

Project Name:

Clarence CSD - Sheridan Hill Elementary (SH)

Project ID:

_Master Project-CLCS25

Customer PO:**Sales Rep:**

David Prince

Received:

08/12/2025 10:15

Reported:

08/26/2025 16:49

Notes and Definitions

Item	Definition
D	Analyte was reported from a dilution run.
P3	Sample was preserved by client prior to getting into laboratory.
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

Owen McKenna Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



EMSL ANALYTICAL, INC.
TESTING LABS • PRODUCTS • TRAINING

Lead Chain of Custody

EMSL Order Number / Lab Use Only

EMSL Analytical, Inc.
200 Route 130 North
Cinnaminson, NJ 08077

PHONE: (800) 220-3675

EMAIL: CinnaminsonLeadLab@emsl.com

AD31010

Customer Information		Billing Information		
Customer ID:		Billing ID:		
Company Name: Clarence Central School District		Company Name: Same as Left		
Contact Name: Brian Logel		Billing Contact:		
Street Address: 9625 main Street		Street Address:		
City, State, Zip: Clarence, NY 14031 Country: USA		City, State, Zip: Country:		
Phone: 716-407-9131		Phone:		
Email(s) for Report: Blogel@clarenceschools.org		Email(s) for Invoice:		
Project Information				
Project Name/No: Clarence CSD - Sheridan Hill Elementary (SH)		Purchase Order:		
EMSL LIMS Project ID: (If applicable, EMSL will provide)		US State where samples collected: NY State of Connecticut (CT) must select project location:		
Sampled By Name: Brian Logel		Commercial (Taxable) ☐ Residential (Non-Taxable) ☐		
Sampled By Signature:		No. of Samples in Shipment:		
Turn-Around-Time (TAT)				
☐ 3 Hour ☐ 6 Hour ☐ 24 Hour ☐ 32 Hour ☐ 48 Hour ☐ 72 Hour ☐ 96 Hour ☐ 1 Week ☒ 2 Week				
Please call ahead for large projects and/or turnaround times 6 Hours or Less. *32 Hour TAT available for select tests only; samples must be submitted by 11:30am.				
MATRIX	METHOD	INSTRUMENT	REPORTING LIMIT	SELECTION
CHIPS ☐ % by wt. ☐ ppm (mg/kg) ☐ mg/cm ²	SW 846-7000B	Flame Atomic Absorption	0.008% (80ppm)	☐
Reporting Limit based on a minimum 0.25g sample weight.	SW 846-6010D	ICP-OES	0.0004% (4ppm)	☐
**Not appropriate for Ceramic Tiles - XRF is recommended	NIOSH 7082	Flame Atomic Absorption	4µg/filter	☐
AIR	NIOSH 7300M / NIOSH 7303M	ICP-OES	0.5µg/filter	☐
	NIOSH 7300M / NIOSH 7303M	ICP-MS	0.05µg/filter	☐
WIPE ☐ ASTM ☐ NON-ASTM	SW 846-7000B	Flame Atomic Absorption	10µg/wipe	☐
If no box is checked, non-ASTM Wipe is assumed	SW 846-6010D	ICP-OES	1.0µg/wipe	☐
TCLP	SW 846-1311 / 7000B / SM 3111B	Flame Atomic Absorption	0.4 mg/L (ppm)	☐
	SW 846-1311 / SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)	☐
SPLP	SW 846-1312 / 7000B / SM 3111B	Flame Atomic Absorption	0.4 mg/L (ppm)	☐
	SW 846-1312 / SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)	☐
TTLIC	22 CCR App. II, 7000B	Flame Atomic Absorption	40mg/kg (ppm)	☐
	22 CCR App. II, SW 846-6010D*	ICP-OES	2mg/kg (ppm)	☐
STLC	22 CCR App. II, 7000B	Flame Atomic Absorption	0.4 mg/L (ppm)	☐
	22 CCR App. II, SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)	☐
Soil	SW 846-7000B	Flame Atomic Absorption	40mg/kg (ppm)	☐
	SW 846-6010D*	ICP-OES	2mg/kg (ppm)	☐
Wastewater	SM 3111B / SW 846-7000B	Flame Atomic Absorption	0.4 mg/L (ppm)	☐
Unpreserved ☐	EPA 200.7	ICP-OES	0.020 mg/L (ppm)	☐
Preserved with HNO ₃ ☐ PH<2	EPA 200.5	ICP-OES	0.003 mg/L (ppm)	☐
Drinking Water	EPA 200.8	ICP-MS	0.001 mg/L (ppm)	☒
Unpreserved ☐				☐
Preserved with HNO ₃ ☒ PH<2				☐
TSP/SPM Filter	40 CFR Part 50	ICP-OES	12 µg/filter	☐
Other:				☐
Sample Number	Sample Location	Volume / Area	Date / Time Sampled	
SH-001 Up To	See Attached Sheets		6/13/25	
SH-085	See Attached Sheets			
Method of Shipment:		Sample Condition Upon Receipt:		
Relinquished by: Brian Logel	Date/Time: 8/7/25, 5pm	Received by:	Date/Time: 8/12/25	
Relinquished by:	Date/Time:	Received by:	Date/Time:	

Controlled Document - COC-25 Lead R17 05/09/2022

*6010C Available Upon Request



AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.

AD31010

Clarence Central School District

Building Sheridan Hill		FIRST DRAW										
SAMPLE NUMBER	DATE	TIME	LOCATION	MAIN SC	WATER COOLER	BUBBLER	SINK FAUCET	ICE MACHINE	POT FILLER	STEAM KETTLE	OTHER (SPECIFY)	RESULT ppb
SH-001	6/18/25	6:00am	Main Office Lav Sink									
SH-002	6/18/25		Nurse Sink									
SH-003	6/18/25		103 work 24: Lav Sink									
SH-004	6/18/25		Media Work Rm 401 Sink									
SH-005	6/18/25		110 Sink Left <i>Lav</i>									
SH-006	6/18/25		110 Sink Right									
SH-007	6/18/25		112 Sink Left <i>Lav</i>									
SH-008	6/18/25		112 Sink Right									
SH-009 <i>★</i>	6/18/25		113 Sink									
SH-010	6/18/25		113 Lav Sink									
SH-011 <i>★</i>	6/18/25	6:30am	114 sink Left									
SH-012	6/18/25		114 Sink Right									
SH-013	6/18/25		115 Sink Left <i>Lav</i>									
SH-014	6/18/25		115 Sink Right									
SH-015	6/18/25		116 Sink Left									
SH-016	6/18/25		116 Sink Right									
SH-017	6/18/25		117 Sink Left <i>Lav</i>									
SH-018	6/18/25		117 Sink Right									

AD31010

Clarence Central School District

Building <u>Sheridan Hill</u>												
SAMPLE NUMBER	FIRST DRAW		LOCATION	MAIN SC	WATER COOLER	BUBBLER	SINK FAUCET	ICE MACHINE	POT FILLER	STEAM KETTLE	OTHER (SPECIFY)	RESULT ppb
	DATE	TIME										
SH-019	6/18/25		118 Sink Left <i>Lev</i>									
SH-020	6/18/25		118 Sink Right									
SH-021	6/18/25	7:00am	119 Sink Left <i>Lev</i>									
SH-022	6/18/25		119 Sink Right									
SH-023	6/18/25		121 Sink Left <i>Lev</i>									
SH-024	6/18/25		121 Sink Right									
SH-025	6/18/25		123 Sink									
SH-026	6/18/25		Bottle Filler by 201									
SH-027	6/18/25		Girls Gang Lav Sink #1 Left									
SH-028	6/18/25		Girls Gang Lav Sink #2									
SH-029	6/18/25		Girls Gang Lav Sink #3									
SH-030	6/18/25		Girls Gang Lav Sink #4 Right									
SH-031	6/18/25	7:30am	Boys Gang Lav Sink #1 Left									
SH-032	6/18/25		Boys Gang Lav Sink #2									
SH-033	6/18/25		Boys Gang Lav Sink #3									
SH-034	6/18/25		Boys Gang Lav Sink #4 Right									
SH-035 ✓	6/18/25		201 Sink									
SH-036 ✓	6/18/25		201 Lav Sink									

AD31010
Sheridan
HCU

Building	FIRST DRAW											
	DATE	TIME	LOCATION	MAIN SC	WATER COOLER	BUBBLER	SINK FAUCET	ICE MACHINE	POT FILLER	STEAM KETTLE	OTHER (SPECIFY)	RESULT ppb
SAMPLE NUMBER												
HH-037	6/18/25		205 Sink									
HH-038	6/18/25		206 Sink									
HH-039	6/18/25		208 Sink									
HH-040	6/18/25		210 Sink									
HH-041	6/18/25	8:00am	207Sink									
HH-042	6/18/25		209Sink									
HH-043	6/18/25		212 Sink									
HH-044	6/18/25		214 Sink									
HH-045	6/18/25		216 Sink									
HH-046	6/18/25		218 Sink									
HH-047	6/18/25		213 Sink									
HH-048	6/18/25		Women Gang Lav Sink Left									
HH-049	6/18/25		Women Gang Lav Sink Right									
HH-050	6/18/25	8:30am	Mens Gang Lav Sink Left									
HH-051	6/18/25		Mens Gang Lav Sink Right									
HH-052	6/18/25		315 Sink Left									
HH-053	6/18/25		315 Sink Right									
HH-054	6/18/25		314 Sink Left									

AD31010

Clarence Central School District

Building Sheridan Hill												
FIRST DRAW												
SAMPLE NUMBER	DATE	TIME	LOCATION	MAIN SC	WATER COOLER	BUBBLER	SINK FAUCET	ICE MACHINE	POT FILLER	STEAM KETTLE	OTHER (SPECIFY)	RESULT ppb
SH-055	6/18/25		Faculty Break Room Sink ✓									
SH-056	6/18/25		Bottle Filler by Faculty Break room ✓									
SH-057	6/18/25		Boys Gang Lav Sink #1 Left (by 303) ✓									
SH-058	6/18/25		Boys Gang Lav Sink #2 (by 303) ✓									
SH-059	6/18/25		Boys Gang Lav Sink #3 (by 303) ✓									
SH-060	6/18/25		Girls Gang Lav Sink #1 Left (by 303) ✓									
SH-061	6/18/25		Girls Gang Lav Sink #2 (by 303) ✓									
SH-062	6/18/25		Girls Gang Lav Sink #3 (by 303) ✓									
SH-063	6/18/25		Staff Women Lav Sink (Single) ✓									
SH-064	6/18/25		Staff Men Lav Sink (Single) ✓									
SH-065	6/18/25		312 Art Sink Left ✓									
SH-066	6/18/25		312 Art Sink Right ✓									
SH-067	6/18/25		311 Sink ✓									
SH-068	6/18/25		310 Sink ✓									
SH-069	6/18/25		309 Sink ✓									
SH-070	6/18/25		308 Sink ✓									
SH-071	6/18/25		307 Sink ✓									
SH-072	6/18/25		306 Sink ✓									

AD31010

Clarence Central School District

RD 31010

FIRST DRAW												
Building Sheridan Hill	DATE	TIME	LOCATION	MAIN SC	WATER COOLER	BUBBLER	SINK FAUCET	ICE MACHINE	POT FILLER	STEAM KETTLE	OTHER (SPECIFY)	RESULT ppb
SAMPLE NUMBER												
SH-073	6/18/25		305 Sink ✓									
SH-074	6/18/25		303 Sink ✓									
SH-075	6/18/25		301 Sink ✓									
SH-076	6/18/25		Women Gang Lav Sink Left ✓									
SH-077	6/18/25		Women Gang Lav Sink Right ✓									
SH-078	6/18/25		Mens Gang Lav Sink Left ✓									
SH-079	6/18/25		Mens Gang Lav Sink Right ✓									
SH-080	6/18/25		217 Sink ✓									
SH-081	6/18/25		215 Sink ✓									
SH-082	6/18/25		213 Sink ✓									
SH-083	6/18/25		210 Sink ✓									
SH-084	6/18/25		211 Sink ✓									
SH-085	6/18/25		208 Sink ✓									
SH-086	6/18/25		200 HALL WATER FOUNTAIN ✓									