

1.2 Executive Summary of Sampling and Analysis:

Summary of Samples Collected at Victor Early Childhood School:

Building Name	Date of Sampling	Total Samples	At or Below Action Level*	Above Action Level*
Victor Early Childhood School	June 3, 2025	182	164	18
	August 27, 2025	18	13	5

*NYS Action Level is 5 parts per billion

Listing of Outlets Requiring Remediation

The following outlets were analyzed above the NYS Action Level:

Sample #	Location	Fixture/Outlet Type	Laboratory Analysis (in ppb)	
			6/3/2025	8/27/2025
203.4-06	Boys Lav by elevator right	Sink	6.9	1.7 – Cleared
203.4-10	Girls Lav by 208 Left	Sink	5.1	1.4 – Cleared
203.4-11	Girls Lav by 208 Right	Sink	6.4	1.2 – Cleared
203.4-13	Room 208	Drinking Fountain	5.0	< 1.0 – Cleared
203.4-18	Room 218	Sink	8.4	61.8
203.4-19	Room 218	Drinking Fountain	9.4	1.9 – Cleared
203.4-58	Room 013 Main	Sink	10.4	6.9
203.4-59	Room 013 Fac Lav	Sink	7.8	9.1
203.4-81	Kitchen 3 Bay Left	Sink	23.1	5.9
203.4-86	Kitchen Dishwash Handwash	Sink	9.7	1.5 – Cleared
203.4-88	PT Room 122/123	Sink	5.6	4.6 – Cleared
203.4-89A	DF Across from Gym	Drinking Fountain	14.1	1.6 – Cleared
203.4-89B	DF Across from Gym	Bottle Fill	23.3	1.6 – Cleared
203.4-91	119 Lav	Sink	12.5	4.3 – Cleared
203.4-92	Room 118	Sink	5.5	2.4 – Cleared
203.4-104	129 Rear Room	Sink	6.2	4.8 – Cleared
203.4-119	Girls Lav by 101 Left	Sink	6.6	1.8 – Cleared
203.4-158	Mens Lav Main Entrance	Sink	8.8	6.2

1.2 Executive Summary of Sampling and Analysis:

Summary of Samples Collected at Victor Primary School:

Building Name	Date of Sampling	Total Samples	At or Below Action Level*	Above Action Level*
Victor Primary School	June 3, 2025	174	141	33
	August 27, 2025	29	11	18

*NYS Action Level is 5 parts per billion

Listing of Outlets Requiring Remediation

The following outlets were analyzed above the NYS Action Level:

Sample #	Location	Fixture/Outlet Type	Laboratory Analysis (in ppb)	
			6/3/2025	8/27/2025
172.3-9	Kitchen Combitherm Sprayer Right	Sink	8.0	—
172.3-14	Room 138	Sink	11.7	1.7 – Cleared
172.3-15	Room 138	Drinking Fountain	6.4	< 1.0 – Cleared
172.3-16	Room 136	Sink	6.5	1.7 – Cleared
172.3-17	Room 131 Lav	Sink	5.9	1.8 – Cleared
172.3-18	Room 131 Lav	Sink	7.5	—
172.3-23	129 Women’s Fac Left	Sink	5.1	Sample Hold
172.3-25	Room 134	Sink	9.1	< 1.0 – Cleared
172.3-27	Room 132	Sink	12.0	Sample Hold
172.3-28	Room 132	Drinking Fountain	39.1	1.1 – Cleared
172.3-29	Room 130	Sink	12.6	< 1.0 – Cleared
172.3-30	Room 128	Sink	7.5	3.9 – Cleared
172.3-34	Room 125 Rear	Sink	14.0	26.5
172.3-35	Kiln Room	Sink	13.4	105
172.3-37	Room 123	Drinking Fountain	14.2	< 1.0 – Cleared
172.3-62	Room 113	Drinking Fountain	5.5	< 1.0 – Cleared
172.3-86	Room 107	Drinking Fountain	5.0	3.3 – Cleared
172.3-87	Room 143	Drinking Fountain	10.3	1.1 – Cleared
172.3-125	Room 168	Sink	5.8	2.8 – Cleared
172.3-133	Room 164	Sink	5.1	2.4 – Cleared
172.3-134	Room 161	Sink	9.9	5.1

Sample #	Location	Fixture/Outlet Type	Laboratory Analysis (in ppb)	
			6/3/2025	8/27/2025
172.3-135	Room 161	Drinking Fountain	14.5	1.2 – Cleared
172.3-141	Room 160	Drinking Fountain	5.0	< 1.0 – Cleared
172.3-142	Room 157	Sink	6.1	5.1
172.3-145	Room 158	Sink	8.3	14.3
172.3-146	Room 158	Drinking Fountain	12.1	< 1.0 – Cleared
172.3-148	Room 201	Sink	11.2	9.5
172.3-149	Room 156	Sink	5.0	4.6 – Cleared
172.3-151	Room 156 Lav	Sink	5.6	6.1
172.3-157	Girls Lav Center Left	Sink	8.1	8.4
172.3-158	Girls Lav Center Right	Sink	8.0	6.2
172.3-159	Girls Lav 2nd Right	Sink	6.7	8.5
172.3-174	Room 153 Lav	Sink	8.2	12.4

1.2 Executive Summary of Sampling and Analysis:

Summary of Samples Collected at Victor Intermediate School:

Building Name	Date of Sampling	Total Samples	At or Below Action Level*	Above Action Level*
Victor Intermediate School	June 2, 2025	165	117	48
	August 27, 2025	44	16	28

*NYS Action Level is 5 parts per billion

Listing of Outlets Requiring Remediation

The following outlets were analyzed above the NYS Action Level:

Sample #	Location	Fixture/Outlet Type	Laboratory Analysis (in ppb)	
			6/2/2025	8/27/2025
203.2-01	Receiving 143 Unisex Rest Room	Sink	5.6	2.1 – Cleared
203.2-10	Kitchen 3 Bay Right	Sink	10.1	—
203.2-11	Kitchen 3 Bay Left	Sink	8.5	—
203.2-14	Snack Bar 146	Sink	10.6	9.5
203.2-15	Aide Room 149 inside room 148	Sink	7.5	—
203.2-18	Fac Women by 195 left	Sink	5.0	2.0 – Cleared
203.2-19	Unisex in 195	Sink	485	8.1
203.2-20	PPS Office Fac Lav Left	Sink	8.1	1.1 – Cleared
203.2-21	PPS Office Fac Lav Right	Sink	9.3	1.6 – Cleared
203.2-22	Room 160 Lav	Sink	155	6.6
203.2-34	Music Room 193	Sink	18.9	85.8
203.2-56	Girls Lav Outside 116A C	Sink	9.1	6.4
203.2-57	Girls Lav outside 116a R	Sink	6.1	14.4
203.2-62	Room 184	Sink	7.3	Sample Hold
203.2-63	Room 183	Sink	6.0	3.1 – Cleared
203.2-107	DF by Elevator	Drinking Fountain	5.2	1.0 – Cleared
203.2-108	Room 134	Sink	9.5	16.7
203.2-110	Room 135	Sink	16.3	142
203.2-111	Room 136	Sink	21.9	150
203.2-112	Room 137	Sink	18.7	50.6
203.2-113	Boys Lav by Lib L	Sink	5.2	7.2

Sample #	Location	Fixture/Outlet Type	Laboratory Analysis (in ppb)	
			6/2/2025	8/27/2025
203.2-115	Boys Lav by Lib RC	Sink	11.6	1.2 – Cleared
203.2-116	Boys Lav by Lib R	Sink	149	10.7
203.2-119	Girls Lav by Lib L	Sink	12.1	7.0
203.2-121	Girls Lav by Lib RC	Sink	8.7	1.1 – Cleared
203.2-124	Room 213	Sink	10.3	8.7
203.2-125	Room 212	Sink	6.7	12.9
203.2-126	Room 214	Sink	13.5	1.8 – Cleared
203.2-127	Room 211	Sink	6.8	13.7
203.2-128	Room 215	Sink	7.7	3.7 – Cleared
203.2-129	Room 210	Sink	8.2	14.7
203.2-131	Room 209	Sink	8.0	2.3 – Cleared
203.2-132	Room 208	Sink	6.7	46.6
203.2-133	Room 217	Sink	8.3	24.7
203.2-136	Boys Lav Across 207 RC	Sink	6.4	< 1.0 – Cleared
203.2-140	Room 207	Sink	13.3	44.7
203.2-147	Room 219 Handwash sink L	Sink	10.5	3.9 – Cleared
203.2-148	Room 221 Handwash sink L	Sink	10.8	2.9 – Cleared
203.2-149	Room 206	Sink	12.2	65.0
203.2-150	Room 205	Sink	13.1	6.0
203.2-151	Room 223	Sink	15.0	3.6 – Cleared
203.2-154	Room 204	Sink	11.4	20.9
203.2-155	Room 203	Sink	13.0	41.2
203.2-156	Room 227	Sink	26.5	6.2
203.2-157	Room 202 Far Door L	Sink	14.4	24.3
203.2-159	Room 202 Near Door L	Sink	8.8	16.5
203.2-160	Room 202 Near Door R	Sink	10.3	26.0
203.2-161	DF Outside 227	Drinking Fountain	5.5	1.3 – Cleared

1.2 Executive Summary of Sampling and Analysis:

Summary of Samples Collected at Victor Jr/Sr High School:

Building Name	Date of Sampling	Total Samples	At or Below Action Level*	Above Action Level*
Victor Jr/Sr High School	June 2, 2025	207	192	15
	August 27, 2025	4	3	1

*NYS Action Level is 5 parts per billion

Listing of Outlets Requiring Remediation

The following outlets were analyzed above the NYS Action Level:

Sample #	Location	Fixture/Outlet Type	Laboratory Analysis (in ppb)	
			6/2/2025	8/27/2025
203.1-30	C244 Center	Sink	7.0	2.3 – Cleared
203.1-50	A221A Storage	Sink	9.3	—
203.1-80	Old Boys Locker L	Sink	55.4	—
203.1-81	Old Boys Locker C	Sink	29.9	—
203.1-82	Old Boys Locker R	Sink	9.8	—
203.1-87	Middle Kitchen Sink	Sink	9.4	—
203.1-88	Double Sink Left	Sink	12.1	—
203.1-89	Double Sink Right	Sink	40.4	—
203.1-90	Sprayer in middle	Sink	59.7	—
203.1-94	DF Outside 166 Left	Drinking Fountain	11.5	< 1.0 – Cleared
203.1-102	Boys Locker L	Sink	21.4	1.1 – Cleared
203.1-115	Boys Locker L	Sink	17.9	16.3
203.1-140	Room 116A Prep	Sink	10.6	—
203.1-178	Kitchen By Dough Mixer	Sink	9.1	—
203.1-182	Concession Stand Sink Right	Sink	8.5	—