ENDYNE Inc.
Environmental Laboratories

Laboratory Report

Champlain Valley Edu Services 200674
1585 Military Turnpike
Plattsburgh, NY 12901

Atten: Stephanie Trombly

PROJECT: Lead in School Taps, TiCSD
WORK ORDER: **2408-24464**
DATE RECEIVED: August 06, 2024
DATE REPORTED: August 14, 2024
SAMPLER: Eric Grinnell

Enclosed please find the results of the analyses performed for the samples referenced on the attached chain of custody located at the end of this report.

The column labeled Lab/Tech in the accompanying report denotes the laboratory facility where the testing was performed and the technician who conducted the assay. A "W" designates the Williston, VT lab under NELAC certification ELAP 11263; "R" designates the Lebanon, NH facility under certification NH 2037 and "N" the Plattsburgh, NY lab under certification ELAP 11892. "Sub" indicates the testing was performed by a subcontracted laboratory. The accreditation status of the subcontracted lab is referenced in the corresponding NELAC and Qual fields.

This NELAC column also denotes the accreditation status of each laboratory for each reported parameter. "A" indicates the referenced laboratory is NELAC accredited for the parameter reported. "N" indicates the laboratory is not accredited. "U" indicates that NELAC does not offer accreditation for that parameter in that specific matrix. Test results denoted with an "A" meet all National Environmental Laboratory Accreditation Program requirements except where denoted by pertinent data qualifiers. Test results are representative of the samples as they were received at the laboratory.

Endyne, Inc. warrants, to the best of its knowledge and belief, the accuracy of the analytical test results contained in this report, but makes no other warranty, expressed or implied, especially no warranties of merchantability or fitness for a particular purpose.

Reviewed by:

Christina A Lafountain
Laboratory Director Plattsburgh, NY

Laboratory Report

CLIENT: Champlain Valley Edu Services
PROJECT: Lead in School Taps, TiCSD

WORK ORDER: **2408-24464**
DATE RECEIVED: 8/6/24

001 Site: DF Girls Locker Room E/S — Stagnant: 8.13 Hrs — Date Sampled: 8/4/24 — Time: 15:00

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.0063	mg/L	EPA 200.8	8/13/24	W RSB	A	

002 Site: DF East 1312 HS Supply — Stagnant: 8.20 Hrs — Date Sampled: 8/4/24 — Time: 15:10

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.0202	mg/L	EPA 200.8	8/13/24	W RSB	A	

003 Site: Kitchen Steamer HS Supply — Stagnant: 8.32 Hrs — Date Sampled: 8/4/24 — Time: 15:19

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.0039	mg/L	EPA 200.8	8/13/24	W RSB	A	

004 Site: Kitchen Side Sink – Faucet changed — Stagnant: 8.25 Hrs — Date Sampled: 8/4/24 — Time: 15:15

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.0034	mg/L	EPA 200.8	8/13/24	W RSB	A	

005 Site: Kitchen Back Sink #1 HS Supply — Stagnant: 8.25 Hrs — Date Sampled: 8/5/24 — Time: 14:00

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.0140	mg/L	EPA 200.8	8/13/24	W RSB	A	

Test results comply with all NELAC requirements unless otherwise noted. This Laboratory Report includes the client's COC sample documentation and shall not be reproduced except in full, without written approval of the laboratory.

Endyne, Inc. - Plattsburgh Lab

LAB USE ONLY
Due Date:

315 New York Road
Plattsburgh, NY 12903
Phone (518)563-1720
Fax (518)563-0052
info@endynelabs.com
ELAP #11892

Client: Champlain Valley E.D. | Account #: 205674
Email Address:
Contact Person: Eric Grinnell | Project Name Bacts
Phone: 518-585-3542 | 3T - Lead in Schools
PO # 17-01062

SAMPLE SUPPLY INFORMATION
PWS # Town of Ticonderoga Water Dept.
Collection Address: Ticonderoga Central School
5 Calkins Place
City: Ticonderoga State: NY Zip: 12883
Collector's Name: Eric Grinnell

Pag 1 of

SAMPLE MATRIX CODES
DW=drinking water SW=Surface Water
WW=waste water SO=solid
MW=monitoring well SO=soil
HW=hazardous waste SL=sludge

Compliance? Yes
Initial Testing
or
Repeat Testing

TURNAROUND TIME REQUESTED
Standard (2-4 weeks)

Sample ID / Collection Site	Date/Time	Bottle Tyoe / Volume	Matrix	Preservation	First Draw (Y)	Flushed Line (Y)	Analysis Requested: Total Lead	Water Last Used (Date / Time)	Lab Use Sample #
1 DF Girls Locker room E/S	8/4/24 3:00pm	250mL, P	DW	*			X	8/4/24 6:52A	001
2 DF East 1312 HS Supply	8/4/24 3:10pm	250mL, P	DW	*			X	8/4/24 6:58A	002
3 Kitchen Steamer HS Supply	8/4/24 3:19pm	250mL, P	DW	*			X	8/4/24 7:00A	003
4 Kitchen Side Sink	8/4/24 3:25pm	250mL, P	DW	*			X	8/4/24 7:00A	004
~~5 Kitchen Back Sink #1 supply~~		250mL, P	DW	*			X	~~8/4/24 7:00A~~	~~005~~
6		250mL, P	DW	*			X		006
7 Kitchen Back Sink #1 HS Supply	8/5/24 2:00pm	250mL, P	DW	*			X	8/5/24 5:45a	~~007~~ 005
8		250mL, P	DW	*			X		008
9		250mL, P	DW	*			X		009
10		250mL, P	DW	*			X		010
11		250mL, P	DW	*			X		011
12		250mL, P	DW	*			X		012

SAMPLE RECEIPT (Lab Use Only)	Date	Time	Sample Relinquished By (SIGN HERE)	Samples Received By
Samples Intact? YES	8/6/24	1139		
Filled to proper volume? YES				
# of Containers 5				

2408-24464

Champlain Valley Edu Services
Lead in School Taps, TICSD

* Samples preserved with NHO3 to pH < 2 after receipt at the lab.

Note: Results are emailed to the Health Department at the same time as the client unless otherwise noted on the COC.

OFFICE USE ONLY
Analysis Fee $ _____ or A/R
Terms are net 30 days with.
Payment Method ☐ Cash ☐ Check ☐ MC/Visa ☐ Money Order Check, MO, Receipt # _____