



Laboratory Report

E/M Retest

Champlain Valley Edu Services 200674
1585 Military Turnpike
Plattsburgh, NY 12901

Atten: Stephanie Trombly

PROJECT: Lead in School Taps, Ti Elem
WORK ORDER: 2406-16875
DATE RECEIVED: June 11, 2024
DATE REPORTED: June 28, 2024
SAMPLER: Gary Olcott

Enclosed please find the results of the analyses performed for the samples referenced on the attached chain of custody located at the end of this report.

The column labeled Lab/Tech in the accompanying report denotes the laboratory facility where the testing was performed and the technician who conducted the assay. A "W" designates the Williston, VT lab under NELAC certification ELAP 11263; "R" designates the Lebanon, NH facility under certification NH 2037 and "N" the Plattsburgh, NY lab under certification ELAP 11892. "Sub" indicates the testing was performed by a subcontracted laboratory. The accreditation status of the subcontracted lab is referenced in the corresponding NELAC and Qual fields.

This NELAC column also denotes the accreditation status of each laboratory for each reported parameter. "A" indicates the referenced laboratory is NELAC accredited for the parameter reported. "N" indicates the laboratory is not accredited. "U" indicates that NELAC does not offer accreditation for that parameter in that specific matrix. Test results denoted with an "A" meet all National Environmental Laboratory Accreditation Program requirements except where denoted by pertinent data qualifiers. Test results are representative of the samples as they were received at the laboratory.

Endyne, Inc. warrants, to the best of its knowledge and belief, the accuracy of the analytical test results contained in this report, but makes no other warranty, expressed or implied, especially no warranties of merchantability or fitness for a particular purpose.

Reviewed by:

Christina A Lafountain
Laboratory Director Plattsburgh, NY



160 James Brown Dr., Williston, VT 05495
Ph 802-879-4333 Fax 802-879-7103

www.endynelabs.com

315 New York Rd., Plattsburgh, NY 12903
Ph 518-563-1720 Fax 518-563-0052



Laboratory Report

CLIENT: Champlain Valley Edu Services
 PROJECT: Lead in School Taps, Ti Elem

WORK ORDER: 2406-16875
 DATE RECEIVED: 6/11/24

001 Site: DF Girls Lock Rm 2053 Stagnant: 10.20 Hrs Date Sampled: 6/9/24 Time: 19:58

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.0051	mg/L	EPA 200.8	6/27/24	W RSB	A	

002 Site: DF 2133 Stagnant: 10.15 Hrs Date Sampled: 6/9/24 Time: 20:00

Parameter	Result	Units	Method	Analysis Date	Lab/Tech	NELAC	Qual.
Lead, Total	0.0037	mg/L	EPA 200.8	6/27/24	W RSB	A	

Test results comply with all NELAC requirements unless otherwise noted. This Laboratory Report includes the client's COC sample documentation and shall not be reproduced except in full, without written approval of the laboratory.

Endyne, Inc. - Plattsburgh Lab

LAB USE ONLY

Due Date:

315 New York Road
Plattsburgh, NY 12903
Phone (518)563-1720

Fax (518)563-0052
info@endynelabs.com
ELAP #11892

Client: CHAMPLAIN VALLEY ED.

Account #: 200674

SAMPLE SUPPLY INFORMATION

Email Address:

PWS # TOWN OF TICONDEROGA WATER DEPT.

Contact Person: GARY OLCOTT

Project Name BOCES

Collection Address: TICONDEROGA ELEMENTARY

Phone: 518-585-7400 EXT 141

3T - Lead in Schools

116 ALEXANDRIA AVE

PO # 17-01062

City: TICONDEROGA State: NY Zip: 12883

Pag 1 of

Collector's Name: GARY OLCOTT

SAMPLE MATRIX CODES

DW=drinking water SW=Surface Water
WW=waste water SD=solid
MW=monitoring well SO=soil
HW=hazardous waste SL=sludge

Compliance? Yes
Initial Testing
or
Repeat Testing

TURNAROUND TIME REQUESTED

Standard (2-4 weeks)

Sample ID / Collection Site

Date/Time

Bottle Type / Volume

M
a
t
r
i
x

Preservation

First Draw (Y)

Flushed Line (Y)

Total Lead

Analysis Requested:

Water Last Used
(Date / Time)

Lab Use
Sample #

*1

1 DF GIRLS LOCK RM 2053 6/9/24 7:58pm

250mL, P

DW

*

X

6/9/24 9:46

001

2 DF 2133

8:00pm

250mL, P

DW

*

X

9:51

002

3

250mL, P

DW

*

X

003

4

250mL, P

DW

*

X

004

5

250mL, P

DW

*

X

005

6

250mL, P

DW

*

X

006

7

250mL, P

DW

*

X

007

8

250mL, P

DW

*

X

008

9

250mL, P

DW

*

X

009

10

250mL, P

DW

*

X

010

11

250mL, P

DW

*

X

011

12

250mL, P

DW

*

X

012

SAMPLE RECEIPT (Lab Use Only)

Date

Time

Sample Relinquished By (SIGN HERE)

Samples Received By

Samples Intact?

11 Jun 24 1154

Gary Olcott

[Signature]

Filled to proper volume?

of Containers

2406-16875

* Samples preserved with NHO3 to pH < 2 after receipt at the lab.

Note: Results are emailed to the Health Department at the same time as the client unless otherwise noted on the COC.

OFFICE USE ONLY

Analysis Fee \$

or A/R

Payment Method

Cash

Check

MC/Visa

Money Order

Check, MO, Receipt #

Terms are net 30 days with bill up front, up to date account



2406-16875

Champlain Valley Edu Services
Lead in School Taps, Ti Elem

* ID on bottle is EL DF 2052 Girls Lockw RM 11 Jun 24