

April 9, 2025

**HMC Architects Project No. 3431008**  
City of Lodi Construction application No. 2024-1249

**ADDENDUM NO. 1**  
LUSD District Warehouse Freezer Generator  
Lodi, California

---

HMC Architects

---

Capital Engineering Consultants, Inc.

1. ALL WORKMANSHIP, MATERIALS, APPLIANCES AND EQUIPMENT which may be included in the following items shall be the same relative quantity as described for similar work set forth in the original or main specifications of which these Addendum items shall be considered a part.
2. ADDENDUM SECTIONS (included with this Addendum)  
The following modify or supplement the issued bid documents.
  - A. 00 01 20 List of Schedules:
    1. Paragraph d. Construction: ADD note to read  
  
“Weekend work is not required but is permitted upon approval. This work includes a new connection and PG&E meter, so gas shut-off is not applicable.
  - B. 01 1100 Summary of Work:
    1. Section 1.3 Work by Others, Paragraph C: DELETE Item 1 and REPLACE with, “1. PG&E gas line and connection from new gas meter to public connection. General Contractor shall be responsible for the work from the meter to the remainder of the work shown.”
3. ADDENDUM DRAWINGS (included with this Addendum)  
The following modify or supplement the issued bid documents.

- A. P1.0 Plumbing Site Demolition Plan
  - 1. At generator note DELETE note in its entirety and REPLACE with  
“Location of new electric gas-fired generator 100KW, 3180CFH”

\* \* \* END OF ADDENDUM \* \* \*

*P:\Sacramento\3431 Lodi USD\008-000\_Warehouse Generator\10 Construction\03 BID\02 ADD*