



May 20, 2022

Zach Nannestad
Douglas County School District
2812 N. Highway 85
Castle Rock, CO 80109

**Re: DCSD; Roxborough Primary School
8000 Village Cr. West., Littleton, CO 80125
Radon Sampling Assessment**

Dear Mr. Nannestad:

Quality Environmental Services & Technologies Inc. (QUEST) is pleased to assist Douglas County School District with the ongoing radon survey of its schools. At your request, QUEST conducted radon testing at Roxborough Primary School, located at 8000 Village Circle West, in Littleton, Colorado.

Seventy-seven (77) AirChek radon test kits were placed on May 16, 2022, and seventy-six (76) were retrieved on May 18, 2022. One (1) test kit was missing from the Cafeteria at the time of our retrieval. The attached laboratory results specify radon concentrations to be all within the EPA guideline of 4 pCi/L for acceptable radon concentrations.

If you have any questions, or if we may be of additional assistance, please contact QUEST, Inc. at 303-935-1573. We look forward to our continued association.

Sincerely,

A handwritten signature in black ink, appearing to read "Robert A. Woellner".

Robert A. Woellner
Senior Scientist
NEHA: NRPP Certification #105324RT

A handwritten signature in black ink, appearing to read "Anatole Konowal".

Anatole Konowal
Project Manager

Attachment: Laboratory Report

Radon test result report for:**ROXBOROUGH PRIMARY SCHOOL**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11189085	A11.1	2022-05-16 @ 10:00 am	2022-05-18 @ 10:00 am	< 0.3	2022-05-19
11189086	A11.2	2022-05-16 @ 10:00 am	2022-05-18 @ 10:00 am	< 0.3	2022-05-19
11189081	A129/A9	2022-05-16 @ 10:00 am	2022-05-18 @ 10:00 am	< 0.3	2022-05-19
11196946	A143	2022-05-16 @ 11:00 am	2022-05-18 @ 11:00 am	0.6	2022-05-19
11189082	A9.1	2022-05-16 @ 10:00 am	2022-05-18 @ 10:00 am	< 0.3	2022-05-19
11189083	A9.2	2022-05-16 @ 10:00 am	2022-05-18 @ 10:00 am	< 0.3	2022-05-19
11189084	B101 (ART)	2022-05-16 @ 10:00 am	2022-05-18 @ 10:00 am	< 0.3	2022-05-19
11189090	B102	2022-05-16 @ 10:00 am	2022-05-18 @ 10:00 am	< 0.3	2022-05-19
11189087	B102	2022-05-16 @ 10:00 am	2022-05-18 @ 10:00 am	0.6	2022-05-19
11189089	B103 (BLANK)	2022-05-16 @ 10:00 am	2022-05-18 @ 10:00 am	< 0.3	2022-05-19
11189088	B103 (DUPLICATE)	2022-05-16 @ 10:00 am	2022-05-18 @ 10:00 am	< 0.3	2022-05-19
11189091	B105	2022-05-16 @ 10:00 am	2022-05-18 @ 10:00 am	< 0.3	2022-05-19
11189092	B112	2022-05-16 @ 10:00 am	2022-05-18 @ 10:00 am	< 0.3	2022-05-19
11196905	B123	2022-05-16 @ 10:00 am	2022-05-18 @ 11:00 am	< 0.3	2022-05-19
11196906	B126	2022-05-16 @ 10:00 am	2022-05-18 @ 11:00 am	0.5	2022-05-19
11196910	B127	2022-05-16 @ 10:00 am	2022-05-18 @ 11:00 am	0.6	2022-05-19
11196907	B129	2022-05-16 @ 10:00 am	2022-05-18 @ 11:00 am	0.5	2022-05-19
11196909	B129 (BLANK)	2022-05-16 @ 10:00 am	2022-05-18 @ 11:00 am	< 0.3	2022-05-19
11196908	B129 (DUPLICATE)	2022-05-16 @ 10:00 am	2022-05-18 @ 11:00 am	< 0.3	2022-05-19
11196911	B130	2022-05-16 @ 10:00 am	2022-05-18 @ 11:00 am	0.5	2022-05-19
11196912	B132	2022-05-16 @ 10:00 am	2022-05-18 @ 11:00 am	0.5	2022-05-19
11196913	B134	2022-05-16 @ 10:00 am	2022-05-18 @ 11:00 am	< 0.3	2022-05-19
11196914	B135	2022-05-16 @ 10:00 am	2022-05-18 @ 11:00 am	0.5	2022-05-19
11196915	B137	2022-05-16 @ 10:00 am	2022-05-18 @ 11:00 am	< 0.3	2022-05-19
11196916	B146	2022-05-16 @ 10:00 am	2022-05-18 @ 11:00 am	< 0.3	2022-05-19
11196917	B147	2022-05-16 @ 10:00 am	2022-05-18 @ 11:00 am	< 0.3	2022-05-19
11196932	B150 - LIBRARY	2022-05-16 @ 11:00 am	2022-05-18 @ 11:00 am	< 0.3	2022-05-19
11196920	B157 = A21	2022-05-16 @ 11:00 am	2022-05-18 @ 11:00 am	< 0.3	2022-05-19
11196931	B158 - LIBRARY	2022-05-16 @ 11:00 am	2022-05-18 @ 11:00 am	0.5	2022-05-19
11196918	B159	2022-05-16 @ 10:00 am	2022-05-18 @ 11:00 am	< 0.3	2022-05-19
11196919	B159 (DUPLICATE)	2022-05-16 @ 10:00 am	2022-05-18 @ 11:00 am	< 0.3	2022-05-19
11196934	B160	2022-05-16 @ 11:00 am	2022-05-18 @ 11:00 am	< 0.3	2022-05-19
11196935	B160 - TIME OUT ROOM	2022-05-16 @ 11:00 am	2022-05-18 @ 11:00 am	< 0.3	2022-05-19
11196936	B162	2022-05-16 @ 11:00 am	2022-05-18 @ 11:00 am	< 0.3	2022-05-19
11196937	B162 - OFFICE 1	2022-05-16 @ 11:00 am	2022-05-18 @ 11:00 am	< 0.3	2022-05-19
11196938	B162 - OFFICE 2 (MIDDLE)	2022-05-16 @ 11:00 am	2022-05-18 @ 11:00 am	< 0.3	2022-05-19
11196939	B162 - OFFICE 2 (MIDDLE) (DUPLICATE)	2022-05-16 @ 11:00 am	2022-05-18 @ 11:00 am	< 0.3	2022-05-19

Radon test result report for:**ROXBOROUGH PRIMARY SCHOOL**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11196940	B162 CONT. ROOM	2022-05-16 @ 11:00 am	2022-05-18 @ 11:00 am	0.5	2022-05-19
11196921	C101	2022-05-16 @ 11:00 am	2022-05-18 @ 11:00 am	< 0.3	2022-05-19
11196922	C103	2022-05-16 @ 11:00 am	2022-05-18 @ 11:00 am	< 0.3	2022-05-19
11196923	C104	2022-05-16 @ 11:00 am	2022-05-18 @ 11:00 am	0.6	2022-05-19
11196924	C106	2022-05-16 @ 11:00 am	2022-05-18 @ 11:00 am	< 0.3	2022-05-19
11196925	C108	2022-05-16 @ 11:00 am	2022-05-18 @ 11:00 am	< 0.3	2022-05-19
11196927	C110	2022-05-16 @ 11:00 am	2022-05-18 @ 11:00 am	< 0.3	2022-05-19
11196926	C111	2022-05-16 @ 11:00 am	2022-05-18 @ 11:00 am	< 0.3	2022-05-19
11196928	C113	2022-05-16 @ 11:00 am	2022-05-18 @ 11:00 am	0.6	2022-05-19
11196930	C113 (BLANK)	2022-05-16 @ 11:00 am	2022-05-18 @ 11:00 am	< 0.3	2022-05-19
11196929	C113 (DUPLICATE)	2022-05-16 @ 11:00 am	2022-05-18 @ 11:00 am	0.6	2022-05-19
11196945	CAFETERIA	2022-05-16 @ 11:00 am	2022-05-18 @ 11:00 am	< 0.3	2022-05-19
11189093	D101	2022-05-16 @ 10:00 am	2022-05-18 @ 10:00 am	< 0.3	2022-05-19
11189094	D103	2022-05-16 @ 10:00 am	2022-05-18 @ 10:00 am	< 0.3	2022-05-19
11189095	D104	2022-05-16 @ 10:00 am	2022-05-18 @ 10:00 am	< 0.3	2022-05-19
11189096	D106	2022-05-16 @ 10:00 am	2022-05-18 @ 10:00 am	< 0.3	2022-05-19
11189097	D108	2022-05-16 @ 10:00 am	2022-05-18 @ 10:00 am	0.7	2022-05-19
11189100	D112	2022-05-16 @ 10:00 am	2022-05-18 @ 10:00 am	< 0.3	2022-05-19
11196901	D113	2022-05-16 @ 10:00 am	2022-05-18 @ 11:00 am	0.6	2022-05-19
11196903	D115	2022-05-16 @ 10:00 am	2022-05-18 @ 11:00 am	< 0.3	2022-05-19
11196902	D116	2022-05-16 @ 10:00 am	2022-05-18 @ 11:00 am	< 0.3	2022-05-19
11196904	D118	2022-05-16 @ 10:00 am	2022-05-18 @ 11:00 am	< 0.3	2022-05-19
11196942	GYM (A136)	2022-05-16 @ 11:00 am	2022-05-18 @ 11:00 am	0.5	2022-05-19
11196941	GYM (A136)	2022-05-16 @ 11:00 am	2022-05-18 @ 11:00 am	0.6	2022-05-19
11196933	LIBRARY ROOM BEHIND DESK	2022-05-16 @ 11:00 am	2022-05-18 @ 11:00 am	< 0.3	2022-05-19
11189071	OFFICE A104	2022-05-16 @ 9:00 am	2022-05-18 @ 10:00 am	< 0.3	2022-05-19
11189072	OFFICE A106	2022-05-16 @ 9:00 am	2022-05-18 @ 10:00 am	< 0.3	2022-05-19
11189073	OFFICE A107	2022-05-16 @ 9:00 am	2022-05-18 @ 10:00 am	< 0.3	2022-05-19
11189076	OFFICE A109	2022-05-16 @ 9:00 am	2022-05-18 @ 10:00 am	0.5	2022-05-19
11189075	OFFICE A111	2022-05-16 @ 9:00 am	2022-05-18 @ 10:00 am	< 0.3	2022-05-19
11189074	OFFICE A113	2022-05-16 @ 9:00 am	2022-05-18 @ 10:00 am	< 0.3	2022-05-19
11189098	OFFICE IN D108/D112	2022-05-16 @ 10:00 am	2022-05-18 @ 10:00 am	< 0.3	2022-05-19
11189099	OFFICE IN D108/D112 (DUPLICATE)	2022-05-16 @ 10:00 am	2022-05-18 @ 10:00 am	< 0.3	2022-05-19
11196943	OFFICE IN GYM (A8.3	2022-05-16 @ 11:00 am	2022-05-18 @ 11:00 am	< 0.3	2022-05-19
11189070	OFFICE RECEPTION	2022-05-16 @ 9:00 am	2022-05-18 @ 10:00 am	< 0.3	2022-05-19
11189077	PRESCHOOL	2022-05-16 @ 9:00 am	2022-05-18 @ 10:00 am	0.6	2022-05-19
11189078	PRESCHOOL A (120)	2022-05-16 @ 10:00 am	2022-05-18 @ 10:00 am	< 0.3	2022-05-19

May 19, 2022

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:

ROXBOROUGH PRIMARY SCHOOL

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11189080	PRESCHOOL A123	2022-05-16 @ 10:00 am	2022-05-18 @ 10:00 am	0.7	2022-05-19
11189079	PRESCHOOL D	2022-05-16 @ 10:00 am	2022-05-18 @ 10:00 am	< 0.3	2022-05-19

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498