

Comprehensive Fire Safety, Casualty Safety and Sanitation Report

District: Pinellas County Schools

Local Municipal Inspection Authority:

St. Petersburg Fire & Rescue
400 Dr. MLK Jr. St S.
St. Petersburg, 33701
727 893-7694

Fiscal Year: 2024-2025

Inspection Date: 11/14/2024

Scheduled Reinspection Date :

Facility: Bear Creek ES

FISH #: 72-16900-00001

Address: 350 61st. St. S
St. Petersburg, 33707

727 893-2332

Facility Type: K-6 (Elementary)

Area: 3

State Inspector: Chris Hengstenberg

Inspector #: 144425

Office of:

WPSC
11111 S. Belcher Rd
Largo, 33773
727 547-7100

Print Date: 12/18/2024

Legend:

Citations from Code:

FAC 69A-58 = Fire Safety Standards and Requirements for Educational and Ancillary Facilities and Plants (Florida Administrative Code)

SREF = State Requirements for Educational Facilities (2012), Chapter 5

NFPA = National Fire Protection Association

Deficiency Type and Corrective Action Planned and Schedule:

O = Operation of Plant -- School Responsibility to complete within 7 days of receipt of inspection report

M = Maintenance of Plant -- 90 days to complete after Inspection Date

C = Capital Outlay -- June 30 of fiscal year or becomes part of Plan of Correction

Validated = Correction verified by a certified inspector

Complete:

Y = Yes

N = No

Priority:

1 = Serious

2 = High

3 = Moderate

4 = Low

5 = Minimal

Category:

A = Fire Safety

B = Casualty Safety and Sanitation

Fire Exit Drill Requirements:

NFPA 101-15.7.2.3(1): Elementary schools shall conduct 6 fire and 6 emergency drills every school year; middle and high schools shall conduct 4 fire and 6 emergency drills every school year.

NFPA 101-15.7.2.3(3): The first fire and emergency drills shall take place within the first ten (10) days of school.

Certifications of Compliance with Florida Statutes:

District **HAS** complied with section 1013.12(2)(d) of Florida Statutes regarding plan of action and schedule for correction of each fire safety deficiency.

Local Authority **HAS** complied with section 1013.12(2)(d) of Florida Statutes regarding plan of action and schedule for correction of each fire safety deficiency

Required Exit Drills Completed as of this inspection date.

Signatures:

Signature of Facility Administrator Acknowledging Awareness of Discovered Deficiencies: _____ Date: _____

Signature of Facility Administrator Verifying Required Exit Drills Completed: _____ Date: _____

Signature of School District Inspector Reporting Deficiencies: _____ Date: _____

Signature of Local Municipal Inspection Authority Inspector Reporting Deficiencies (if Applicable): _____ Date: _____

**Comprehensive Fire Safety, Casualty
Safety and Sanitation Report**

Date Inspected: 11/14/2024

Facility: Bear Creek ES

Fiscal Year: 2024-2025

Citation	Priority Category	Bldg Room	State Bldg Nbr	Deficiency Description and Corrective Action Required <i>Inspector's Notes, if any.</i> Location of Deficiency, if specified.	Defic Type Violat n Code	Prev Years Cited	Work Order # Est Comple Date	Date Corrected Date Validated	Comple t
NFPA 72-10.6.5.2.1	3 A	B001 008	0	Branch circuit disconnecting means location shall be permanently identified at the control unit. <i>SHALL INSTALL RED-COLORED BREAKER LOCK</i>	O 499	0			N
NFPA 101-9.6.1.3	2 A	B001 008	0	FACP indicates trouble condition. Shall have system repaired as soon as possible. <i>'COMM FAULT BLDG 2/003 HEAT' TROUBLE SIGNAL. SHALL FOLLOW UP WITH SAI.</i>	M 407	0			N
NFPA 72-14.3.4	2 A	B001 008	0	Fire alarm system is overdue for required annual inspection and testing.	M 402	0			N
NFPA 1-11.1.5.2	2 A	B001 010	0	Plug appliance directly into outlet. Do not use extension cord.	O 804	0			N
NFPA 101-7.9.1.1	2 A	B002 001	0	Repair/replace emergency light. <i>DINING ROOM 2ND YEAR</i>	M 204	0			N
SREF-5(9)(a)1	3 A	B003 002	0	Decorations and loosely hanging items forbidden, shall be flame resistant.	O 399	0			N
NFPA 1-11.1.5.2	2 A	B003 004	0	Plug appliance directly into outlet. Do not use extension cord.	O 804	0			N
NFPA 72-14.4.5.6	3 A	B005 003	0	Replace batteries <i>BPS BATTs 2018</i>	M 404	0			N
NFPA 101-7.9.1.1	2 A	B006 004	0	Repair/replace emergency light.	M 204	0			N
NFPA 101-15.3.1.1	3 B	B008 001	0	Replace damaged ceiling tiles. <i>REPAIR HOLE</i>	M 301	0			N
FBC 453.20.4.2	2 A	B009 001	0	Repair/replace explosion-proof exhaust fan for flammable storage. <i>VERIFY IF ELECTRIC OR MECHANICAL FAN IS REQUIRED TO ADEQUATELY VENTILATE SPACE.</i>	M 1203	0			N

**Comprehensive Fire Safety, Casualty
Safety and Sanitation Report**

Date Inspected: 11/14/2024

Facility: Bear Creek ES

Fiscal Year: 2024-2025

Citation	Priority	Bldg	State Bldg Nbr	Deficiency Description and Corrective Action Required <i>Inspector's Notes, if any.</i> Location of Deficiency, if specified.	Defic Type Violat n Code	Prev Years Cited	Work Order # Est Comple t Date	Date Corrected Date Validated	Comple t
NFPA 70-406.6	2 A	B011 000	0	Replace a missing/damaged electrical cover plate. <i>OUTSIDE OUTLETS</i>	M 807	0			N

Number of Serious Fire Safety Citations: 0

Total number of Fire Safety, Casualty Safety and Sanitation Citations: 12

Total Number of Already Completed and Validated Items: 0