



GRANITE STATE ANALYTICAL SERVICES, LLC.

22 Manchester Road, Unit 2, Derry, NH 03038

Phone: (800) 699-9920 | (603) 432-3044

website: www.granitestateanalytical.com

DRINKING WATER COMPLIANCE REPORT

DATE PRINTED: 04/05/2019 CHEMICAL RESULTS FOR THE 2nd QUARTER 2019
SAMPLE ID#: 1904-00340-001 LAB ID#: 1015
SAMPLED BY: Primeau, Rick-PWW

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: TIMBERLANE REGIONAL HS
SYSTEM TOWN: Plaistow
SAMPLE AGENT #: 603-913-2378
SAMPLE LOCATION: 511 DEP Tap AF Trtmt/Boiler Room/001
BAR CODE: 20190328071-001

EPA ID #: 1935030
DATE & TIME COLLECTED: 04/02/2019 10:30AM
DATE & TIME RECEIVED: 04/03/2019 9:15AM
WATER SYS TYPE: Non-Transient, Non-Community
RECEIPT TEMP: ON ICE 3.8° CELSIUS
CLIENT JOB #

Legend	
Passes	✓
Fails EPA Primary	⊗
Fails EPA Secondary	▽
Fails State Guideline	✕
Attention	⚠

Test Description	Results	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
Arsenic*	0.0079	mg/L	✓		0.001	0.010 mg/L	EPA 200.8	JLR-NH	04/04/19 7:17PM

The results presented in this report relate to the samples listed above in the condition in which they were received.
RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.

Data Qualifier (DQ) Flags: None

* NELAP Accredited Analysis



Donald A. D'Anjou, Ph. D.
Laboratory Director

This analysis meets NELAP requirements except as noted.

State Certifications: | NH 1015 | MA M-NH003 | ME NH00003 | RI 101513 | VT VT-101507 |

This certificate shall not be reproduced, except in full, without the written approval of Granite State Analytical Services, LLC



GRANITE STATE ANALYTICAL SERVICES, LLC.

22 Manchester Road, Unit 2, Derry, NH 03038
Phone: (800) 699-9920 | (603) 432-3044 website: www.granitestateanalytical.com

DRINKING WATER COMPLIANCE REPORT

DATE PRINTED: 04/08/2019 CHEMICAL RESULTS FOR THE 2nd QUARTER 2019
SAMPLE ID#: 1904-00341-001 LAB ID#: 1015
SAMPLED BY: Primeau, Rick-PWW

Legend	
Passes	✓
Fails EPA Primary	⊗
Fails EPA Secondary	▽
Fails State Guideline	✕
Attention	⚠

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: TIMBERLANE REGIONAL HS EPA ID #: 1935030
SYSTEM TOWN: Plaistow DATE & TIME COLLECTED: 04/02/2019 10:15AM
SAMPLE AGENT #: 603-913-2378 DATE & TIME RECEIVED: 04/03/2019 9:15AM
SAMPLE LOCATION: 322 Handwash Sink/Kitchen WATER SYS TYPE: Non-Transient, Non-Community
RECEIPT TEMP: ON ICE 3.8° CELSIUS
BAR CODE: 20190327159-001 CLIENT JOB #

Test Description	Results	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
Bromodichloromethane*	2.8	ug/L			0.5	No Limit	EPA 524.3	WS-NH	04/04/19 8:29AM
Bromoform*	<0.5	ug/L			0.5	No Limit	EPA 524.3	WS-NH	04/04/19 8:29AM
Chloroform*	2.9	ug/L			0.5	No Limit	EPA 524.3	WS-NH	04/04/19 8:29AM
Dibromochloromethane*	1.8	ug/L			0.5	No Limit	EPA 524.3	WS-NH	04/04/19 8:29AM
Total THMs*	7.5	ug/L	✓		0.5	80 ug/L	EPA 524.3	WS-NH	04/04/19 8:29AM
1,2-Dichlorobenzene-d4	103	%	✓		0.5	70-130%	EPA 524.3 - SS	WS-NH	04/04/19 8:29AM
4-Bromofluorobenzene	105	%	✓		0.5	70-130%	EPA 524.3 - SS	WS-NH	04/04/19 8:29AM
Methyl tert-Butyl Ether-d3	101	%	✓		0.5	70-130%	EPA 524.3 - SS	WS-NH	04/04/19 8:29AM
Date Extracted	-					No Limit	EPA 552.2	TA-NH	04/05/19 9:05AM
Dibromoacetic Acid*	<1	ug/L			1	No Limit	EPA 552.2	KV-NH	04/06/19 1:08AM
Dichloroacetic Acid*	1.2	ug/L			1	No Limit	EPA 552.2	KV-NH	04/06/19 1:08AM
Monobromoacetic Acid*	<1	ug/L			1	No Limit	EPA 552.2	KV-NH	04/06/19 1:08AM
Monochloroacetic Acid*	<2	ug/L			2	No Limit	EPA 552.2	KV-NH	04/06/19 1:08AM
Total Haloacetic Acids*	1.2	ug/L	✓		1	60 ug/L	EPA 552.2	KV-NH	04/06/19 1:08AM
Trichloroacetic Acid*	<1	ug/L			1	No Limit	EPA 552.2	KV-NH	04/06/19 1:08AM
2,3-Dibromopropionic Acid	98	%	✓			70-130%	EPA 552.2 - SS	KV-NH	04/06/19 1:08AM

The results presented in this report relate to the samples listed above in the condition in which they were received.
RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.

Data Qualifier (DQ) Flags: None

* NELAP Accredited Analysis



Donald A. D'Anjou, Ph. D.
Laboratory Director



GRANITE STATE ANALYTICAL SERVICES, LLC.

22 Manchester Road, Unit 2, Derry, NH 03038
Phone: (800) 699-9920 | (603) 432-3044 website: www.granitestateanalytical.com

DRINKING WATER COMPLIANCE REPORT

DATE PRINTED: 04/08/2019 CHEMICAL RESULTS FOR THE 2nd QUARTER 2019
SAMPLE ID#: 1904-00341-002 LAB ID#: 1015
SAMPLED BY: Primeau, Rick-PWW

Legend	
Passes	✓
Fails EPA Primary	⊗
Fails EPA Secondary	▽
Fails State Guideline	✕
Attention	!

SAMPLE CATEGORY: Routine Sample
SYSTEM NAME: TIMBERLANE REGIONAL HS EPA ID #: 1935030
SYSTEM TOWN: Plaistow DATE & TIME COLLECTED: 04/02/2019 10:00AM
SAMPLE AGENT #: 603-913-2378 DATE & TIME RECEIVED: 04/03/2019 9:15AM
SAMPLE LOCATION: 321 Nurses Sink Kitchen WATER SYS TYPE: Non-Transient, Non-Community
RECEIPT TEMP: ON ICE 3.8° CELSIUS
BAR CODE: 20190327159-002 CLIENT JOB #

Test Description	Results	Test Units	Pass /Fail	DQ Flag	RL	Limit	Method	Analyst	Date & Time Analyzed
Bromodichloromethane*	2.8	ug/L			0.5	No Limit	EPA 524.3	WS-NH	04/04/19 8:52AM
Bromoform*	<0.5	ug/L			0.5	No Limit	EPA 524.3	WS-NH	04/04/19 8:52AM
Chloroform*	3.2	ug/L			0.5	No Limit	EPA 524.3	WS-NH	04/04/19 8:52AM
Dibromochloromethane*	2.1	ug/L			0.5	No Limit	EPA 524.3	WS-NH	04/04/19 8:52AM
Total THMs*	8.1	ug/L	✓		0.5	80 ug/L	EPA 524.3	WS-NH	04/04/19 8:52AM
1,2-Dichlorobenzene-d4	101	%	✓		0.5	70-130%	EPA 524.3 - SS	WS-NH	04/04/19 8:52AM
4-Bromofluorobenzene	104	%	✓		0.5	70-130%	EPA 524.3 - SS	WS-NH	04/04/19 8:52AM
Methyl tert-Butyl Ether-d3	100	%	✓		0.5	70-130%	EPA 524.3 - SS	WS-NH	04/04/19 8:52AM
Date Extracted	-					No Limit	EPA 552.2	TA-NH	04/05/19 9:05AM
Dibromoacetic Acid*	<1	ug/L			1	No Limit	EPA 552.2	KV-NH	04/06/19 1:48AM
Dichloroacetic Acid*	1.4	ug/L			1	No Limit	EPA 552.2	KV-NH	04/06/19 1:48AM
Monobromoacetic Acid*	<1	ug/L			1	No Limit	EPA 552.2	KV-NH	04/06/19 1:48AM
Monochloroacetic Acid*	<2	ug/L			2	No Limit	EPA 552.2	KV-NH	04/06/19 1:48AM
Total Haloacetic Acids*	1.4	ug/L	✓		1	60 ug/L	EPA 552.2	KV-NH	04/06/19 1:48AM
Trichloroacetic Acid*	<1	ug/L			1	No Limit	EPA 552.2	KV-NH	04/06/19 1:48AM
2,3-Dibromopropionic Acid	99	%	✓			70-130%	EPA 552.2 - SS	KV-NH	04/06/19 1:48AM

The results presented in this report relate to the samples listed above in the condition in which they were received.
RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.

Data Qualifier (DQ) Flags: None

* NELAP Accredited Analysis



Donald A. D'Anjou, Ph. D.
Laboratory Director

PENNICHUCK WATER WORKS LAB

200 Concord St., Nashua, NH 03064

603-913-2377

Lab Contact: Matthew Day, Laboratory Manager

Date Printed: April 03, 2019

NH Laboratory ID # 1030

DRINKING WATER BACTERIA REPORT Bacteria Results for the Month of: April 2019

Receipt Temperature: on ice at 14°Celsius

SYSTEM NAME: TIMBERLANE REGIONAL HS WATER SYSTEM TYPE: NC/NT

Method: SM 9223 B Colilert 18 *

EPA #: 1935030

SAMPLE TOWN: Plaistow

SAMPLE PURPOSE: RT

SAMPLING AGENT: Rick Primeau

SAMPLING AGENT PHONE #: 603-913-2378

CHLORINATED SYSTEM: Yes

Test Units: P-A/100mL

Analyst: Jane Vukelich

Date & Time Received: 04-02-19/14:44

Received By: Jane Vukelich

Site ID #	Sample Location	Chlorine Residual	Sample ID Number	Date & Time Collected	Date & Time Prepared	Date & Time Analyzed	Total Coliform	E. Coli
001	Nurses Sink	0.30	20190327158-002	04-02-19/10:00	04-02-19/14:46	04-03-19/11:46	ABSENT	ABSENT
002	HANDWASH SINK /KITCHEN	0.43	20190327158-001	04-02-19/10:15	04-02-19/14:46	04-03-19/11:46	ABSENT	ABSENT

NCX1
Charge X1

Comments:

*NELAC Accredited Analysis

Page 1 of 1

Authorized by:

MM 4-3-19