

# Notice: Lead Water Test Information

January 12, 2023

Dear Parents, Guardians, and Staff,

We are writing to let you know that Timberlane Regional Middle School recently completed testing for lead in drinking water. This is part of an ongoing effort related to New Hampshire’s House Bill 1421, which requires school and childcare facilities to test for lead in drinking water and to act when lead is found at levels at or above 5 parts per billion (ppb).

Lead is a toxic heavy metal that has a range of adverse health effects if inhaled or swallowed. Lead typically enters drinking water due to the wearing away of piping, faucets, fixtures, and other plumbing materials. Lead rarely occurs naturally in New Hampshire’s drinking water sources (groundwater or surface water).

Because lead is tasteless, odorless, and colorless in drinking water, testing is a way to learn whether lead is present. It is important to sample each faucet or water fountain that is used for drinking or food prep because test results can vary between locations.

During recent testing, we collected samples from 104 water outlets (e.g., drinking fountains, classroom faucets, kitchen sinks), with 45 samples testing at or above 5 ppb, the level where action must be taken.

We have removed access to these outlets until the problem can be corrected. To view a list of all the tested outlets, their locations, sample results and our planned remediation see the list below:

Facility ID	Location / Room Number	Result(s) (ppb)	Remediation
22760-1	213	10.9 ppb	Posted For Handwashing Only
22760-2	100 AG rr	1.52 ppb	
22760-3	100 a grr left Drinking fountain	16.8 ppb	Posted For Handwashing Only
22760-5	Agrr rt	2.51 ppb	
22760-6	102-1 Drinking fountain	BRL	

22760-7	102b staff-2	37.5 ppb	Posted For Handwashing Only
22760-8	102f-3	2.58 ppb	
22760-9	102f-4	17.7 ppb	Posted For Handwashing Only
22760-10	102f right-5	3.5 ppb	
22760-11	102f left-6	3.49 ppb	
22760-12	102f kettle-7	0.919 ppb	
22760-13	102f single-9	3.68 ppb	
22760-14	102f hand	10.3 ppb	Posted For Handwashing Only
22760-15	110b Drinking fountain	0.417 ppb	
22760-16	Boys locker room	1.77 ppb	
22760-17	Glr-1104 Drinking Fountain	7.42 ppb	Posted For Handwashing Only
22760-18	Glr-1105	5.27 ppb	Posted For Handwashing Only
22760-19	Glr-1105	11.3 ppb	Posted For Handwashing Only
22760-20	110b lr	6.64 ppb	Posted For Handwashing Only
22760-22	200-2	0.668 ppb	
22760-23	200-3	BRL	
22760-26	204 sisters closet-6	178 ppb	Posted For Handwashing Only
22760-27	213 left-7 Drinking Fountain	BRL	
22760-29	213 200 girls rest room-9	BRL	

22760-30	201-1	7.89 ppb	Posted For Handwashing Only
22760-31	204-1	3.52 ppb	
22760-32	204-2	2.39 ppb	
22760-33	204-3	0.489 ppb	
22760-34	204-4	0.774 ppb	
22760-35	206-1	0.965 ppb	
22760-36	206-2	7.48 ppb	Posted For Handwashing Only
22760-37	206-3	0.537 ppb	
22760-38	206-4	0.653 ppb	
22760-39	209-1	193 ppb	Posted For Handwashing Only
22760-44	209-6	80.2 ppb	Posted For Handwashing Only
22760-45	209-7	34.9 ppb	Posted For Handwashing Only
22760-46	211-1	96.9 ppb	Posted For Handwashing Only
22760-47	211-2	121 ppb	Posted For Handwashing Only
22760-48	211-3	27 ppb	Posted For Handwashing Only
22760-51	211-6	39 ppb	Posted For Handwashing Only
22760-52	211-7	16.5 ppb	Posted For Handwashing Only

22760-54	213-1	176 ppb	Posted For Handwashing Only
22760-55	213-2	95.4 ppb	Posted For Handwashing Only
22760-56	213-4	6.19 ppb	Posted For Handwashing Only
22760-57	213-5	12 ppb	Posted For Handwashing Only
22760-58	213-6	56.5 ppb	Posted For Handwashing Only
22760-59	213-7	1.29 ppb	
22760-61	300 faculty rest room-1	0.573 ppb	
22760-62	307-2 Drinking Fountain	BRL	
22760-63	300 grr-3	9.53 ppb	Posted For Handwashing Only
22760-64	300 grr-4	3.52 ppb	
22760-65	300 grr-5	4.05 ppb	
22760-66	300 brr-6	4.59 ppb	
22760-67	400 brr-1	5.12 ppb	
22760-68	400 brr-2	4.34 ppb	
22760-69	400brr-3	3.42 ppb	
22760-70	400 brr-4	5.75 ppb	Posted For Handwashing Only
22760-71	412-1	5.38 ppb	Posted For Handwashing Only
22760-72	412-2	BRL	
22760-75	500 -3	3.03 ppb	
22760-77	500 grr-5	4.35 ppb	

22760-78	500 grr-6	5.07 ppb	Posted For Handwashing Only
22760-79	500 grr-7	2.47 ppb	
22760-80	500 grr-8	2.76 ppb	
22760-81	508 grr-9	3.65 ppb	
22760-82	600 sprayer-1	82.6 ppb	Posted For Handwashing Only
22760-83	600 faucet-2	6.02 ppb	Posted For Handwashing Only
22760-84	600 BRR-4	4.92 ppb	
22760-85	600 brr-5	3.74 ppb	
22760-86	600 brr-6	3.67 ppb	
22760-87	600 brr-7	2.07 ppb	
22760-89	602 faucet-2	15.6 ppb	Posted For Handwashing Only
22760-90	603 lft-1	4.56 ppb	
22760-92	604 left-2	6.93 ppb	Posted For Handwashing Only
22760-93	604 rt-3	3.37 ppb	
22760-94	606 rt-2	5.6 ppb	Posted For Handwashing Only
22760-95	606 spray-3	78 ppb	Posted For Handwashing Only
22760-96	607-1	10.6 ppb	Posted For Handwashing Only
22760-97	607-2	7.47 ppb	Posted For Handwashing Only
22760-98	607-3	5.96 ppb	Posted For Handwashing Only
22760-99	607-4	5.93 ppb	Posted For Handwashing Only

22760-100	607-5	3.76 ppb	
22760-101	607-6	13.8 ppb	Posted For Handwashing Only
22760-102	608-1	3.11 ppb	
22760-103	608-2	2.92 ppb	
22760-104	608 sprayer-3	27 ppb	Posted For Handwashing Only
22760-105	609-1	15.4 ppb	Posted For Handwashing Only
22760-106	610-1	9.34 ppb	Posted For Handwashing Only
22760-107	610-2	12.7 ppb	Posted For Handwashing Only
22760-108	lt pt kitchen 100c-10	0.936 ppb	
22760-109	100c bathroom-11	2.56 ppb	
22760-110	102f hand-10	7.57 ppb	
22760-111	102 womens-11	2.23 ppb	
22760-112	102 mens-12	2.84 ppb	
22760-113	200 girls rest room-10	BRL	
22760-114	213 200 grr-11	BRL	
22760-115	213 200 grr-12	4.04 ppb	
22760-117	213 brr-14	0.544 ppb	
22760-119	213 brr-16	BRL	
22760-120	508 grr-10	2.17 ppb	

22760-121	508grr-11	5.75 ppb	Posted For Handwashing Only
22760-122	508grr-12	11.1 ppb	Posted For Handwashing Only
22760-124	604 left-14 Fountain	BRL	
22760-125	211/209 lab closet	257 ppb	Posted For Handwashing Only

All sample results and additional resources from the New Hampshire Department of Environmental Services (NHDES) can be viewed at [gettheleadoutnh.org](http://gettheleadoutnh.org).

Sincerely,

Karl Ingoldsby  
Certified Building Operator  
Certified Educational Facilities Professional  
Certified School Facilities Specialist  
Director of Plant Operations  
Timberlane Regional School District  
30 Greenough Rd.  
Plaistow, NH 03865  
603-382-6541 ext:3350