

Notice: Lead Water Test Information

April 10, 2023

Dear Parents, Guardians, and Staff,

We are writing to let you know that Timberlane Regional High School recently completed testing for lead in drinking water. This is part of an ongoing effort related to New Hampshire’s House Bill 1421, which requires school and childcare facilities to test for lead in drinking water and to act when lead is found at levels at or above 5 parts per billion (ppb).

Lead is a toxic heavy metal that has a range of adverse health effects if inhaled or swallowed. Lead typically enters drinking water due to the wearing away of piping, faucets, fixtures, and other plumbing materials. Lead rarely occurs naturally in New Hampshire’s drinking water sources (groundwater or surface water).

Because lead is tasteless, odorless, and colorless in drinking water, testing is a way to learn whether lead is present. It is important to sample each faucet or water fountain that is used for drinking or food prep because test results can vary between locations.

During recent testing, we collected samples from 104 water outlets (e.g., drinking fountains, classroom faucets, kitchen sinks), with 45 samples testing at or above 5 ppb, the level where action must be taken.

We have removed access to these outlets until the problem can be corrected. To view a list of all the tested outlets, their locations, sample results and our planned re mediation see the list below:

Facility ID	Location / Room Number	Results	Results	Remediation Plans
22770-1	124	Classroom Faucet	18.8 ppb	Posted For Handwashing Only
22770-2	114	Classroom Faucet	105 ppb	Posted For Handwashing Only
22770-5	116-1	Drinking Fountain	9.72 ppb	Removed from Service
22770-7	114-4	Bathroom Faucet	0.922 ppb	Posted For Handwashing Only
22770-8	112-5	Bathroom Faucet	0.718 ppb	Posted For Handwashing Only
22770-10	100-7	Nurse's Sink	0.61 ppb	
22770-11	100-8	Nurse's Sink	0.735 ppb	

22770-12	100-9	Nurse's Sink	0.406 ppb	
22770-13	111-2	Classroom Faucet	5.59 ppb	Posted For Handwashing Only
22770-14	111-3	Classroom Faucet	3.66 ppb	
22770-15	111-4	Classroom Faucet	42.2 ppb	Posted For Handwashing Only
22770-16	111-5	Classroom Faucet	11.9 ppb	Posted For Handwashing Only
22770-17	111-6	Classroom Faucet	4.34 ppb	
22770-18	113-1	Other	2.97 ppb	
22770-19	114-1	Classroom Faucet	39.8 ppb	Posted For Handwashing Only
22770-27	116-1	Classroom Faucet	45.4 ppb	Posted For Handwashing Only
22770-28	116-2	Classroom Faucet	24.7 ppb	Posted For Handwashing Only
22770-29	116-3	Classroom Faucet	16.4 ppb	Posted For Handwashing Only
22770-30	116-4	Classroom Faucet	7.81 ppb	Posted For Handwashing Only
22770-31	116-5	Classroom Faucet	24.9 ppb	Posted For Handwashing Only
22770-32	116-6	Classroom Faucet	13 ppb	Posted For Handwashing Only
22770-33	116-7	Classroom Faucet	5.18 ppb	Posted For Handwashing Only
22770-34	116-8	Classroom Faucet	8.76 ppb	Posted For Handwashing Only
22770-35	116-9	Classroom Faucet	13.5 ppb	Posted For Handwashing Only
22770-36	118-1	Classroom Faucet	26.1 ppb	Posted For Handwashing Only
22770-37	118-2	Classroom Faucet	14.6 ppb	Posted For Handwashing Only
22770-38	118-3	Classroom Faucet	49.4 ppb	Posted For Handwashing Only
22770-39	118-4	Classroom Faucet	73.9 ppb	Posted For Handwashing Only
22770-40	118-5	Classroom Faucet	45 ppb	Posted For Handwashing Only
22770-41	118-6	Classroom Faucet	52.4 ppb	Posted For Handwashing Only
22770-42	118-7	Classroom Faucet	50.7 ppb	Posted For Handwashing Only
22770-45	120-1	Classroom Faucet	63.5 ppb	Posted For Handwashing Only
22770-46	120-2	Classroom Faucet	47.8 ppb	Posted For Handwashing Only
22770-48	120-4	Classroom Faucet	4.7 ppb	

22770-49	120-5	Classroom Faucet	1.38 ppb	
22770-50	120-6	Classroom Faucet	BRL	
22770-51	120-7	Classroom Faucet	1.46 ppb	
22770-52	120-8	Classroom Faucet	1.02 ppb	
22770-53	120-9	Classroom Faucet	1.4 ppb	
22770-54	120-10	Classroom Faucet	1.49 ppb	
22770-55	122-1	Classroom Faucet	1.23 ppb	
22770-56	122-2	Classroom Faucet	26.9 ppb	Posted For Handwashing Only
22770-57	122-3	Classroom Faucet	39.6 ppb	Posted For Handwashing Only
22770-58	122-4	Classroom Faucet	16.1 ppb	Posted For Handwashing Only
22770-59	122-5	Classroom Faucet	14.4 ppb	Posted For Handwashing Only
22770-60	122-6	Classroom Faucet	13.4 ppb	Posted For Handwashing Only
22770-61	122-7	Classroom Faucet	22.6 ppb	Posted For Handwashing Only
22770-62	122-8	Classroom Faucet	7.27 ppb	Posted For Handwashing Only
22770-64	126-2	Classroom Faucet	7.85 ppb	Posted For Handwashing Only
22770-65	126-3	Classroom Faucet	13.5 ppb	Posted For Handwashing Only
22770-66	126-4	Classroom Faucet	3.81 ppb	
22770-67	126-5	Classroom Faucet	8.17 ppb	Posted For Handwashing Only
22770-68	126-6	Classroom Faucet	13 ppb	Posted For Handwashing Only
22770-69	126-7	Classroom Faucet	9.46 ppb	Posted For Handwashing Only
22770-70	126-8	Classroom Faucet	11.7 ppb	Posted For Handwashing Only
22770-72	128-1	Bathroom Faucet	0.742 ppb	
22770-73	128-2	Bathroom Faucet	BRL	
22770-74	128-3	Bathroom Faucet	1.27 ppb	
22770-75	128-4	Bathroom Faucet	BRL	
22770-76	128-5	Bathroom Faucet	BRL	
22770-77	128-6	Bathroom Faucet	0.511 ppb	

22770-78	120-7	Drinking Fountain	0.438 ppb	
22770-79	300 boys rest room outside cafeteria	Bathroom Faucet	0.817 ppb	
22770-80	300 girls restroom left	Bathroom Faucet	0.504 ppb	
22770-81	300 girls rest room right	Bathroom Faucet	0.588 ppb	
22770-82	300 hallway fountain outside cafeteria	Drinking Fountain	BRL	
22770-104	318-1	Classroom Faucet	10.9 ppb	Posted For Handwashing Only
22770-105	318-2	Other	0.974 ppb	
22770-106	318-3	Classroom Faucet	3.69 ppb	
22770-107	318-4	Classroom Faucet	1.91 ppb	
22770-109	318-6	Classroom Faucet	3.53 ppb	
22770-110	318-7	Classroom Faucet	2.87 ppb	
22770-111	318-8	Classroom Faucet	3.01 ppb	
22770-112	318-9	Classroom Faucet	2.78 ppb	
22770-113	320-1	Classroom Faucet	2.77 ppb	
22770-114	320-2	Classroom Faucet	12.8 ppb	Posted For Handwashing Only
22770-115	320-3	Classroom Faucet	1.71 ppb	
22770-116	320-4	Classroom Faucet	2.03 ppb	
22770-121	320-9	Classroom Faucet	3.37 ppb	
22770-122	322-1	Classroom Faucet	0.582 ppb	
22770-123	322-2	Other	BRL	
22770-125	324-2	Classroom Faucet	1.3 ppb	
22770-126	326-1	Classroom Faucet	0.988 ppb	
22770-127	400-1	Kitchen Faucet	0.775 ppb	
22770-128	400-2	Drinking Fountain	BRL	
22770-129	400-3	Bathroom Faucet	BRL	
22770-130	400-4	Bathroom Faucet	0.742 ppb	
22770-131	413-5	Drinking Fountain	BRL	

22770-132	412-6	Faucet	0.607 ppb	
22770-133	402-1	Kitchen Faucet	0.426 ppb	
22770-134	402-2	Kitchen Faucet	BRL	
22770-135	402-3	Kitchen Faucet	BRL	
22770-136	402-4	Kitchen Faucet	0.535 ppb	
22770-137	402-5	Kitchen Faucet	0.575 ppb	
22770-138	402-6	Kitchen Faucet	2.15 ppb	
22770-139	412-1	Bathroom Faucet	0.699 ppb	
22770-141	412-3	Bathroom Faucet	1.34 ppb	
22770-142	413	Classroom Faucet	5.14 ppb	Posted For Handwashing Only
22770-150	600-1	Bathroom Faucet	2.88 ppb	
22770-152	600-3	Bathroom Faucet	19.6 ppb	Posted For Handwashing Only
22770-174	700-1	Bathroom Faucet	BRL	
22770-182	709-1	Bathroom Faucet	2.19 ppb	
22770-183	709-2	Bathroom Faucet	1.84 ppb	
22770-184	709-3	Bathroom Faucet	0.843 ppb	
22770-185	709-4	Bathroom Faucet	1.1 ppb	
22770-186	709-5	Bathroom Faucet	0.883 ppb	
22770-188	711-2	Bathroom Faucet	0.458 ppb	
22770-189	711-3	Bathroom Faucet	0.878 ppb	
22770-190	711-4	Bathroom Faucet	1.22 ppb	
22770-194	714	Bathroom Faucet	1.29 ppb	
22770-206	111-11	Classroom Faucet	26.3 ppb	Posted For Handwashing Only
22770-213	116-10	Classroom Faucet	13.5 ppb	Posted For Handwashing Only
22770-214	116-11	Classroom Faucet	18.8 ppb	Posted For Handwashing Only
22770-215	116-12	Classroom Faucet	8.46 ppb	Posted For Handwashing Only
22770-216	116-13	Classroom Faucet	14.5 ppb	Posted For Handwashing Only

22770-217	116-14	Classroom Faucet	20.1 ppb	Posted For Handwashing Only
22770-218	120-10	Classroom Faucet	2.34 ppb	
22770-219	120-11	Classroom Faucet	0.639 ppb	
22770-220	120-12	Classroom Faucet	1.5 ppb	
22770-224	122-10	Classroom Faucet	8.77 ppb	Posted For Handwashing Only
22770-225	122-11	Classroom Faucet	11.3 ppb	Posted For Handwashing Only
22770-226	122-12	Classroom Faucet	13.2 ppb	Posted For Handwashing Only
22770-228	122-14	Other	20.1 ppb	Posted For Handwashing Only
22770-230	126-10	Classroom Faucet	13.1 ppb	Posted For Handwashing Only
22770-231	126-11	Classroom Faucet	9.9 ppb	Posted For Handwashing Only
22770-232	126-12	Classroom Faucet	10.4 ppb	Posted For Handwashing Only
22770-233	126-13	Classroom Faucet	15.7 ppb	Posted For Handwashing Only
22770-234	126-14		15.7 ppb	Posted For Handwashing Only
22770-235	318-10	Classroom Faucet	1.74 ppb	
22770-236	318-11	Classroom Faucet	1.36 ppb	
22770-237	318-12	Classroom Faucet	4.7 ppb	
22770-238	318-13	Classroom Faucet	3.35 ppb	
22770-239	318-14	Classroom Faucet	5.62 ppb	Posted For Handwashing Only
22770-274	400-402	Classroom Faucet	92.5 ppb	Posted For Handwashing Only

All sample results and additional resources from the New Hampshire Department of Environmental Services (NHDES) can be viewed at gettheleadoutnh.org.

Please note that additional testing will be completed over the April Break and results will again be posted, this will be for the remaining outlets that were not sampled.

Sincerely,

Karl Ingoldsby
 Certified Building Operator
 Certified Educational Facilities Professional
 Certified School Facilities Specialist

Director of Plant Operations
Timberlane Regional School District
30 Greenough Rd.
Plaistow, NH 03865
603-382-6541 ext:3350