




The State of New Hampshire  
**Department of Environmental Services**



Robert R. Scott, Commissioner

July 25, 2024

JUSTIN KRIEGER  
TIMBERLANE SCHOOL DISTRICT  
30 GREENOUGH RD  
PLAISTOW NH 03865

*Via email:*

justin.krieger@timberlane.net

Subject: PWS ID: 0115010 -- Public Water Sys: ATKINSON ACADEMY SCH Town: ATKINSON  
**Lead and Copper Sampling Reduction**

Dear Owner:

The New Hampshire Department of Environmental Services (NHDES) is in receipt of the lead and copper sample results for the monitoring period July 1, 2024 – September 30, 2024. Your calculated 90<sup>th</sup> percentile values are:

90 <sup>th</sup> Percentile for Lead:	0.004 mg/L
90 <sup>th</sup> Percentile for Copper:	0.307 mg/L

Based on your service population and your compliance status with this department, NHDES approves reduction of your lead and copper sampling frequency.

**Your next round of samples will be due in: 2027**

**You must now sample once every 3 years in your assigned quarter: Q3 JUL 1 - SEPT 30**

**The number of samples required will be: 5**

Your Master Sampling Schedule and all analysis request forms are available on the NHDES [OneStop](#). Simply [click here](#) and enter the PWSID. Further information about select topics is available in multiple [NHDES Fact Sheets](#).

Please note, bi-weekly monitoring of Routine Water Quality Parameters (RWQP) is still required, but operator logs do not need to be submitted to NHDES unless the system has another action level exceedance. Please email your last RWQP log for the current compliance period to [dwmonitoring@des.nh.gov](mailto:dwmonitoring@des.nh.gov).

As always, we recommend that you sample early in your designated compliance period in case additional samples are needed. If access is no longer possible to your site(s) or the resident no longer wishes to participate in the program, please contact this office in writing to request a sample site change.

Please contact me at (603) 271-2516 or [dwmonitoring@des.nh.gov](mailto:dwmonitoring@des.nh.gov) with any questions.

Sincerely,

Sarah Richos  
Lead and Copper Program  
Drinking Water and Groundwater Bureau

cc: DONALD WARE, Primary Operator  
KARL INGOLDSBY, Primary Contact