

A & P Water Testing
P.O. Box 925
Morrisville, NY 13408
315-684-3169

NYS DOH ELAP-Accredited Certification ID#: 11405

Analysis Report For:

Brookfield Central School
1910 Fairground Road
Brookfield, NY 13314

Report Number: 252339

Page 1/3

Sample Number: 09102507C Collection Date: 09/10/25 Collection Time: 6:00 am Date Received: 09/10/25 Time Received: 4:05 pm Matrix: Potable Water	Sample ID: Brookfield Central School Brookfield, NY Location: Gym hall fountain Sample Collector: K. Plows Brookfield Central School
---	---

<u>Method & Parameter</u>	<u>Result & Qualifiers</u>	<u>Units</u>	<u>Analysis Date/Time</u>	
EPA 200.7			<u>Prep Date</u>	<u>Analysis Date</u>
Copper, Total (Cu)	0.128	mg/L	09/12/25	09/22/25
<i>Analyzed by ELAP ID#: 11246</i>				
EPA 200.8				
Lead, Total (Pb)	0.0012	mg/L	09/17/25	09/17/25
<i>Analyzed by ELAP ID#: 10478</i>				

Sample Number: 09102508C Collection Date: 09/10/25 Collection Time: 6:05 am Date Received: 09/10/25 Time Received: 4:05 pm Matrix: Potable Water	Sample ID: Brookfield Central School Brookfield, NY Location: 6 th grade hall fountain Sample Collector: K. Plows Brookfield Central School
---	---

<u>Method & Parameter</u>	<u>Result & Qualifiers</u>	<u>Units</u>	<u>Analysis Date/Time</u>	
EPA 200.7			<u>Prep Date</u>	<u>Analysis Date</u>
Copper, Total (Cu)	0.319	mg/L	09/12/25	09/22/25
<i>Analyzed by ELAP ID#: 11246</i>				
EPA 200.8				
Lead, Total (Pb)	0.0019	mg/L	09/17/25	09/17/25
<i>Analyzed by ELAP ID#: 10478</i>				

A & P Water Testing
P.O. Box 925
Morrisville, NY 13408
315-684-3169

NYS DOH ELAP-Accredited Certification ID#: 11405

Analysis Report For:

Brookfield Central School
1910 Fairground Road
Brookfield, NY 13314

Report Number: 252339

Page 3/3

Sample Number: 09102511C	Sample ID: Brookfield Central School
Collection Date: 09/10/25	Brookfield, NY
Collection Time: 6:25 am	Location: Upstairs fountain
Date Received: 09/10/25	Sample Collector: K. Plows
Time Received: 4:05 pm	Brookfield Central School
Matrix: Potable Water	

<u>Method & Parameter</u>	<u>Result & Qualifiers</u>	<u>Units</u>	<u>Analysis Date/Time</u>	
EPA 200.7			<u>Prep Date</u>	<u>Analysis Date</u>
Copper, Total (Cu)	0.321	mg/L	09/12/25	09/23/25
Analyzed by ELAP ID#: 11246				
EPA 200.8				
Lead, Total (Pb)	0.0041	mg/L	09/17/25	09/17/25
Analyzed by ELAP ID#: 10478				

Additional Information:

CC: Madison County DOH
mg/L=milligrams per Liter(ppm)
<=less than

Disclaimer: The laboratory interpretations of the data obtained and results reported by A & P Water Testing are believed by A & P Water Testing to be accurate and reliable for the sample(s) as received and tested. By accepting this report, the client agrees that the full extent of any and all liability for actual and consequential damages of A & P Water Testing for services performed shall be equal to the fee charged to the client for the services as liquidated damages. No part of this report shall be reproduced, except in full, without written approval of the laboratory.

Laboratory Approval:

Annette Popino 10/16/25
Annette Popino, Director Date Approved
Test results meet all requirements of NELAC, unless noted
Raised seal at right indicates original report