



October 20, 2025

Scott Gillette  
OHM BOCES Sauquoit Valley Central School  
District  
2601 Oneida Street  
Sauquoit, NY 13456

RE: Project: SAUQUOIT VALLEY HIGH SCHOOL  
Pace Project No.: 70384496

Dear Scott Gillette:

Enclosed are the analytical results for sample(s) received by the laboratory on October 08, 2025. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Melville

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Alexandria Correa  
alexandria.correa@pacelabs.com  
516-370-6000  
Project Manager

Enclosures

cc: OHM BOCES Safety Services, OHM BOCES Sauquoit  
Valley Central School District



## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



## CERTIFICATIONS

Project: SAUQUOIT VALLEY HIGH SCHOOL

Pace Project No.: 70384496

---

### **Pace Analytical Services, LLC - Melville, NY**

575 Broad Hollow Rd, Melville, NY 11747

Connecticut Certification #: PH-0435

Delaware Certification # NY 10478

Maryland Certification #: 208

Massachusetts Certification #: M-NY026

New Hampshire Certification #: 2987

New Jersey Certification #: NY158

New York Certification #: 10478 Primary Accrediting Body

Pennsylvania Certification #: 68-00350

Rhode Island Certification #: LAO00340

Texas Certification #: T104704582

Florida Certification #: E871198

---

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: SAUQUOIT VALLEY HIGH SCHOOL

Pace Project No.: 70384496

Sample: HS 101	Lab ID: 70384496001	Collected: 10/03/25 05:07	Received: 10/08/25 06:00	Matrix: Drinking Water					
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville								
Lead	<b>8.8</b>	ug/L	1.0	1		10/17/25 13:20	7439-92-1		

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: SAUQUOIT VALLEY HIGH SCHOOL

Pace Project No.: 70384496

Sample: HS 109		Lab ID: 70384496002	Collected: 10/03/25 05:10	Received: 10/08/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.4	ug/L	1.0	1		10/17/25 13:27	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: SAUQUOIT VALLEY HIGH SCHOOL

Pace Project No.: 70384496

Sample: HS 110		Lab ID: 70384496003	Collected: 10/03/25 05:13	Received: 10/08/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.4	ug/L	1.0	1		10/17/25 13:29	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: SAUQUOIT VALLEY HIGH SCHOOL

Pace Project No.: 70384496

Sample: HS 121		Lab ID: 70384496004	Collected: 10/03/25 05:19	Received: 10/08/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		10/17/25 13:30	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: SAUQUOIT VALLEY HIGH SCHOOL

Pace Project No.: 70384496

Sample: HS 113		Lab ID: 70384496005	Collected: 10/03/25 05:14	Received: 10/08/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		10/17/25 13:31	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: SAUQUOIT VALLEY HIGH SCHOOL

Pace Project No.: 70384496

Sample: HS 114		Lab ID: 70384496006	Collected: 10/03/25 05:14	Received: 10/08/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		10/17/25 13:33	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: SAUQUOIT VALLEY HIGH SCHOOL

Pace Project No.: 70384496

Sample: HS 115		Lab ID: 70384496007	Collected: 10/03/25 05:18	Received: 10/08/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.3	ug/L	1.0	1		10/17/25 13:34	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: SAUQUOIT VALLEY HIGH SCHOOL

Pace Project No.: 70384496

Sample: HS 116		Lab ID: 70384496008	Collected: 10/03/25 05:18	Received: 10/08/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>3.2</b>	ug/L	1.0	1		10/17/25 13:36	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: SAUQUOIT VALLEY HIGH SCHOOL

Pace Project No.: 70384496

Sample: HS 117		Lab ID: 70384496009	Collected: 10/03/25 05:19	Received: 10/08/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.4	ug/L	1.0	1		10/17/25 13:37	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: SAUQUOIT VALLEY HIGH SCHOOL

Pace Project No.: 70384496

Sample: HS 118		Lab ID: 70384496010	Collected: 10/03/25 05:19	Received: 10/08/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.3	ug/L	1.0	1		10/17/25 13:39	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: SAUQUOIT VALLEY HIGH SCHOOL

Pace Project No.: 70384496

Sample: HS 119		Lab ID: 70384496011	Collected: 10/03/25 05:19	Received: 10/08/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.1	ug/L	1.0	1		10/17/25 13:43	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: SAUQUOIT VALLEY HIGH SCHOOL

Pace Project No.: 70384496

Sample: HS 120		Lab ID: 70384496012	Collected: 10/03/25 05:20	Received: 10/08/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.3	ug/L	1.0	1		10/17/25 13:44	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: SAUQUOIT VALLEY HIGH SCHOOL

Pace Project No.: 70384496

Sample: HS 125		Lab ID: 70384496013	Collected: 10/03/25 05:16	Received: 10/08/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		10/17/25 13:46	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: SAUQUOIT VALLEY HIGH SCHOOL

Pace Project No.: 70384496

Sample: HS 127		Lab ID: 70384496014	Collected: 10/03/25 05:19	Received: 10/08/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		10/17/25 13:47	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: SAUQUOIT VALLEY HIGH SCHOOL

Pace Project No.: 70384496

Sample: HS 129		Lab ID: 70384496015	Collected: 10/03/25 05:27	Received: 10/08/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		10/17/25 13:49	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: SAUQUOIT VALLEY HIGH SCHOOL

Pace Project No.: 70384496

Sample: HS 130		Lab ID: 70384496016	Collected: 10/03/25 05:27	Received: 10/08/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		10/17/25 13:50	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: SAUQUOIT VALLEY HIGH SCHOOL

Pace Project No.: 70384496

Sample: HS 131		Lab ID: 70384496017	Collected: 10/03/25 05:22	Received: 10/08/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		10/17/25 13:52	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: SAUQUOIT VALLEY HIGH SCHOOL

Pace Project No.: 70384496

Sample: HS 132	Lab ID: 70384496018	Collected: 10/03/25 05:22	Received: 10/08/25 06:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		10/17/25 13:53	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: SAUQUOIT VALLEY HIGH SCHOOL

Pace Project No.: 70384496

Sample: HS 133		Lab ID: 70384496019	Collected: 10/03/25 05:31	Received: 10/08/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>11.8</b>	ug/L	1.0	1		10/17/25 13:55	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: SAUQUOIT VALLEY HIGH SCHOOL

Pace Project No.: 70384496

Sample: HS 135		Lab ID: 70384496020	Collected: 10/03/25 05:32	Received: 10/08/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>3.4</b>	ug/L	1.0	1		10/17/25 14:02	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: SAUQUOIT VALLEY HIGH SCHOOL

Pace Project No.: 70384496

Sample: HS 204	Lab ID: 70384496021	Collected: 10/03/25 05:49	Received: 10/08/25 06:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		10/17/25 14:06	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: SAUQUOIT VALLEY HIGH SCHOOL

Pace Project No.: 70384496

Sample: HS 205		Lab ID: 70384496022	Collected: 10/03/25 05:49	Received: 10/08/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		10/17/25 14:11	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: SAUQUOIT VALLEY HIGH SCHOOL

Pace Project No.: 70384496

Sample: HS 207		Lab ID: 70384496023	Collected: 10/03/25 05:41	Received: 10/08/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Preparation Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>41.7</b>	ug/L	1.0	1	10/17/25 06:57	10/17/25 16:20	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: SAUQUOIT VALLEY HIGH SCHOOL

Pace Project No.: 70384496

Sample: HS 208		Lab ID: 70384496024	Collected: 10/03/25 05:42	Received: 10/08/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>5.4</b>	ug/L	1.0	1		10/17/25 14:12	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: SAUQUOIT VALLEY HIGH SCHOOL

Pace Project No.: 70384496

Sample: HS 209		Lab ID: 70384496025	Collected: 10/03/25 05:42	Received: 10/08/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>2.5</b>	ug/L	1.0	1		10/17/25 14:13	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: SAUQUOIT VALLEY HIGH SCHOOL

Pace Project No.: 70384496

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: HS 210</b>								
<b>Lab ID: 70384496026</b>								
Collected: 10/03/25 05:43								
Received: 10/08/25 06:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	1.5	ug/L	1.0	1		10/17/25 14:18	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: SAUQUOIT VALLEY HIGH SCHOOL

Pace Project No.: 70384496

Sample: HS 211		Lab ID: 70384496027	Collected: 10/03/25 05:43	Received: 10/08/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>9.1</b>	ug/L	1.0	1		10/17/25 14:19	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: SAUQUOIT VALLEY HIGH SCHOOL

Pace Project No.: 70384496

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: HS 212</b>								
<b>Lab ID: 70384496028</b>								
Collected: 10/03/25 05:44								
Received: 10/08/25 06:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	5.6	ug/L	1.0	1		10/17/25 14:21	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: SAUQUOIT VALLEY HIGH SCHOOL

Pace Project No.: 70384496

Sample: HS 213		Lab ID: 70384496029	Collected: 10/03/25 05:44	Received: 10/08/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>9.7</b>	ug/L	1.0	1		10/17/25 14:22	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: SAUQUOIT VALLEY HIGH SCHOOL

Pace Project No.: 70384496

Sample: HS 214	Lab ID: 70384496030	Collected: 10/03/25 05:46	Received: 10/08/25 06:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>4.7</b>	ug/L	1.0	1		10/17/25 14:24	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: SAUQUOIT VALLEY HIGH SCHOOL

Pace Project No.: 70384496

Sample: HS 219		Lab ID: 70384496031	Collected: 10/03/25 05:52	Received: 10/08/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		10/17/25 14:25	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: SAUQUOIT VALLEY HIGH SCHOOL

Pace Project No.: 70384496

Sample: HS 220		Lab ID: 70384496032	Collected: 10/03/25 05:52	Received: 10/08/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		10/17/25 14:26	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: SAUQUOIT VALLEY HIGH SCHOOL

Pace Project No.: 70384496

Sample: HS 221		Lab ID: 70384496033	Collected: 10/03/25 05:54	Received: 10/08/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		10/17/25 14:28	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: SAUQUOIT VALLEY HIGH SCHOOL

Pace Project No.: 70384496

Sample: HS 222		Lab ID: 70384496034	Collected: 10/03/25 05:54	Received: 10/08/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		10/17/25 14:29	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: SAUQUOIT VALLEY HIGH SCHOOL

Pace Project No.: 70384496

Sample: HS 226		Lab ID: 70384496035	Collected: 10/03/25 05:57	Received: 10/08/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		10/17/25 14:31	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: SAUQUOIT VALLEY HIGH SCHOOL

Pace Project No.: 70384496

Sample: HS 227		Lab ID: 70384496036	Collected: 10/03/25 05:57	Received: 10/08/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		10/17/25 14:35	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: SAUQUOIT VALLEY HIGH SCHOOL

Pace Project No.: 70384496

Sample: HS 235		Lab ID: 70384496037	Collected: 10/03/25 06:27	Received: 10/08/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		10/17/25 14:37	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: SAUQUOIT VALLEY HIGH SCHOOL

Pace Project No.: 70384496

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: HS 236</b>								
<b>Lab ID: 70384496038</b>								
Collected: 10/03/25 06:27								
Received: 10/08/25 06:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		10/17/25 14:38	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: SAUQUOIT VALLEY HIGH SCHOOL

Pace Project No.: 70384496

Sample: HS 245		Lab ID: 70384496039	Collected: 10/07/25 06:20	Received: 10/08/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		10/17/25 14:40	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: SAUQUOIT VALLEY HIGH SCHOOL

Pace Project No.: 70384496

Sample: HS 244	Lab ID: 70384496040	Collected: 10/07/25 06:19	Received: 10/08/25 06:00	Matrix: Drinking Water					
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		10/17/25 14:41	7439-92-1		

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: SAUQUOIT VALLEY HIGH SCHOOL

Pace Project No.: 70384496

Sample: HS 304		Lab ID: 70384496041	Collected: 10/07/25 06:23	Received: 10/08/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		10/17/25 14:45	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: SAUQUOIT VALLEY HIGH SCHOOL

Pace Project No.: 70384496

Sample: HS 303		Lab ID: 70384496042	Collected: 10/07/25 06:24	Received: 10/08/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		10/17/25 14:53	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: SAUQUOIT VALLEY HIGH SCHOOL

Pace Project No.: 70384496

Sample: HS 307		Lab ID: 70384496043	Collected: 10/07/25 06:16	Received: 10/08/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		10/17/25 14:57	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



**QUALITY CONTROL DATA**

Project: SAUQUOIT VALLEY HIGH SCHOOL

Pace Project No.: 70384496

QC Batch:	423907	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70384496001, 70384496002, 70384496003, 70384496004, 70384496005, 70384496006, 70384496007, 70384496008, 70384496009, 70384496010, 70384496011, 70384496012, 70384496013, 70384496014, 70384496015, 70384496016, 70384496017, 70384496018, 70384496019		

METHOD BLANK:	2259658	Matrix:	Water
Associated Lab Samples:	70384496001, 70384496002, 70384496003, 70384496004, 70384496005, 70384496006, 70384496007, 70384496008, 70384496009, 70384496010, 70384496011, 70384496012, 70384496013, 70384496014, 70384496015, 70384496016, 70384496017, 70384496018, 70384496019		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	10/17/25 13:13	

LABORATORY CONTROL SAMPLE:	2259659					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	50.5	101	85-115	

MATRIX SPIKE SAMPLE:	2259661						
Parameter	Units	70384422002 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	5.1	50	50.5	91	70-130	

MATRIX SPIKE SAMPLE:	2259663						
Parameter	Units	70384496001 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	8.8	50	56.7	96	70-130	

SAMPLE DUPLICATE:	2259660					
Parameter	Units	70384422002 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	5.1	4.6	10		

SAMPLE DUPLICATE:	2259662					
Parameter	Units	70384496001 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	8.8	8.6	3		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



**QUALITY CONTROL DATA**

Project: SAUQUOIT VALLEY HIGH SCHOOL

Pace Project No.: 70384496

QC Batch:	423908	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70384496020, 70384496021, 70384496022, 70384496024, 70384496025, 70384496026, 70384496027, 70384496028, 70384496029, 70384496030, 70384496031, 70384496032, 70384496033, 70384496034, 70384496035, 70384496036, 70384496037, 70384496038, 70384496039, 70384496040		

METHOD BLANK:	2259664	Matrix:	Water
Associated Lab Samples:	70384496020, 70384496021, 70384496022, 70384496024, 70384496025, 70384496026, 70384496027, 70384496028, 70384496029, 70384496030, 70384496031, 70384496032, 70384496033, 70384496034, 70384496035, 70384496036, 70384496037, 70384496038, 70384496039, 70384496040		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	10/17/25 13:56	

LABORATORY CONTROL SAMPLE:	2259665					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	46.5	93	85-115	

MATRIX SPIKE SAMPLE:	2259667						
Parameter	Units	70384496020 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	3.4	50	54.4	102	70-130	

MATRIX SPIKE SAMPLE:	2259669						
Parameter	Units	70384496021 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	48.3	96	70-130	

SAMPLE DUPLICATE:	2259666					
Parameter	Units	70384496020 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	3.4	3.4	2		

SAMPLE DUPLICATE:	2259668					
Parameter	Units	70384496021 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	<1.0	<1.0			

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



**QUALITY CONTROL DATA**

Project: SAUQUOIT VALLEY HIGH SCHOOL

Pace Project No.: 70384496

QC Batch:	423909	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville

Associated Lab Samples: 70384496041, 70384496042, 70384496043

METHOD BLANK: 2259670 Matrix: Water  
 Associated Lab Samples: 70384496041, 70384496042, 70384496043

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	10/17/25 14:42	

LABORATORY CONTROL SAMPLE: 2259671

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	51.2	102	85-115	

MATRIX SPIKE SAMPLE: 2259673

Parameter	Units	70384496041 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	50.6	101	70-130	

MATRIX SPIKE SAMPLE: 2259675

Parameter	Units	70384496042 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	51.0	102	70-130	

SAMPLE DUPLICATE: 2259672

Parameter	Units	70384496041 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

SAMPLE DUPLICATE: 2259674

Parameter	Units	70384496042 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



**QUALITY CONTROL DATA**

Project: SAUQUOIT VALLEY HIGH SCHOOL  
 Pace Project No.: 70384496

QC Batch: 423881 Analysis Method: EPA 200.8  
 QC Batch Method: EPA 200.8 Analysis Description: 200.8 MET Drinking Water  
 Laboratory: Pace Analytical Services - Melville

Associated Lab Samples: 70384496023

METHOD BLANK: 2259582 Matrix: Water  
 Associated Lab Samples: 70384496023

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	10/17/25 16:12	

LABORATORY CONTROL SAMPLE & LCSD: 2259583 2259584

Parameter	Units	Spike Conc.	LCS Result	LCSD Result	LCS % Rec	LCSD % Rec	% Rec Limits	RPD	Max RPD	Qualifiers
Lead	ug/L	50	52.4	54.3	105	109	85-115	4	20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



## QUALIFIERS

Project: SAUQUOIT VALLEY HIGH SCHOOL

Pace Project No.: 70384496

---

### DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: SAUQUOIT VALLEY HIGH SCHOOL

Pace Project No.: 70384496

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70384496023	HS 207	EPA 200.8	423881	EPA 200.8	423919
70384496001	HS 101	EPA 200.8	423907		
70384496002	HS 109	EPA 200.8	423907		
70384496003	HS 110	EPA 200.8	423907		
70384496004	HS 121	EPA 200.8	423907		
70384496005	HS 113	EPA 200.8	423907		
70384496006	HS 114	EPA 200.8	423907		
70384496007	HS 115	EPA 200.8	423907		
70384496008	HS 116	EPA 200.8	423907		
70384496009	HS 117	EPA 200.8	423907		
70384496010	HS 118	EPA 200.8	423907		
70384496011	HS 119	EPA 200.8	423907		
70384496012	HS 120	EPA 200.8	423907		
70384496013	HS 125	EPA 200.8	423907		
70384496014	HS 127	EPA 200.8	423907		
70384496015	HS 129	EPA 200.8	423907		
70384496016	HS 130	EPA 200.8	423907		
70384496017	HS 131	EPA 200.8	423907		
70384496018	HS 132	EPA 200.8	423907		
70384496019	HS 133	EPA 200.8	423907		
70384496020	HS 135	EPA 200.8	423908		
70384496021	HS 204	EPA 200.8	423908		
70384496022	HS 205	EPA 200.8	423908		
70384496024	HS 208	EPA 200.8	423908		
70384496025	HS 209	EPA 200.8	423908		
70384496026	HS 210	EPA 200.8	423908		
70384496027	HS 211	EPA 200.8	423908		
70384496028	HS 212	EPA 200.8	423908		
70384496029	HS 213	EPA 200.8	423908		
70384496030	HS 214	EPA 200.8	423908		
70384496031	HS 219	EPA 200.8	423908		
70384496032	HS 220	EPA 200.8	423908		
70384496033	HS 221	EPA 200.8	423908		
70384496034	HS 222	EPA 200.8	423908		
70384496035	HS 226	EPA 200.8	423908		
70384496036	HS 227	EPA 200.8	423908		
70384496037	HS 235	EPA 200.8	423908		
70384496038	HS 236	EPA 200.8	423908		
70384496039	HS 245	EPA 200.8	423908		
70384496040	HS 244	EPA 200.8	423908		
70384496041	HS 304	EPA 200.8	423909		
70384496042	HS 303	EPA 200.8	423909		
70384496043	HS 307	EPA 200.8	423909		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.

**WO#: 70384496**



**CHAIN-OF-CUSTODY Analytical Request Document**  
Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

Pace® Location Requested (City/State):  
Pace Analytical Long Island NY  
575 Broad Hollow Rd, Melville, NY 11747

Company Name: OHM BOCES\_Sauquoit Valley Central School District  
Street Address: 2601 Oneida Street  
Sauquoit, NY 13456

Customer Project #: SAUQUOIT VALLEY HIGH SCHOOL

Project Name: SAUQUOIT VALLEY HIGH SCHOOL

Site Collection Info/Facility ID (as applicable):

Time Zone Collected: [ ] AK [ ] PT [ ] MT [ ] CT [ ] ET [ ]

Data Deliverables:  
[ ] Level II [ ] Level III [ ] Level IV  
[ ] EQUIS  
[ ] Other

Regulatory Program (DW, RCRA, etc.) as applicable: Reportable [ ] Yes [ ] No

Country / State origin of sample(s): New York

Field Filtered (if applicable): [ ] Yes [ ] No

Analysis:  
DW PWSID # or WW Permit # as applicable:  
Rush (Pre-approval required):  
[ ] Same Day [ ] 1 Day [ ] 2 Day [ ] 3 Day [ ] Other

Date Results Requested:

\* Matrix Codes (insert in Matrix box below): Drinking Water (DW), Waste Water (WW), Product (P), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS), Bioassay (B), Vapor (V), Surface Water (SW), Sediment (SED), Sludge (SL), Caulk (CK), Leachate (LL), Biosolid (BS), Other (OT)

Customer Sample ID	Matrix* Comp / Grab	Composite Start		Collected or Composite End		# Cont.	Res. Results	Units
		Date	Time	Date	Time			
HS101		10/3/25	5:07 AM					
HS109		10/3/25	5:10 AM					
HS110		10/3/25	5:13 AM					
HS112	HS121	10/3/25	5:19 AM					
HS113		10/3/25	5:14 AM					
HS114		10/3/25	5:14 AM					
HS115		10/3/25	5:18 AM					
HS116		10/3/25	5:18 AM					
HS117		10/3/25	5:19 AM					
HS118		10/3/25	5:19 AM					

200.8 MET ICPMs Drinking Water

Customer Remarks / Special Conditions / Possible Hazards:

# Coolers: 1  
Thermometer ID: 18.3  
Correction Factor (°C): +1  
Obs. Temp. (°C): 18.3  
Corrected Temp. (°C): 18.4  
On Ice: N

Tracking Number: 10-7-25 (1113)

Date/Time: 10-7-25 10:00  
Date/Time: 10-7-25 10:00

Delivered by: [ ] In-Person [ ] Courier

Page: 1 of 1

Specify Container Size \*\*

Identify Container Preservative Type\*\*\*

Analysis Requested

Proj. Mgr: Alexandria Correa  
AcctNum / Client ID:  
Table #:  
Profile / Template: 10621  
Prelog / Bottle Ord. ID: EZ 3235841  
Sample Comment

Preservation non-conformance Identified for

\*\* Container Size: (1) 1L, (2) 500mL, (3) 250mL, (4) 125mL, (5) 100mL, (6) 40mL vial, (7) EnCores, (8) TerraCore, (9) 90mL, (10) Other

\*\*\* Preservative Types: (1) None, (2) HNO3, (3) H2SO4, (4) HCl, (5) HAcOH, (6) Zn Acetate, (7) NaHSO4, (8) Sod. Thiosulfate, (9) Ascorbic Acid, (10) MeOH, (11) Other

Additional Instructions from Pace®:

Collected By: Scott Gillette  
(Printed Name)  
Signature: 

Received by Company: (Signature)  
Date/Time: 10-7-25 10:00

Relinquished by Company: (Signature)  
Date/Time: 10-7-25 10:00



Pace® Location Requested (City/State):  
Pace Analytical Long Island NY  
575 Broad Hollow Rd, Melville, NY 11747

### CHAIN-OF-CUSTODY Analytical Request Document

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

Company Name: OHM BOCES\_Sauquoit Valley Central School District  
 Street Address: 2601 Oneida Street  
 Sauquoit, NY 13456

Contact/Report To: Scott Gillette  
 Phone #: 315-983-1694  
 E-Mail: sgillette@svcsd.org  
 Cc E-Mail:

Customer Project #: SAUQUOIT VALLEY HIGH SCHOOL  
 Project Name: SAUQUOIT VALLEY HIGH SCHOOL

Invoice To: Kathy Wakefield  
 Invoice E-Mail: kwakefield@svcsd.org  
 Purchase Order # (if applicable):  
 Quote #:

Site Collection Info/Facility ID (as applicable):  
 County/State origin of sample(s): New York  
 Reportable  Yes  No

Time Zone Collected: [ ] AK [ ] PT [ ] MT [ ] CT [ ] ET  
 Data Deliverables:  
 Level II  Level III  Level IV  
 EQUIS  
 Other

**Rush (Pre-approval required):**  
 Same Day  1 Day  2 Day  3 Day  Other

Field Filtered (if applicable):  Yes  No

Analysis:  
 DW PWSID # or WW Permit # as applicable:  
 Regulatory Program (DW, RCRA, etc.) as applicable:  
 Matrix \*  Same Day  1 Day  2 Day  3 Day  Other

Customer Sample ID	Matrix *	Comp / Grab		Composite Start		Collected or Composite End		# Cont.	Res. Chlorine	Results	Units
		Date	Time	Date	Time						
HS119		10/3/25	5:19 AM								
HS120		10/3/25	5:20 AM								
HS125		10/3/25	5:16 AM								
HS127		10/3/25	5:19 AM								
HS129		10/3/25	5:27 AM								
HS130		10/3/25	5:27 AM								
HS131		10/3/25	5:22 AM								
HS132		10/3/25	5:22 AM								
HS133		10/3/25	5:31 AM								
HS135		10/3/25	5:32 AM								

Additional Instructions from Pace®:  
 Collected By: Scott Gillette  
 Signature: *[Signature]*

Received by/Company: (Signature)  
 Received by/Company: *[Signature]*

Relinquished by/Company: (Signature)  
 Relinquished by/Company: *[Signature]*

LAB USE ONLY - Affix Workorder/Login Label Here



Scan QR Code for instructions

Specify Container Size \*\*  
 \*\*Container Size: (1) 1L, (2) 500mL, (3) 250mL, (4) 125mL, (5) 100mL, (6) 40mL vial, (7) EnCore, (8) TerraCore, (9) 50mL, (10) Other

Identify Container Preservative Type\*\*\*  
 \*\*\* Preservative Types: (1) None, (2) HNO3, (3) H2SO4, (4) HCl, (5) NaOH, (6) Zn Acetate, (7) NaHSO4, (8) Sod. Thiosulfate, (9) Ascorbic Acid, (10) MeOH, (11) Other

Analysis Requested

Proj. Mgr.: Alexandria Correa  
 AcctNum / Client ID:  
 Table #:  
 Profile / Template: 10621  
 Preg / Bottle Ord ID: EZ 3235841  
 Sample Comment

200.8 MET ICPMS Drinking Water


Preservation non-conformance identified for sample

Customer Remarks / Special Conditions / Possible Hazards:

# Coolers: 1  
 Thermometer ID: 18.3  
 Correction Factor (°C): 18.3  
 Obs. Temp (°C): 18.3  
 Corrected Temp. (°C): 18.4  
 On Ice: N

Date/Time: 10/27/25 10:00  
 Date/Time: 10/27/25 10:00  
 Date/Time: 10/27/25 10:00  
 Date/Time: 10/27/25 10:00

Delivered by: [ ] In-Person [ ] Courier  
 Page: 1 of 1



Pace® Location Requested (City/State):  
 Pace Analytical Long Island NY  
 575 Broad Hollow Rd, Melville, NY 11747

### CHAIN-OF-CUSTODY Analytical Request Document

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

Company Name: OHM BOCES\_Sauquoit Valley Central School District  
 Street Address: 2601 Oneida Street, Sauquoit, NY 13456  
 Contact/Report To: Scott Gillette  
 Phone #: 315-983-1694  
 E-Mail: sgillette@svcsd.org  
 Cc E-Mail:

Customer Project #: SAUQUOIT VALLEY HIGH SCHOOL  
 Project Name: SAUQUOIT VALLEY HIGH SCHOOL  
 Site Collection Info/Facility ID (as applicable):  
 Time Zone Collected: [ ] AK [ ] PT [ ] MT [ ] CT [ ] ET  
 Data Deliverables: [ ] Level II [ ] Level III [ ] Level IV  
 [ ] EQUIS  
 [ ] Other

Regulatory Program (DW, RCRA, etc.) as applicable: Reportable [ ] Yes [ ] No  
 County / State origin of sample(s): New York  
 Invoice To: Kathy Wakefield  
 Invoice E-Mail: kwakefield@svcsd.org  
 Purchase Order # (if applicable):  
 Quote #:  
 Rush (Pre-approval required): DW PWSID # or WW Permit # as applicable:  
 [ ] Same Day [ ] 1 Day [ ] 2 Day [ ] 3 Day [ ] Other  
 Date Results Requested:  
 Analysis: Field Filtered (if applicable): [ ] Yes [ ] No

Customer Sample ID	Matrix *	Composite Start		# Cont.	Res. Chlorine Results	Units
		Date	Time			
HS 204		10/3/25	5:49 AM			
HS 205		10/3/25	5:49 AM			
HS 207		10/3/25	5:41 AM			
HS 208		10/3/25	5:42 AM			
HS 209		10/3/25	5:48 AM			
HS 210		10/3/25	5:43 AM			
HS 211		10/3/25	5:43 AM			
HS 212		10/3/25	5:44 AM			
HS 213		10/3/25	5:44 AM			
HS 214		10/3/25	5:46 AM			

Additional Instructions from Pace®:  
 Collected By: Scott Gillette  
 (Printed Name)  
 Signature: *[Signature]*  
 Date/Time: 10/3/25  
 Relinquished by Company (Signature): *[Signature]*  
 Date/Time: 10-7-25  
 Relinquished by Company (Signature): *[Signature]*  
 Date/Time: 10-7-25  
 Relinquished by Company (Signature): *[Signature]*  
 Date/Time: 10-7-25  
 Relinquished by Company (Signature): *[Signature]*  
 Date/Time: 10-7-25

LAB USE ONLY - Affix Workorder/Login Label Here



Scan QR Code for instructions


Specify Container Size \*\*  
 Identify Container Preservative Type\*\*  
 Analysis Requested

Proj. Mgr.: Alexandria Correa  
 AcctNum / Client ID:  
 Table #:  
 Profile / Template: 10621  
 Pregol / Bottle Ord. ID: EZ 3235841  
 Sample Comment

200.8 MET ICPMS Drinking Water

Preservation non-conformance identified for sample

Customer Remarks / Special Conditions / Possible Hazards:  
 # Coolers: 1  
 # Monitors: 1  
 Obs. Temp. (°C): 18.4  
 Correction Factor (°C): 18.3  
 Tracking Number: 07-1113  
 Date/Time: 10/7/25  
 Date/Time: 10/8/25  
 Date/Time: 10/8/25  
 Date/Time: 10/8/25  
 Delivered by: [ ] In-Person [ ] Courier  
 Page: 1 of 1



Pace® Location Requested (City/State):  
Pace Analytical Long Island NY  
575 Broad Hollow Rd, Melville, NY 11747

**CHAIN-OF-CUSTODY Analytical Request Document**  
Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

Company Name: OHM BOCES\_Sauquoit Valley Central School District  
Street Address: 2601 Oneida Street, Sauquoit, NY 13456  
Customer Project #: SAUQUOIT VALLEY HIGH SCHOOL  
Project Name: SAUQUOIT VALLEY HIGH SCHOOL  
Site Collection Info/Facility ID (as applicable):  
Time Zone Collected: [ ] AK [ ] PT [ ] MT [ ] CT [ ] ET  
Data Deliverables: Regulatory Program (DW, RCRA, etc.) as applicable: Reportable [ ] Yes [ ] No

Contact/Report To: Scott Gillette  
Phone #: 315-983-1694  
E-Mail: sgillette@svcsd.org  
Cc E-Mail:  
Invoice To: Kathy Wakefield  
Invoice E-Mail: kwakefield@svcsd.org  
Purchase Order # (if applicable):  
Quote #:

Specify Container Size \*\*  
Identify Container Preservative Type\*\*\*  
Analysis Requested

\*\*Container Size: (1) 1L, (2) 500mL, (3) 250mL, (4) 125mL, (5) 100mL, (6) 40mL vial, (7) 5mL Cuvet, (8) TerraCore, (9) 50mL, (10) Other  
\*\*\*Preservative Type: (1) None, (2) HNO3, (3) H2SO4, (4) HCl, (5) NaOH, (6) Zn Acetate, (7) NaHSO4, (8) Sod. Thiosulfate, (9) Ascorbic Acid, (10) MeOH, (11) Other

Lab Use Only  
Proj. Mgr: Alexandria Correa  
AcctNum / Client ID:  
Table #:  
Profile / Template: 10621  
Prelog / Bottle Ord. ID: EZ 3235841  
Sample Comment:

200.8 MET ICPMS Drinking Water  
Field Filtered (if applicable): [ ] Yes [ ] No  
Analysis:  
Rush (Pre-approval required):  
[ ] Same Day [ ] 1 Day [ ] 2 Day [ ] 3 Day [ ] Other  
DW PWSID # or WW permit # as applicable:  
Date Results Requested:  
[ ] Other  
Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Waste Water (WW), Product (P), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS), Bioassay (B), Vapor (V), Surface Water (SW), Sediment (SED), Sludge (SL), Caustic (CK), Leachate (LL), Biosolid (BS), Other (OT)

Customer Sample ID	Matrix *	Comp / Grab		Composite Start		Collected or Composite End		# Cont.	Res. Results	Units
		Date	Time	Date	Time					
HS219		10/3/25	5:52 AM							
HS220		10/3/25	5:52 AM							
HS221		10/3/25	5:54 AM							
HS222		10/3/25	5:54 AM							
HS226		10/3/25	5:57 AM							
HS227		10/3/25	5:57 AM							
HS235		6:27	10/3/25							
HS236		6:27	10/3/25							

Additional Instructions from Pace\*:  
Collected By: Scott Gillette  
Signature:  
Received by/Company: Signature: [Signature]  
Date/Time: 10/8/25 6:00  
Received by/Company: Signature: [Signature]  
Date/Time: 10/7/25  
Received by/Company: Signature: [Signature]  
Date/Time: 10/18/25 6:00  
Received by/Company: Signature: [Signature]  
Date/Time: 10/18/25 6:00  
Tracking Number: 1822518  
Delivered by: [ ] In-Person [ ] Courier  
# Coolers: 18.3 Corrected Temp (°C) 18.9 Corrected Temp (°C) On Ice  
Customer Remarks / Special Conditions / Possible Hazards:

**CHAIN-OF-CUSTODY Analytical Request Document**  
 Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

Company Name: OHM BOCES\_Sauquoit Valley Central School District  
 Street Address: 2601 Onelda Street  
 Sauquoit, NY 13456

Contact/Report To: Scott Gillette  
 Phone #: 315-983-1694  
 E-Mail: sgillette@svcsd.org  
 Cc E-Mail:

Project Name: SAUQUOIT VALLEY HIGH SCHOOL

Invoice To: Kathy Wakefield  
 Invoice E-Mail: kwakefield@svcsd.org  
 Purchase Order # (if applicable):  
 Quote #:

County / State origin of sample(s): New York

Time Zone Collected: [ ] AK [ ] PT [ ] MT [ ] CT [ ] ET

Data Deliverables:  
 [ ] Level II [ ] Level III [ ] Level IV  
 [ ] EQUIS

Regulatory Program (DW, RCRA, etc.) as applicable: Reportable [ ] Yes [ ] No

**Rush (Pre-approval required):**  
 [ ] Same Day [ ] 1 Day [ ] 2 Day [ ] 3 Day [ ] Other

Field Filtered (if applicable): [ ] Yes [ ] No

Analysis:

Matrix \*  
 Customer Sample ID  
 HS 245  
 HS 244  
 HS 304  
 HS 303  
 HS 307

Composite Start  
 Date Time  
 10/7/25 6:20 AM  
 10/7/25 6:19 AM  
 10/7/25 6:23 AM  
 10/7/25 6:24 AM  
 10/7/25 6:16 AM

Matrix *	Comp / Grab	Date	Time	Collected or Composite End Date	Time	# Cont.	Res. Results	Chlorine Units
HS 245		10/7/25	6:20 AM					
HS 244		10/7/25	6:19 AM					
HS 304		10/7/25	6:23 AM					
HS 303		10/7/25	6:24 AM					
HS 307		10/7/25	6:16 AM					

200.8 MET ICPMS Drinking Water

Lab Use Only  
 Proj. Mgr: **Alexandria Correa**  
 AcctNum / Client ID:  
 Table #:  
 Profile / Template: **10621**  
 Prelog / Bottle Ord. ID: **EZ 3235841**  
 Sample Comment

Preservation non-conformance identified for sample:

Additional Instructions from Pace®:

Collected By: *[Signature]*  
 (Printed Name)  
 Signature: *[Signature]*

Received by/Company: *[Signature]*  
 Date/Time: 10-27-25

Customer Remarks / Special Conditions / Possible Hazards:

# Coolers: *[Signature]*  
 Thermometer ID: *[Signature]*  
 Correction Factor (°C): +1  
 Obs. Temp. (°C): 3.5  
 Corrected Temp. (°C): 3.6  
 On Ice: *[Signature]*

Date/Time: 10-27-25 11:13  
 Date/Time: 10-27-25 12:00  
 Date/Time: 10-27-25 6:00  
 Date/Time:

Tracking Number: *[Signature]*

Delivered by: [ ] In-Person [ ] Courier

Page: 1 of 1



Scan QR Code for instructions

Specify Container Size \*\*

Identify Container Preservative Type\*\*\*

Analysis Requested

\*\* Container Size: (1) 1L, (2) 500mL, (3) 250mL, (4) 125mL, (5) 100mL, (6) 40mL vial, (7) Encore, (8) TerraCore, (9) 90mL, (10) Other

\*\*\* Preservative Types: (1) None, (2) HNO3, (3) H2SO4, (4) HCl, (5) NaOH, (6) Zn Acetate, (7) NaHSO4, (8) Soil, Thioullate, (9) Ascorbic Acid, (10) Mech, (11) Other

**WO#: 70384496**

**PM: ALC Due Date: 10/17/25**  
**CLIENT: SauquoitCSD**

Client Name: Sauquoit CSD Project # \_\_\_\_\_  
 Courier:  Fed Ex  UPS  USPS  Client  Commercial  Pace  Other  
 Tracking #: \_\_\_\_\_

Custody Seal on Cooler/Box Present:  Yes  No Seals intact:  Yes  No Temperature Blank Present:  Yes  No  
 Packing Material:  Bubble Wrap  Bubble Bags  Ziploc  None  Other Type of Ice: Wet Blue None  
 Thermometer Used: T629 Correction Factor: 0.1  Samples on ice, cooling process has begun  
 Cooler Temperature(°C): 18.3 Cooler Temperature Corrected(°C): 18.4 Date/Time 5035A kits placed in freezer \_\_\_\_\_  
 Temp should be above freezing to 6.0°C

USDA Regulated Soil (  N/A, water sample)  
 Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)?  Yes  No  
 Did samples originate from a foreign source including Hawaii and Puerto Rico)?  Yes  No

If Yes to either question, fill out a Regulated Soil Checklist (ENV-FRM-MELV-0076) and include with SCUR/COC paperwork.

Date and Initials of person examining contents: 10/12/25 RD

	COMMENTS:
Chain of Custody Present: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	1. <u>RD</u>
Chain of Custody Filled Out: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	2.
Chain of Custody Relinquished: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	3.
Sampler Name & Signature on COC: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	4.
Samples Arrived within Hold Time: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	5.
Short Hold Time Analysis (<72hr): <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	6.
Rush Turn Around Time Requested: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	7.
Sufficient Volume: (Triple volume provided for MS/MSD) <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	8.
Correct Containers Used: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	9.
-Pace Containers Used: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	10.
Containers Intact: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	11.
Filtered volume received for Dissolved tests: <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	11. Note: if sediment is visible in the dissolved container,
Sample Labels match COC: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	12.
-Includes date/time/ID/Analysis Matrix: <u>SI</u> <u>WT</u> <u>OIL</u> <u>OTHER</u>	

Date and Initials of person checking preservation: 10/12/25 RD

All containers needing preservation have been pH paper Lot # <u>231229</u> All containers needing preservation are found to be in compliance with method recommendation? (HNO <sub>3</sub> , H <sub>2</sub> SO <sub>4</sub> , HCl, NaOH>9 Sulfide, NAOH>12 Cyanide) <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water). Per Method, VOA pH is checked after analysis	13. <input type="checkbox"/> HNO <sub>3</sub> <input type="checkbox"/> H <sub>2</sub> SO <sub>4</sub> <input type="checkbox"/> NaOH <input type="checkbox"/> HCl Sample # _____ Initial when completed: _____ Lot # of added preservative: _____ Date/Time preservative added: _____
Samples checked for dechlorination: KI starch test strips Lot # _____ Residual chlorine strips Lot # _____	14. Positive for Res. Chlorine? <input type="checkbox"/> Y <input checked="" type="checkbox"/> N
SM 4500 CN samples checked for sulf <input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Lead Acetate Strips Lot # _____	15. Positive for Sulfide? <input type="checkbox"/> Y <input checked="" type="checkbox"/> N
Headspace in ALK Bottle (>6mm): <input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	16.
Headspace in VOA Vials (>6mm): <input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	17.
Trip Blank Present: <input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Trip Blank Custody Seals Present <input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	

Client Notification/ Resolution: \_\_\_\_\_ Field Data Required? Y / N  
 Person Contacted: \_\_\_\_\_ Date/Time: \_\_\_\_\_  
 Comments/ Resolution: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

\* PM (Project Manager) review (which includes the SCUR) is documented electronically in LIMS.