

Cattaraugus County Laboratory Services

Public Water System Laboratory Results



ELAP ID # - 10110
1 Leo Moss Dr, Olean NY 14760
PH# - 716-373-8055 Fax # - 716-701-3717
Laboratory Supervisor - Paula DeCerber, pjdecerber@cattco.org



System Sampled : Ellicottville Central School

Sample Point: frr

Collection Date : 10/15/2025 Collection Time: 15:45

Collected By : Michael Hastings Acceptable upon Receipt? Yes
Chlorine Residual: (field test) 1.16 mg/l
(if applicable)

Result: Total Coliform Neg. - E. Coli Neg.

Test Requested: Colilert - 24 hr

Test Method: SM 20, 21-23 9223B(-04)

Verified By: Kimberly Stewart

Analysis Start Date/Time: 10/16/25 13:21 End Date/Time: 10/17/25 14:01

Comments and QA/QC concerns:

Collector Comments / Addl. Location Info :

Laboratory Comments / QA-QC Issues :

The Laboratory Director authorizes the release of this report. The results in this report relate only to the sample submitted to the laboratory.

For CCHD Office Use Only:	
Code:	<u>6413</u>
PWS ID:	<u>NY0416765</u>
CCHD ID#:	<u>102025.254</u>
Bill Type:	<u>Email</u>
Method:	<u>Email</u>
Page 1 of 1	
Email :	<u>gsnyder@ecsny.org; mward@ecsny.org</u>
Fax:	
Address:	<u>Public Water System :Ellicottville Central School</u> <u>Gene Snyder</u> <u>Ellicottville Central School</u> <u>5873 Route 219 S</u> <u>Ellicottville NY, 14731</u>