

Facility or Building Name	Camden High School
Did the facility test using the MDH testing program (WIIN)? (Yes or No)	No
Facility Type (School or Child Care)	School
School ID Number or Child Care License Number	0001-03-354
Facility or Building Address	4320 N Newton Ave, Minneapolis, MN 55412
Mailing Address	1225 North 7th Street Minneapolis, MN 55411
Contact Person	Lee Setter
Title	Manager, EH&S
Phone	612-668-0308
Email	Lee.Setter@mpls.k12.mn.us

SUMMARY	ANSWER
Total number of samples	35
Total number of fixtures sampled	35
Total number of results above 5 ppb	0
Total number of remediation actions	5
Next Scheduled Sampling Date (Month/Year)	09/2030

\* MPS custodian will flush gym build daily due to limited use.  
5 fixture locations that tested below detection level

Location Description	Fixture Status	Sample Collection	Laboratory	Date/Time	Date/Time	Numeric Result	Unit of	Name of Laboratory Used For	Remediation Action	Other	Was Remediation Successful	Additional Notes or
Hallway Drinking Fountain (DF) Room 316	Active - Consumption	Initial - First Draw	25-11664	9/25/2025 4:42	9/30/2025 12:07	ND		Twin City Water Clinic, Inc.				
Hallway Drinking Fountain (BF) Room 315	Active - Consumption	Initial - First Draw	25-11665	9/25/2025 4:43	9/30/2025 12:13	ND	µg/L	Twin City Water Clinic, Inc.				
Hallway Drinking Fountain (DF) Room 309	Active - Consumption	Initial - First Draw	25-11666	9/25/2025 4:55	9/30/2025 12:19	ND	µg/L	Twin City Water Clinic, Inc.				
Hallway Drinking Fountain (BFR) Room 306	Active - Consumption	Initial - First Draw	25-11667	9/25/2025 4:59	9/30/2025 12:25	ND	µg/L	Twin City Water Clinic, Inc.				
Hallway Drinking Fountain (DFL) Room 306	Active - Consumption	Initial - First Draw	25-11668	9/25/2025 4:59	9/30/2025 12:32	ND	µg/L	Twin City Water Clinic, Inc.				
Hallway Drinking Fountain (BFR) Room 214	Active - Consumption	Initial - First Draw	25-11669	9/25/2025 5:02	9/30/2025 13:04	ND	µg/L	Twin City Water Clinic, Inc.				
Hallway Drinking Fountain (DFL) Room 214	Active - Consumption	Initial - First Draw	25-11670	9/25/2025 5:02	10/1/2025 11:57	ND	µg/L	Twin City Water Clinic, Inc.				
Hallway Drinking Fountain (DF) Room 219	Active - Consumption	Initial - First Draw	25-11671	9/25/2025 5:06	10/1/2025 12:03	ND	µg/L	Twin City Water Clinic, Inc.				
Hallway Drinking Fountain (DF) Room 208	Active - Consumption	Initial - First Draw	25-11672	9/25/2025 5:12	10/1/2025 12:09	ND	µg/L	Twin City Water Clinic, Inc.				
Hallway Drinking Fountain (BFR) Room 206	Active - Consumption	Initial - First Draw	25-11673	9/25/2025 5:14	10/1/2025 12:15	ND	µg/L	Twin City Water Clinic, Inc.				
Hallway Drinking Fountain (DFL) Room 206	Active - Consumption	Initial - First Draw	25-11674	9/25/2025 5:14	10/1/2025 12:21	ND	µg/L	Twin City Water Clinic, Inc.				
Hallway Drinking Fountain (DF) Room 170	Active - Consumption	Initial - First Draw	25-11675	9/25/2025 5:17	10/1/2025 12:27	ND	µg/L	Twin City Water Clinic, Inc.				
Hallway Drinking Fountain (BFR) Room 168	Active - Consumption	Initial - First Draw	25-11676	9/25/2025 5:19	10/1/2025 12:34	ND	µg/L	Twin City Water Clinic, Inc.				
Hallway Drinking Fountain (DFL) Room 168	Active - Consumption	Initial - First Draw	25-11677	9/25/2025 5:19	10/7/2025 10:51	ND	µg/L	Twin City Water Clinic, Inc.				
Hallway Drinking Fountain (DF) Room 156	Active - Consumption	Initial - First Draw	25-11678	9/25/2025 5:21	10/7/2025 10:57	ND	µg/L	Twin City Water Clinic, Inc.				
Hallway Drinking Fountain (BFR) Room 150	Active - Consumption	Initial - First Draw	25-11679	9/25/2025 5:23	10/7/2025 11:15	ND	µg/L	Twin City Water Clinic, Inc.				
Hallway Drinking Fountain (DFL) Room 150	Active - Consumption	Initial - First Draw	25-11680	9/25/2025 5:24	10/7/2025 11:34	ND	µg/L	Twin City Water Clinic, Inc.				
Hallway Drinking Fountain (DF) Room 149	Active - Consumption	Initial - First Draw	25-11681	9/25/2025 5:24	10/7/2025 11:40	ND	µg/L	Twin City Water Clinic, Inc.				
Health Office Sink Room 153	Active - Consumption	Initial - First Draw	25-11682	9/25/2025 5:27	10/7/2025 11:46	ND	µg/L	Twin City Water Clinic, Inc.				
Hallway Drinking Fountain (BFR) Room 103	Active - Consumption	Initial - First Draw	25-11683	9/25/2025 5:29	10/7/2025 11:52	ND	µg/L	Twin City Water Clinic, Inc.				
Hallway Drinking Fountain (DFL) Room 103	Active - Consumption	Initial - First Draw	25-11684	9/25/2025 5:29	10/7/2025 11:58	ND	µg/L	Twin City Water Clinic, Inc.				
Hallway Drinking Fountain (DF) Room 127	Active - Consumption	Initial - First Draw	25-11685	9/25/2025 5:30	10/7/2025 12:03	ND	µg/L	Twin City Water Clinic, Inc.				
Hallway Drinking Fountain (BFR) Room 121	Active - Consumption	Initial - First Draw	25-11686	9/25/2025 5:32	10/7/2025 12:09	ND	µg/L	Twin City Water Clinic, Inc.				
Hallway Drinking Fountain (DFL) Room 121	Active - Consumption	Initial - First Draw	25-11687	9/25/2025 5:33	10/7/2025 12:15	ND	µg/L	Twin City Water Clinic, Inc.				
Eng. Office-Sink	Active - Consumption	Initial - First Draw	25-11688	9/25/2025 5:34	10/7/2025 12:21	ND	µg/L	Twin City Water Clinic, Inc.				
Kitchen Prep Sink	Active - Consumption	Initial - First Draw	25-11689	9/25/2025 5:35	10/9/2025 11:23	ND	µg/L	Twin City Water Clinic, Inc.				
Kitchen Wash Sink	Active - Consumption	Initial - First Draw	25-11690	9/25/2025 5:36	10/9/2025 11:29	ND	µg/L	Twin City Water Clinic, Inc.				
Lunch Room Drinking Fountain (DFL)	Active - Consumption	Initial - First Draw	25-11691	9/25/2025 5:38	10/10/2025 13:38	ND	µg/L	Twin City Water Clinic, Inc.				
Lunch Room Drinking Fountain (DFR)	Active - Consumption	Initial - First Draw	25-11692	9/25/2025 5:39	10/10/2025 13:44	ND	µg/L	Twin City Water Clinic, Inc.				
Hallway Drinking Fountain (DF) Loading AREA	Active - Consumption	Initial - First Draw	25-11693	9/25/2025 5:41	10/10/2025 13:50	ND	µg/L	Twin City Water Clinic, Inc.				
G100 Concession-Sink	Active - Consumption	Initial - First Draw	25-11694	9/25/2025 5:42	10/10/2025 13:56	ND	µg/L	Twin City Water Clinic, Inc.	Building Flushing Program-Daily			
Gym Lobby-Drinking Fountain (DF)	Active - Consumption	Initial - First Draw	25-11695	9/25/2025 5:43	10/10/2025 14:02	ND	µg/L	Twin City Water Clinic, Inc.	Building Flushing Program-Daily			
Hallway Drinking Fountain (DF) G13	Active - Consumption	Initial - First Draw	25-11696	9/25/2025 5:45	10/10/2025 14:08	ND	µg/L	Twin City Water Clinic, Inc.	Building Flushing Program-Daily			
Girls Locker Room-Drinking Fountain (DF)	Active - Consumption	Initial - First Draw	25-11697	9/25/2025 5:46	10/10/2025 14:14	ND	µg/L	Twin City Water Clinic, Inc.	Building Flushing Program-Daily			
Boys Locker Room-Drinking Fountain (DF)	Active - Consumption	Initial - First Draw	25-11698	9/25/2025 5:47	10/10/2025 14:20	ND	µg/L	Twin City Water Clinic, Inc.	Building Flushing Program-Daily			

KEY: DF=Drinking Fountain  
BF=Bottle Filler  
S=Sink  
DFL & DFR=Drinking fountain left and right

Definitions of Reporting Fields

Field Name	Response Needed or Definition	Where does this information come from?
<b>Unique Sample Site Identification Number</b>	A unique number or code using numbers and or letters that a facility assigns to each fixture in the building. This prevents confusion about which sample goes with which fixture.	<b>Facility</b>
<b>Fixture Type</b>	Describes the type of fixture such as sink, fountain, bottle filler, ice machine, kitchen kettle, coffee machine, etc..	<b>Facility</b>
<b>Location Description</b>	Specific description of the location of the fixture. Ex. Classroom sink in Room 112 or Left drinking fountain in gym	<b>Facility</b>
<b>Fixture Status</b>	Describes if the fixture is currently being used and how it is used. Examples are Active-Consumption, Inactive-Consumption, Active-Nonconsumption, Inactive-Nonconsumption	<b>Facility</b>
<b>Sample Collection Type</b>	Initial first draw, Initial Flushed, Follow-up First Draw, Follow-up Flushed, Other	<b>Facility</b>
<b>Laboratory Identification Number</b>	Number assigned by the laboratory to each sample. It may be helpful for facilities using this spreadsheet to cross reference to their lab results. (Optional)	<b>Lab</b>
<b>Date/Time Collected</b>	Date and time the sample was collected Ex. 2/12/2024 7:03 PM or 3/8/24 13:02	<b>Lab</b>
<b>Date/Time Analyzed</b>	Date and time the sample was analyzed Ex. 2/12/2024 7:03 PM or 3/8/24 13:02	<b>Lab</b>
<b>Numeric Result</b>	This is the number representing the result reported by the lab. Ex. 5.12, 7.03, 89.02, for results that are not detected please use ND	<b>Lab</b>
<b>Unit of Measure</b>	This is the unit of the result reported by the lab Ex. Parts per billion (ppb), micrograms per liter (ug/L).	<b>Lab</b>
<b>Name of Laboratory Used For Analysis</b>	The name of the laboratory used for sample analysis.	<b>Lab</b>
<b>Remediation Action</b>	Describes the type of remediation (if needed). Select from drop down menu. You only need to complete if result is 5ppb or more. If the action you took is not listed select OTHER and describe	<b>Facility</b>
<b>Other Remediation-Please Describe</b>	Use this field to type in your remediation action if the choice was not listed in the Remediation Action Drop down menu.	<b>Facility</b>
<b>Was Remediation Successful (ie. Follow-up)</b>	Select from the drop down. Options are Yes, No, Not Applicable(N/A), and Pending Results	<b>Facility</b>

Other Important Terms	Definitions
<b>Consumption</b>	For the purposes of this testing consumption means a fixture where the water is used for drinking water or food/formula preparation.
<b>Non-Consumption</b>	A fixture that is not used for drinking water or food preparation such as a laboratory sink or a mop sink in a locked custodial closet. MDH recommends that non-consumption fixtures be labeled as not for drinking if they are not tested.
<b>Active</b>	A fixture currently able to be used.
<b>Inactive</b>	A fixture that has been taken out of service either temporarily or permanently
<b>First Draw</b>	A type of water sample where the water has been stagnant for 8-18 hours before collecting a sample. The most common type of lead sample type.
<b>Flushed</b>	A type of water sample where the water has been allowed to run before collecting. Typically collected when investigating to source of lead or evaluating remediation options.
<b>Initial</b>	This is typically a first draw sample collected during a round of monitoring. A sample may be an initial-first draw or an initial-flushed
<b>Follow-up</b>	This is typically collected if an initial sample collected during a round of sampling is 5ppb or more. Follow-up samples can be repeated first draw samples or flushed samples depending on the type of follow-up activities conducted to reduce lead.