

Districtwide Lead in Drinking Water Sampling and Remediation Plan for 2023-2025 Compliance

Half Hollow Hills CSD

June 2025

(updated 8/22/25)

Enviroscience Project #23234



2150 Smithtown Ave., Suite 3, Ronkonkoma, NY 11779

T: 631.580.3191 • **F:** 631.580.3195 • **W:** envirohealth.org

DISTRICTWIDE LEAD IN DRINKING WATER SAMPLING AND REMEDIATION PLAN

2023-2025

JUNE 2025

ENVIROSCIENCE PROJECT #23234

Prepared for: HALF HOLLOW HILLS CSD
525 Half Hollow Road
Dix Hills, NY 11746

Prepared by: ENVIROSCIENCE CONSULTANTS, LLC
2150 Smithtown Avenue
Ronkonkoma, New York 11779
(631) 580-3191

Project Manager: *Pam Chadderton*

TABLE OF CONTENTS

<u>Section</u>	<u>Title</u>
1.0	Executive Summary
2.0	Sampling Methodology
3.0	Initial Results

Appendices

Appendix A	Half Hollow Hills High School East
Appendix B	Half Hollow Hills High School West
Appendix C	Candlewood Middle School
Appendix D	West Hollow Middle School
Appendix E	Forest Park Elementary School
Appendix F	Chestnut Hill Elementary School
Appendix G	Otsego Elementary School
Appendix H	Sunquam Elementary School
Appendix I	Paumanok Elementary School
Appendix J	Signal Hill Elementary School
Appendix K	Vanderbilt Elementary School
Appendix L	Fran Greenspan Administration Building
Appendix M	Natatorium, Transportation Garage and Facilities

1.0 EXECUTIVE SUMMARY

The Half Hollow Hills CSD has developed their Lead in Drinking Water Sampling and Remediation Plan for the 2023-2025 compliance period, as required by the New York State Department of Health (Public Health Law Sections 1370-a and 1110, Subpart 67-4 Lead Testing in School Drinking Water).

In accordance with the regulation, this Lead Remediation Plan is prepared to identify locations deemed as Applicable Drinking Water Sources and report first draw sample results, to mitigate locations where sample results exceed 5 parts per billion, to identify locations deemed as Non-Applicable Water Sources, communicate this designation to building occupants, and to develop strategies for monitoring locations deemed Non-Applicable Water Sources to insure building occupants do not consume water from these locations.

The following locations within the Half Hollow Hills CSD buildings have been deemed Applicable Drinking Water Sources by the administration:

- 1) Water fountains and bottle filling stations;
- 2) Kitchen water faucets and pot fillers used in food preparation;
- 3) Ice machines
- 4) Home Economics classroom sinks
- 5) Nurse's Office and Faculty Room sinks

First draw samples were collected from each of these locations within the district and analyzed by a New York State Department of Health ELAP certified laboratory. The chains of custody are available upon request. For results at or below 5 ppb, no further action is required until 2028. For locations above 5 ppb, options include: second and third draw sample collection to determine source of lead, designation of the location as Non-applicable Water Source, or permanent removal of the fixture from the location. In either case, the result was communicated by Enviroscience Consultants, and the fixture was shut off by the district immediately upon receipt of results.

The following locations within the Half Hollow Hills CSD buildings were deemed Non-Applicable Water Sources by the administration:

- 1) Science Laboratory sinks
- 2) Art Room sinks
- 3) Technical Classroom sinks
- 4) Other Classroom sinks
- 5) Bathroom sinks
- 6) Outside spigots
- 7) Custodial Closet sinks
- 8) Mixed Valve sinks (or hot only)

In these cases, the Half Hollow Hills CSD staff have placed signs adjacent to the fixture to notify occupants that the water is not intended for consumption. To further support this protocol, the following management of the locations is required:

- 1) Science Laboratory sinks - communicate in writing with students that these locations are for science experiments and hand washing only, not for consumption. This is most easily accomplished by including this language in the laboratory safety paperwork distributed to students at the beginning of the school year. This program should be monitored by the respective science teachers, and any deficiencies reported for assessment and revision, if necessary, by the Facilities Department.
- 2) Art Room sinks - communicate in writing to students that these locations are for cleaning of art supplies and hand washing only, not for consumption. This is most easily accomplished by including this language in the course paperwork distributed to students at the beginning of the school year. This program should be monitored by the respective art teachers, and any deficiencies reported for assessment and revision, if necessary, by the Facilities Department.
- 3) Technical Classroom sinks - classrooms in this category often include wood shop or auto mechanics classrooms, where students are to hand wash after bathroom usage or activities as part of a regular hygiene program. This program should be monitored by teachers and staff to ensure consumption is not taking place, and any deficiencies reported for assessment and revision, if necessary, by the Facilities Department.
- 4) Other classroom sinks - classrooms in this category often include elementary classrooms, where students are to hand wash after bathroom usage or activities as part of a regular hygiene program. This program should be monitored by teachers and staff

to ensure consumption is not taking place, and any deficiencies reported for assessment and revision, if necessary, by the Facilities Department.


- 5) Bathroom sinks - in intermediate buildings, signage should be sufficient for communicating the concept of hand washing only. In elementary schools, personal hygiene should be integrated into curriculum to ensure students understand bathroom sinks are for hand washing only, and not consumption. Further, show what the signage looks like in bathrooms, so they learn to recognize its meaning. This program should be monitored by teachers and staff to ensure consumption is not taking place, and any deficiencies reported for assessment and revision, if necessary, by the Facilities Department.
- 6) Outside spigots - all-weather signage will be installed at each location. Further, spigots will have a special key maintained by the custodial staff to ensure that non-authorized persons do not fill sports coolers or use hoses for consumption. This program should be monitored by custodial staff to ensure consumption is not taking place, and any deficiencies reported for assessment and revision, if necessary, by the Facilities Department.
- 7) Custodial Closet sinks - these locations should be accessed by custodial personnel only and locked when not in use. Access to others should be restricted. This program should be monitored by custodial staff to ensure consumption is not taking place, and any deficiencies reported for assessment and revision, if necessary, by the Facilities Department.
- 8) Mixed Valve sinks (or hot only) – per Public Health Law Sections 1370-a and 1110, Subpart 67-4 Lead Testing in School Drinking Water mixed valve or hot water only sources are not required to be sampled. Signage is required for these sources. Signage should be sufficient for communicating the concept of hand washing only. In elementary schools, personal hygiene should be integrated into curriculum to ensure students understand bathroom sinks are for hand washing only, and not consumption. Further, show what the signage looks like so they learn to recognize its meaning. This program should be monitored by teachers and staff to ensure consumption is not taking place, and any deficiencies reported for assessment and revision, if necessary, by the Facilities Department.

All locations deemed non-applicable, but do not have signs, should be taken offline until signs have been posted. Signs are suggested to have pictures that instruct for handwashing only, do not drink.

2.0 SAMPLING METHODOLOGY

In accordance with the regulation, Enviroscience Consultants, LLC performed initial water sampling at the Half Hollow Hills CSD buildings from June 7 to June 25, 2025. Samples were collected in wide-mouth 250 milliliter containers and were collected in the morning hours before the facilities opened. The water sources were not used for at least 8 hours and not more than 18 hours prior to sampling. Unique source numbers and designations were assigned to each source location. Unique sample identification numbers were assigned to each sample taken. The key to fixture type codes, source designations, and the sampling location schematics are shown below.

Code Key for Lead in Water			
Fixture Type Codes			
BF	Bottle Filler	SK	Sink
HB	Hose Bib	SL	Supply Line
IM	Ice Machine	SP	Spigot
OS	Other Source	SPY	Spray
PF	Pot Filler	SS	Slop Sink
		V	Valve
		WC	Water Cooler
		WF	Water Fountain
Source Designations			
App	Applicable	N/A	Non-applicable



SCIENCE ROOM TYPE 1 DIAGRAM	SCIENCE ROOM TYPE 2 DIAGRAM	SCIENCE ROOM TYPE 3 DIAGRAM																																																																																												
SAMPLE IDENTIFICATION (example) <table><tr><th>LOCATION</th><th>SOURCE</th></tr><tr><td>Room 200 - Teacher Station</td><td>SK</td></tr><tr><td>Room 200 - Counter 1 @ (A)</td><td>SK</td></tr><tr><td>Room 200 - Counter 1 @ (B)</td><td>SK</td></tr><tr><td>Room 200 - Counter 2 @ (A)</td><td>SK</td></tr><tr><td>Room 200 - Counter 2 @ (B)</td><td>SK</td></tr><tr><td>Room 200 - Counter 3 @ (A)</td><td>SK</td></tr><tr><td>Room 200 - Counter 3 @ (B)</td><td>SK</td></tr></table>	LOCATION	SOURCE	Room 200 - Teacher Station	SK	Room 200 - Counter 1 @ (A)	SK	Room 200 - Counter 1 @ (B)	SK	Room 200 - Counter 2 @ (A)	SK	Room 200 - Counter 2 @ (B)	SK	Room 200 - Counter 3 @ (A)	SK	Room 200 - Counter 3 @ (B)	SK	SAMPLE IDENTIFICATION (example) <table><tr><th>LOCATION</th><th>SOURCE</th></tr><tr><td>Room 200 - Teacher Station</td><td>SK</td></tr><tr><td>Room 200 - Table 1 @ (A)</td><td>SK</td></tr><tr><td>Room 200 - Table 1 @ (B)</td><td>SK</td></tr><tr><td>Room 200 - Table 2 @ (A)</td><td>SK</td></tr><tr><td>Room 200 - Table 2 @ (B)</td><td>SK</td></tr><tr><td>Room 200 - Table 3 @ (A)</td><td>SK</td></tr><tr><td>Room 200 - Table 3 @ (B)</td><td>SK</td></tr><tr><td>Room 200 - Table 4 @ (A)</td><td>SK</td></tr><tr><td>Room 200 - Table 4 @ (B)</td><td>SK</td></tr><tr><td>Room 200 - Counter 1 @ (A)</td><td>SK</td></tr><tr><td>Room 200 - Counter 1 @ (B)</td><td>SK</td></tr><tr><td>Room 200 - Counter 2 @ (A)</td><td>SK</td></tr><tr><td>Room 200 - Counter 2 @ (B)</td><td>SK</td></tr><tr><td>Room 200 - Counter 3 @ (A)</td><td>SK</td></tr><tr><td>Room 200 - Counter 3 @ (B)</td><td>SK</td></tr><tr><td>Room 200 - Counter 4 @ (A)</td><td>SK</td></tr><tr><td>Room 200 - Counter 4 @ (B)</td><td>SK</td></tr></table>	LOCATION	SOURCE	Room 200 - Teacher Station	SK	Room 200 - Table 1 @ (A)	SK	Room 200 - Table 1 @ (B)	SK	Room 200 - Table 2 @ (A)	SK	Room 200 - Table 2 @ (B)	SK	Room 200 - Table 3 @ (A)	SK	Room 200 - Table 3 @ (B)	SK	Room 200 - Table 4 @ (A)	SK	Room 200 - Table 4 @ (B)	SK	Room 200 - Counter 1 @ (A)	SK	Room 200 - Counter 1 @ (B)	SK	Room 200 - Counter 2 @ (A)	SK	Room 200 - Counter 2 @ (B)	SK	Room 200 - Counter 3 @ (A)	SK	Room 200 - Counter 3 @ (B)	SK	Room 200 - Counter 4 @ (A)	SK	Room 200 - Counter 4 @ (B)	SK	SAMPLE IDENTIFICATION (example) <table><tr><th>LOCATION</th><th>SOURCE</th></tr><tr><td>Room 200 - Teacher Station</td><td>SK</td></tr><tr><td>Room 200 - POD 1 @ (A)</td><td>SK</td></tr><tr><td>Room 200 - POD 1 @ (B)</td><td>SK</td></tr><tr><td>Room 200 - POD 1 @ (C)</td><td>SK</td></tr><tr><td>Room 200 - POD 1 @ (D)</td><td>SK</td></tr><tr><td>Room 200 - POD 1 @ (E)</td><td>SK</td></tr><tr><td>Room 200 - POD 1 @ (F)</td><td>SK</td></tr><tr><td>Room 200 - POD 2 @ (A)</td><td>SK</td></tr><tr><td>Room 200 - POD 2 @ (B)</td><td>SK</td></tr><tr><td>Room 200 - POD 2 @ (C)</td><td>SK</td></tr><tr><td>Room 200 - POD 2 @ (D)</td><td>SK</td></tr><tr><td>Room 200 - POD 2 @ (E)</td><td>SK</td></tr><tr><td>Room 200 - POD 2 @ (F)</td><td>SK</td></tr><tr><td>Room 200 - POD 3 @ (A)</td><td>SK</td></tr><tr><td>Room 200 - POD 3 @ (B)</td><td>SK</td></tr><tr><td>Room 200 - POD 3 @ (C)</td><td>SK</td></tr><tr><td>Room 200 - POD 3 @ (D)</td><td>SK</td></tr><tr><td>Room 200 - POD 3 @ (E)</td><td>SK</td></tr><tr><td>Room 200 - POD 3 @ (F)</td><td>SK</td></tr></table>	LOCATION	SOURCE	Room 200 - Teacher Station	SK	Room 200 - POD 1 @ (A)	SK	Room 200 - POD 1 @ (B)	SK	Room 200 - POD 1 @ (C)	SK	Room 200 - POD 1 @ (D)	SK	Room 200 - POD 1 @ (E)	SK	Room 200 - POD 1 @ (F)	SK	Room 200 - POD 2 @ (A)	SK	Room 200 - POD 2 @ (B)	SK	Room 200 - POD 2 @ (C)	SK	Room 200 - POD 2 @ (D)	SK	Room 200 - POD 2 @ (E)	SK	Room 200 - POD 2 @ (F)	SK	Room 200 - POD 3 @ (A)	SK	Room 200 - POD 3 @ (B)	SK	Room 200 - POD 3 @ (C)	SK	Room 200 - POD 3 @ (D)	SK	Room 200 - POD 3 @ (E)	SK	Room 200 - POD 3 @ (F)	SK
LOCATION	SOURCE																																																																																													
Room 200 - Teacher Station	SK																																																																																													
Room 200 - Counter 1 @ (A)	SK																																																																																													
Room 200 - Counter 1 @ (B)	SK																																																																																													
Room 200 - Counter 2 @ (A)	SK																																																																																													
Room 200 - Counter 2 @ (B)	SK																																																																																													
Room 200 - Counter 3 @ (A)	SK																																																																																													
Room 200 - Counter 3 @ (B)	SK																																																																																													
LOCATION	SOURCE																																																																																													
Room 200 - Teacher Station	SK																																																																																													
Room 200 - Table 1 @ (A)	SK																																																																																													
Room 200 - Table 1 @ (B)	SK																																																																																													
Room 200 - Table 2 @ (A)	SK																																																																																													
Room 200 - Table 2 @ (B)	SK																																																																																													
Room 200 - Table 3 @ (A)	SK																																																																																													
Room 200 - Table 3 @ (B)	SK																																																																																													
Room 200 - Table 4 @ (A)	SK																																																																																													
Room 200 - Table 4 @ (B)	SK																																																																																													
Room 200 - Counter 1 @ (A)	SK																																																																																													
Room 200 - Counter 1 @ (B)	SK																																																																																													
Room 200 - Counter 2 @ (A)	SK																																																																																													
Room 200 - Counter 2 @ (B)	SK																																																																																													
Room 200 - Counter 3 @ (A)	SK																																																																																													
Room 200 - Counter 3 @ (B)	SK																																																																																													
Room 200 - Counter 4 @ (A)	SK																																																																																													
Room 200 - Counter 4 @ (B)	SK																																																																																													
LOCATION	SOURCE																																																																																													
Room 200 - Teacher Station	SK																																																																																													
Room 200 - POD 1 @ (A)	SK																																																																																													
Room 200 - POD 1 @ (B)	SK																																																																																													
Room 200 - POD 1 @ (C)	SK																																																																																													
Room 200 - POD 1 @ (D)	SK																																																																																													
Room 200 - POD 1 @ (E)	SK																																																																																													
Room 200 - POD 1 @ (F)	SK																																																																																													
Room 200 - POD 2 @ (A)	SK																																																																																													
Room 200 - POD 2 @ (B)	SK																																																																																													
Room 200 - POD 2 @ (C)	SK																																																																																													
Room 200 - POD 2 @ (D)	SK																																																																																													
Room 200 - POD 2 @ (E)	SK																																																																																													
Room 200 - POD 2 @ (F)	SK																																																																																													
Room 200 - POD 3 @ (A)	SK																																																																																													
Room 200 - POD 3 @ (B)	SK																																																																																													
Room 200 - POD 3 @ (C)	SK																																																																																													
Room 200 - POD 3 @ (D)	SK																																																																																													
Room 200 - POD 3 @ (E)	SK																																																																																													
Room 200 - POD 3 @ (F)	SK																																																																																													
NOT TO SCALE Date: 9/26/2016 By: Robert Cardona	WATER SAMPLING METHODOLOGY	KEY PLAN NO SCALE ENVIROSCIENCE CONSULTANTS, INC. 2150 SMITHTOWN AVENUE ROCKY HILL, CT 06067 (831) 580-3191 FAX 580-3195 www.envirohealth.org																																																																																												

3.0 Initial Results

All water source locations in each of the school buildings were assessed. Water source locations identified as drinking water sources were considered Applicable, and first draw samples were collected. Water source locations identified as non-drinking water sources were considered non-applicable and these locations were documented.

The results of the initial sampling and the use of signs warning against water use at non-applicable sources is documented in the School Water Outlet Inventory for each building.

All elevated locations should be taken off line until the remediation is completed. Any other drinking water sources in these buildings that were not functional at the time of initial sampling and have not been tested should be tested before returning to service. All locations deemed non-applicable, but do not have signs, should be taken offline until signs have been posted. Signs are suggested to have pictures that instruct for handwashing only, do not drink.

The following is a summary of results in parts per billion (ppb) of locations in the Half Hollow Hills CSD where sample results were found above 5 ppb:

Half Hollow Hills High School East			
SAMPLE LOCATION	RESULT	SAMPLE DATE	REMARKS
Kitchen-Pot Filler	22.0	6/14/2025	Removed from service, pending remediation

Half Hollow Hills High School West			
SAMPLE LOCATION	RESULT	SAMPLE DATE	REMARKS
Home Economics Room 151 Station-4 Sink	40.0	6/7/20205	Removed from service, pending remediation
Home Economics Room 151 Station-4 Spray	17.0	6/7/2025	Removed from service, pending remediation
Home Economics Room 151 Station-5 Sink	10.0	6/7/2025	Removed from service, pending remediation

Candlewood Middle School			
SAMPLE LOCATION	RESULT	SAMPLE DATE	REMARKS
Room 402-Teacher's Station Sink	322.0	6/13/2025	Removed from service, pending remediation
Room 402 Prep Room Sink	155.0	6/13/2025	Removed from service, pending remediation
Room 402-Counter @ C Sink	6.0	6/13/2025	Removed from service, pending remediation
Room 402-Counter @ F Sink	42.0	6/13/2025	Removed from service, pending remediation
Room 402-Counter @ G Sink	82.0	6/13/2025	Removed from service, pending remediation

West Hollow Middle School			
SAMPLE LOCATION	RESULT	SAMPLE DATE	REMARKS
Kitchen Island Prep by Freezer Sink	12.0	6/20/2025	Removed from service, pending remediation
Prep Room 223/225 (laundry) Sink	7.0	6/20/2025	Removed from service, pending remediation

Forest Park Elementary School			
SAMPLE LOCATION	RESULT	SAMPLE DATE	REMARKS
No exceedances			

Chestnut Hill Elementary School			
SAMPLE LOCATION	RESULT	SAMPLE DATE	REMARKS
No exceedances			

Otsego Elementary School			
SAMPLE LOCATION	RESULT	SAMPLE DATE	REMARKS
No exceedances			

Sunquam Elementary School			
SAMPLE LOCATION	RESULT	SAMPLE DATE	REMARKS
No exceedances			

Paumanok Elementary School			
SAMPLE LOCATION	RESULT	SAMPLE DATE	REMARKS
Kitchen-Serving Area – Single Unit Sink	22.0	6/17/2025	Removed from service, pending remediation
Kitchen-Potfiller Hose by Stove	52.0	6/17/2025	Removed from service, pending remediation

Signal Hill Elementary School			
SAMPLE LOCATION	RESULT	SAMPLE DATE	REMARKS
Kitchen Potfiller	6.0	6/18/2025	Removed from service, pending remediation

Vanderbilt Elementary School			
SAMPLE LOCATION	RESULT	SAMPLE DATE	REMARKS
Kitchen 2-Bay Prep Sink	180.0	6/18/2025	Removed from service, pending remediation

Fran Greenspan Administration Building			
SAMPLE LOCATION	RESULT	SAMPLE DATE	REMARKS
Mail Room Office Kitchenette Sink	20.0	6/17/2025	Removed from service, pending remediation
Mail Room Office Kitchenette Spray	6.0	6/17/2025	Removed from service, pending remediation

Half Hollow Hills Natatorium			
SAMPLE LOCATION	RESULT	SAMPLE DATE	REMARKS
No exceedances			

Transportation Garage			
SAMPLE LOCATION	RESULT	SAMPLE DATE	REMARKS
No exceedances			

Facilities Building			
SAMPLE LOCATION	RESULT	SAMPLE DATE	REMARKS
No exceedances			

Appendix A

Half Hollow Hills High School East

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1 st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
0001-1	Hall By Room 908	WF	App		6/14/2025	-	-	-	Removed from service, sampling required before returning to service
0002-1	Women's Bathroom by Room 906 @A	SK	N/A		6/14/2025	-	-	-	Sign
0002-2	Women's Bathroom by Room 906 @B	SK	N/A		6/14/2025	-	-	-	Sign
0002-3	Women's Bathroom by Room 906 @C	SK	N/A		6/14/2025	-	-	-	Sign
0002-4	Women's Bathroom by Room 906 @D	SK	N/A		6/14/2025	-	-	-	Sign
0003-1	Custodial Closet by Room 906	SS	N/A		6/14/2025	-	-	-	Sign
0004-1	Men's Bathroom by Room 906 @A	SK	N/A		6/14/2025	-	-	-	Sign
0004-2	Men's Bathroom by Room 906 @B	SK	N/A		6/14/2025	-	-	-	Sign
0004-3	Men's Bathroom by Room 906 @C	SK	N/A		6/14/2025	-	-	-	Sign
0005-1	Hall by Room 901	WF	App		6/14/2025	-	-	-	Removed from service, sampling required before returning to service
0005-1	Hall by Room 901	BF	App	<1.0	6/14/2025	-	-	-	
0006-1	Girl's Locker Room Exit Vestibule	WF	App		6/14/2025	-	-	-	Removed from service, sampling required before returning to service
0006-2	Girl's Coach's Office Bathroom	SK	N/A		6/14/2025	-	-	-	Sign
0006-3	Girl's Locker Room Bathroom @A	SK	N/A		6/14/2025	-	-	-	Sign
0006-4	Girl's Locker Room Bathroom @B	SK	N/A		6/14/2025	-	-	-	Sign
0006-5	Girl's Locker Room Bathroom @C	SK	N/A		6/14/2025	-	-	-	Sign
0006-6	Girl's Locker Room Custodial Closet	SS	N/A		6/14/2025	-	-	-	Sign
0007-1	Boy's Coach's Office Bathroom	SK	N/A		6/14/2025	-	-	-	Sign
0007-2	Boy's Locker Room	BF	App	<1.0	6/14/2025	-	-	-	
0007-3	Boy's Locker Room Bathroom @A	SK	N/A		6/14/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1 st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
0007-4	Boy's Locker Room Bathroom @B	SK	N/A		6/14/2025	-	-	-	Sign
0007-5	Boy's Locker Room Bathroom @C	SK	N/A		6/14/2025	-	-	-	Sign
0007-6	Boy's Locker Room Custodial Closet	SS	N/A		6/14/2025	-	-	-	Sign
0008-1	Boy's Team Room Bathroom @A	SK	N/A		6/14/2025	-	-	-	Sign
0008-2	Boy's Team Room Bathroom @B	SK	N/A		6/14/2025	-	-	-	Sign
0008-3	Boy's Team Room	WF	App		6/14/2025	-	-	-	Removed from service, sampling required before returning to service
0008-4	Boy's Team Room Coach's Office Bathroom	SK	N/A		6/14/2025	-	-	-	Sign
1001-1	Cafeteria B	WF	App	<1.0	6/14/2025	-	-	-	
1001-2	Cafeteria B	BF	App	<1.0	6/14/2025	-	-	-	
1002-1	Kitchen-Serving Area-Handwash-Left	SK	N/A		6/14/2025	-	-	-	Sign
1002-3	Kitchen-Custodial Closet	SS	N/A		6/14/2025	-	-	-	Sign
1002-4	Kitchen-2 Bay Unit	SK	App	1.0	6/14/2025	-	-	-	
1002-5	Kitchen-2 Bay Unit	SPY	App	1.0	6/14/2025	-	-	-	
1002-6	Kitchen Bathroom	SK	N/A		6/14/2025	-	-	-	Sign
1002-7	Kitchen-Handwash-Right	SK	N/A		6/14/2025	-	-	-	Sign
1002-8	Kitchen-Pot Filler	PF	App	4.0	8/22/2025	-	-	-	Remediation Complete
				22.0	6/14/2025	-	-	-	Removed from service, pending remediation
1002-9	Kitchen-3 Bay Unit-Left	SK	N/A		6/14/2025	-	-	-	Sign
1002-10	Kitchen-3 Bay Unit-Right	SK	N/A		6/14/2025	-	-	-	Sign
1002-11	Kitchen-3 Bay Unit	SPY	N/A		6/14/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1 st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1002-12	Kitchen-Prep Island	SK	N/A		6/14/2025	-	-	-	Sign
1003-1	Faculty Room Cafeteria-Serving Line	SK	N/A		6/14/2025	-	-	-	Sign
1003-2	Faculty Room-Cafeteria	WF	App		6/14/2025	-	-	-	Removed from service, sampling required before returning to service
1004-1	Cafeteria A	WF	App	<1.0	6/14/2025	-	-	-	
1004-2	Cafeteria A	BF	App	<1.0	6/14/2025	-	-	-	
1004-3	Cafeteria A-Custodial Closet	SS	N/A		6/14/2025	-	-	-	Sign
1005-1	Boy's Bathroom by Cafeteria A @A	SK	N/A		6/14/2025	-	-	-	Sign
1005-2	Boy's Bathroom by Cafeteria A @B	SK	N/A		6/14/2025	-	-	-	Sign
1005-3	Boy's Bathroom by Cafeteria A @C	SK	N/A		6/14/2025	-	-	-	Sign
1006-1	Men's Faculty Bathroom by Cafeteria A	SK	N/A		6/14/2025	-	-	-	Sign
1007-1	Custodial Closet by Cafeteria A	SS	N/A		6/14/2025	-	-	-	Sign
1008-1	Girl's Bathroom by Cafeteria A @A	SK	N/A		6/14/2025	-	-	-	Sign
1008-2	Girl's Bathroom by Cafeteria A @B	SK	N/A		6/14/2025	-	-	-	Sign
1008-3	Girl's Bathroom by Cafeteria A @C	SK	N/A		6/14/2025	-	-	-	Sign
1009-1	Women's Faculty Bathroom by Cafeteria A	SK	N/A		6/14/2025	-	-	-	Sign
1010-1	Fencing Bathroom by Cafeteria A @A	SK	N/A		6/14/2025	-	-	-	Sign
1010-2	Fencing Bathroom by Cafeteria A @B	SK	N/A		6/14/2025	-	-	-	Sign
1011-1	Hall by Room 812	WF	App		6/14/2025	-	-	-	Removed from service, sampling required before returning to service
1012-1	Room 812-Teacher's Station	SK	N/A		6/14/2025	-	-	-	Sign
1012-2	Room 812-Counter @A	SK	N/A		6/14/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1012-3	Room 812-Counter @B	SK	N/A		6/14/2025	-	-	-	Sign
1012-4	Room 812-Island 1 @A	SK	N/A		6/14/2025	-	-	-	Sign
1012-5	Room 812-Island 1 @B	SK	N/A		6/14/2025	-	-	-	Sign
1012-6	Room 812-Island 1 @C	SK	N/A		6/14/2025	-	-	-	Sign
1012-7	Room 812-Island 1 @D	SK	N/A		6/14/2025	-	-	-	Sign
1012-9	Room 812-Island 2 @B	SK	N/A		6/14/2025	-	-	-	Sign
1012-10	Room 812-Island 2 @C	SK	N/A		6/14/2025	-	-	-	Sign
1012-11	Room 812-Island 2 @D	SK	N/A		6/14/2025	-	-	-	Sign
1013-1	Hall by Room 707	WF	App		6/14/2025	-	-	-	Removed from service, sampling required before returning to service
1014-1	Custodial Closet by Room 711	SS	N/A		6/14/2025	-	-	-	Sign
1015-1	Faculty Men's Bathroom @A	SK	N/A		6/14/2025	-	-	-	Sign
1015-2	Faculty Men's Bathroom @B	SK	N/A		6/14/2025	-	-	-	Sign
1015-3	Faculty Men's Bathroom @C	SK	N/A		6/14/2025	-	-	-	Sign
1016-1	Hall by Room 711	BF	App	<1.0	6/14/2025	-	-	-	
1017-1	Room 711	SK	N/A		6/14/2025	-	-	-	Sign
1018-1	Staff Bathroom by Room 715 @A	SK	N/A		6/14/2025	-	-	-	Sign
1018-2	Staff Bathroom by Room 715 @B	SK	N/A		6/14/2025	-	-	-	Sign
1018-3	Staff Bathroom by Room 715 @C	SK	N/A		6/14/2025	-	-	-	Sign
1019-1	Loading Dock Bathroom	SK	N/A		6/14/2025	-	-	-	Sign
1020-1	Hall by Room 911	WF	App		6/14/2025	-	-	-	Removed from service, sampling required before returning to service

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1021-1	Boy's Bathroom by Room 916 @A	SK	N/A		6/14/2025	-	-	-	Sign
1021-2	Boy's Bathroom by Room 916 @B	SK	N/A		6/14/2025	-	-	-	Sign
1021-3	Boy's Bathroom by Room 916 @C	SK	N/A		6/14/2025	-	-	-	Sign
1022-1	Custodial Closet by Room 916	SS	N/A		6/14/2025	-	-	-	Sign
1023-1	Girl's Bathroom by Room 916 @A	SK	N/A		6/14/2025	-	-	-	Sign
1023-2	Girl's Bathroom by Room 916 @B	SK	N/A		6/14/2025	-	-	-	Sign
1023-3	Girl's Bathroom by Room 916 @C	SK	N/A		6/14/2025	-	-	-	Sign
1023-4	Girl's Bathroom by Room 916 @D	SK	N/A		6/14/2025	-	-	-	Sign
1024-1	Hall by Room 917	WF	App		6/14/2025	-	-	-	Removed from service, sampling required before returning to service
1025-1	Women's Bathroom by Guidance Office @A	SK	N/A		6/14/2025	-	-	-	Sign
1025-2	Women's Bathroom by Guidance Office @B	SK	N/A		6/14/2025	-	-	-	Sign
1025-3	Women's Bathroom by Guidance Office @C	SK	N/A		6/14/2025	-	-	-	Sign
1026-1	Hall by Room 717	WF	App		6/14/2025	-	-	-	Removed from service, sampling required before returning to service
1027-1	Men's Bathroom by Room 717 @A	SK	N/A		6/14/2025	-	-	-	Sign
1027-2	Men's Bathroom by Room 717 @B	SK	N/A		6/14/2025	-	-	-	Sign
1027-3	Men's Bathroom by Room 717 @C	SK	N/A		6/14/2025	-	-	-	Sign
1028-1	Nurse's Office	SK	N/A		6/14/2025	-	-	-	Sign
1028-2	Nurse's Office Bathroom	SK	N/A		6/14/2025	-	-	-	Sign
1028-3	Nurse's Office Ice Machine	IM	App	<1.0	6/14/2025	-	-	-	
1029-1	Principal's Office Bathroom	SK	N/A		6/14/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1029-2	Main Office Kitchenette	SK	N/A		6/14/2025	-	-	-	Sign
1030-1	Men's Bathroom by Mail Room @A	SK	N/A		6/14/2025	-	-	-	Sign
1030-2	Men's Bathroom by Mail Room @B	SK	N/A		6/14/2025	-	-	-	Sign
1030-3	Men's Bathroom by Mail Room @C	SK	N/A		6/14/2025	-	-	-	Sign
1031-1	Hall by Mail Room	WF	App		6/14/2025	-	-	-	Removed from service, sampling required before returning to service
1031-2	Hall by Mail Room	BF	App	<1.0	6/14/2025	-	-	-	
1032-1	Girl's Bathroom by Room 701 @A	SK	N/A		6/14/2025	-	-	-	Sign
1032-2	Girl's Bathroom by Room 701 @B	SK	N/A		6/14/2025	-	-	-	Sign
1033-1	Hall by Room 703	WF	App		6/14/2025	-	-	-	Removed from service, sampling required before returning to service
1034-1	Room 703	SK	N/A		6/14/2025	-	-	-	Sign
1035-1	Girl's Bathroom by Room 611	SK	N/A		6/14/2025	-	-	-	Sign
1036-1	Custodial Closet by Reoom 611	SS	N/A		6/14/2025	-	-	-	Sign
1037-1	Boy's Bathroom by Room 611	SK	N/A		6/14/2025	-	-	-	Sign
1038-1	Hall by Room 609	BF	App	<1.0	6/14/2025	-	-	-	
1039-1	Hall by Room 603	WF	App		6/14/2025	-	-	-	Removed from service, sampling required before returning to service
1040-1	Women's Bathroom by Room 603	SK	N/A		6/14/2025	-	-	-	Sign
1041-1	Men's Bathroom by Room 603	SK	N/A		6/14/2025	-	-	-	Sign
1042-1	Room 605 @A	SK	N/A		6/14/2025	-	-	-	Sign
1042-2	Room 605 @B	SK	N/A		6/14/2025	-	-	-	Sign
1042-3	Room 605 @C	SK	N/A		6/14/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1 st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1043-1	Women's Bathroom by Auditorium/Lobby @A	SK	N/A		6/14/2025	-	-	-	Sign
1043-2	Women's Bathroom by Auditorium/Lobby @B	SK	N/A		6/14/2025	-	-	-	Sign
1043-3	Women's Bathroom by Auditorium/Lobby @C	SK	N/A		6/14/2025	-	-	-	Sign
1043-4	Women's Bathroom by Auditorium/Lobby @D	SK	N/A		6/14/2025	-	-	-	Sign
1043-5	Women's Bathroom by Auditorium/Lobby @E	SK	N/A		6/14/2025	-	-	-	Sign
1044-1	Hall by Women's Bathroom	WF	App		6/14/2025	-	-	-	Removed from service, sampling required before returning to service
1045-1	Hall by Men's Bathroom	BF	App	<1.0	6/14/2025	-	-	-	
1046-2	Men's Bathroom by Auditorium/Lobby @B	SK	N/A		6/14/2025	-	-	-	Sign
1046-3	Men's Bathroom by Auditorium/Lobby @C	SK	N/A		6/14/2025	-	-	-	Sign
1046-4	Men's Bathroom-Custodial Closet	SS	N/A		6/14/2025	-	-	-	Sign
1047-1	Hall by Main Gym-Girl's Side	WF	App		6/14/2025	-	-	-	Removed from service, sampling required before returning to service
1048-1	Main Gym-Girl's Side	WF	App	<1.0	6/14/2025	-	-	-	
1048-2	Main Gym-Girl's Side	BF	App	<1.0	6/14/2025	-	-	-	
1049-1	Trainer's Office	IM	App	<1.0	6/14/2025	-	-	-	
1049-2	Trainer's Office	SS	N/A		6/14/2025	-	-	-	Sign
1049-3	Trainer's Office Sports Jug	SK	App	2.0	6/14/2025	-	-	-	
1050-1	Main Gym-Boy's Side	WF	App		6/14/2025	-	-	-	Removed from service, sampling required before returning to service
1051-1	Hall by Main Gym-Boy's Side	WF	App		6/14/2025	-	-	-	Removed from service, sampling required before returning to service
1052-1	Boy's Bathroom by Room 211 @A	SK	N/A		6/14/2025	-	-	-	Sign
1052-2	Boy's Bathroom by Room 211 @B	SK	N/A		6/14/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1052-3	Boy's Bathroom by Room 211 @C	SK	N/A		6/14/2025	-	-	-	Sign
1052-4	Boy's Bathroom by Room 211 @D	SK	N/A		6/14/2025	-	-	-	Sign
1052-5	Boy's Bathroom by Room 211 @E	SK	N/A		6/14/2025	-	-	-	Sign
1053-1	Custodial Closet by Room 211	SS	N/A		6/14/2025	-	-	-	Sign
1054-1	Girl's Bathroom by Room 211 @A	SK	N/A		6/14/2025	-	-	-	Sign
1054-2	Girl's Bathroom by Room 211 @B	SK	N/A		6/14/2025	-	-	-	Sign
1054-3	Girl's Bathroom by Room 211 @C	SK	N/A		6/14/2025	-	-	-	Sign
1054-4	Girl's Bathroom by Room 211 @D	SK	N/A		6/14/2025	-	-	-	Sign
1054-5	Girl's Bathroom by Room 211 @E	SK	N/A		6/14/2025	-	-	-	Sign
1055-1	Room 208	SK	N/A		6/14/2025	-	-	-	Sign
1056-1	Room 204-Counter @A	SK	App	1.0	6/14/2025	-	-	-	
1056-2	Room 204-Counter @A	SPY	N/A		6/14/2025	-	-	-	Sign
1056-3	Room 204-Counter @B	SK	App	2.0	6/14/2025	-	-	-	
1056-4	Room 204-Counter @B	SPY	N/A		6/14/2025	-	-	-	Sign
1056-5	Room 204-Counter @C	SK	App	2.0	6/14/2025	-	-	-	
1056-6	Room 204-Counter @C	SPY	N/A		6/14/2025	-	-	-	Sign
1056-7	Room 204-Counter @D	SK	App	2.0	6/14/2025	-	-	-	
1056-8	Room 204-Counter @D	SPY	N/A		6/14/2025	-	-	-	Sign
1056-9	Room 204-Counter @E	SK	App	1.0	6/14/2025	-	-	-	
1056-10	Room 204-Counter @E	SPY	N/A		6/14/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1 st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1056-11	Room 204-Counter @F	SK	App	2.0	6/14/2025	-	-	-	
1056-12	Room 204-Counter @F	SPY	N/A		6/14/2025	-	-	-	Sign
1057-1	Room 202	SS	N/A		6/14/2025	-	-	-	Sign
1058-1	Hall by Room 105	WF	App		6/14/2025	-	-	-	Removed from service, sampling required before returning to service
1058-1	Hall by Room 105	BF	App	<1.0	6/14/2025	-	-	-	
1059-1	Room 105	SK	N/A		6/14/2025	-	-	-	Sign
1060-1	Library Kitchenette	SK	N/A		6/14/2025	-	-	-	Sign
1061-1	Women's Bathroom by Lecture Hall	SK	N/A		6/14/2025	-	-	-	Sign
1062-1	Hall by Lecture Hall	WF	App	<1.0	6/14/2025	-	-	-	
1062-2	Hall by Lecture Hall	BF	App	<1.0	6/14/2025	-	-	-	
1063-1	Men's Bathroom by Lecture Hall	SK	N/A		6/14/2025	-	-	-	Sign
1064-1	East Wing Office Kitchenette	SK	N/A		6/14/2025	-	-	-	Sign
1064-2	Assistant Principal's Office Bathroom	SK	N/A		6/14/2025	-	-	-	Sign
1065-1	Women's Bathroom by East Office	SK	N/A		6/14/2025	-	-	-	Sign
1066-1	Hall by East Office	WF	App		6/14/2025	-	-	-	Removed from service, sampling required before returning to service
1067-1	Men's Bathroom by East Office	SK	N/A		6/14/2025	-	-	-	Sign
1068-1	East Nurse's Office Bathroom	SK	N/A		6/14/2025	-	-	-	Sign
1068-2	East Nurse's Office	IM	App	<1.0	6/14/2025	-	-	-	
1068-3	East Nurse's Office	SK	N/A		6/14/2025	-	-	-	Sign
1068-4	East Nurse's Office-Exam Room	SK	N/A		6/14/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1 st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1069-1	IPC Girl's Bathroom by Weight Room @A	SK	N/A		6/14/2025	-	-	-	Sign
1069-2	IPC Girl's Bathroom by Weight Room @B	SK	N/A		6/14/2025	-	-	-	Sign
1070-1	Custodial Closet by Weight Room	SS	N/A		6/14/2025	-	-	-	Sign
1071-1	IPC Boy's Bathroom by Weight Room @A	SK	N/A		6/14/2025	-	-	-	Sign
1071-2	IPC Boy's Bathroom by Weight Room @B	SK	N/A		6/14/2025	-	-	-	Sign
1072-1	Room 555-2 Bay Unit	SK	N/A		6/14/2025	-	-	-	Sign
1073-1	Custodial Office Bathroom	SK	N/A		6/14/2025	-	-	-	Sign
1074-1	Room 554-Counter @A	SK	N/A		6/14/2025	-	-	-	Sign
1074-2	Room 554-Counter @B	SK	N/A		6/14/2025	-	-	-	Sign
1075-1	Room 556-Counter @A	SK	N/A		6/14/2025	-	-	-	Sign
1075-2	Room 556-Counter @B	SK	N/A		6/14/2025	-	-	-	Sign
1076-1	District Print Room-Trough @A	SK	N/A		6/14/2025	-	-	-	Sign
1076-2	District Print Room-Trough @B	SK	N/A		6/14/2025	-	-	-	Sign
1076-3	District Print Room-Trough @C	SK	N/A		6/14/2025	-	-	-	Sign
1077-1	Weight Room	WF	App	<1.0	6/14/2025	-	-	-	
1077-2	Weight Room	BF	App	<1.0	6/14/2025	-	-	-	
1078-1	Hall by Room 544	WF	App	<1.0	6/14/2025	-	-	-	
1078-2	Hall by Room 544	BF	App	<1.0	6/14/2025	-	-	-	
1079-1	Boy's East Gym Locker Room Bathroom	SK	N/A		6/14/2025	-	-	-	Sign
1079-2	Boy's East Gym Coach's Office Bathroom	SK	N/A		6/14/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1 st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1080-1	Men's Bathroom by East Gym	SK	N/A		6/14/2025	-	-	-	Sign
1081-1	Custodial Closet by East Gym	SS	N/A		6/14/2025	-	-	-	Sign
1082-1	Women's Bathroom by East Gym @A	SK	N/A		6/14/2025	-	-	-	Sign
1082-2	Women's Bathroom by East Gym @B	SK	N/A		6/14/2025	-	-	-	Sign
1083-1	Girl's East Gym Coach's Office Bathroom	SK	N/A		6/14/2025	-	-	-	Sign
1083-2	Girl's East Gym Locker Room	WF	App		6/14/2025	-	-	-	Removed from service, sampling required before returning to service
1083-3	Girl's East Gym Locker Room Bathroom @	SK	N/A		6/14/2025	-	-	-	Sign
1083-4	Girl's East Gym Locker Room Bathroom @	SK	N/A		6/14/2025	-	-	-	Sign
1084-1	Room 543	SK	N/A		6/14/2025	-	-	-	Sign
1084-2	Room 543-Dark Room	SK	N/A		6/14/2025	-	-	-	Sign
1085-1	Room 541-Left @A	SK	N/A		6/14/2025	-	-	-	Sign
1085-2	Room 541-Left @B	SK	N/A		6/14/2025	-	-	-	Sign
1085-3	Room 541-Left @C	SK	N/A		6/14/2025	-	-	-	Sign
1085-4	Room 541-Right @A	SK	N/A		6/14/2025	-	-	-	Sign
1085-5	Room 541-Right @B	SK	N/A		6/14/2025	-	-	-	Sign
1085-6	Room 541-Right @C	SK	N/A		6/14/2025	-	-	-	Sign
1086-1	Room 406-Teacher's Station @A	SK	N/A		6/14/2025	-	-	-	Sign
1086-2	Room 406-Teacher's Station @B	SK	N/A		6/14/2025	-	-	-	Sign
1086-3	Room 406-Pod 1 @A	SK	N/A		6/14/2025	-	-	-	Sign
1086-4	Room 406-Pod 1 @B	SK	N/A		6/14/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1086-5	Room 406-Pod 2 @A	SK	N/A		6/14/2025	-	-	-	Sign
1086-6	Room 406-Pod 2 @B	SK	N/A		6/14/2025	-	-	-	Sign
1086-7	Room 406-Pod 3 @A	SK	N/A		6/14/2025	-	-	-	Sign
1086-8	Room 406-Pod 3 @B	SK	N/A		6/14/2025	-	-	-	Sign
1086-9	Room 406-Pod 4 @A	SK	N/A		6/14/2025	-	-	-	Sign
1086-10	Room 406-Pod 4 @B	SK	N/A		6/14/2025	-	-	-	Sign
1086-11	Room 406-Pod 5 @A	SK	N/A		6/14/2025	-	-	-	Sign
1086-12	Room 406-Pod 5 @B	SK	N/A		6/14/2025	-	-	-	Sign
1086-13	Room 406-Pod 6 @A	SK	N/A		6/14/2025	-	-	-	Sign
1086-14	Room 406-Pod 6 @B	SK	N/A		6/14/2025	-	-	-	Sign
1086-15	Room 406-Fume Hood	SK	N/A		6/14/2025	-	-	-	Sign
1086-16	Room 406-Counter @A	SK	N/A		6/14/2025	-	-	-	Sign
1086-17	Room 406-Counter @B	SK	N/A		6/14/2025	-	-	-	Sign
1086-18	Room 406-Counter @C	SK	N/A		6/14/2025	-	-	-	Sign
1086-19	Room 406-Prep Room @A	SK	N/A		6/14/2025	-	-	-	Sign
1086-20	Room 406-Prep Room @B	SK	N/A		6/14/2025	-	-	-	Sign
1087-1	Room 408-Teacher's Station @A	SK	N/A		6/14/2025	-	-	-	Sign
1087-2	Room 408-Teacher's Station @B	SK	N/A		6/14/2025	-	-	-	Sign
1087-3	Room 408-Counter @A	SK	N/A		6/14/2025	-	-	-	Sign
1087-4	Room 408-Counter @B	SK	N/A		6/14/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1 st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1087-5	Room 408-Counter @C	SK	N/A		6/14/2025	-	-	-	Sign
1087-6	Room 408-Fume Hood	SK	N/A		6/14/2025	-	-	-	Sign
1087-7	Room 408-Pod 1 @A	SK	N/A		6/14/2025	-	-	-	Sign
1087-8	Room 408-Pod 1 @B	SK	N/A		6/14/2025	-	-	-	Sign
1087-9	Room 408-Pod 2 @A	SK	N/A		6/14/2025	-	-	-	Sign
1087-10	Room 408-Pod 2 @B	SK	N/A		6/14/2025	-	-	-	Sign
1087-11	Room 408-Pod 3 @A	SK	N/A		6/14/2025	-	-	-	Sign
1087-12	Room 408-Pod 3 @B	SK	N/A		6/14/2025	-	-	-	Sign
1087-13	Room 408-Pod 4 @A	SK	N/A		6/14/2025	-	-	-	Sign
1087-14	Room 408-Pod 4 @B	SK	N/A		6/14/2025	-	-	-	Sign
1087-15	Room 408-Pod 5 @A	SK	N/A		6/14/2025	-	-	-	Sign
1087-16	Room 408-Pod 5 @B	SK	N/A		6/14/2025	-	-	-	Sign
1087-17	Room 408-Pod 6 @A	SK	N/A		6/14/2025	-	-	-	Sign
1087-18	Room 408-Pod 6 @B	SK	N/A		6/14/2025	-	-	-	Sign
1088-1	Room 407-Teacher's Station @A	SK	N/A		6/14/2025	-	-	-	Sign
1088-2	Room 407-Teacher's Station @B	SK	N/A		6/14/2025	-	-	-	Sign
1088-3	Room 407-Counter @A	SK	N/A		6/14/2025	-	-	-	Sign
1088-4	Room 407-Counter @B	SK	N/A		6/14/2025	-	-	-	Sign
1088-5	Room 407-Counter @C	SK	N/A		6/14/2025	-	-	-	Sign
1088-6	Room 407-Counter @D	SK	N/A		6/14/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1088-7	Room 407-Counter @E	SK	N/A		6/14/2025	-	-	-	Sign
1088-8	Room 407-Counter @F	SK	N/A		6/14/2025	-	-	-	Sign
1088-9	Room 407-Fume Hood	SK	N/A		6/14/2025	-	-	-	Sign
1088-10	Room 407-Pod 1 @A	SK	N/A		6/14/2025	-	-	-	Sign
1088-11	Room 407-Pod 1 @B	SK	N/A		6/14/2025	-	-	-	Sign
1088-12	Room 407-Pod 2 @A	SK	N/A		6/14/2025	-	-	-	Sign
1088-13	Room 407-Pod 2 @B	SK	N/A		6/14/2025	-	-	-	Sign
1088-14	Room 407-Pod 3 @A	SK	N/A		6/14/2025	-	-	-	Sign
1088-15	Room 407-Pod 3 @B	SK	N/A		6/14/2025	-	-	-	Sign
1088-16	Room 407-Pod 4 @A	SK	N/A		6/14/2025	-	-	-	Sign
1088-17	Room 407-Pod 4 @B	SK	N/A		6/14/2025	-	-	-	Sign
1088-18	Room 407-Pod 5 @A	SK	N/A		6/14/2025	-	-	-	Sign
1088-19	Room 407-Pod 5 @B	SK	N/A		6/14/2025	-	-	-	Sign
1089-1	Room 405-Teacher's Station @A	SK	N/A		6/14/2025	-	-	-	Sign
1089-2	Room 405-Teacher's Station @B	SK	N/A		6/14/2025	-	-	-	Sign
1089-3	Room 405-Counter @A	SK	N/A		6/14/2025	-	-	-	Sign
1089-4	Room 405-Counter @B	SK	N/A		6/14/2025	-	-	-	Sign
1089-5	Room 405-Counter @C	SK	N/A		6/14/2025	-	-	-	Sign
1089-6	Room 405-Counter @D	SK	N/A		6/14/2025	-	-	-	Sign
1089-7	Room 405-Counter @E	SK	N/A		6/14/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1089-8	Room 405-Counter @F	SK	N/A		6/14/2025	-	-	-	Sign
1089-9	Room 405-Fume Hood	SK	N/A		6/14/2025	-	-	-	Sign
1089-10	Room 405-Pod 1 @A	SK	N/A		6/14/2025	-	-	-	Sign
1089-11	Room 405-Pod 1 @B	SK	N/A		6/14/2025	-	-	-	Sign
1089-12	Room 405-Pod 2 @A	SK	N/A		6/14/2025	-	-	-	Sign
1089-13	Room 405-Pod 2 @B	SK	N/A		6/14/2025	-	-	-	Sign
1089-14	Room 405-Pod 3 @A	SK	N/A		6/14/2025	-	-	-	Sign
1089-15	Room 405-Pod 3 @B	SK	N/A		6/14/2025	-	-	-	Sign
1089-16	Room 405-Pod 4 @A	SK	N/A		6/14/2025	-	-	-	Sign
1089-17	Room 405-Pod 4 @B	SK	N/A		6/14/2025	-	-	-	Sign
1089-18	Room 405-Pod 5 @A	SK	N/A		6/14/2025	-	-	-	Sign
1089-19	Room 405-Pod 5 @B	SK	N/A		6/14/2025	-	-	-	Sign
1089-20	Room 405-Prep Room @A	SK	N/A		6/14/2025	-	-	-	Sign
1089-21	Room 405-Prep Room @B	SK	N/A		6/14/2025	-	-	-	Sign
1089-22	Room 405-Prep Room @C	SK	N/A		6/14/2025	-	-	-	Sign
1089-23	Room 405-Prep Room @D	SK	N/A		6/14/2025	-	-	-	Sign
1090-1	Boy's Bathroom by Room 404 @A	SK	N/A		6/14/2025	-	-	-	Sign
1090-2	Boy's Bathroom by Room 404 @B	SK	N/A		6/14/2025	-	-	-	Sign
1090-3	Boy's Bathroom by Room 404 @C	SK	N/A		6/14/2025	-	-	-	Sign
1090-4	Boy's Bathroom by Room 404 @D	SK	N/A		6/14/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1091-1	Custodial Closet by Room 404	SS	N/A		6/14/2025	-	-	-	Sign
1092-1	Hall by Room 404	WF	App		6/14/2025	-	-	-	Removed from service, sampling required before returning to service
1093-1	Girl's Bathroom by Room 404 @A	SK	N/A		6/14/2025	-	-	-	Sign
1093-2	Girl's Bathroom by Room 404 @B	SK	N/A		6/14/2025	-	-	-	Sign
1093-3	Girl's Bathroom by Room 404 @C	SK	N/A		6/14/2025	-	-	-	Sign
1093-4	Girl's Bathroom by Room 404 @D	SK	N/A		6/14/2025	-	-	-	Sign
1094-1	Faculty Room-Women's Bathroom @A	SK	N/A		6/14/2025	-	-	-	Sign
1094-2	Faculty Room-Women's Bathroom @B	SK	N/A		6/14/2025	-	-	-	Sign
1094-3	Faculty Room-Women's Kitchenette	SK	N/A		6/14/2025	-	-	-	Sign
1094-4	Faculty Room-Men's Kitchenette	SK	N/A		6/14/2025	-	-	-	Sign
1094-5	Faculty Room-Men's Bathroom	SK	N/A		6/14/2025	-	-	-	Sign
1095-1	Main Lobby	BF	App		2/5/2025				
2001-1	Copy Room Kitchenette	SK	N/A		6/14/2025	-	-	-	Sign
2002-1	Women's Bathroom by Room 721	SK	N/A		6/14/2025	-	-	-	Sign
2003-1	Men's Bathroom by Room 721	SK	N/A		6/14/2025	-	-	-	Sign
2004-1	Girl's Bathroom by Room 721 @A	SK	N/A		6/14/2025	-	-	-	Sign
2004-2	Girl's Bathroom by Room 721 @B	SK	N/A		6/14/2025	-	-	-	Sign
2005-1	Hall by Room 721	BF	App	<1.0	6/14/2025	-	-	-	
2006-1	Room 723-Teacher's Station	SK	N/A		6/14/2025				Sign
2006-2	Room 723-Counter @A	SK	N/A		6/14/2025				Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2006-3	Room 723-Counter @B	SK	N/A		6/14/2025				Sign
2006-4	Room 723-Counter @C	SK	N/A		6/14/2025				Sign
2006-5	Room 723-Counter @D	SK	N/A		6/14/2025				Sign
2007-1	Room 725-Teacher's Station	SK	N/A		6/14/2025				Sign
2007-2	Room 725-Counter	SK	N/A		6/14/2025				Sign
2007-3	Room 725-Pod 1 @A	SK	N/A		6/14/2025				Sign
2007-4	Room 725-Pod 1 @B	SK	N/A		6/14/2025				Sign
2007-5	Room 725-Pod 2 @A	SK	N/A		6/14/2025				Sign
2007-6	Room 725-Pod 2 @B	SK	N/A		6/14/2025				Sign
2007-7	Room 725-Pod 3 @A	SK	N/A		6/14/2025				Sign
2007-8	Room 725-Pod 3 @B	SK	N/A		6/14/2025				Sign
2007-9	Room 725-Pod 4 @A	SK	N/A		6/14/2025				Sign
2007-10	Room 725-Pod 4 @B	SK	N/A		6/14/2025				Sign
2007-11	Room 725-Pod 5 @A	SK	N/A		6/14/2025				Sign
2007-12	Room 725-Pod 5 @B	SK	N/A		6/14/2025				Sign
2007-13	Room 725-Island @A	SK	N/A		6/14/2025				Sign
2008-1	Room 727-Teacher's Station	SK	N/A		6/14/2025				Sign
2008-2	Room 727-Pod 1 @A	SK	N/A		6/14/2025				Sign
2008-3	Room 727-Pod 1 @B	SK	N/A		6/14/2025				Sign
2008-4	Room 727-Pod 2 @A	SK	N/A		6/14/2025				Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2008-5	Room 727-Pod 2 @B	SK	N/A		6/14/2025				Sign
2008-6	Room 727-Pod 3 @A	SK	N/A		6/14/2025				Sign
2008-7	Room 727-Pod 3 @B	SK	N/A		6/14/2025				Sign
2008-8	Room 727-Counter	SK	N/A		6/14/2025				Sign
2009-1	Hall by Room 729	WF	App		6/14/2025				Removed from service, sampling required before returning to service
2010-1	Room 729-Teacher's Station	SK	N/A		6/14/2025				Sign
2010-2	Room 729-Counter	SK	N/A		6/14/2025				Sign
2010-3	Room 729-Pod 1 @A	SK	N/A		6/14/2025				Sign
2010-4	Room 729-Pod 1 @B	SK	N/A		6/14/2025				Sign
2010-5	Room 729-Pod 2 @A	SK	N/A		6/14/2025				Sign
2010-6	Room 729-Pod 3 @A	SK	N/A		6/14/2025				Sign
2010-7	Room 729-Pod 3 @B	SK	N/A		6/14/2025				Sign
2011-1	Room 731-Teacher's Station @A	SK	N/A		6/14/2025				Sign
2011-2	Room 731-Teacher's Station @B	SK	N/A		6/14/2025				Sign
2011-3	Room 731-Counter @A	SK	N/A		6/14/2025				Sign
2011-4	Room 731-Counter @B	SK	N/A		6/14/2025				Sign
2011-5	Room 731-Counter @C	SK	N/A		6/14/2025				Sign
2011-6	Room 731-Pod 1 @A	SK	N/A		6/14/2025				Sign
2011-7	Room 731-Pod 1 @B	SK	N/A		6/14/2025				Sign
2011-8	Room 731-Pod 2 @A	SK	N/A		6/14/2025				Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2011-9	Room 731-Pod 2 @B	SK	N/A		6/14/2025				Sign
2011-10	Room 731-Pod 3 @A	SK	N/A		6/14/2025				Sign
2011-11	Room 731-Pod 3 @B	SK	N/A		6/14/2025				Sign
2011-12	Room 731-Pod 3 @C	SK	N/A		6/14/2025				Sign
2011-13	Room 731-Pod 3 @D	SK	N/A		6/14/2025				Sign
2011-14	Room 731-Pod 4 @A	SK	N/A		6/14/2025				Sign
2011-15	Room 731-Pod 4 @B	SK	N/A		6/14/2025				Sign
2011-16	Room 731-Pod 5 @A	SK	N/A		6/14/2025				Sign
2011-17	Room 731-Pod 5 @B	SK	N/A		6/14/2025				Sign
2011-18	Room 731-Prep Room @A	SK	N/A		6/14/2025				Sign
2011-19	Room 731-Prep Room @B	SK	N/A		6/14/2025				Sign
2012-1	Custodial Closet by Room 731	SS	N/A		6/14/2025				Sign
2013-1	Room 733-Teacher's Station @A	SK	N/A		6/14/2025				Sign
2013-2	Room 733-Teacher's Station @B	SK	N/A		6/14/2025				Sign
2013-3	Room 733-Pod 1 @A	SK	N/A		6/14/2025				Sign
2013-4	Room 733-Pod 1 @B	SK	N/A		6/14/2025				Sign
2013-5	Room 733-Pod 2 @A	SK	N/A		6/14/2025				Sign
2013-6	Room 733-Pod 2 @B	SK	N/A		6/14/2025				Sign
2013-7	Room 733-Pod 3 @A	SK	N/A		6/14/2025				Sign
2013-8	Room 733-Pod 3 @B	SK	N/A		6/14/2025				Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1 st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2013-9	Room 733-Pod 4 @A	SK	N/A		6/14/2025				Sign
2013-10	Room 733-Pod 4 @B	SK	N/A		6/14/2025				Sign
2013-11	Room 733-Pod 5 @A	SK	N/A		6/14/2025				Sign
2013-12	Room 733-Pod 5 @B	SK	N/A		6/14/2025				Sign
2013-13	Room 733-Pod 6 @A	SK	N/A		6/14/2025				Sign
2013-14	Room 733-Pod 6 @B	SK	N/A		6/14/2025				Sign
2013-15	Room 733-Fume Hood	SK	N/A		6/14/2025				Sign
2013-16	Room 733-Counter @A	SK	N/A		6/14/2025				Sign
2013-17	Room 733-Counter @B	SK	N/A		6/14/2025				Sign
2013-18	Room 733-Counter @C	SK	N/A		6/14/2025				Sign
2014-1	Boy's Bathroom by Room 733 @A	SK	N/A		6/14/2025				Sign
2014-2	Boy's Bathroom by Room 733 @B	SK	N/A		6/14/2025				Sign
2014-3	Boy's Bathroom by Room 733 @C	SK	N/A		6/14/2025				Sign
2015-1	Hall by Room 733	WF	App		6/14/2025				Removed from service, sampling required before returning to service
2016-1	Room 735-Teacher's Station	SK	N/A		6/14/2025				Sign
2016-2	Room 735-Pod 1 @A	SK	N/A		6/14/2025				Sign
2016-3	Room 735-Pod 1 @B	SK	N/A		6/14/2025				Sign
2016-4	Room 735-Pod 2 @A	SK	N/A		6/14/2025				Sign
2016-5	Room 735-Pod 2 @B	SK	N/A		6/14/2025				Sign
2016-6	Room 735-Pod 3 @A	SK	N/A		6/14/2025				Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1 st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2016-7	Room 735-Pod 3 @B	SK	N/A		6/14/2025				Sign
2016-8	Room 735-Pod 4 @A	SK	N/A		6/14/2025				Sign
2016-9	Room 735-Pod 4 @B	SK	N/A		6/14/2025				Sign
2016-10	Room 735-Pod 5 @A	SK	N/A		6/14/2025				Sign
2016-11	Room 735-Pod 5 @B	SK	N/A		6/14/2025				Sign
2016-12	Room 735-Island 1 @A	SK	N/A		6/14/2025				Sign
2016-13	Room 735-Island 1 @B	SK	N/A		6/14/2025				Sign
2016-14	Room 735-Island 2 @A	SK	N/A		6/14/2025				Sign
2016-15	Room 735-Island 2 @B	SK	N/A		6/14/2025				Sign
2016-16	Room 735-Fume Hood	SK	N/A		6/14/2025				Sign
2016-17	Room 735-Counter	SK	N/A		6/14/2025				Sign
2016-18	Room 735-Prep Room	SK	N/A		6/14/2025				Sign
2017-1	Girl's Bathroom by Planetarium @A	SK	N/A		6/14/2025				Sign
2017-2	Girl's Bathroom by Planetarium @B	SK	N/A		6/14/2025				Sign
2017-3	Girl's Bathroom by Planetarium @C	SK	N/A		6/14/2025				Sign
2018-1	Planetarium Office	SK	N/A		6/14/2025				Sign
2019-1	Hall by Room 739	WF	App		6/14/2025				Removed from service, sampling required before returning to service
2020-1	Room 739-Teacher's Station	SK	N/A		6/14/2025				Sign
2020-2	Room 739-Counter @A	SK	N/A		6/14/2025				Sign
2020-3	Room 739-Counter @B	SK	N/A		6/14/2025				Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1 st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2020-4	Room 739-Counter @C	SK	N/A		6/14/2025				Sign
2021-1	Room 741-Teacher's Station	SK	N/A		6/14/2025				Sign
2021-2	Room 741-Counter @A	SK	N/A		6/14/2025				Sign
2021-3	Room 741-Counter @B	SK	N/A		6/14/2025				Sign
2021-4	Room 741-Counter @C	SK	N/A		6/14/2025				Sign
2021-5	Room 741-Counter @D	SK	N/A		6/14/2025				Sign
2021-6	Room 741-Counter @E	SK	N/A		6/14/2025				Sign
2021-7	Room 741-Counter @F	SK	N/A		6/14/2025				Sign
2021-8	Room 741-Prep	SK	N/A		6/14/2025				Sign
2022-1	Room 743-Teacher's Station	SK	N/A		6/14/2025				Sign
2022-2	Room 743-Counter @A	SK	N/A		6/14/2025				Sign
2022-3	Room 743-Counter @B	SK	N/A		6/14/2025				Sign
2022-4	Room 743-Counter @C	SK	N/A		6/14/2025				Sign
2022-5	Room 743-Counter @D	SK	N/A		6/14/2025				Sign
2022-6	Room 743-Counter @E	SK	N/A		6/14/2025				Sign
2022-7	Room 743-Counter @F	SK	N/A		6/14/2025				Sign
2022-8	Room 743-Counter @G	SK	N/A		6/14/2025				Sign
2023-1	Hall by Room 742	WF	App		6/14/2025				Removed from service, sampling required before returning to service
2024-1	Room 745-Teacher's Station @A	SK	N/A		6/14/2025				Sign
2024-2	Room 745-Teacher's Station @B	SK	N/A		6/14/2025				Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1 st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2024-3	Room 745-Counter @A	SK	N/A		6/14/2025				Sign
2024-4	Room 745-Counter @B	SK	N/A		6/14/2025				Sign
2024-5	Room 745-Counter @C	SK	N/A		6/14/2025				Sign
2024-6	Room 745-Fume Hood	SK	N/A		6/14/2025				Sign
2024-7	Room 745-Pod 1 @A	SK	N/A		6/14/2025				Sign
2024-8	Room 745-Pod 1 @B	SK	N/A		6/14/2025				Sign
2024-9	Room 745-Pod 2 @A	SK	N/A		6/14/2025				Sign
2024-10	Room 745-Pod 2 @B	SK	N/A		6/14/2025				Sign
2024-11	Room 745-Pod 3 @A	SK	N/A		6/14/2025				Sign
2024-12	Room 745-Pod 3 @B	SK	N/A		6/14/2025				Sign
2024-13	Room 745-Pod 4 @A	SK	N/A		6/14/2025				Sign
2024-14	Room 745-Pod 4 @B	SK	N/A		6/14/2025				Sign
2024-15	Room 745-Pod 5 @A	SK	N/A		6/14/2025				Sign
2024-16	Room 745-Pod 5 @B	SK	N/A		6/14/2025				Sign
2024-17	Room 745-Pod 6 @A	SK	N/A		6/14/2025				Sign
2024-18	Room 745-Pod 6 @B	SK	N/A		6/14/2025				Sign
2024-19	Room 745-Pod 7 @A	SK	N/A		6/14/2025				Sign
2024-20	Room 745-Pod 7 @B	SK	N/A		6/14/2025				Sign
2024-21	Room 745-Prep Room @A	SK	N/A		6/14/2025				Sign
2024-22	Room 745-Prep Room @B	SK	N/A		6/14/2025				Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1 st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2025-1	Custodial Closet by Room 746	SS	N/A		6/14/2025				Sign
2026-1	Boy's Bathroom by Room 747 @A	SK	N/A		6/14/2025				Sign
2026-2	Boy's Bathroom by Room 747 @B	SK	N/A		6/14/2025				Sign
2026-3	Boy's Bathroom by Room 747 @C	SK	N/A		6/14/2025				Sign
2027-1	Hall by Room 747	WF	App		6/14/2025				Removed from service, sampling required before returning to service
2028-1	Room 747-Teacher's Station @A	SK	N/A		6/14/2025				Sign
2028-2	Room 747-Teacher's Station @B	SK	N/A		6/14/2025				Sign
2028-3	Room 747-Pod 1 @A	SK	N/A		6/14/2025				Sign
2028-4	Room 747-Pod 1 @B	SK	N/A		6/14/2025				Sign
2028-5	Room 747-Pod 2 @A	SK	N/A		6/14/2025				Sign
2028-6	Room 747-Pod 2 @B	SK	N/A		6/14/2025				Sign
2028-7	Room 747-Pod 3 @A	SK	N/A		6/14/2025				Sign
2028-8	Room 747-Pod 3 @B	SK	N/A		6/14/2025				Sign
2028-9	Room 747-Pod 4 @A	SK	N/A		6/14/2025				Sign
2028-10	Room 747-Pod 4 @B	SK	N/A		6/14/2025				Sign
2028-11	Room 747-Pod 5 @A	SK	N/A		6/14/2025				Sign
2028-12	Room 747-Pod 5 @B	SK	N/A		6/14/2025				Sign
2028-13	Room 747-Pod 6 @A	SK	N/A		6/14/2025				Sign
2028-14	Room 747-Pod 6 @B	SK	N/A		6/14/2025				Sign
2028-15	Room 747-Fume Hood	SK	N/A		6/14/2025				Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2028-16	Room 747-Counter @A	SK	N/A		6/14/2025				Sign
2028-17	Room 747-Counter @B	SK	N/A		6/14/2025				Sign
2028-18	Room 747-Counter @C	SK	N/A		6/14/2025				Sign
2029-1	Mezzanine Balcony Custodial Closet	SS	N/A		6/14/2025				Sign

Laboratory Report

NYE Report #: 2502880-33630

June 17, 2025

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Half Hollow Hills Csd; Half Hollow Hills High School East

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on June 17, 2025. New York Environmental analyzed the samples on June 17, 2025 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	14 Jun 2025
Date Received:	17 Jun 2025
Date Analyzed:	17 Jun 2025

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
250617J001	1	Hall by Mail Room-BF, Initial	0.001	<0.001	mg/L	
250617J002	2	Hall By Room 901-BF, Initial	0.001	<0.001	mg/L	
250617J003	3	Hall By Room 711-BF, Initial	0.001	<0.001	mg/L	
250617J004	4	Cafeteria A-BF, Initial	0.001	<0.001	mg/L	
250617J005	5	Cafeteria A-WF, Initial	0.001	<0.001	mg/L	
250617J006	6	Cafeteria B-BF, Initial	0.001	<0.001	mg/L	
250617J007	7	Cafeteria B-WF, Initial	0.001	<0.001	mg/L	
250617J008	8	Kitchen-Pot Filler-PF, Initial	0.001	0.022	mg/L	H
250617J009	9	Kitchen-2 Bay Unit-SK, Initial	0.001	0.001	mg/L	
250617J010	10	Kitchen-2 Bay Unit-SPY, Initial	0.001	0.001	mg/L	
250617J011	11	Main Gym-Girl's Side-BF, Initial	0.001	<0.001	mg/L	
250617J012	12	Main Gym-Girl's Side-WF, Initial	0.001	<0.001	mg/L	
250617J013	13	Trainers Office-IM, Initial	0.001	<0.001	mg/L	
250617J014	14	Trainers Office Sports Jug-SK, Initial	0.001	0.002	mg/L	
250617J015	15	Hall By Mens Bathroom-BF, Initial	0.001	<0.001	mg/L	
250617J016	16	Boys Locker Room-BF, Initial	0.001	<0.001	mg/L	
250617J017	17	Hall By Room 609-BF, Initial	0.001	<0.001	mg/L	
250617J018	18	Room 204- Counter @A-SK, Initial	0.001	0.001	mg/L	
250617J019	19	Room 204- Counter @B-SK, Initial	0.001	0.002	mg/L	
250617J020	20	Room 204- Counter @C-SK, Initial	0.001	0.002	mg/L	
250617J021	21	Room 204-Counter @D-SK, Initial	0.001	0.002	mg/L	
250617J022	22	Room 204-Counter @E-SK, Initial	0.001	0.001	mg/L	
250617J023	23	Room 204-Counter @F-SK, Initial	0.001	0.002	mg/L	
250617J024	24	Hall By Room 105-BF, Initial	0.001	<0.001	mg/L	
250617J025	25	Hall By Lecture Hall-BF, Initial	0.001	<0.001	mg/L	
250617J026	26	Hall By Lecture Hall-WF, Initial	0.001	<0.001	mg/L	

Date Collected:	14 Jun 2025
Date Received:	17 Jun 2025
Date Analyzed:	17 Jun 2025

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
250617J027	27	Hall By Room 544-BF, Initial	0.001	<0.001	mg/L	
250617J028	28	Hall By Room 544-WF, Initial	0.001	<0.001	mg/L	
250617J029	29	Weight Room-BF, Initial	0.001	<0.001	mg/L	
250617J030	30	Weight Room-WF, Initial	0.001	<0.001	mg/L	
250617J031	31	East Nurses Office-IM, Initial	0.001	<0.001	mg/L	
250617J032	32	Hall by Room 721-BF, Initial	0.001	<0.001	mg/L	
250617J033	33	Nurses Office Ice Machine-IM, Initial	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

H: Sample result exceeds applicable regulatory limit.

Laboratory Report

August 27, 2025

Pam Chadderton
Enviroscience Consultants, Inc.
2150 Smithtown Ave.
Ronkonkoma, NY, 11779

Project: Half Hollow Hills
Project Address: Hhh HS East
Report ID: 250822022
Sample IDs: 250822022-307 - 250822022-310

New York Environmental is a NELAC accredited laboratory. Attached reported results meet the requirements of the NELAC standard unless otherwise noted.

Samples' analytical results relate only to the parameters tested for the samples received in the condition received by the laboratory, as noted on the Chain of Custody. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	22-Aug-25
Date Received:	22-Aug-25
Date Analyzed:	25-Aug-25

Analytical Method:	EPA 200.9
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
250822022-307	1	Pot Filler-Kitchen - PF, initial	0.001	0.004	mg/L	
250822022-308	2	Concession stand - BF, initial	0.001	0.001	mg/L	
250822022-309	3	Concession stand Left - WF, initial	0.001	0.003	mg/L	
250822022-310	4	Concession stand Right - WF, initial	0.001	0.006	mg/L	H

Comment(s):

LOQ: Limit of Quantitation

CID: Client ID

H: Sample result exceeds applicable regulatory limit.



Laboratory Report

September 11, 2025

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Ave.
Ronkonkoma, NY, 11779

Project: Half Hollow Hills CSD
Project Address: Half Hollow Hills High School East
Report ID: 250910008
Sample IDs: 250910008-066 - 250910008-066

New York Environmental is a NELAC accredited laboratory. Attached reported results meet the requirements of the NELAC standard unless otherwise noted.

Samples' analytical results relate only to the parameters tested for the samples received in the condition received by the laboratory, as noted on the Chain of Custody. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	10-Sep-25
Date Received:	10-Sep-25
Date Analyzed:	11-Sep-25

Analytical Method:	EPA 200.9
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
250910008-066	1	Concession Stand (Right) - WF, Initial	0.001	0.001	mg/L	

Comment(s):

LOQ: Limit of Quantitation

CID: Client ID

NA: Samples not analyzed as per customer request.



Laboratory Report

NYE Report #: 2500480-32290

February 6, 2025

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Half Hollow Hills CSD; High School East

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on February 05, 2025. New York Environmental analyzed the samples on February 06, 2025 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	05 Feb 2025
Date Received:	05 Feb 2025
Date Analyzed:	06 Feb 2025

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

<u>Lab ID</u>	<u>CID</u>	<u>Sample Location/Description</u>	<u>LOQ</u>	<u>Result</u>	<u>Units</u>	<u>Flag</u>
250205R001	1	Main Lobby - BF, Initial	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

Appendix B

Half Hollow Hills High School West

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1001-1	Kitchen Handwash by Slicer	SK	N/A		6/7/2025	-	-	-	Sign
1001-2	Kitchen Prep by Slicer	SK	App	2.0	6/7/2025	-	-	-	
1001-3	Kitchen Prep by Slicer	SPY	App	4.0	6/7/2025	-	-	-	
1001-4	Kitchen Handwash by Dishwash Station	SK	N/A		6/7/2025	-	-	-	Sign
1001-5	Kitchen Dishwash @ A	SK	N/A		6/7/2025	-	-	-	Sign
1001-6	Kitchen Dishwash @ A	SPY	N/A		6/7/2025	-	-	-	Sign
1001-7	Kitchen Dishwash @ B	SK	N/A		6/7/2025	-	-	-	Sign
1001-8	Kitchen Pot Filler	PF	App	3.0	6/7/2025	-	-	-	
1001-9	Kitchen Handwash by Pot Filler	SK	N/A		6/7/2025	-	-	-	Sign
1001-10	Serving Line Handwash	SK	N/A		6/7/2025	-	-	-	Sign
1002-1	Cafeteria South	BF	App	<1.0	6/7/2025	-	-	-	
1002-2	Cafeteria South	WF	App		6/7/2025	-	-	-	Removed from service, sampling required before returning to service
1003-1	Men's Bathroom by Cafeteria South (left)	SK	N/A		6/7/2025	-	-	-	Sign
1003-2	Men's Bathroom by Cafeteria South (right)	SK	N/A		6/7/2025	-	-	-	Sign
1004-1	Home Economics Room 151 Laundry Room	SK	N/A		6/7/2025	-	-	-	Sign
1004-1	Home Economics Room 151 Station 1	SK	App	<1.0	6/7/2025	-	-	-	
1004-2	Home Economics Room 151 Station 1	SPY	App	<1.0	6/7/2025	-	-	-	
1004-3	Home Economics Room 151 Station 2	SK	App	<1.0	6/7/2025	-	-	-	
1004-4	Home Economics Room 151 Station 2	SPY	App	<1.0	6/7/2025	-	-	-	

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1 st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1004-5	Home Economics Room 151 Station 3	SK	App	<1.0	6/7/2025	-	-	-	
1004-6	Home Economics Room 151 Station 3	SPY	App	<1.0	6/7/2025	-	-	-	
1004-7	Home Economics Room 151 Station 4	SK	App	2.0	8/22/2025				Remediation complete
				40.0	6/7/2025	-	-	-	Removed from service, pending remediation
1004-8	Home Economics Room 151 Station 4	SPY	NA	12.0	8/22/2025	<1.0	<1.0	8/22/2025	Sign Posted
				17.0	6/7/2025	-	-	-	Removed from service, pending remediation
1004-9	Home Economics Room 151 Station 5	SK	App	5.0	8/22/2025	-	-	-	Remediation complete
				10.0	6/7/2025	-	-	-	Removed from service, pending remediation
1004-10	Home Economics Room 151 Station 5	SPY	App	3.0	6/7/2025	-	-	-	
1004-6	Home Economics Room 151 Back Office (l	SK	N/A		6/7/2025	-	-	-	Sign
1004-7	Home Economics Room 151 Back Office (r	SK	N/A		6/7/2025	-	-	-	Sign
1005-1	Women's Bathroom by Cafeteria South (left	SK	N/A		6/7/2025	-	-	-	Sign
1005-2	Women's Bathroom by Cafeteria South (right	SK	N/A		6/7/2025	-	-	-	Sign
1006-1	Principal's Office Break Room	SK	N/A		6/7/2025	-	-	-	Sign
1007-1	Main Office Copy Room	SK	N/A		6/7/2025	-	-	-	Sign
1008-1	Faculty Room	SK	N/A		6/7/2025	-	-	-	Sign
1008-2	Faculty Room Bathroom 1	SK	N/A		6/7/2025	-	-	-	Sign
1008-3	Faculty Room Bathroom 2 (left)	SK	N/A		6/7/2025	-	-	-	Sign
1008-4	Faculty Room Bathroom 2 (right)	SK	N/A		7-Jun				Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1009-1	Cafeteria North	BF	App	<1.0	8/22/2025	-	-	-	New Fixture Summer 2025
1011-1	Cafeteria Girl's Bathroom (left)	SK	N/A		6/7/2025	-	-	-	Sign
1011-2	Cafeteria Girl's Bathroom (right)	SK	N/A		6/7/2025	-	-	-	Sign
1012-1	Hall by Room 174	WF	App	<1.0	6/7/2025	-	-	-	
1012-2	Hall by Room 174	BF	App	<1.0	6/7/2025	-	-	-	
1013-1	Boy's Bathroom by Room 174 @ A	SK	N/A		6/7/2025	-	-	-	Sign
1013-2	Boy's Bathroom by Room 174 @ B	SK	N/A		6/7/2025	-	-	-	Sign
1013-3	Boy's Bathroom by Room 174 @ C	SK	N/A		6/7/2025	-	-	-	Sign
1013-4	Boy's Bathroom by Room 174 @ D	SK	N/A		6/7/2025	-	-	-	Sign
1014-1	Custodial Closet by Room 174	SS	N/A		6/7/2025	-	-	-	Sign
1015-1	Girl's Bathroom by Room 174 @ A	SK	N/A		6/7/2025	-	-	-	Sign
1015-2	Girl's Bathroom by Room 174 @ B	SK	N/A		6/7/2025	-	-	-	Sign
1015-3	Girl's Bathroom by Room 174 @ C	SK	N/A		6/7/2025	-	-	-	Sign
1015-4	Girl's Bathroom by Room 174 @ D	SK	N/A		6/7/2025	-	-	-	Sign
1016-2	Nurse's Office	BF	App	<1.0	6/7/2025	-	-	-	
1016-1	Nurse's Office Bathroom	SK	N/A		6/7/2025	-	-	-	Sign
1017-1	Hall by Weight Room	WF	N/A		6/7/2025	-	-	-	Removed from service, sampling required before returning to service
1017-2	Hall by Weight Room	BF	App	<1.0	6/7/2025	-	-	-	
1018-1	Boy's Bathroom by Weight Room (left)	SK	N/A		6/7/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1018-2	Boy's Bathroom by Weight Room (right)	SK	N/A		6/7/2025	-	-	-	Sign
1019-1	Custodial Closet by Weight Room	SS	N/A		6/7/2025	-	-	-	Sign
1020-1	Boy's Locker Room Bathroom @ A	SK	N/A		6/7/2025	-	-	-	Sign
1020-2	Boy's Locker Room Bathroom @ B	SK	N/A		6/7/2025	-	-	-	Sign
1020-3	Boy's Locker Room Bathroom @ C	SK	N/A		6/7/2025	-	-	-	Sign
1020-4	Boy's Locker Room Handicap Bathroom	SK	N/A		6/7/2025	-	-	-	Sign
1021-1	Hall by New Gym	WF	App	<1.0	6/7/2025	-	-	-	
1021-2	Hall by New Gym	BF	App	<1.0	6/7/2025	-	-	-	
1022-1	Trainer's Room Ice Machine	IM	App	<1.0	6/7/2025	-	-	-	
1022-2	Trainer's Room	SS	N/A		6/7/2025	-	-	-	Sign
1022-3	Trainer's Room Sports Jug Filler	SK	App	1.0	6/7/2025	-	-	-	
	Boy's Locker Room	BF	App	<1.0	6/7/2025	-	-	-	
	Boy's Locker Room	WF	App	<1.0	6/7/2025	-	-	-	
	Girl's Locker Room	BF	App	<1.0	6/7/2025	-	-	-	
	Girl's Locker Room	WF	App		6/7/2025	-	-	-	Removed from service, sampling required before returning to service
1023-1	Girl's Locker Room Bathroom @A	SK	N/A		6/7/2025	-	-	-	Sign
1023-2	Girl's Locker Room Bathroom @B	SK	N/A		6/7/2025	-	-	-	Sign
1023-3	Girl's Locker Room Bathroom @C	SK	N/A		6/7/2025	-	-	-	Sign
1023-4	Girl's Locker Room Handicap Bathroom	SK	N/A		6/7/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1024-1	Custodial Closet by Elevator	SS	N/A		6/7/2025	-	-	-	Sign
1025-1	Girl's Bathroom by Room 102 (left)	SK	N/A		6/7/2025	-	-	-	Sign
1025-2	Girl's Bathroom by Room 102 (right)	SK	N/A		6/7/2025	-	-	-	Sign
1026-1	Hall by Room 102	BF	App	1.0	6/7/2025	-	-	-	
2001-1	Assistant Principal's Break Room	SK	N/A		6/7/2025	-	-	-	Sign
2002-1	Hall by Room 251	BF	App	<1.0	6/7/2025	-	-	-	
2003-1	Girl's Bathroom by 251 @ A	SK	N/A		6/7/2025	-	-	-	Sign
2003-2	Girl's Bathroom by 251 @ B	SK	N/A		6/7/2025	-	-	-	Sign
2003-3	Girl's Bathroom by 251 @ C	SK	N/A		6/7/2025	-	-	-	Sign
2003-4	Girl's Bathroom by 251 @ D	SK	N/A		6/7/2025	-	-	-	Sign
2003-5	Girl's Bathroom by 251 @ E	SK	N/A		6/7/2025	-	-	-	Sign
2004-1	Staff Women's Bathroom (left)	SK	N/A		6/7/2025	-	-	-	Sign
2004-2	Staff Women's Bathroom (right)	SK	N/A		6/7/2025	-	-	-	Sign
2005-1	Staff Men's Bathroom (left)	SK	N/A		6/7/2025	-	-	-	Sign
2005-2	Staff Men's Bathroom (right)	SK	N/A		6/7/2025	-	-	-	Sign
2006-1	Hall by Room 235	BF	App		8/22/2025	-	-	-	New Fixture Summer 2025
2007-1	Boy's Bathroom by Room 235 @ A	SK	N/A		6/7/2025	-	-	-	Sign
2007-2	Boy's Bathroom by Room 235 @ B	SK	N/A		6/7/2025	-	-	-	Sign
2007-3	Boy's Bathroom by Room 235 @ C	SK	N/A		6/7/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2007-4	Boy's Bathroom by Room 235 @ D	SK	N/A		6/7/2025	-	-	-	Sign
2007-5	Boy's Bathroom by Room 235 @ E	SK	N/A		6/7/2025	-	-	-	Sign
2007-6	Boy's Bathroom by Room 235 @ F	SK	N/A		6/7/2025	-	-	-	Sign
2007-7	Boy's Bathroom by Room 235 @ G	SK	N/A		6/7/2025	-	-	-	Sign
2007-8	Boy's Bathroom by Room 235 @ H	SK	N/A		6/7/2025	-	-	-	Sign
2008-1	Custodial Closet by Room 231	SS	N/A		6/7/2025	-	-	-	Sign
2009-1	Hall by Room 230	WF	N/A		6/7/2025	-	-	-	Removed from service, sampling required before returning to service
2010-1	Hall by Room 272	BF	App	<1.0	6/7/2025	-	-	-	
2010-2	Hall by Room 272	WF	App	<1.0	6/7/2025	-	-	-	
2011-1	Boy's Bathroom by Room 272 @ A	SK	N/A		6/7/2025	-	-	-	Sign
2011-2	Boy's Bathroom by Room 272 @ B	SK	N/A		6/7/2025	-	-	-	Sign
2011-3	Boy's Bathroom by Room 272 @ C	SK	N/A		6/7/2025	-	-	-	Sign
2012-1	Girl's Bathroom by Room 272 @ A	SK	N/A		6/7/2025	-	-	-	Sign
2012-2	Girl's Bathroom by Room 272 @ B	SK	N/A		6/7/2025	-	-	-	Sign
2012-3	Girl's Bathroom by Room 272 @ C	SK	N/A		6/7/2025	-	-	-	Sign
2013-1	Staff Bathroom by Room 273	SK	N/A		6/7/2025	-	-	-	Sign
2014-1	Custodial Closet by Room 270	SS	N/A		6/7/2025	-	-	-	Sign
2015-1	Room 271 Teacher's Station	SK	N/A		6/7/2025	-	-	-	Sign
2015-2	Room 271 Side Counter	SK	N/A		6/7/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2015-3	Room 271 Counter @ A	SK	N/A		6/7/2025	-	-	-	Sign
2015-4	Room 271 Counter @ B	SK	N/A		6/7/2025	-	-	-	Sign
2015-5	Room 271 Counter @ C	SK	N/A		6/7/2025	-	-	-	Sign
2015-6	Room 271 Counter @ D	SK	N/A		6/7/2025	-	-	-	Sign
2015-7	Room 271 Counter @ E	SK	N/A		6/7/2025	-	-	-	Sign
2015-8	Room 271 Counter @ F	SK	N/A		6/7/2025	-	-	-	Sign
2015-9	Room 271 Counter @ G	SK	N/A		6/7/2025	-	-	-	Sign
2015-10	Room 271 Counter @ H	SK	N/A		6/7/2025	-	-	-	Sign
2015-11	Room 271 Counter @ I	SK	N/A		6/7/2025	-	-	-	Sign
2015-12	Room 271 Counter @ J	SK	N/A		6/7/2025	-	-	-	Sign
2015-13	Room 271 Prep Room	SK	N/A		6/7/2025	-	-	-	Sign
2016-1	Room 270 Teacher's Station	SK	N/A		6/7/2025	-	-	-	Sign
2016-2	Room 270 Side Counter	SK	N/A		6/7/2025	-	-	-	Sign
2016-3	Room 270 Counter @ A	SK	N/A		6/7/2025	-	-	-	Sign
2016-4	Room 270 Counter @ B	SK	N/A		6/7/2025	-	-	-	Sign
2016-5	Room 270 Counter @ C	SK	N/A		6/7/2025	-	-	-	Sign
2016-6	Room 270 Counter @ D	SK	N/A		6/7/2025	-	-	-	Sign
2016-7	Room 270 Counter @ E	SK	N/A		6/7/2025	-	-	-	Sign
2016-8	Room 270 Counter @ F	SK	N/A		6/7/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2016-9	Room 270 Counter @ G	SK	N/A		6/7/2025	-	-	-	Sign
2016-10	Room 270 Counter @ H	SK	N/A		6/7/2025	-	-	-	Sign
2016-11	Room 270 Counter @ I	SK	N/A		6/7/2025	-	-	-	Sign
2016-12	Room 270 Counter @ J	SK	N/A		6/7/2025	-	-	-	Sign
2016-13	Room 270 Prep Room	SK	N/A		6/7/2025	-	-	-	Sign
2017-1	Room 272 Teacher's Station	SK	N/A		6/7/2025	-	-	-	Sign
2017-2	Room 272 Side Counter	SK	N/A		6/7/2025	-	-	-	Sign
2017-3	Room 272 Counter @ A	SK	N/A		6/7/2025	-	-	-	Sign
2017-4	Room 272 Counter @ B	SK	N/A		6/7/2025	-	-	-	Sign
2017-6	Room 272 Counter @ D	SK	N/A		6/7/2025	-	-	-	Sign
2017-7	Room 272 Counter @ E	SK	N/A		6/7/2025	-	-	-	Sign
2017-8	Room 272 Counter @ F	SK	N/A		6/7/2025	-	-	-	Sign
2017-9	Room 272 Counter @ G	SK	N/A		6/7/2025	-	-	-	Sign
2017-10	Room 272 Counter @ H	SK	N/A		6/7/2025	-	-	-	Sign
2017-11	Room 272 Counter @ I	SK	N/A		6/7/2025	-	-	-	Sign
2017-12	Room 272 Counter @ J	SK	N/A		6/7/2025	-	-	-	Sign
2017-13	Room 272 Prep Room	SK	N/A		6/7/2025	-	-	-	Sign
2018-1	Room 273 Teacher's Station	SK	N/A		6/7/2025	-	-	-	Sign
2018-2	Room 273 Side Counter	SK	N/A		6/7/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2018-3	Room 273 Counter @ A	SK	N/A		6/7/2025	-	-	-	Sign
2018-4	Room 273 Counter @ B	SK	N/A		6/7/2025	-	-	-	Sign
2018-5	Room 273 Counter @ C	SK	N/A		6/7/2025	-	-	-	Sign
2018-6	Room 273 Counter @ D	SK	N/A		6/7/2025	-	-	-	Sign
2018-7	Room 273 Counter @ E	SK	N/A		6/7/2025	-	-	-	Sign
2018-8	Room 273 Counter @ F	SK	N/A		6/7/2025	-	-	-	Sign
2018-9	Room 273 Counter @ G	SK	N/A		6/7/2025	-	-	-	Sign
2018-10	Room 273 Counter @ H	SK	N/A		6/7/2025	-	-	-	Sign
2018-11	Room 273 Counter @ I	SK	N/A		6/7/2025	-	-	-	Sign
2018-12	Room 273 Counter @ J	SK	N/A		6/7/2025	-	-	-	Sign
2018-13	Room 273 Prep Room	SK	N/A		6/7/2025	-	-	-	Sign
2019-1	Hall by Room 217	WF	N/A		6/7/2025	-	-	-	Removed from service, sampling required before returning to service
2020-1	Room 217 Teacher's Station	SK	N/A		6/7/2025	-	-	-	Sign
2020-2	Room 217 Side Counter	SK	N/A		6/7/2025	-	-	-	Sign
2020-3	Room 217 Counter @ A	SK	N/A		6/7/2025	-	-	-	Sign
2020-4	Room 217 Counter @ B	SK	N/A		6/7/2025	-	-	-	Sign
2020-5	Room 217 Counter @ C	SK	N/A		6/7/2025	-	-	-	Sign
2020-6	Room 217 Counter @ D	SK	N/A		6/7/2025	-	-	-	Sign
2020-7	Room 217 Counter @ E	SK	N/A		6/7/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2020-8	Room 217 Counter @ F	SK	N/A		6/7/2025	-	-	-	Sign
2020-9	Room 217 Counter @ G	SK	N/A		6/7/2025	-	-	-	Sign
2020-10	Room 217 Counter @ H	SK	N/A		6/7/2025	-	-	-	Sign
2020-11	Room 217 Counter @ I	SK	N/A		6/7/2025	-	-	-	Sign
2020-12	Room 217 Counter @ J	SK	N/A		6/7/2025	-	-	-	Sign
2020-13	Room 217 Counter @ K	SK	N/A		6/7/2025	-	-	-	Sign
2020-14	Room 217 Counter @ L	SK	N/A		6/7/2025	-	-	-	Sign
2020-15	Room 217 Prep Room	SK	N/A		6/7/2025	-	-	-	Sign
2020-16	Room 217 Chemical Room	SK	N/A		6/7/2025	-	-	-	Sign
2021-1	Room 216 Teacher's Station	SK	N/A		6/7/2025	-	-	-	Sign
2021-2	Room 216 Side Counter	SK	N/A		6/7/2025	-	-	-	Sign
2021-3	Room 216 Counter @ A	SK	N/A		6/7/2025	-	-	-	Sign
2021-4	Room 216 Counter @ B	SK	N/A		6/7/2025	-	-	-	Sign
2021-5	Room 216 Counter @ C	SK	N/A		6/7/2025	-	-	-	Sign
2021-6	Room 216 Counter @ D	SK	N/A		6/7/2025	-	-	-	Sign
2021-7	Room 216 Counter @ E	SK	N/A		6/7/2025	-	-	-	Sign
2021-8	Room 216 Counter @ F	SK	N/A		6/7/2025	-	-	-	Sign
2021-9	Room 216 Counter @ G	SK	N/A		6/7/2025	-	-	-	Sign
2021-10	Room 216 Counter @ H	SK	N/A		6/7/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2021-11	Room 216 Counter @ I	SK	N/A		6/7/2025	-	-	-	Sign
2021-12	Room 216 Counter @ J	SK	N/A		6/7/2025	-	-	-	Sign
2021-13	Room 216 Counter @ K	SK	N/A		6/7/2025	-	-	-	Sign
2021-14	Room 216 Counter @ L	SK	N/A		6/7/2025	-	-	-	Sign
2022-1	Room 218 Teacher's Station	SK	N/A		6/7/2025	-	-	-	Sign
2022-2	Room 218 Counter @ A	SK	N/A		6/7/2025	-	-	-	Sign
2022-3	Room 218 Counter @ B	SK	N/A		6/7/2025	-	-	-	Sign
2022-4	Room 218 Counter @ C	SK	N/A		6/7/2025	-	-	-	Sign
2022-5	Room 218 Counter @ D	SK	N/A		6/7/2025	-	-	-	Sign
2023-1	Room 220	SK	N/A		6/7/2025	-	-	-	Sign
2024-1	Room 221	SK	N/A		6/7/2025	-	-	-	Sign
2024-2	Room 221 Dark Room	SK	N/A		6/7/2025	-	-	-	Sign
2024-3	Room 221 Dark Room	SPY	N/A		6/7/2025	-	-	-	Sign
2025-1	Room 222 Art Sink @ A	SK	N/A		6/7/2025	-	-	-	Sign
2025-2	Room 222 Art Sink @ B	SK	N/A		6/7/2025	-	-	-	Sign
2025-3	Room 222 Art Sink @ C	SK	N/A		6/7/2025	-	-	-	Sign
2025-4	Room 222 Art Sink @ D	SK	N/A		6/7/2025	-	-	-	Sign
2025-5	Room 222 Art Sink @ E	SK	N/A		6/7/2025	-	-	-	Sign
2025-6	Room 222 Art Sink @ F	SK	N/A		6/7/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2026-1	Room 215 Teacher's Station	SK	N/A		6/7/2025	-	-	-	Sign
2026-2	Room 215 Side Counter	SK	N/A		6/7/2025	-	-	-	Sign
2026-3	Room 215 Counter @ A	SK	N/A		6/7/2025	-	-	-	Sign
2026-4	Room 215 Counter @ B	SK	N/A		6/7/2025	-	-	-	Sign
2026-5	Room 215 Counter @ C	SK	N/A		6/7/2025	-	-	-	Sign
2026-6	Room 215 Counter @ D	SK	N/A		6/7/2025	-	-	-	Sign
2026-7	Room 215 Counter @ E	SK	N/A		6/7/2025	-	-	-	Sign
2026-8	Room 215 Counter @ F	SK	N/A		6/7/2025	-	-	-	Sign
2026-9	Room 215 Counter @ G	SK	N/A		6/7/2025	-	-	-	Sign
2026-10	Room 215 Counter @ H	SK	N/A		6/7/2025	-	-	-	Sign
2026-11	Room 215 Counter @ I	SK	N/A		6/7/2025	-	-	-	Sign
2026-12	Room 215 Counter @ J	SK	N/A		6/7/2025	-	-	-	Sign
2026-13	Room 215 Counter @ K	SK	N/A		6/7/2025	-	-	-	Sign
2026-14	Room 215 Counter @ L	SK	N/A		6/7/2025	-	-	-	Sign
2026-15	Room 215 Prep Room	SK	N/A		6/7/2025	-	-	-	Sign
2027-1	Room 214 Teacher's Station	SK	N/A		6/7/2025	-	-	-	Sign
2027-2	Room 214 Side Counter	SK	N/A		6/7/2025	-	-	-	Sign
2027-3	Room 214 Counter @ A	SK	N/A		6/7/2025	-	-	-	Sign
2027-4	Room 214 Counter @ B	SK	N/A		6/7/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2027-5	Room 214 Counter @ C	SK	N/A		6/7/2025	-	-	-	Sign
2027-6	Room 214 Counter @ D	SK	N/A		6/7/2025	-	-	-	Sign
2027-7	Room 214 Counter @ E	SK	N/A		6/7/2025	-	-	-	Sign
2027-8	Room 214 Counter @ F	SK	N/A		6/7/2025	-	-	-	Sign
2027-9	Room 214 Counter @ G	SK	N/A		6/7/2025	-	-	-	Sign
2027-10	Room 214 Counter @ H	SK	N/A		6/7/2025	-	-	-	Sign
2027-11	Room 214 Counter @ I	SK	N/A		6/7/2025	-	-	-	Sign
2027-12	Room 214 Counter @ J	SK	N/A		6/7/2025	-	-	-	Sign
2027-13	Room 214 Counter @ K	SK	N/A		6/7/2025	-	-	-	Sign
2027-14	Room 214 Counter @ L	SK	N/A		6/7/2025	-	-	-	Sign
2028-1	Room 213 Teacher's Station	SK	N/A		6/7/2025	-	-	-	Sign
2028-2	Room 213 Side Counter	SK	N/A		6/7/2025	-	-	-	Sign
2028-3	Room 213 Counter @ A	SK	N/A		6/7/2025	-	-	-	Sign
2028-4	Room 213 Counter @ B	SK	N/A		6/7/2025	-	-	-	Sign
2028-5	Room 213 Counter @ C	SK	N/A		6/7/2025	-	-	-	Sign
2028-6	Room 213 Counter @ D	SK	N/A		6/7/2025	-	-	-	Sign
2028-7	Room 213 Counter @ E	SK	N/A		6/7/2025	-	-	-	Sign
2028-8	Room 213 Counter @ F	SK	N/A		6/7/2025	-	-	-	Sign
2028-9	Room 213 Counter @ G	SK	N/A		6/7/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2028-10	Room 213 Counter @ H	SK	N/A		6/7/2025	-	-	-	Sign
2028-11	Room 213 Counter @ I	SK	N/A		6/7/2025	-	-	-	Sign
2028-12	Room 213 Counter @ J	SK	N/A		6/7/2025	-	-	-	Sign
2028-13	Room 213 Counter @ K	SK	N/A		6/7/2025	-	-	-	Sign
2028-14	Room 213 Counter @ L	SK	N/A		6/7/2025	-	-	-	Sign
2028-15	Room 213 Prep Room	SK	N/A		6/7/2025	-	-	-	Sign
2029-1	Custodial Closet by 213	SK	N/A		6/7/2025	-	-	-	Sign
2030-1	Room 212 Teacher's Station	SK	N/A		6/7/2025	-	-	-	Sign
2030-2	Room 212 Side Counter	SK	N/A		6/7/2025	-	-	-	Sign
2030-3	Room 212 Counter @ A	SK	N/A		6/7/2025	-	-	-	Sign
2030-4	Room 212 Counter @ B	SK	N/A		6/7/2025	-	-	-	Sign
2030-5	Room 212 Counter @ C	SK	N/A		6/7/2025	-	-	-	Sign
2030-6	Room 212 Counter @ D	SK	N/A		6/7/2025	-	-	-	Sign
2030-7	Room 212 Counter @ E	SK	N/A		6/7/2025	-	-	-	Sign
2030-8	Room 212 Counter @ F	SK	N/A		6/7/2025	-	-	-	Sign
2030-9	Room 212 Counter @ G	SK	N/A		6/7/2025	-	-	-	Sign
2030-10	Room 212 Counter @ H	SK	N/A		6/7/2025	-	-	-	Sign
2030-11	Room 212 Counter @ I	SK	N/A		6/7/2025	-	-	-	Sign
2030-12	Room 212 Counter @ J	SK	N/A		6/7/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2030-13	Room 212 Counter @ K	SK	N/A		6/7/2025	-	-	-	Sign
2030-14	Room 212 Counter @ L	SK	N/A		6/7/2025	-	-	-	Sign
2030-15	Room 212 Prep Room	SK	N/A		6/7/2025	-	-	-	Sign
2031-2	Hall by Room 211	BF	App	<1.0	6/7/2025	-	-	-	
2031-1	Hall by Room 211	WF	N/A		6/7/2025	-	-	-	Removed from service, sampling required before returning to service
2032-1	Room 211 Teacher's Station	SK	N/A		6/7/2025	-	-	-	Sign
2032-2	Room 211 Side Counter	SK	N/A		6/7/2025	-	-	-	Sign
2032-3	Room 211 Counter @ A	SK	N/A		6/7/2025	-	-	-	Sign
2032-4	Room 211 Counter @ B	SK	N/A		6/7/2025	-	-	-	Sign
2032-5	Room 211 Counter @ C	SK	N/A		6/7/2025	-	-	-	Sign
2032-6	Room 211 Counter @ D	SK	N/A		6/7/2025	-	-	-	Sign
2032-7	Room 211 Counter @ E	SK	N/A		6/7/2025	-	-	-	Sign
2032-8	Room 211 Counter @ F	SK	N/A		6/7/2025	-	-	-	Sign
2032-9	Room 211 Counter @ G	SK	N/A		6/7/2025	-	-	-	Sign
2032-10	Room 211 Counter @ H	SK	N/A		6/7/2025	-	-	-	Sign
2032-11	Room 211 Counter @ I	SK	N/A		6/7/2025	-	-	-	Sign
2032-12	Room 211 Counter @ J	SK	N/A		6/7/2025	-	-	-	Sign
2032-13	Room 211 Counter @ K	SK	N/A		6/7/2025	-	-	-	Sign
2032-14	Room 211 Counter @ L	SK	N/A		6/7/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2033-1	Room 210 Teacher's Station	SK	N/A		6/7/2025	-	-	-	Sign
2033-2	Room 210 Side Counter	SK	N/A		6/7/2025	-	-	-	Sign
2033-3	Room 210 Counter @ A	SK	N/A		6/7/2025	-	-	-	Sign
2033-4	Room 210 Counter @ B	SK	N/A		6/7/2025	-	-	-	Sign
2033-5	Room 210 Counter @ C	SK	N/A		6/7/2025	-	-	-	Sign
2033-6	Room 210 Counter @ D	SK	N/A		6/7/2025	-	-	-	Sign
2033-7	Room 210 Counter @ E	SK	N/A		6/7/2025	-	-	-	Sign
2033-8	Room 210 Counter @ F	SK	N/A		6/7/2025	-	-	-	Sign
2033-9	Room 210 Counter @ G	SK	N/A		6/7/2025	-	-	-	Sign
2033-10	Room 210 Counter @ H	SK	N/A		6/7/2025	-	-	-	Sign
2033-11	Room 210 Counter @ I	SK	N/A		6/7/2025	-	-	-	Sign
2033-12	Room 210 Counter @ J	SK	N/A		6/7/2025	-	-	-	Sign
2033-13	Room 210 Counter @ K	SK	N/A		6/7/2025	-	-	-	Sign
2033-14	Room 210 Counter @ L	SK	N/A		6/7/2025	-	-	-	Sign
2034-1	Room 204 Teacher's Station	SK	N/A		6/7/2025	-	-	-	Sign
2034-2	Room 204 Counter @ A	SK	N/A		6/7/2025	-	-	-	Sign
2034-3	Room 204 Counter @ B	SK	N/A		6/7/2025	-	-	-	Sign
2034-4	Room 204 Counter @ C	SK	N/A		6/7/2025	-	-	-	Sign
2034-5	Room 204 Counter @ D	SK	N/A		6/7/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
0001-1	Basement Custodial Bathroom	SK	N/A		6/7/2025	-	-	-	Sign

Laboratory Report

NYE Report #: 2502865-33624

June 17, 2025

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Half Hollow Hills Csd; Half Hollow Hills High School West

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on June 13, 2025. New York Environmental analyzed the samples on June 16, 2025 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	07 Jun 2025
Date Received:	13 Jun 2025
Date Analyzed:	16 Jun 2025

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
250613Q001	1	Kitchen Prep by Slicer-SK, Initial	0.001	0.002	mg/L	
250613Q002	2	Kitchen Prep by Slicer-SPY, Initial	0.001	0.004	mg/L	
250613Q003	3	Kitchen Pot Filler-PF, Initial	0.001	0.003	mg/L	
250613Q004	4	Cafeteria South-BF, Initial	0.001	<0.001	mg/L	
250613Q005	5	Home Economics Room 151 Station 1-SK, Initial	0.001	<0.001	mg/L	
250613Q006	6	Home Economics Room 151 Station 1-SPY, Initial	0.001	<0.001	mg/L	
250613Q007	7	Home Economics Room 151 Station 2-SK, Initial	0.001	<0.001	mg/L	
250613Q008	8	Home Economics Room 151 Station 2-SPY, Initial	0.001	<0.001	mg/L	
250613Q009	9	Home Economics Room 151 Station 3-SK, Initial	0.001	<0.001	mg/L	
250613Q010	10	Home Economics Room 151 Station 3-SPY, Initial	0.001	<0.001	mg/L	
250613Q011	11	Home Economics Room 151 Station 4-SK, Initial	0.001	0.040	mg/L	H
250613Q012	12	Home Economics Room 151 Station 4-SPY, Initial	0.001	0.017	mg/L	H
250613Q013	13	Home Economics Room 151 Station 5-SK, Initial	0.001	0.010	mg/L	H
250613Q014	14	Home Economics Room 151 Station 5-SPY, Initial	0.001	0.003	mg/L	
250613Q015	15	Hall by Room 102-BF, Initial	0.001	0.001	mg/L	
250613Q016	16	Nurse's Office-BF, Initial	0.001	<0.001	mg/L	
250613Q017	17	Hall by Weight Room-BF, Initial	0.001	<0.001	mg/L	
250613Q018	18	Hall by Room 174-BF, Initial	0.001	<0.001	mg/L	
250613Q019	19	Hall by Room 174-WF, Initial	0.001	<0.001	mg/L	
250613Q020	20	Hall by New Gym-BF, Initial	0.001	<0.001	mg/L	
250613Q021	21	Hall by New Gym-WF, Initial	0.001	<0.001	mg/L	
250613Q022	22	Trainer's Room Ice Machine-IM, Initial	0.001	<0.001	mg/L	
250613Q023	23	Trainer's Room Sport Jug Filler-SK, Initial	0.001	0.001	mg/L	
250613Q024	24	Boys Locker Room-BF, Initial	0.001	<0.001	mg/L	
250613Q025	25	Boys Locker Room-WF, Initial	0.001	<0.001	mg/L	
250613Q026	26	Girls Locker Room-BF, Initial	0.001	<0.001	mg/L	

Date Collected:	07 Jun 2025
Date Received:	13 Jun 2025
Date Analyzed:	16 Jun 2025

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
250613Q027	27	Hall by Room 211-BF, Initial	0.001	<0.001	mg/L	
250613Q028	28	Hall by Room 251-BF, Initial	0.001	<0.001	mg/L	
250613Q029	29	Hall by Room 272-BF, Initial	0.001	<0.001	mg/L	
250613Q030	30	Hall by Room 272-WF, Initial	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

H: Sample result exceeds applicable regulatory limit.

Laboratory Report

August 26, 2025

Pam Chadderton
Enviroscience Consultants, Inc.
2150 Smithtown Ave.
Ronkonkoma, NY, 11779


Project: Half Hollow Hills
Project Address: Hhh HS West
Report ID: 250822017
Sample IDs: 250822017-272 - 250822017-282

New York Environmental is a NELAC accredited laboratory. Attached reported results meet the requirements of the NELAC standard unless otherwise noted.

Samples' analytical results relate only to the parameters tested for the samples received in the condition received by the laboratory, as noted on the Chain of Custody. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	22-Aug-25
Date Received:	22-Aug-25
Date Analyzed:	25-Aug-25

Analytical Method:	EPA 200.9
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
250822017-272	1	Station 4 rm. 151 - SK, initial	0.001	0.002	mg/L	
250822017-273	2	Station 4 rm. 151 - SK, 15 Second Flush	0.001	N/A	mg/L	
250822017-274	3	Station 4 rm. 151 - SK, 60 Second Flush	0.001	N/A	mg/L	
250822017-275	4	Station 4 rm. 151 - SPY, initial	0.001	0.012	mg/L	H
250822017-276	5	Station 4 rm. 151 - SPY, 15 Second Flush	0.001	<0.001	mg/L	
250822017-277	6	Station 4 rm. 151 - SPY, 60 Second Flush	0.001	<0.001	mg/L	
250822017-278	7	Station 5 rm. 151 - SK, initial	0.001	0.005	mg/L	
250822017-279	8	Station 5 rm. 151 - SK, 15 Second Flush	0.001	N/A	mg/L	
250822017-280	9	Station 5 rm. 151 - SK, 60 Second Flush	0.001	N/A	mg/L	
250822017-281	10	North Caf - BF, Initial	0.001	<0.001	mg/L	
250822017-282	11	BF-new-by rm. 235 - BF, Initial	0.001	<0.001	mg/L	

Comment(s):

LOQ: Limit of Quantitation

CID: Client ID

H: Sample result exceeds applicable regulatory limit.

NA: Samples not analyzed as per customer request.



Appendix C

Candlewood Middle School

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
0001-1	Basement-Old Laundry Room	SS	N/A		6/13/2025	-	-	-	Sign
1001-1	Custodial Office	SS	N/A		6/13/2025	-	-	-	Sign
1001-2	Custodial Office Bathroom	SK	N/A		6/13/2025	-	-	-	Sign
1002-1	Kitchen-Handwash	SK	N/A		6/13/2025	-	-	-	Sign
1002-2	Kitchen-2 Sink Unit	SK	N/A		6/13/2025	-	-	-	Sign
1002-3	Kitchen-Single Unit	SK	N/A		6/13/2025	-	-	-	Sign
1002-4	Kitchen-2 Bay- Dishwash	SK	N/A		6/13/2025	-	-	-	Sign
1002-5	Kitchen-2 Bay- Dishwash	SPY	N/A		6/13/2025	-	-	-	Sign
1002-6	Kitchen-Serving Area	SK	N/A		6/13/2025	-	-	-	Sign
1002-7	Kitchen-Ice Cream Serving Area-Single Unit	SK	N/A		6/13/2025	-	-	-	Sign
1002-8	Kitchen-Ice Cream Serving Area-Handwash	SK	N/A		6/13/2025	-	-	-	Sign
1002-9	Kitchen-Serving Area by Custodial Office	SK	N/A		6/13/2025	-	-	-	Sign
1002-10	Kitchen Bathroom	SK	N/A		6/13/2025	-	-	-	Sign
1002-11	Kitchen-Pot Filler	PF	App	4.0	6/13/2025	-	-	-	-
1002-12	Kitchen-Island Prep Sink	SK	App	3.0	6/13/2025	-	-	-	-
1003-1	Cafeteria	WF	App	<1.0	6/13/2025	-	-	-	-
1003-2	Cafeteria	BF	App	<1.0	6/13/2025	-	-	-	-
1004-1	Room 301	WF	App		6/13/2025	-	-	-	Removed from service, sampling required before returning to service
1004-2	Room 301-Trough @A	SK	N/A		6/13/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1004-3	Room 301-Trough @B	SK	N/A		6/13/2025	-	-	-	Sign
1005-1	Room 302	WF	App		6/13/2025	-	-	-	Removed from service, sampling required before returning to service
1005-2	Room 302-Trough @A	SK	N/A		6/13/2025	-	-	-	Sign
1005-3	Room 302-Trough @B	SK	N/A		6/13/2025	-	-	-	Sign
1006-1	Room 303	WF	App		6/13/2025	-	-	-	Removed from service, sampling required before returning to service
1006-2	Room 303-Trough @A	SK	N/A		6/13/2025	-	-	-	Sign
1006-3	Room 303-Trough @B	SK	N/A		6/13/2025	-	-	-	Sign
1007-1	Vestibule by New Gym	WF	App		6/13/2025	-	-	-	Removed from service, sampling required before returning to service
1007-2	Vestibule by New Gym	BF	App	<1.0	6/13/2025	-	-	-	-
1007-3	Vestibule by New Gym	WF	App	<1.0	6/13/2025	-	-	-	-
1008-1	Boy's Locker Room-Coach's Office Bathroom	SK	N/A		6/13/2025	-	-	-	Sign
1008-3	Boy's Locker Room Bathroom @A	SK	N/A		6/13/2025	-	-	-	Sign
1008-4	Boy's Locker Room Bathroom @B	SK	N/A		6/13/2025	-	-	-	Sign
1009-1	Hallway by Boy's Locker Room	WF	App	1.0	6/13/2025	-	-	-	-
1009-2	Hallway by Boy's Locker Room	BF	App	<1.0	6/13/2025	-	-	-	-
1009-3	Hallway by Room 103	BF	App	<1.0	6/13/2025	-	-	-	
1010-1	Custodial Closet by Girl's Locker Room	SS	N/A		6/13/2025	-	-	-	Sign
1011-1	Vestibule by Girl's Locker Room	WF	App		6/13/2025	-	-	-	Removed from service, sampling required before returning to service
1012-1	Girl's Locker Room	WF	App		6/13/2025	-	-	-	Removed from service, sampling required before returning to service

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1012-2	Girl's Locker Room-Coach's Office Bathroom	SK	N/A		6/13/2025	-	-	-	Sign
1012-3	Girl's Locker Room Bathroom @A	SK	N/A		6/13/2025	-	-	-	Sign
1012-4	Girl's Locker Room Bathroom @B	SK	N/A		6/13/2025	-	-	-	Sign
1013-1	Hallway by Room 301	WF	App		6/13/2025	-	-	-	Removed from service, sampling required before returning to service
1014-1	Boy's Bathroom by Kitchen @A	SK	N/A		6/13/2025	-	-	-	Sign
1014-2	Boy's Bathroom by Kitchen @B	SK	N/A		6/13/2025	-	-	-	Sign
1015-1	Men's Bathroom by Kitchen	SK	N/A		6/13/2025	-	-	-	Sign
1016-1	Women's Bathroom by Kitchen	SK	N/A		6/13/2025	-	-	-	Sign
1017-1	Custodial Closet by Kitchen	SS	N/A		6/13/2025	-	-	-	Sign
1018-1	Hallway by Cafeteria	WF	App		6/13/2025	-	-	-	Removed from service, sampling required before returning to service
1019-1	Faculty Room Kitchenette	SK	N/A		6/13/2025	-	-	-	Sign
1020-1	Girl's Bathroom by Faculty Room @A	SK	N/A		6/13/2025	-	-	-	Sign
1020-2	Girl's Bathroom by Faculty Room @B	SK	N/A		6/13/2025	-	-	-	Sign
1021-1	Library Kitchenette	SK	N/A		6/13/2025	-	-	-	Sign
1022-1	Girl's Bathroom by Room 101 @A	SK	N/A		6/13/2025	-	-	-	Sign
1022-2	Girl's Bathroom by Room 101 @B	SK	N/A		6/13/2025	-	-	-	Sign
1022-3	Girl's Bathroom by Room 101 @C	SK	N/A		6/13/2025	-	-	-	Sign
1022-4	Girl's Bathroom by Room 101 @D	SK	N/A		6/13/2025	-	-	-	Sign
1023-1	Boy's Bathroom by Room 101 @A	SK	N/A		6/13/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1023-2	Boy's Bathroom by Room 101 @B	SK	N/A		6/13/2025	-	-	-	Sign
1023-3	Boy's Bathroom by Room 101 @C	SK	N/A		6/13/2025	-	-	-	Sign
1023-4	Boy's Bathroom by Room 101 @D	SK	N/A		6/13/2025	-	-	-	Sign
1023-5	Boy's Bathroom by Room 101 @E	SK	N/A		6/13/2025	-	-	-	Sign
1024-1	Custodial Closet by Room 101	SS	N/A		6/13/2025	-	-	-	Sign
1025-1	Hallway by Room 101	WF	App		6/13/2025	-	-	-	Removed from service, sampling required before returning to service
1026-1	Hallway by Room 104	WF	App		6/13/2025	-	-	-	Removed from service, sampling required before returning to service
1027-1	Hallway by Room 127	WF	App		6/13/2025	-	-	-	Removed from service, sampling required before returning to service
1027-2	Hallway by Room 127	BF	App	<1.0	6/13/2025	-	-	-	
1028-1	Men's Bathroom by Elevator	SK	N/A		6/13/2025	-	-	-	Sign
1029-1	Women's Bathroom by Elevator	SK	N/A		6/13/2025	-	-	-	Sign
1030-1	Women's Bathroom by Room 401	SK	N/A		6/13/2025	-	-	-	Sign
1031-1	Men's Bathroom by Room 401	SK	N/A		6/13/2025	-	-	-	Sign
1032-1	Room 401-Teacher's Station	SK	N/A		6/13/2025	-	-	-	Sign
1032-2	Room 401-Pod 1 @A	SK	N/A		6/13/2025	-	-	-	Sign
1032-3	Room 401-Pod 1 @B	SK	N/A		6/13/2025	-	-	-	Sign
1032-4	Room 401-Pod 2 @A	SK	N/A		6/13/2025	-	-	-	Sign
1032-5	Room 401-Pod 2 @B	SK	N/A		6/13/2025	-	-	-	Sign
1032-6	Room 401-Pod 3 @A	SK	N/A		6/13/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1032-7	Room 401-Pod 3 @B	SK	N/A		6/13/2025	-	-	-	Sign
1032-8	Room 401-Pod 4 @A	SK	N/A		6/13/2025	-	-	-	Sign
1032-9	Room 401-Pod 4 @B	SK	N/A		6/13/2025	-	-	-	Sign
1032-10	Room 401-Counter	SK	N/A		6/13/2025	-	-	-	Sign
1032-11	Room 401 Prep Room	SK	N/A		6/13/2025	-	-	-	Sign
1033-1	Room 402-Teacher's Station	SK	N/A	322.0	6/13/2025	-	-	-	Sign Posted
1033-2	Room 402 Prep Room	SK	N/A	155.0	6/13/2025	-	-	-	Sign Posted
1033-3	Room 402-Counter @A	SK	App	5.0	6/13/2025	-	-	-	-
1033-4	Room 402-Counter @B	SK	App	5.0	6/13/2025	-	-	-	-
1033-5	Room 402-Counter @C	SK	App	<1.0	8/22/2025				Remediation Complete
				6.0	6/13/2025	-	-	-	Removed From Services; Pending Remediation
1033-6	Room 402-Counter @D	SK	App	4.0	6/13/2025	-	-	-	-
1033-7	Room 402-Counter @E	SK	App	1.0	6/13/2025	-	-	-	-
1033-8	Room 402-Counter @F	SK	App	42.0	6/13/2025	-	-	-	Removed From Services; Pending Remediation
1033-9	Room 402-Counter @G	SK	App	82.0	6/13/2025	-	-	-	Removed From Services; Pending Remediation
1034-1	Hallway by Room 403	BF	App	2.0	6/13/2025	-	-	-	-
1035-1	Room 405-Teacher's Station	SK	N/A		6/13/2025	-	-	-	Sign
1035-2	Room 405-Pod 1 @A	SK	N/A		6/13/2025	-	-	-	Sign
1035-3	Room 405-Pod 1 @B	SK	N/A		6/13/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1035-4	Room 405-Pod 2 @A	SK	N/A		6/13/2025	-	-	-	Sign
1035-5	Room 405-Pod 2 @B	SK	N/A		6/13/2025	-	-	-	Sign
1035-6	Room 405-Pod 3 @A	SK	N/A		6/13/2025	-	-	-	Sign
1035-7	Room 405-Pod 3 @B	SK	N/A		6/13/2025	-	-	-	Sign
1035-8	Room 405-Pod 4 @A	SK	N/A		6/13/2025	-	-	-	Sign
1035-9	Room 405-Pod 4 @B	SK	N/A		6/13/2025	-	-	-	Sign
1035-10	Room 405-Pod 5 @A	SK	N/A		6/13/2025	-	-	-	Sign
1035-11	Room 405-Pod 5 @B	SK	N/A		6/13/2025	-	-	-	Sign
1035-12	Room 405-Pod 6 @A	SK	N/A		6/13/2025	-	-	-	Sign
1035-13	Room 405-Pod 6 @B	SK	N/A		6/13/2025	-	-	-	Sign
1035-14	Room 405-Counter	SK	N/A		6/13/2025	-	-	-	Sign
1035-15	Room 405 Prep Room	SK	N/A		6/13/2025	-	-	-	Sign
1036-1	Room 501-Teacher's Station	SK	N/A		6/13/2025	-	-	-	Sign
1036-2	Room 501-Counter	SK	N/A		6/13/2025	-	-	-	Sign
1036-3	Room 501-Pod 1 @A	SK	N/A		6/13/2025	-	-	-	Sign
1036-4	Room 501-Pod 1 @B	SK	N/A		6/13/2025	-	-	-	Sign
1036-5	Room 501-Pod 2 @A	SK	N/A		6/13/2025	-	-	-	Sign
1036-6	Room 501-Pod 2 @B	SK	N/A		6/13/2025	-	-	-	Sign
1036-7	Room 501-Pod 3 @A	SK	N/A		6/13/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1036-8	Room 501-Pod 3 @B	SK	N/A		6/13/2025	-	-	-	Sign
1036-9	Room 501-Pod 4 @A	SK	N/A		6/13/2025	-	-	-	Sign
1036-10	Room 501-Pod 4 @B	SK	N/A		6/13/2025	-	-	-	Sign
1036-11	Room 501-Pod 5 @A	SK	N/A		6/13/2025	-	-	-	Sign
1036-12	Room 501-Pod 5 @B	SK	N/A		6/13/2025	-	-	-	Sign
1036-13	Room 501-Pod 6 @A	SK	N/A		6/13/2025	-	-	-	Sign
1036-14	Room 501-Pod 6 @B	SK	N/A		6/13/2025	-	-	-	Sign
1036-15	Room 501 Prep Room	SK	N/A		6/13/2025	-	-	-	Sign
1037-1	Girl's Bathroom by Room 502 @A	SK	N/A		6/13/2025	-	-	-	Sign
1037-2	Girl's Bathroom by Room 502 @B	SK	N/A		6/13/2025	-	-	-	Sign
1037-3	Girl's Bathroom by Room 502 @C	SK	N/A		6/13/2025	-	-	-	Sign
1037-4	Girl's Bathroom by Room 502 @D	SK	N/A		6/13/2025	-	-	-	Sign
1038-1	Custodial Closet by Room 502	SS	N/A		6/13/2025	-	-	-	Sign
1039-1	Boy's Bathroom by Room 502 @A	SK	N/A		6/13/2025	-	-	-	Sign
1039-3	Boy's Bathroom by Room 502 @C	SK	N/A		6/13/2025	-	-	-	Sign
1039-4	Boy's Bathroom by Room 502 @D	SK	N/A		6/13/2025	-	-	-	Sign
1039-5	Boy's Bathroom by Room 502 @E	SK	N/A		6/13/2025	-	-	-	Sign
1040-1	Hallway by Room 502	WF	App		6/13/2025	-	-	-	Removed from service, sampling required before returning to service
1041-1	Room 706-Teacher's Station	SK	N/A		6/13/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1041-2	Room 706-Counter @A	SK	N/A		6/13/2025	-	-	-	Sign
1041-3	Room 706-Counter @B	SK	N/A		6/13/2025	-	-	-	Sign
1041-4	Room 706-Fume Hood	SK	N/A		6/13/2025	-	-	-	Sign
1041-5	Room 706-Pod 1 @A	SK	N/A		6/13/2025	-	-	-	Sign
1041-6	Room 706-Pod 1 @B	SK	N/A		6/13/2025	-	-	-	Sign
1041-7	Room 706-Pod 2 @A	SK	N/A		6/13/2025	-	-	-	Sign
1041-8	Room 706-Pod 2 @B	SK	N/A		6/13/2025	-	-	-	Sign
1041-9	Room 706-Pod 3 @A	SK	N/A		6/13/2025	-	-	-	Sign
1041-10	Room 706-Pod 3 @B	SK	N/A		6/13/2025	-	-	-	Sign
1041-11	Room 706-Pod 4 @A	SK	N/A		6/13/2025	-	-	-	Sign
1041-12	Room 706-Pod 4 @B	SK	N/A		6/13/2025	-	-	-	Sign
1041-13	Room 706-Pod 5 @A	SK	N/A		6/13/2025	-	-	-	Sign
1041-14	Room 706-Pod 5 @B	SK	N/A		6/13/2025	-	-	-	Sign
1041-15	Room 706-Island @A	SK	N/A		6/13/2025	-	-	-	Sign
1041-16	Room 706 Prep Room	SK	N/A		6/13/2025	-	-	-	Sign
1042-1	Room 708-Teacher's Station	SK	N/A		6/13/2025	-	-	-	Sign
1042-2	Room 708-Counter @A	SK	N/A		6/13/2025	-	-	-	Sign
1042-3	Room 708-Counter @B	SK	N/A		6/13/2025	-	-	-	Sign
1042-4	Room 708-Fume Hood	SK	N/A		6/13/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1042-5	Room 708-Pod 1 @A	SK	N/A		6/13/2025	-	-	-	Sign
1042-6	Room 708-Pod 1 @B	SK	N/A		6/13/2025	-	-	-	Sign
1042-7	Room 708-Pod 2 @A	SK	N/A		6/13/2025	-	-	-	Sign
1042-8	Room 708-Pod 2 @B	SK	N/A		6/13/2025	-	-	-	Sign
1042-9	Room 708-Pod 3 @A	SK	N/A		6/13/2025	-	-	-	Sign
1042-10	Room 708-Pod 3 @B	SK	N/A		6/13/2025	-	-	-	Sign
1042-11	Room 708-Pod 4 @A	SK	N/A		6/13/2025	-	-	-	Sign
1042-12	Room 708-Pod 4 @B	SK	N/A		6/13/2025	-	-	-	Sign
1042-13	Room 708-Pod 5 @A	SK	N/A		6/13/2025	-	-	-	Sign
1042-14	Room 708-Pod 5 @B	SK	N/A		6/13/2025	-	-	-	Sign
1042-15	Room 708-Island @A	SK	N/A		6/13/2025	-	-	-	Sign
1042-16	Room 708 Prep Room	SK	N/A		6/13/2025	-	-	-	Sign
1043-1	Room 710-Teacher's Station	SK	N/A		6/13/2025	-	-	-	Sign
1043-2	Room 710-Counter @A	SK	N/A		6/13/2025	-	-	-	Sign
1043-3	Room 710-Counter @B	SK	N/A		6/13/2025	-	-	-	Sign
1043-4	Room 710-Fume Hood	SK	N/A		6/13/2025	-	-	-	Sign
1043-5	Room 710-Pod 1 @A	SK	N/A		6/13/2025	-	-	-	Sign
1043-6	Room 710-Pod 1 @B	SK	N/A		6/13/2025	-	-	-	Sign
1043-7	Room 710-Pod 2 @A	SK	N/A		6/13/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1043-8	Room 710-Pod 2 @B	SK	N/A		6/13/2025	-	-	-	Sign
1043-9	Room 710-Pod 3 @A	SK	N/A		6/13/2025	-	-	-	Sign
1043-10	Room 710-Pod 3 @B	SK	N/A		6/13/2025	-	-	-	Sign
1043-11	Room 710-Pod 4 @A	SK	N/A		6/13/2025	-	-	-	Sign
1043-12	Room 710-Pod 4 @B	SK	N/A		6/13/2025	-	-	-	Sign
1043-13	Room 710-Pod 5 @A	SK	N/A		6/13/2025	-	-	-	Sign
1043-14	Room 710-Pod 5 @B	SK	N/A		6/13/2025	-	-	-	Sign
1043-15	Room 710-Island @A	SK	N/A		6/13/2025	-	-	-	Sign
1043-16	Room 710 Prep Room	SK	N/A		6/13/2025	-	-	-	Sign
1044-1	Boy's Bathroom by Room 710 @A	SK	N/A		6/13/2025	-	-	-	Sign
1044-2	Boy's Bathroom by Room 710 @B	SK	N/A		6/13/2025	-	-	-	Sign
1044-3	Boy's Bathroom by Room 710 @C	SK	N/A		6/13/2025	-	-	-	Sign
1045-1	Girl's Bathroom by Room 710 @A	SK	N/A		6/13/2025	-	-	-	Sign
1045-2	Girl's Bathroom by Room 710 @B	SK	N/A		6/13/2025	-	-	-	Sign
1045-3	Girl's Bathroom by Room 710 @C	SK	N/A		6/13/2025	-	-	-	Sign
1046-1	Room 607-Home Economics	SK	App	3.0	6/13/2025	-	-	-	-
1046-2	Room 607-Home Economics	SKY	App	<1.0	6/13/2025	-	-	-	-
1047-1	Room 605-Home Economics-Left	SK	App	<1.0	6/13/2025	-	-	-	-
1047-3	Room 605-Home Economics-Right	SK	App	1.0	6/13/2025	-	-	-	-

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1047-4	Room 605-Home Economics-Right	SPY	App	<1.0	6/13/2025	-	-	-	-
1048-1	Hallway by Room 604	WF	App		6/13/2025	-	-	-	Removed from service, sampling required before returning to service
1049-1	Room 604-Art-Left Trough @A	SK	N/A		6/13/2025	-	-	-	Sign
1049-2	Room 604-Art-Left Trough @B	SK	N/A		6/13/2025	-	-	-	Sign
1049-3	Room 604-Art-Right Trough @A	SK	N/A		6/13/2025	-	-	-	Sign
1049-4	Room 604-Art-Right Trough @B	SK	N/A		6/13/2025	-	-	-	Sign
1050-1	Room 603-Teacher's Station	SK	N/A		6/13/2025	-	-	-	Sign
1050-2	Room 603-Pod 1 @A	SK	N/A		6/13/2025	-	-	-	Sign
1050-3	Room 603-Pod 1 @B	SK	N/A		6/13/2025	-	-	-	Sign
1050-4	Room 603-Pod 2 @A	SK	N/A		6/13/2025	-	-	-	Sign
1050-5	Room 603-Pod 2 @B	SK	N/A		6/13/2025	-	-	-	Sign
1050-6	Room 603-Pod 3 @A	SK	N/A		6/13/2025	-	-	-	Sign
1050-7	Room 603-Pod 3 @B	SK	N/A		6/13/2025	-	-	-	Sign
1050-8	Room 603-Pod 4 @A	SK	N/A		6/13/2025	-	-	-	Sign
1050-9	Room 603-Pod 4 @B	SK	N/A		6/13/2025	-	-	-	Sign
1050-10	Room 603-Pod 5 @A	SK	N/A		6/13/2025	-	-	-	Sign
1050-11	Room 603-Pod 5 @B	SK	N/A		6/13/2025	-	-	-	Sign
1050-12	Room 603-Pod 6 @A	SK	N/A		6/13/2025	-	-	-	Sign
1050-13	Room 603-Pod 6 @B	SK	N/A		6/13/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1050-14	Room 603-Counter	SK	N/A		6/13/2025	-	-	-	Sign
1050-15	Room 603 Prep Room	SK	N/A		6/13/2025	-	-	-	Sign
1051-1	Room 602-Trough 1 @A	SK	N/A		6/13/2025	-	-	-	Sign
1051-2	Room 602-Trough 1 @B	SK	N/A		6/13/2025	-	-	-	Sign
1051-3	Room 602-Trough 2 @A	SK	N/A		6/13/2025	-	-	-	Sign
1051-4	Room 602-Trough 2 @B	SK	N/A		6/13/2025	-	-	-	Sign
1052-1	Room 601-Trough 1 @A	SK	N/A		6/13/2025	-	-	-	Sign
1052-2	Room 601-Trough 1 @B	SK	N/A		6/13/2025	-	-	-	Sign
1052-3	Room 601-Trough 2 @A	SK	N/A		6/13/2025	-	-	-	Sign
1052-4	Room 601-Trough 2 @B	SK	N/A		6/13/2025	-	-	-	Sign
1053-1	Nurse's Office	SK	App	<1.0	6/13/2025	-	-	-	-
1053-2	Nurse's Office Exam Room	SK	N/A		6/13/2025	-	-	-	Sign
1053-3	Nurse's Office Bathroom	SK	N/A		6/13/2025	-	-	-	Sign
1054-1	Custodial Closet by Main Office	SS	N/A		6/13/2025	-	-	-	Sign
1055-1	Hallway by Main Office-Left	WF	App	<1.0	6/13/2025	-	-	-	-
1055-2	Hallway by Main Office-Right	WF	App	<1.0	6/13/2025	-	-	-	-
1055-3	Hallway by Main Office-Right	BF	App	<1.0	6/13/2025	-	-	-	-
1056-1	Men's Bathroom by Main Office @A	SK	N/A		6/13/2025	-	-	-	Sign
1056-2	Men's Bathroom by Main Office @B	SK	N/A		6/13/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1056-3	Men's Bathroom by Main Office @C	SK	N/A		6/13/2025	-	-	-	Sign
1057-1	Women's Bathroom by Main Office @A	SK	N/A		6/13/2025	-	-	-	Sign
1057-2	Women's Bathroom by Main Office @B	SK	N/A		6/13/2025	-	-	-	Sign
1057-3	Women's Bathroom by Main Office @C	SK	N/A		6/13/2025	-	-	-	Sign
1058-1	Main Office Bathroom	SK	N/A		6/13/2025	-	-	-	Sign
1058-2	Main Office Kitchenette	SK	N/A		6/13/2025	-	-	-	Sign
1059-1	Hall by Room 121	BF	App	<1.0	2/5/2025				
2001-1	Hallway by Room 216	WF	App		6/13/2025	-	-	-	Removed from service, sampling required before returning to service
2002-1	Girl's Bathroom by Room 201 @A	SK	N/A		6/13/2025	-	-	-	Sign
2002-2	Girl's Bathroom by Room 201 @B	SK	N/A		6/13/2025	-	-	-	Sign
2002-3	Girl's Bathroom by Room 201 @C	SK	N/A		6/13/2025	-	-	-	Sign
2002-4	Girl's Bathroom by Room 201 @D	SK	N/A		6/13/2025	-	-	-	Sign
2003-1	Custodial Closet by Room 201	SS	N/A		6/13/2025	-	-	-	Sign
2004-1	Boy's Bathroom by Room 201 @A	SK	N/A		6/13/2025	-	-	-	Sign
2004-2	Boy's Bathroom by Room 201 @B	SK	N/A		6/13/2025	-	-	-	Sign
2004-3	Boy's Bathroom by Room 201 @C	SK	N/A		6/13/2025	-	-	-	Sign
2004-4	Boy's Bathroom by Room 201 @D	SK	N/A		6/13/2025	-	-	-	Sign
2004-5	Boy's Bathroom by Room 201 @E	SK	N/A		6/13/2025	-	-	-	Sign
2005-1	Hallway by Room 203	BF	App	<1.0	6/13/2025	-	-	-	-

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2006-1	Hallway by Room 204	WF	App		6/13/2025	-	-	-	Removed from service, sampling required before returning to service
2007-1	Women's Bathroom by Room 205	SK	N/A		6/13/2025	-	-	-	Sign
2008-1	Room 207A	SK	N/A		6/13/2025	-	-	-	Sign
2009-1	Men's Bathroom by Room 207A	SK	N/A		6/13/2025	-	-	-	Sign
2010-1	Hallway by Room 207A	WF	App		6/13/2025	-	-	-	Removed from service, sampling required before returning to service
2011-1	Hallway by Room 208	WF	App		6/13/2025	-	-	-	Removed from service, sampling required before returning to service
2012-1	Hallway by Room 212	BF	App	<1.0	6/13/2025	-	-	-	-

Laboratory Report

NYE Report #: 2502866-33625

June 17, 2025

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Half Hollow Hills; Candlewood Middle School

Dear Project Manager,

Enclosed is the Laboratory Analytical Report for potable water sample(s) received on June 13, 2025. New York Environmental analyzed the samples on June 16, 2025 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	13 Jun 2025
Date Received:	13 Jun 2025
Date Analyzed:	16 Jun 2025

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
250613Q031	1	Kitchen-Pot Filler-PF, Initial	0.001	0.004	mg/L	
250613Q032	2	Kitchen-Island Prep Sink-SK, Initial	0.001	0.003	mg/L	
250613Q033	3	Cafeteria-BF, Initial	0.001	<0.001	mg/L	
250613Q034	4	Cafeteria-WF, Initial	0.001	<0.001	mg/L	
250613Q035	5	Vestibule by New Gym-BF, Initial	0.001	<0.001	mg/L	
250613Q036	6	Vestibule by New Gym-WF, Initial	0.001	<0.001	mg/L	
250613Q037	7	Hallway by Boy's Locker Room-WF, Initial	0.001	0.001	mg/L	
250613Q038	8	Hallway by Boy's Locker Room-BF, Initial	0.001	<0.001	mg/L	
250613Q039	9	Hallway by Room 103-BF, Initial	0.001	<0.001	mg/L	
250613Q040	10	Hallway by Room 127-BF, Initial	0.001	<0.001	mg/L	
250613Q041	11	Hallway by Room 203-BF, Initial	0.001	<0.001	mg/L	
250613Q042	12	Hallway by Room 212-BF, Initial	0.001	<0.001	mg/L	
250613Q043	13	Room 402-Teacher's Station-SK, Initial	0.001	0.322	mg/L	E,H
250613Q044	14	Room 402 Prep Room-SK, Initial	0.001	0.155	mg/L	E,H
250613Q045	15	Room 402-Counter @A-SK, Initial	0.001	0.005	mg/L	
250613Q046	16	Room 402-Counter @B-SK, Initial	0.001	0.005	mg/L	
250613Q047	17	Room 402-Counter @C-SK, Initial	0.001	0.006	mg/L	H
250613Q048	18	Room 402-Counter @D-SK, Initial	0.001	0.004	mg/L	
250613Q049	19	Room 402-Counter @E-SK, Initial	0.001	0.001	mg/L	
250613Q050	20	Room 402-Counter @F-SK, Initial	0.001	0.042	mg/L	H
250613Q051	21	Room 402-Counter @G-SK, Initial	0.001	0.082	mg/L	E,H
250613Q052	22	Hallway by Room 403-BF, Initial	0.001	0.002	mg/L	
250613Q053	23	Room 605-Home Economics-Left-SK, Initial	0.001	0.001	mg/L	
250613Q054	24	Room 605-Home Economics-Left-SPY, Initial	0.001	<0.001	mg/L	
250613Q055	25	Room 605-Home Economics-Right-SK, Initial	0.001	0.001	mg/L	
250613Q056	26	Room 605-Home Economics-Right-SPY, Initial	0.001	<0.001	mg/L	

Date Collected:	13 Jun 2025
Date Received:	13 Jun 2025
Date Analyzed:	16 Jun 2025

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
250613Q057	27	Room 607-Home Economics-SK, Initial	0.001	0.003	mg/L	
250613Q058	28	Room 607-Home Economics-SKY, Initial	0.001	<0.001	mg/L	
250613Q059	29	Nurse's Office-SK, Initial	0.001	<0.001	mg/L	
250613Q060	30	Hallway by Main Office-Left-WF, Initial	0.001	<0.001	mg/L	
250613Q061	31	Hallway by Main Office-Right-BF, Initial	0.001	<0.001	mg/L	
250613Q062	32	Hallway by Main Office-Right-WF, Initial	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

E: Sample result exceeds instrument calibration, value is estimated.

H: Sample result exceeds applicable regulatory limit.

Laboratory Report

August 26, 2025

Pam Chadderton
Enviroscience Consultants, Inc.
2150 Smithtown Ave.
Ronkonkoma, NY, 11779

Project: Half Hollow Hills
Project Address: Candlewood
Report ID: 250822018
Sample IDs: 250822018-286 - 250822018-288

New York Environmental is a NELAC accredited laboratory. Attached reported results meet the requirements of the NELAC standard unless otherwise noted.

Samples' analytical results relate only to the parameters tested for the samples received in the condition received by the laboratory, as noted on the Chain of Custody. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	22-Aug-25
Date Received:	22-Aug-25
Date Analyzed:	25-Aug-25

Analytical Method:	EPA 200.9
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
250822018-286	1	Counter 'c', initial	0.001	<0.001	mg/L	
250822018-287	2	Counter 'c', 15 Second Flush	0.001	N/A	mg/L	
250822018-288	3	Counter 'c', 60 Second Flush	0.001	N/A	mg/L	

Comment(s):

LOQ: Limit of Quantitation

CID: Client ID

NA: Samples not analyzed as per customer request.



Laboratory Report

NYE Report #: 2500481-32291

February 6, 2025

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Half Hollow Hills CSD; Candlewood Middle School

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on February 05, 2025. New York Environmental analyzed the samples on February 06, 2025 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	05 Feb 2025
Date Received:	05 Feb 2025
Date Analyzed:	06 Feb 2025

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

<u>Lab ID</u>	<u>CID</u>	<u>Sample Location/Description</u>	<u>LOQ</u>	<u>Result</u>	<u>Units</u>	<u>Flag</u>
250205R002	1	Hall @ Room 121- BF, Initial	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

Appendix D

West Hollow Middle School

**Half Hollow Hills CSD
West Hollow Middle School**

School Water Outlet Inventory

Lead in School Drinking Water Program 2023 - 2025

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
0001-1	Boiler Room	SS	N/A		6/23/2025	-	-	-	Sign
0002-1	Custodian basement room bathroom	SK	N/A		6/23/2025	-	-	-	Sign
1001-1	Custodial office kinchenett	SK	N/A		6/23/2025	-	-	-	Sign
1002-1	Room 117	SK	N/A		6/23/2025	-	-	-	Sign
1003-1	Custodial closet by Room 117	SS	N/A		6/23/2025	-	-	-	Sign
1004-1	Hall nearby Room 117	WF	App		6/23/2025				Removed from service
1005-1	Room 118 @ A	SK	N/A		6/23/2025	-	-	-	Sign
1005-2	Room 118 @ B	SK	N/A		6/23/2025	-	-	-	Sign
1005-3	Room 118	WF	App		6/23/2025				Removed from service
1006-1	Room 119 @ A	SK	N/A		6/23/2025	-	-	-	Sign
1006-2	Room 119 @ B	SK	N/A		6/23/2025	-	-	-	Sign
1006-3	Room 119	WF	App		6/23/2025				Removed from service
1007-1	Room 120	WF	App		6/23/2025				Removed from service
1007-2	Room 120	SK	N/A		6/23/2025	-	-	-	Sign
1008-1	Kitchen handwash @ A	SK	N/A		6/23/2025	-	-	-	Sign
1008-2	Kitchen 2-bay prep Left	SK	App	<1.0	6/23/2025	-	-	-	-
1008-3	Kitchen 2-bay prep Right	SK	App	<1.0	6/23/2025	-	-	-	-
1008-4	Kitchen canwash closet	SS	N/A		6/23/2025	-	-	-	Sign

**Half Hollow Hills CSD
West Hollow Middle School**

School Water Outlet Inventory

Lead in School Drinking Water Program 2023 - 2025

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1008-5	Kitchen bathroom @ A	SK	N/A		6/23/2025	-	-	-	Sign
1008-6	Kitchen bathroom @ B	SK	N/A		6/23/2025	-	-	-	Sign
1008-7	Kitchen island prep by freezer	SK	N/A	12.0	6/23/2025				Sign Posted
1008-8	Kitchen handwash @ B	SK	N/A		6/23/2025	-	-	-	Sign
1008-9	Kitchen 1-bay prep by pot filler	SK	App	<1.0	6/23/2025	-	-	-	-
1008-10	Kitchen serving line by lockers	SK	App	<1.0	6/23/2025	-	-	-	-
1008-11	Kitchen custodian closet	SS	N/A		6/23/2025	-	-	-	Sign
1008-12	Kitchen sanitizer station @ A	SK	N/A		6/23/2025	-	-	-	Sign
1008-13	Kitchen sanitizer station @ B	SK	N/A		6/23/2025	-	-	-	Sign
1008-14	Kitchen sanitizer station @ C	SK	N/A		6/23/2025	-	-	-	Sign
1008-15	Kitchen island prep by ovens	SK	App	2.0	6/23/2025	-	-	-	-
1008-16	Kitchen pot filler station Left	SK	App	1.0	6/23/2025	-	-	-	-
1008-17	Kitchen pit filler station Right	SK	App	<1.0	6/23/2025	-	-	-	-
1008-18	Kitchen pot filler station @ C	SK	App		6/23/2025	-	-	-	Sign
1008-19	Kitchen island by steam ovens	SK	App		6/23/2025	-	-	-	Sign
1009-1	Faculty dining kinchenett	SK	N/A		6/23/2025	-	-	-	Sign
1010-1	Room 122 - Band Room	SK	N/A		6/23/2025	-	-	-	Sign
1011-1	Hall by Auditorium	WF	App		6/23/2025				Removed from service

**Half Hollow Hills CSD
West Hollow Middle School**

School Water Outlet Inventory

Lead in School Drinking Water Program 2023 - 2025

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1012-1	Men faculty bathroom by Auditorium @ A	SK	N/A		6/23/2025	-	-	-	Sign
1012-2	Men faculty bathroom by Auditorium @ B	SK	N/A		6/23/2025	-	-	-	Sign
1013-1	Women faculty bathroom by Auditorium @	SK	N/A		6/23/2025	-	-	-	Sign
1013-2	Women faculty bathroom by Auditorium @	SK	N/A		6/23/2025	-	-	-	Sign
1014-1	Hall by Auditorium	BF	App	<1.0	6/23/2025	-	-	-	-
1015-1	Main office Hall women bathroom @ A	SK	N/A		6/23/2025	-	-	-	Sign
1015-2	Main office Hall women bathroom @ B	SK	N/A		6/23/2025	-	-	-	Sign
1016-1	Main office Hall men bathroom	SK	N/A		6/23/2025	-	-	-	Sign
1017-1	Principal's office bathroom	SK	N/A		6/23/2025	-	-	-	Sign
1018-1	Main office kinchenett	SK	N/A		6/23/2025	-	-	-	Sign
1018-2	Main office kinchenett	SPY	N/A		6/23/2025	-	-	-	Sign
1019-1	Custodial closet by Room 109A	SS	N/A		6/23/2025	-	-	-	Sign
1020-1	Hall by Room 111	BF	App	<1.0	6/23/2025	-	-	-	-
1021-1	Hall by Room 142 (left)	WF	App	<1.0	6/23/2025	-	-	-	-
1021-2	Hall by Room 142 (right)	WF	App	<1.0	6/23/2025	-	-	-	-
1021-3	Hall by Room 142 (right)	BF	App	<1.0	6/23/2025	-	-	-	-
1022-1	Women faculty bathroom by Room 142 @ A	SK	N/A		6/23/2025	-	-	-	Sign
1022-2	Women faculty bathroom by Room 142 @ B	SK	N/A		6/23/2025	-	-	-	Sign

**Half Hollow Hills CSD
West Hollow Middle School**

School Water Outlet Inventory

Lead in School Drinking Water Program 2023 - 2025

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1022-3	Women faculty bathroom by Room 142 @ C	SK	N/A		6/23/2025	-	-	-	Sign
1023-1	Custodial closet by Room 142	SS	N/A		6/23/2025	-	-	-	Sign
1024-1	Girls locker room	WF	App		6/23/2025				Removed from service
1024-2	Girls locker room bathroom @ A	SK	N/A		6/23/2025	-	-	-	Sign
1024-3	Girls locker room bathroom @ B	SK	N/A		6/23/2025	-	-	-	Sign
1024-4	Girls locker room bathroom @ C	SK	N/A		6/23/2025	-	-	-	Sign
1025-1	Custodial closet by The Annex	SS	N/A		6/23/2025	-	-	-	Sign
1026-1	Men faculty bathroom by The Annex	SK	N/A		6/23/2025	-	-	-	Sign
1027-1	The Annex bathroom	SK	N/A		6/23/2025	-	-	-	Sign
1028-1	Room 114 teacher's station	SK	N/A		6/23/2025	-	-	-	Sign
1028-2	Room 114 counter @ A	SK	N/A		6/23/2025	-	-	-	Sign
1028-4	Room 114 counter @ C	SK	N/A		6/23/2025	-	-	-	Sign
1028-5	Room 114 counter @ D	SK	N/A		6/23/2025	-	-	-	Sign
1028-6	Room 114 counter @ E	SK	N/A		6/23/2025	-	-	-	Sign
1028-7	Room 114 counter @ F	SK	N/A		6/23/2025	-	-	-	Sign
1029-1	Prep room 114/116	SK	N/A		6/23/2025	-	-	-	Sign
1030-1	Gymnasium foyer - Girls locker room side	BF	App	<1.0	6/23/2025	-	-	-	-
1031-1	Girls bathroom by Gymnasium @ A	SK	N/A		6/23/2025	-	-	-	Sign

**Half Hollow Hills CSD
West Hollow Middle School**

School Water Outlet Inventory

Lead in School Drinking Water Program 2023 - 2025

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1031-2	Girls bathroom by Gymnasium @ B	SK	N/A		6/23/2025	-	-	-	Sign
1031-3	Girls bathroom by Gymnasium @ C	SK	N/A		6/23/2025	-	-	-	Sign
1031-4	Girls bathroom by Gymnasium @ D	SK	N/A		6/23/2025	-	-	-	Sign
1031-5	Girls bathroom by Gymnasium @ E	SK	N/A		6/23/2025	-	-	-	Sign
1031-6	Girls bathroom by Gymnasium @ F	SK	N/A		6/23/2025	-	-	-	Sign
1031-7	Girls bathroom by Gymnasium @ G	SK	N/A		6/23/2025	-	-	-	Sign
1032-1	Boys bathroom by Gymnasium @ A	SK	N/A		6/23/2025	-	-	-	Sign
1032-2	Boys bathroom by Gymnasium @ B	SK	N/A		6/23/2025	-	-	-	Sign
1032-3	Boys bathroom by Gymnasium @ C	SK	N/A		6/23/2025	-	-	-	Sign
1032-4	Boys bathroom by Gymnasium @ D	SK	N/A		6/23/2025	-	-	-	Sign
1032-5	Boys bathroom by Gymnasium @ E	SK	N/A		6/23/2025	-	-	-	Sign
1032-6	Boys bathroom by Gymnasium @ F	SK	N/A		6/23/2025	-	-	-	Sign
1032-7	Boys bathroom by Gymnasium @ G	SK	N/A		6/23/2025	-	-	-	Sign
1033-1	Nurse's office	SK	App		6/23/2025	-	-	-	Sign
1033-2	Nurse's office storage	SK	N/A		6/23/2025	-	-	-	Sign
1033-3	Nurse's office bathroom	SK	N/A		6/23/2025	-	-	-	Sign
1034-1	Gymnasium foyer - Boys locker room side	WF	App		6/23/2025				Removed from service
1035-1	Boys locker room bathroom @ A	SK	N/A		6/23/2025	-	-	-	Sign

**Half Hollow Hills CSD
West Hollow Middle School**

School Water Outlet Inventory

Lead in School Drinking Water Program 2023 - 2025

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1035-2	Boys locker room bathroom @ B	SK	N/A		6/23/2025	-	-	-	Sign
1035-3	Boys locker room bathroom @ C	SK	N/A		6/23/2025	-	-	-	Sign
2001-1	Room 223 - Station #1	SK	App	2.0	6/23/2025	-	-	-	-
2001-2	Room 223 - Station #2	SK	App	1.0	6/23/2025	-	-	-	-
2001-3	Room 223 - Station #3	SK	App	<1.0	6/23/2025	-	-	-	-
2001-4	Room 223 - Station #4	SK	App	<1.0	6/23/2025	-	-	-	-
2001-5	Room 223 - Station #5	SK	App	1.0	6/23/2025	-	-	-	-
2001-6	Room 223 - Station #6	SK	App	1.0	6/23/2025	-	-	-	-
2002-1	Prep room 223/225 (laundry)	SK	N/A	7.0	6/23/2025				Sign Posted
2003-1	Room 225 - Station #1	SK	App	3.0	6/23/2025	-	-	-	-
2003-2	Room 225 - Station #2	SK	App	<1.0	6/23/2025	-	-	-	-
2003-3	Room 225 - Station #3	SK	App	5.0	6/23/2025	-	-	-	-
2003-4	Room 225 - Station #4	SK	App	4.0	6/23/2025	-	-	-	-
2004-1	Room 226 - Station #1	SK	App	<1.0	6/23/2025	-	-	-	-
2004-2	Room 226 - Station #2	SK	App	2.0	6/23/2025	-	-	-	-
2005-1	Room 218 counter @ A	SK	N/A		6/23/2025	-	-	-	Sign
2005-2	Room 218 counter @ B	SK	N/A		6/23/2025	-	-	-	Sign
2005-3	Room 218 counter @ C	SK	N/A		6/23/2025	-	-	-	Sign

**Half Hollow Hills CSD
West Hollow Middle School**

School Water Outlet Inventory

Lead in School Drinking Water Program 2023 - 2025

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2005-4	Room 218 counter @ D	SK	N/A		6/23/2025	-	-	-	Sign
2005-5	Room 218 counter @ E	SK	N/A		6/23/2025	-	-	-	Sign
2006-1	Room 231 unit @ A	SK	N/A		6/23/2025	-	-	-	Sign
2006-2	Room 231 unit @ B	SK	N/A		6/23/2025	-	-	-	Sign
2006-3	Room 231 unit @ C	SK	N/A		6/23/2025	-	-	-	Sign
2006-4	Room 231 unit @ D	SK	N/A		6/23/2025	-	-	-	Sign
2006-5	Room 231 unit @ E	SK	N/A		6/23/2025	-	-	-	Sign
2006-6	Room 231 unit @ F	SK	N/A		6/23/2025	-	-	-	Sign
2007-1	Room 232 counter @ A	SK	N/A		6/23/2025	-	-	-	Sign
2007-2	Room 232 counter @ B	SK	N/A		6/23/2025	-	-	-	Sign
2007-3	Room 232 counter @ C	SK	N/A		6/23/2025	-	-	-	Sign
2007-4	Room 232 counter @ D	SK	N/A		6/23/2025	-	-	-	Sign
2007-5	Room 232 counter @ E	SK	N/A		6/23/2025	-	-	-	Sign
2007-6	Room 232 counter @ F	SK	N/A		6/23/2025	-	-	-	Sign
2008-1	Women faculty bathroom by Room 232	SK	N/A		6/23/2025	-	-	-	Sign
2009-1	Hall by Room 220	WF	App		6/23/2025				Removed from service
2010-1	Men faculty bathroom by Room 220 @ A	SK	N/A		6/23/2025	-	-	-	Sign
2010-2	Men faculty bathroom by Room 220 @ B	SK	N/A		6/23/2025	-	-	-	Sign

**Half Hollow Hills CSD
West Hollow Middle School**

School Water Outlet Inventory

Lead in School Drinking Water Program 2023 - 2025

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2012-1	Women faculty bathroom by Library @ A	SK	N/A		6/23/2025	-	-	-	Sign
2012-2	Women faculty bathroom by Library @ B	SK	N/A		6/23/2025	-	-	-	Sign
2013-1	Hall by Library	BF	App	<1.0	6/23/2025	-	-	-	-
2014-1	Library work room	SK	N/A		6/23/2025	-	-	-	Sign
2015-1	Custodial closet by Room 207A	SS	N/A		6/23/2025	-	-	-	Sign
2016-1	Hall by Room 207A	WF	App		6/23/2025				Removed from service
2017-1	Room 208 teacher's station	SK	N/A		6/23/2025	-	-	-	Sign
2017-2	Room 208 - Table #1 @ A	SK	N/A		6/23/2025	-	-	-	Sign
2017-3	Room 208 - Table #1 @ B	SK	N/A		6/23/2025	-	-	-	Sign
2017-4	Room 208 - Table #1 @ C	SK	N/A		6/23/2025	-	-	-	Sign
2017-5	Room 208 - Table #1 @ D	SK	N/A		6/23/2025	-	-	-	Sign
2017-6	Room 208 - Table #2 @ A	SK	N/A		6/23/2025	-	-	-	Sign
2017-7	Room 208 - Table #2 @ B	SK	N/A		6/23/2025	-	-	-	Sign
2017-8	Room 208 - Table #2 @ C	SK	N/A		6/23/2025	-	-	-	Sign
2017-9	Room 208 - Table #2 @ D	SK	N/A		6/23/2025	-	-	-	Sign
2017-10	Room 208 - Table #3 @ A	SK	N/A		6/23/2025	-	-	-	Sign
2017-11	Room 208 - Table #3 @ B	SK	N/A		6/23/2025	-	-	-	Sign
2017-12	Room 208 - Table #4 @ A	SK	N/A		6/23/2025	-	-	-	Sign

**Half Hollow Hills CSD
West Hollow Middle School**

School Water Outlet Inventory

Lead in School Drinking Water Program 2023 - 2025

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2017-13	Room 208 - Table #4 @ B	SK	N/A		6/23/2025	-	-	-	Sign
2017-14	Room 208 - Table #5 @ A	SK	N/A		6/23/2025	-	-	-	Sign
2017-15	Room 208 - Table #5 @ B	SK	N/A		6/23/2025	-	-	-	Sign
2017-16	Room 208 counter	SK	N/A		6/23/2025	-	-	-	Sign
2018-1	Room 210 teacher's station	SK	N/A		6/23/2025	-	-	-	Sign
2018-2	Room 210 counter	SK	N/A		6/23/2025	-	-	-	Sign
2018-3	Room 210 - Table #1 @ A	SK	N/A		6/23/2025	-	-	-	Sign
2018-4	Room 210 - Table #1 @ B	SK	N/A		6/23/2025	-	-	-	Sign
2018-5	Room 210 - Table #2 @ A	SK	N/A		6/23/2025	-	-	-	Sign
2018-6	Room 210 - Table #2 @ B	SK	N/A		6/23/2025	-	-	-	Sign
2018-7	Room 210 - Table #3 @ A	SK	N/A		6/23/2025	-	-	-	Sign
2018-8	Room 210 - Table #3 @ B	SK	N/A		6/23/2025	-	-	-	Sign
2018-9	Room 210 - Table #4 @ A	SK	N/A		6/23/2025	-	-	-	Sign
2018-10	Room 210 - Table #4 @ B	SK	N/A		6/23/2025	-	-	-	Sign
2018-11	Room 210 - Table #4 @ C	SK	N/A		6/23/2025	-	-	-	Sign
2018-12	Room 210 - Table #4 @ D	SK	N/A		6/23/2025	-	-	-	Sign
2018-13	Room 210 - Table #5 @ A	SK	N/A		6/23/2025	-	-	-	Sign
2018-14	Room 210 - Table #5 @ B	SK	N/A		6/23/2025	-	-	-	Sign

**Half Hollow Hills CSD
West Hollow Middle School**

School Water Outlet Inventory

Lead in School Drinking Water Program 2023 - 2025

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2018-15	Room 210 - Table #5 @ C	SK	N/A		6/23/2025	-	-	-	Sign
2018-16	Room 210 - Table #5 @ D	SK	N/A		6/23/2025	-	-	-	Sign
2019-1	Room 209 teacher's station	SK	N/A		6/23/2025	-	-	-	Sign
2019-2	Room 209 counter	SK	N/A		6/23/2025	-	-	-	Sign
2019-3	Room 209 - Table #1 @ A	SK	N/A		6/23/2025	-	-	-	Sign
2019-4	Room 209 - Table #1 @ B	SK	N/A		6/23/2025	-	-	-	Sign
2019-5	Room 209 - Table #2 @ A	SK	N/A		6/23/2025	-	-	-	Sign
2019-6	Room 209 - Table #2 @ B	SK	N/A		6/23/2025	-	-	-	Sign
2019-7	Room 209 - Table #3 @ A	SK	N/A		6/23/2025	-	-	-	Sign
2019-8	Room 209 - Table #3 @ B	SK	N/A		6/23/2025	-	-	-	Sign
2019-9	Room 209 - Table #4 @ A	SK	N/A		6/23/2025	-	-	-	Sign
2019-10	Room 209 - Table #4 @ B	SK	N/A		6/23/2025	-	-	-	Sign
2019-11	Room 209 - Table #4 @ C	SK	N/A		6/23/2025	-	-	-	Sign
2019-12	Room 209 - Table #4 @ D	SK	N/A		6/23/2025	-	-	-	Sign
2019-13	Room 209 - Table #5 @ A	SK	N/A		6/23/2025	-	-	-	Sign
2019-14	Room 209 - Table #5 @ B	SK	N/A		6/23/2025	-	-	-	Sign
2019-15	Room 209 - Table #5 @ C	SK	N/A		6/23/2025	-	-	-	Sign
2019-16	Room 209 - Table #5 @ D	SK	N/A		6/23/2025	-	-	-	Sign

**Half Hollow Hills CSD
West Hollow Middle School**

School Water Outlet Inventory

Lead in School Drinking Water Program 2023 - 2025

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2020-1	Room 211 teacher's station	SK	N/A		6/23/2025	-	-	-	Sign
2020-2	Room 211 - Table #1 @ A	SK	N/A		6/23/2025	-	-	-	Sign
2020-3	Room 211 - Table #1 @ B	SK	N/A		6/23/2025	-	-	-	Sign
2020-4	Room 211 - Table #1 @ C	SK	N/A		6/23/2025	-	-	-	Sign
2020-5	Room 211 - Table #1 @ D	SK	N/A		6/23/2025	-	-	-	Sign
2020-6	Room 211 - Table #2 @ A	SK	N/A		6/23/2025	-	-	-	Sign
2020-7	Room 211 - Table #2 @ B	SK	N/A		6/23/2025	-	-	-	Sign
2020-8	Room 211 - Table #2 @ C	SK	N/A		6/23/2025	-	-	-	Sign
2020-9	Room 211 - Table #2 @ D	SK	N/A		6/23/2025	-	-	-	Sign
2020-10	Room 211 - Table #3 @ A	SK	N/A		6/23/2025	-	-	-	Sign
2020-11	Room 211 - Table #3 @ B	SK	N/A		6/23/2025	-	-	-	Sign
2020-12	Room 211 - Table #4 @ A	SK	N/A		6/23/2025	-	-	-	Sign
2020-13	Room 211 - Table #4 @ B	SK	N/A		6/23/2025	-	-	-	Sign
2020-14	Room 211 - Table #5 @ A	SK	N/A		6/23/2025	-	-	-	Sign
2020-15	Room 211 - Table #5 @ B	SK	N/A		6/23/2025	-	-	-	Sign
2020-16	Room 211 counter	SK	N/A		6/23/2025	-	-	-	Sign
2021-1	Hall by Room 242 (left)	WF	App	<1.0	6/23/2025	-	-	-	-
2021-2	Hall by Room 242 (right)	WF	App	<1.0	6/23/2025	-	-	-	-

**Half Hollow Hills CSD
West Hollow Middle School**

School Water Outlet Inventory

Lead in School Drinking Water Program 2023 - 2025

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2021-3	Hall by Room 242 (right)	BF	App	<1.0	6/23/2025	-	-	-	-
2022-1	Boys bathroom by Room 242 @ A	SK	N/A		6/23/2025	-	-	-	Sign
2022-2	Boys bathroom by Room 242 @ B	SK	N/A		6/23/2025	-	-	-	Sign
2022-3	Boys bathroom by Room 242 @ C	SK	N/A		6/23/2025	-	-	-	Sign
2022-4	Boys bathroom by Room 242 @ D	SK	N/A		6/23/2025	-	-	-	Sign
2023-1	Custodial closet by Room 242	SS	N/A		6/23/2025	-	-	-	Sign
2024-1	2nd floor Greenhouse	SS	N/A		6/23/2025	-	-	-	Sign
2025-1	Room 212 teacher's station	SK	N/A		6/23/2025	-	-	-	Sign
2025-2	Room 212 counter	SK	N/A		6/23/2025	-	-	-	Sign
2025-3	Room 212 - Table #1 @ A	SK	N/A		6/23/2025	-	-	-	Sign
2025-4	Room 212 - Table #1 @ B	SK	N/A		6/23/2025	-	-	-	Sign
2025-5	Room 212 - Table #2 @ A	SK	N/A		6/23/2025	-	-	-	Sign
2025-6	Room 212 - Table #2 @ B	SK	N/A		6/23/2025	-	-	-	Sign
2025-7	Room 212 - Table #3 @ A	SK	N/A		6/23/2025	-	-	-	Sign
2025-8	Room 212 - Table #3 @ B	SK	N/A		6/23/2025	-	-	-	Sign
2025-9	Room 212 - Table #4 @ A	SK	N/A		6/23/2025	-	-	-	Sign
2025-10	Room 212 - Table #4 @ B	SK	N/A		6/23/2025	-	-	-	Sign
2025-11	Room 212 - Table #4 @ C	SK	N/A		6/23/2025	-	-	-	Sign

**Half Hollow Hills CSD
West Hollow Middle School**

School Water Outlet Inventory

Lead in School Drinking Water Program 2023 - 2025

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2025-12	Room 212 - Table #4 @ D	SK	N/A		6/23/2025	-	-	-	Sign
2025-13	Room 212 - Table #5 @ A	SK	N/A		6/23/2025	-	-	-	Sign
2025-14	Room 212 - Table #5 @ B	SK	N/A		6/23/2025	-	-	-	Sign
2025-15	Room 212 - Table #5 @ C	SK	N/A		6/23/2025	-	-	-	Sign
2025-16	Room 212 - Table #5 @ D	SK	N/A		6/23/2025	-	-	-	Sign
2026-1	Room 213 teacher's station	SK	N/A		6/23/2025	-	-	-	Sign
2026-2	Room 213 - Table #1 @ A	SK	N/A		6/23/2025	-	-	-	Sign
2026-3	Room 213 - Table #1 @ B	SK	N/A		6/23/2025	-	-	-	Sign
2026-4	Room 213 - Table #2 @ A	SK	N/A		6/23/2025	-	-	-	Sign
2026-5	Room 213 - Table #2 @ B	SK	N/A		6/23/2025	-	-	-	Sign
2026-6	Room 213 - Table #3 @ A	SK	N/A		6/23/2025	-	-	-	Sign
2026-7	Room 213 - Table #3 @ B	SK	N/A		6/23/2025	-	-	-	Sign
2026-8	Room 213 counter	SK	N/A		6/23/2025	-	-	-	Sign
2026-9	Room 213 - Table #4 @ A	SK	N/A		6/23/2025	-	-	-	Sign
2026-10	Room 213 - Table #4 @ B	SK	N/A		6/23/2025	-	-	-	Sign
2026-11	Room 213 - Table #4 @ C	SK	N/A		6/23/2025	-	-	-	Sign
2026-12	Room 213 - Table #4 @ D	SK	N/A		6/23/2025	-	-	-	Sign
2026-13	Room 213 - Table #5 @ A	SK	N/A		6/23/2025	-	-	-	Sign

**Half Hollow Hills CSD
West Hollow Middle School**

School Water Outlet Inventory

Lead in School Drinking Water Program 2023 - 2025

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2026-14	Room 213 - Table #5 @ B	SK	N/A		6/23/2025	-	-	-	Sign
2026-15	Room 213 - Table #5 @ C	SK	N/A		6/23/2025	-	-	-	Sign
2026-16	Room 213 - Table #5 @ D	SK	N/A		6/23/2025	-	-	-	Sign
2027-1	Boys bathroom by Room 214 @ A	SK	N/A		6/23/2025	-	-	-	Sign
2027-2	Boys bathroom by Room 214 @ B	SK	N/A		6/23/2025	-	-	-	Sign
2027-3	Boys bathroom by Room 214 @ C	SK	N/A		6/23/2025	-	-	-	Sign
2027-4	Boys bathroom by Room 214 @ D	SK	N/A		6/23/2025	-	-	-	Sign
2027-5	Boys bathroom by Room 214 @ E	SK	N/A		6/23/2025	-	-	-	Sign
2027-6	Boys bathroom by Room 214 @ F	SK	N/A		6/23/2025	-	-	-	Sign
2027-7	Boys bathroom by Room 214 @ G	SK	N/A		6/23/2025	-	-	-	Sign
2028-1	Custodial closet by Room 214	SS	N/A		6/23/2025	-	-	-	Sign
2029-1	Room 214 teacher's station	SK	N/A		6/23/2025	-	-	-	Sign
2029-2	Room 214 - Table #1 @ A	SK	N/A		6/23/2025	-	-	-	Sign
2029-3	Room 214 - Table #1 @ B	SK	N/A		6/23/2025	-	-	-	Sign
2029-4	Room 214 - Table #1 @ C	SK	N/A		6/23/2025	-	-	-	Sign
2029-5	Room 214 - Table #1 @ D	SK	N/A		6/23/2025	-	-	-	Sign
2029-6	Room 214 - Table #2 @ A	SK	N/A		6/23/2025	-	-	-	Sign
2029-7	Room 214 - Table #2 @ B	SK	N/A		6/23/2025	-	-	-	Sign

**Half Hollow Hills CSD
West Hollow Middle School**

School Water Outlet Inventory

Lead in School Drinking Water Program 2023 - 2025

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2029-8	Room 214 - Table #2 @ C	SK	N/A		6/23/2025	-	-	-	Sign
2029-9	Room 214 - Table #2 @ D	SK	N/A		6/23/2025	-	-	-	Sign
2029-10	Room 214 - Table #3 @ A	SK	N/A		6/23/2025	-	-	-	Sign
2029-11	Room 214 - Table #3 @ B	SK	N/A		6/23/2025	-	-	-	Sign
2029-12	Room 214 - Table #4 @ A	SK	N/A		6/23/2025	-	-	-	Sign
2029-13	Room 214 - Table #4 @ B	SK	N/A		6/23/2025	-	-	-	Sign
2029-14	Room 214 - Table #5 @ A	SK	N/A		6/23/2025	-	-	-	Sign
2029-15	Room 214 - Table #5 @ B	SK	N/A		6/23/2025	-	-	-	Sign
2029-16	Room 214 counter	SK	N/A		6/23/2025	-	-	-	Sign
2030-1	Room 216 teacher's station	SK	N/A		6/23/2025	-	-	-	Sign
2030-2	Room 216 counter	SK	N/A		6/23/2025	-	-	-	Sign
2030-3	Room 216 - Table #1 @ A	SK	N/A		6/23/2025	-	-	-	Sign
2030-4	Room 216 - Table #1 @ B	SK	N/A		6/23/2025	-	-	-	Sign
2030-5	Room 216 - Table #2 @ A	SK	N/A		6/23/2025	-	-	-	Sign
2030-6	Room 216 - Table #2 @ B	SK	N/A		6/23/2025	-	-	-	Sign
2030-7	Room 216 - Table #3 @ A	SK	N/A		6/23/2025	-	-	-	Sign
2030-8	Room 216 - Table #3 @ B	SK	N/A		6/23/2025	-	-	-	Sign
2030-9	Room 216 - Table #4 @ A	SK	N/A		6/23/2025	-	-	-	Sign

**Half Hollow Hills CSD
West Hollow Middle School**

School Water Outlet Inventory

Lead in School Drinking Water Program 2023 - 2025

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2030-10	Room 216 - Table #4 @ B	SK	N/A		6/23/2025	-	-	-	Sign
2030-11	Room 216 - Table #4 @ C	SK	N/A		6/23/2025	-	-	-	Sign
2030-12	Room 216 - Table #4 @ D	SK	N/A		6/23/2025	-	-	-	Sign
2030-13	Room 216 - Table #5 @ A	SK	N/A		6/23/2025	-	-	-	Sign
2030-14	Room 216 - Table #5 @ B	SK	N/A		6/23/2025	-	-	-	Sign
2030-15	Room 216 - Table #5 @ C	SK	N/A		6/23/2025	-	-	-	Sign
2030-16	Room 216 - Table #5 @ D	SK	N/A		6/23/2025	-	-	-	Sign
2031-1	Girls bathroom by Room 216 @ A	SK	N/A		6/23/2025	-	-	-	Sign
2031-2	Girls bathroom by Room 216 @ B	SK	N/A		6/23/2025	-	-	-	Sign
2031-3	Girls bathroom by Room 216 @ C	SK	N/A		6/23/2025	-	-	-	Sign
2031-4	Girls bathroom by Room 216 @ D	SK	N/A		6/23/2025	-	-	-	Sign
2031-5	Girls bathroom by Room 216 @ E	SK	N/A		6/23/2025	-	-	-	Sign
2031-6	Girls bathroom by Room 216 @ F	SK	N/A		6/23/2025	-	-	-	Sign
2031-7	Girls bathroom by Room 216 @ G	SK	N/A		6/23/2025	-	-	-	Sign
2032-1	Hall by Room 216	WF	App		6/23/2025	-	-	-	Sign
2033-1	Men faculty bathroom by Room 216	SK	N/A		6/23/2025	-	-	-	Sign
2034-1	Science Department bathroom	SK	N/A		6/23/2025	-	-	-	Sign
2035-1	Custodial closet by Room 217D	SS	N/A		6/23/2025	-	-	-	Sign

**Half Hollow Hills CSD
West Hollow Middle School**

School Water Outlet Inventory

Lead in School Drinking Water Program 2023 - 2025

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2036-1	Hall by Room 217D	BF	App	<1.0	6/23/2025	-	-	-	-
2036-2	Hall by Room 217D	WF	App		6/23/2025				Removed from service

Laboratory Report

NYE Report #: 2503012-33718

June 25, 2025

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Half Hollow Hills Csd; West Hollow Middle School

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on June 24, 2025. New York Environmental analyzed the samples on June 25, 2025 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	21 Jun 2025
Date Received:	24 Jun 2025
Date Analyzed:	25 Jun 2025

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
250624O016	1	Kitchen 2-bay prep Left-SK, Initial	0.001	<0.001	mg/L	
250624O017	2	Kitchen 2-bay prep Right-SK, Initial	0.001	<0.001	mg/L	
250624O018	3	Kitchen pot filler station Left-SK, Initial	0.001	0.001	mg/L	
250624O019	4	Kitchen pot filler station Right-SK, Initial	0.001	<0.001	mg/L	
250624O020	5	Kitchen island prep by ovens-SK, Initial	0.001	0.002	mg/L	
250624O021	6	Kitchen 1-bay prep by pot filler-SK, Initial	0.001	<0.001	mg/L	
250624O022	7	Kitchen island prep by freezer-SK, Initial	0.001	0.012	mg/L	H
250624O023	8	Kitchen serving line by lockers-SK, Initial	0.001	<0.001	mg/L	
250624O024	9	Hall by Auditorium-BF, Initial	0.001	<0.001	mg/L	
250624O025	10	Hall by Room 111-BF, Initial	0.001	<0.001	mg/L	
250624O026	11	Hall by Room 142 (left)-WF, Initial	0.001	<0.001	mg/L	
250624O027	12	Hall by Room 142 (right)-BF, Initial	0.001	<0.001	mg/L	
250624O028	13	Hall by Room 142 (right)-WF, Initial	0.001	<0.001	mg/L	
250624O029	14	Gymnasium foyer - Girls locker room side-BF, Initial	0.001	<0.001	mg/L	
250624O030	15	Room 223 - Station #1-SK, Initial	0.001	0.002	mg/L	
250624O031	16	Room 223 - Station #2-SK, Initial	0.001	0.001	mg/L	
250624O032	17	Room 223 - Station #3-SK, Initial	0.001	<0.001	mg/L	
250624O033	18	Room 223 - Station #4-SK, Initial	0.001	<0.001	mg/L	
250624O034	19	Room 223 - Station #5-SK, Initial	0.001	0.001	mg/L	
250624O035	20	Room 223 - Station #6-SK, Initial	0.001	0.001	mg/L	
250624O036	21	Prep room 223/225 (laundry)-SK, Initial	0.001	0.007	mg/L	H
250624O037	22	Room 225 - Station #1-SK, Initial	0.001	0.003	mg/L	
250624O038	23	Room 225 - Station #2-SK, Initial	0.001	<0.001	mg/L	
250624O039	24	Room 225 - Station #3-SK, Initial	0.001	0.005	mg/L	
250624O040	25	Room 225 - Station #4-SK, Initial	0.001	0.004	mg/L	
250624O041	26	Room 226 - Station #1-SK, Initial	0.001	<0.001	mg/L	

Date Collected:	21 Jun 2025
Date Received:	24 Jun 2025
Date Analyzed:	25 Jun 2025

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
250624O042	27	Room 226 - Station #2-SK, Initial	0.001	0.002	mg/L	
250624O043	28	Hall by Library-BF, Initial	0.001	<0.001	mg/L	
250624O044	29	Hall by Room 242 (left)-WF, Initial	0.001	<0.001	mg/L	
250624O045	30	Hall by Room 242 (right)-BF, Initial	0.001	<0.001	mg/L	
250624O046	31	Hall by Room 242 (right)-WF, Initial	0.001	<0.001	mg/L	
250624O047	32	Hall by Room 217D-BF, Initial	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

E: Sample result exceeds instrument calibration, value is estimated.

Appendix E

Forest Park Elementary School

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1001-1	Kitchen Dishwashing Station	SK	N/A		6/25/2025	-	-	-	Sign
1001-2	Kitchen Dishwashing Station	SPY	N/A		6/25/2025	-	-	-	Sign
1001-3	Kitchen Handwash	SK	N/A		6/25/2025	-	-	-	Sign
1001-4	Kitchen 3-Bay @ A	SK	N/A		6/25/2025	-	-	-	Sign
1001-5	Kitchen 3-Bay @ B	SK	N/A		6/25/2025	-	-	-	Sign
1001-6	Kitchen 3-Bay @ B	SPY	N/A		6/25/2025	-	-	-	Sign
1001-7	Kitchen Pot Filler	PF	N/A		6/25/2025	-	-	-	Sign
1001-8	Kitchen Oven Spigot	PF	N/A		6/25/2025	-	-	-	Sign
1001-9	Kitchen Bathroom (left)	SK	N/A		6/25/2025	-	-	-	Sign
1001-10	Kitchen Bathroom (right)	SK	N/A		6/25/2025	-	-	-	Sign
1001-11	Kitchen Custodial Closet	SS	N/A		6/25/2025	-	-	-	Sign
1002-1	Nurse's Office	SK	N/A		6/25/2025	-	-	-	Sign
1002-2	Nurse's Office Bathroom	SK	NA		6/25/2025	-	-	-	Sign
1003-1	Principal's Office Bathroom	SK	N/A		6/25/2025	-	-	-	Sign
1004-1	Main Office Break Room	SK	N/A		6/25/2025	-	-	-	Sign
1005-1	Room 106	SK	N/A		6/25/2025	-	-	-	Sign
1006-1	Hall by Room 104	WF	App	<1.0	6/25/2025	-	-	-	
1006-2	Hall by Room 104	BF	App	<1.0	6/25/2025	-	-	-	
1007-1	Room 104	SK	N/A		6/25/2025	-	-	-	Sign

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1008-1	Room 101	SK	N/A		6/25/2025	-	-	-	Sign
1008-2	Room 101 Bathroom	SK	N/A		6/25/2025	-	-	-	Sign
1009-1	Room 102	SK	N/A		6/25/2025	-	-	-	Sign
1009-2	Room 102 Bathroom	SK	N/A		6/25/2025	-	-	-	Sign
1010-1	Room 103	SK	N/A		6/25/2025	-	-	-	Sign
1011-1	Room 105B	SK	N/A		6/25/2025	-	-	-	Sign
1012-1	Room 107	SK	N/A		6/25/2025	-	-	-	Sign
1013-1	Room 108	SK	N/A		6/25/2025	-	-	-	Sign
1014-1	Room 109	SK	N/A		6/25/2025	-	-	-	Sign
1015-1	Room 111	SK	N/A		6/25/2025	-	-	-	Sign
1016-1	Room 115	SK	N/A		6/25/2025	-	-	-	Sign
1017-1	Girl's Bathroom by Room 117 @A	SK	N/A		6/25/2025	-	-	-	Sign
1017-2	Girl's Bathroom by Room 117 @B	SK	N/A		6/25/2025	-	-	-	Sign
1017-3	Girl's Bathroom by Room 117 @C	SK	N/A		6/25/2025	-	-	-	Sign
1017-4	Girl's Bathroom by Room 117 @D	SK	N/A		6/25/2025	-	-	-	Sign
1017-5	Girl's Bathroom by Room 117 @E	SK	N/A		6/25/2025	-	-	-	Sign
1018-1	Faculty Bathroom by Room 117	SK	N/A		6/25/2025	-	-	-	Sign
1019-1	Custodial Closet by Room 117	SS	N/A		6/25/2025	-	-	-	Sign
1020-1	Boy's Bathroom by Room 117 @A	SK	N/A		6/25/2025	-	-	-	Sign

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1020-2	Boy's Bathroom by Room 117 @B	SK	N/A		6/25/2025	-	-	-	Sign
1020-3	Boy's Bathroom by Room 117 @C	SK	N/A		6/25/2025	-	-	-	Sign
1020-4	Boy's Bathroom by Room 117 @D	SK	N/A		6/25/2025	-	-	-	Sign
1020-5	Boy's Bathroom by Room 117 @E	SK	N/A		6/25/2025	-	-	-	Sign
1021-1	Hall by Room 117 (right)	WF	App		6/25/2025	-	-	-	Removed from service, sampling required before returning to service
1021-2	Hall by Room 117 (left)	WF	App	<1.0	6/25/2025	-	-	-	
1021-3	Hall by Room 117 (left)	BF	App	<1.0	6/25/2025	-	-	-	
1022-1	Room 117	SK	N/A		6/25/2025	-	-	-	Sign
1023-1	Room 119	SK	N/A		6/25/2025	-	-	-	Sign
1024-1	Room 121	SK	N/A		6/25/2025	-	-	-	Sign
1025-1	Room 120	SK	N/A		6/25/2025	-	-	-	Sign
1026-1	Room 118	SK	N/A		6/25/2025	-	-	-	Sign
1027-1	Room 116	SK	N/A		6/25/2025	-	-	-	Sign
1028-1	Room 114	SK	N/A		6/25/2025	-	-	-	Sign
1029-1	Room 112	SK	N/A		6/25/2025	-	-	-	Sign
1030-1	Room 110	SK	N/A		6/25/2025	-	-	-	Sign
1031-1	Boy's Bathroom by Room 110 (left)	SK	N/A		6/25/2025	-	-	-	Sign
1031-2	Boy's Bathroom by Room 110 (right)	SK	N/A		6/25/2025	-	-	-	Sign
1032-1	Custodial Closet by Room 110	SS	N/A		6/25/2025	-	-	-	Sign

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1033-1	Faculty Bathroom by Room 110	SK	N/A		6/25/2025	-	-	-	Sign
1034-1	Girl's Bathroom by Room 110 @A	SK	N/A		6/25/2025	-	-	-	Sign
1034-2	Girl's Bathroom by Room 110 @B	SK	N/A		6/25/2025	-	-	-	Sign
1034-3	Girl's Bathroom by Room 110 @C	SK	N/A		6/25/2025	-	-	-	Sign
1035-1	Assistant Principal's Office	SK	N/A		6/25/2025	-	-	-	Sign
1036-1	Women's Bathroom by Gym	SK	N/A		6/25/2025	-	-	-	Sign
1037-1	Men's Bathroom by Gym	SK	N/A		6/25/2025	-	-	-	Sign
1038-1	Girl's Bathroom by Gym @ A	SK	N/A		6/25/2025	-	-	-	Sign
1038-2	Girl's Bathroom by Gym @ B	SK	N/A		6/25/2025	-	-	-	Sign
1038-3	Girl's Bathroom by Gym @ C	SK	N/A		6/25/2025	-	-	-	Sign
1039-1	Custodial Closet by Gym	SS	N/A		6/25/2025	-	-	-	Sign
1040-1	Boy's Bathroom by Gym @ A	SK	N/A		6/25/2025	-	-	-	Sign
1040-2	Boy's Bathroom by Gym @ B	SK	N/A		6/25/2025	-	-	-	Sign
1040-3	Boy's Bathroom by Gym @ C	SK	N/A		6/25/2025	-	-	-	Sign
1041-1	Room 21	SK	N/A		6/25/2025	-	-	-	Sign
1042-1	Hall by Room 19	WF	App	<1.0	6/25/2025	-	-	-	
1042-2	Hall by Room 19	BF	App	<1.0	6/25/2025	-	-	-	
1043-1	Room 19	SK	N/A		6/25/2025	-	-	-	Sign
1044-1	Room 17	SK	N/A		6/25/2025	-	-	-	Sign

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1045-1	Room 15	SK	N/A		6/25/2025	-	-	-	Sign
1046-1	Room 13	SK	N/A		6/25/2025	-	-	-	Sign
1047-1	Room 11	SK	N/A		6/25/2025	-	-	-	Sign
1048-1	Room 10	SK	N/A		6/25/2025	-	-	-	Sign
1049-1	Room 12	SK	N/A		6/25/2025	-	-	-	Sign
1050-1	Room 14	SK	N/A		6/25/2025	-	-	-	Sign
1051-1	Room 16	SK	N/A		6/25/2025	-	-	-	Sign
1052-1	Boy's Bathroom in Hexagon (left)	SK	N/A		6/25/2025	-	-	-	Sign
1052-2	Boy's Bathroom in Hexagon (right)	SK	N/A		6/25/2025	-	-	-	Sign
1053-1	Girl's Bathroom in Hexagon (left)	SK	N/A		6/25/2025	-	-	-	Sign
1053-2	Girl's Bathroom in Hexagon (right)	SK	N/A		6/25/2025	-	-	-	Sign
1054-1	Men's Bathroom in Hexagon	SK	N/A		6/25/2025	-	-	-	Sign
1055-1	Women's Bathroom in Hexagon	SK	N/A		6/25/2025	-	-	-	Sign
1056-1	Hall to Hexagon	WF	App	<1.0	6/25/2025	-	-	-	
1056-2	Hall to Hexagon	BF	App	<1.0	6/25/2025	-	-	-	
1057-1	Room 4	SK	N/A		6/25/2025	-	-	-	Sign
1058-1	Room 3	SK	N/A		6/25/2025	-	-	-	Sign
1059-1	Room 2	SK	N/A		6/25/2025	-	-	-	Sign
1060-1	Room 1	SK	N/A		6/25/2025	-	-	-	Sign

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1061-1	Room 9	SK	N/A		6/25/2025	-	-	-	Sign
1062-1	Room 8	SK	N/A		6/25/2025	-	-	-	Sign
1063-1	Custodial Closet in Hexagon	SS	N/A		6/25/2025	-	-	-	Sign
1064-1	Room 7	SK	N/A		6/25/2025	-	-	-	Sign
1065-1	Room 6	SK	N/A		6/25/2025	-	-	-	Sign
1066-1	Room 5	SK	N/A		6/25/2025	-	-	-	Sign
1067-1	Room 18	SK	N/A		6/25/2025	-	-	-	Sign
1068-1	Room 20 Bathroom	SK	N/A		6/25/2025	-	-	-	Sign
1069-1	Room 200E Bathroom	SK	N/A		6/25/2025	-	-	-	Sign
1070-1	Faculty Lounge	SK	N/A		6/25/2025	-	-	-	Sign
1071-1	Boy's Phys Ed Office Bathroom	SK	N/A		6/25/2025	-	-	-	Sign
1071-2	Boy's Phys Ed Office	SS	N/A		6/25/2025	-	-	-	Sign
1072-1	Custodial Office Bathroom	SK	N/A		6/25/2025	-	-	-	Sign

Laboratory Report

NYE Report #: 2503017-33721

June 26, 2025

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Half Hollow Hills Csd; Forest Park Elementary School

Dear Project Manager,

Enclosed is the Laboratory Analytical Report for potable water sample(s) received on June 25, 2025. New York Environmental analyzed the samples on June 26, 2025 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	25 Jun 2025
Date Received:	25 Jun 2025
Date Analyzed:	26 Jun 2025

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
250625O003	1	Hall by Room 104-BF, Intial	0.001	<0.001	mg/L	
250625O004	2	Hall by Room 104-WF, Intial	0.001	<0.001	mg/L	
250625O005	3	Hall by Room 117 (left)-BF, Intial	0.001	<0.001	mg/L	
250625O006	4	Hall by Room 117 (left)-WF, Intial	0.001	<0.001	mg/L	
250625O007	5	Hall by Room 19-BF, Intial	0.001	<0.001	mg/L	
250625O008	6	Hall by Room 19-WF, Intial	0.001	<0.001	mg/L	
250625O009	7	Hall to Hexagon-BF, Intial	0.001	<0.001	mg/L	
250625O010	8	Hall to Hexagon-WF, Intial	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

Appendix F

Chestnut Hill Elementary School

Half Hollow Hills CSD
Chestnut Hill Elementary School

School Water Outlet Inventory

Lead in School Drinking Water Program 2023 - 2025

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1001-1	Custodial Entrance Bathroom	SK	N/A		6/24/2025	-	-	-	Sign
1001-2	Custodial Entrance Custodial Closet	SS	N/A		6/24/2025	-	-	-	Sign
1002-1	Kitchen 2-Bay @ A	SPY	N/A		6/24/2025	-	-	-	Sign
1002-2	Kitchen 2-Bay @ A	SK	N/A		6/24/2025	-	-	-	Sign
1002-3	Kitchen 2-Bay @ B	SK	N/A		6/24/2025	-	-	-	Sign
1002-4	Kitchen 3-Bay @ A	SK	N/A		6/24/2025	-	-	-	Sign
1002-5	Kitchen 3-Bay @ A	SK	N/A		6/24/2025	-	-	-	Sign
1002-6	Kitchen 3-Bay @ A	SK	N/A		6/24/2025	-	-	-	Sign
1002-7	Kitchen Handwash	SK	N/A		6/24/2025	-	-	-	Sign
1002-8	Kitchen Island	SK	N/A		6/24/2025	-	-	-	Sign
1002-9	Kitchen Pot Filler (left)	PF	N/A		6/24/2025	-	-	-	Sign
1002-10	Kitchen Pot Filler (right)	PF	N/A		6/24/2025	-	-	-	Sign
1002-11	Kitchen Bathroom	SK	N/A		6/24/2025	-	-	-	Sign
1002-12	Kitchen Custodial Closet	SS	N/A		6/24/2025	-	-	-	Sign
1002-13	Kitchen Custodial Closet	SPY	N/A		6/24/2025	-	-	-	Sign
1003-1	Bathroom 1	SK	N/A		6/24/2025	-	-	-	Sign
1004-1	Bathroom 2	SK	N/A		6/24/2025	-	-	-	Sign
1005-1	Bathroom 3	SK	N/A		6/24/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1005-2	Bathroom 3	SK	N/A		6/24/2025	-	-	-	Sign
1006-1	Bathroom 4	SK	N/A		6/24/2025	-	-	-	Sign
1006-2	Bathroom 4	SK	N/A		6/24/2025	-	-	-	Sign
1006-3	Bathroom 4	SK	N/A		6/24/2025	-	-	-	Sign
1007-1	Hall by Room 201	BF	App	<1.0	6/24/2025	-	-	-	-
1008-1	Art Room 201 @ A	SK	N/A		6/24/2025	-	-	-	Sign
1008-2	Art Room 201 @ B	SK	N/A		6/24/2025	-	-	-	Sign
1008-3	Art Room 201 @ C	SK	N/A		6/24/2025	-	-	-	Sign
1008-4	Art Room 201 @ D	SK	N/A		6/24/2025	-	-	-	Sign
1009-1	Room 228	WF	App		6/24/2025	-	-	-	Removed from Service
1009-2	Room 228 Bathroom (left)	SK	N/A		6/24/2025	-	-	-	Sign
1009-3	Room 228 Bathroom (right)	SK	N/A		6/24/2025	-	-	-	Sign
1010-2	Room 202	WF	App		6/24/2025	-	-	-	Removed from Service
1011-1	Room 200C	WF	App		6/24/2025	-	-	-	Removed from Service
1011-2	Room 200C Bathroom	SK	N/A		6/24/2025	-	-	-	Sign
1012-1	Room 205	SK	N/A		6/24/2025	-	-	-	Sign
1013-1	Custodial Closet by Room 205	SS	N/A		6/24/2025	-	-	-	Sign
1014-1	Bathroom 5	SK	N/A		6/24/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1015-1	Bathroom 6 @ A	SK	N/A		6/24/2025	-	-	-	Sign
1015-2	Bathroom 6 @ B	SK	N/A		6/24/2025	-	-	-	Sign
1015-3	Bathroom 6 @ C	SK	N/A		6/24/2025	-	-	-	Sign
1015-4	Bathroom 6 @ D	SK	N/A		6/24/2025	-	-	-	Sign
1015-5	Bathroom 6 @ E	SK	N/A		6/24/2025	-	-	-	Sign
1016-1	Bathroom 7	SK	N/A		6/24/2025	-	-	-	Sign
1017-1	Hall by Bathroom 7 Left	WF	App	<1.0	6/24/2025	-	-	-	-
1017-2	Hall by Bathroom 7 Left	BF	App	<1.0	6/24/2025	-	-	-	-
1017-3	Hall by Bathroom 7 Right	WF	App	<1.0	6/24/2025	-	-	-	-
1018-1	Custodial Closet by Bathroom 7	SS	N/A		6/24/2025	-	-	-	Sign
1019-1	Bathroom 8 @ A	SK	N/A		6/24/2025	-	-	-	Sign
1019-2	Bathroom 8 @ B	SK	N/A		6/24/2025	-	-	-	Sign
1019-3	Bathroom 8 @ C	SK	N/A		6/24/2025	-	-	-	Sign
1019-4	Bathroom 8 @ D	SK	N/A		6/24/2025	-	-	-	Sign
1019-5	Bathroom 8 @ E	SK	N/A		6/24/2025	-	-	-	Sign
1020-1	Room 211 Staff Lounge	WC	App		6/24/2025	-	-	-	Removed from Service
1021-1	Room 212	SK	N/A		6/24/2025	-	-	-	Sign
1022-1	Room 213	SK	N/A		6/24/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1023-1	Room 214	SK	N/A		6/24/2025	-	-	-	Sign
1024-1	Room 210	SK	N/A		6/24/2025	-	-	-	Sign
1025-1	Room 209	SK	N/A		6/24/2025	-	-	-	Sign
1026-1	Room 211-Storage	SK	N/A		6/24/2025	-	-	-	Sign
1027-1	Room 212-Storage	SK	N/A		6/24/2025	-	-	-	Sign
1028-1	Room 207	SK	N/A		6/24/2025	-	-	-	Sign
1029-1	Room 206	SK	N/A		6/24/2025	-	-	-	Sign
1030-1	Teacher's Room	SK	N/A		6/24/2025	-	-	-	Sign
1031-1	Room 123	SK	N/A		6/24/2025	-	-	-	Sign
1032-1	Room 124	SK	N/A		6/24/2025	-	-	-	Sign
1032-2	Room 124	WF	App		6/24/2025	-	-	-	Removed from Service
1033-2	Hall by Nurse	BF	App		6/24/2025	-	-	-	Removed from Service
1033-3	Hall by Nurse	BF	App	<1.0	6/24/2025	-	-	-	-
1034-1	Nurse's Office	WC	App	<1.0	6/24/2025	-	-	-	-
1034-2	Nurse's Office	SK	N/A		6/24/2025	-	-	-	Sign
1034-3	Nurse's Office Bathroom	SK	N/A		6/24/2025	-	-	-	Sign
1035-1	Main Office Break Room	SK	N/A		6/24/2025	-	-	-	Sign
1036-1	Principal's Office Bathroom	SK	N/A		6/24/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1037-1	Room 101	SK	N/A		6/24/2025	-	-	-	Sign
1037-2	Room 101	WF	App		6/24/2025	-	-	-	Removed from Service
1038-1	Room 102	SK	N/A		6/24/2025	-	-	-	Sign
1038-2	Room 102	WF	App		6/24/2025	-	-	-	Removed from Service
1039-1	Hall by Room 103	WF	App		6/24/2025	-	-	-	Removed from Service
1039-2	Hall by Room 103	BF	App		6/24/2025	-	-	-	Removed from Service
1040-1	Room 103	SK	N/A		6/24/2025	-	-	-	Sign
1040-2	Room 103	WF	App		6/24/2025	-	-	-	Removed from Service
1041-1	Room 104	SK	N/A		6/24/2025	-	-	-	Sign
1041-2	Room 104	WF	App		6/24/2025	-	-	-	Removed from Service
1042-1	Room 105	SK	N/A		6/24/2025	-	-	-	Sign
1042-2	Room 105	WF	App		6/24/2025	-	-	-	Removed from Service
1043-1	Room 106	SK	N/A		6/24/2025	-	-	-	Sign
1043-2	Room 106	WF	App		6/24/2025	-	-	-	Removed from Service
1044-1	Room 107	SK	N/A		6/24/2025	-	-	-	Sign
1044-2	Room 107	WF	App		6/24/2025	-	-	-	Removed from Service
1045-1	Room 110	SK	N/A		6/24/2025	-	-	-	Sign
1045-2	Room 110	WF	App		6/24/2025	-	-	-	Removed from Service

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1046-1	Room 112 @ A	SK	N/A		6/24/2025	-	-	-	Sign
1046-2	Room 112 @ B	SK	N/A		6/24/2025	-	-	-	Sign
1046-3	Room 112 @ C	SK	N/A		6/24/2025	-	-	-	Sign
1046-4	Room 112 Bathroom	SK	N/A		6/24/2025	-	-	-	Sign
1046-5	Room 112	WF	App		6/24/2025	-	-	-	Removed from Service
1047-1	Room 113	SK	N/A		6/24/2025	-	-	-	Sign
1047-2	Room 113 Bathroom	SK	N/A		6/24/2025	-	-	-	Sign
1047-3	Room 113	WF	App		6/24/2025	-	-	-	Removed from Service
1048-1	Custodial Closet by Room 113	SS	N/A		6/24/2025	-	-	-	Sign
1049-1	Hall by Room 113	WF	App		6/24/2025	-	-	-	Removed from Service
1049-2	Hall by Room 113	BF	App		6/24/2025	-	-	-	Removed from Service
1049-3	Hall by Room 113	BF	App	<1.0	6/24/2025	-	-	-	-
1050-1	Women's Bathroom by Room 113	SK	N/A		6/24/2025	-	-	-	Sign
1051-1	Boy's Bathroom by Room 113 (left)	SK	N/A		6/24/2025	-	-	-	Sign
1051-2	Boy's Bathroom by Room 113 (right)	SK	N/A		6/24/2025	-	-	-	Sign
1052-1	Girl's Bathroom by Room 113 (left)	SK	N/A		6/24/2025	-	-	-	Sign
1052-2	Girl's Bathroom by Room 113 (right)	SK	N/A		6/24/2025	-	-	-	Sign
1053-1	Room 114	SK	N/A		6/24/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1053-2	Room 114	WF	App		6/24/2025	-	-	-	Removed from Service
1053-3	Room 114 Bathroom	SK	N/A		6/24/2025	-	-	-	Sign
1054-1	Room 115	SK	N/A		6/24/2025	-	-	-	Sign
1054-2	Room 115	WF	App		6/24/2025	-	-	-	Removed from Service
1054-3	Room 115 Bathroom	SK	N/A		6/24/2025	-	-	-	Sign
1055-1	Room 111	SK	N/A		6/24/2025	-	-	-	Sign
1055-2	Room 111	WF	App		6/24/2025	-	-	-	Removed from Service
1056-1	Room 116	SK	N/A		6/24/2025	-	-	-	Sign
1056-2	Room 116	WF	App		6/24/2025	-	-	-	Removed from Service
1057-1	Room 117	SK	N/A		6/24/2025	-	-	-	Sign
1057-2	Room 117	WF	App		6/24/2025	-	-	-	Removed from Service
1058-1	Room 118	SK	N/A		6/24/2025	-	-	-	Sign
1058-2	Room 118	WF	App		6/24/2025	-	-	-	Removed from Service
1059-1	Room 119	SK	N/A		6/24/2025	-	-	-	Sign
1059-2	Room 119	WF	App		6/24/2025	-	-	-	Removed from Service
1060-1	Library Kitchenette	SK	N/A		6/24/2025	-	-	-	Sign
1060-2	Library Kitchenette	BF	App		6/24/2025	-	-	-	Removed from Service
1061-1	Room 109	SK	N/A		6/24/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1062-1	Room 108	SK	N/A		6/24/2025	-	-	-	Sign
1062-2	Room 108	WF	App		6/24/2025	-	-	-	Removed from Service
1063-1	Women's Bathroom by Room 108 (left)	SK	N/A		6/24/2025	-	-	-	Sign
1063-2	Women's Bathroom by Room 108 (right)	SK	N/A		6/24/2025	-	-	-	Sign
1064-1	Men's Bathroom by room 108	SK	N/A		6/24/2025	-	-	-	Sign
1065-1	Girl's Bathroom by Room 120 @ A	SK	N/A		6/24/2025	-	-	-	Sign
1065-2	Girl's Bathroom by Room 120 @ B	SK	N/A		6/24/2025	-	-	-	Sign
1065-3	Girl's Bathroom by Room 120 @ C	SK	N/A		6/24/2025	-	-	-	Sign
1066-1	Boy's Bathroom by Room 120 @ A	SK	N/A		6/24/2025	-	-	-	Sign
1066-2	Boy's Bathroom by Room 120 @ B	SK	N/A		6/24/2025	-	-	-	Sign
1066-3	Boy's Bathroom by Room 120 @ C	SK	N/A		6/24/2025	-	-	-	Sign
1066-4	Boy's Bathroom by Room 120 @ D	SK	N/A		6/24/2025	-	-	-	Sign
1067-1	Hall by Room 120	WF	App		6/24/2025	-	-	-	Removed from Service
1067-2	Hall by Room 120	BF	App		6/24/2025	-	-	-	Removed from Service
1068-1	Room 120	SK	N/A		6/24/2025	-	-	-	Sign
1068-2	Room 120	WF	App		6/24/2025	-	-	-	Sign
1069-1	Room 121	SK	N/A		6/24/2025	-	-	-	Sign
1069-2	Room 121	WF	App		6/24/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1070-1	Room 122	SK	N/A		6/24/2025	-	-	-	Sign
1070-2	Room 122	WF	App		6/24/2025	-	-	-	Sign

Laboratory Report

NYE Report #: 2503010-33716

June 25, 2025

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Half Hollow Hills Csd; Chestnut Hill Elementary School

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on June 24, 2025. New York Environmental analyzed the samples on June 25, 2025 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	24 Jun 2025
Date Received:	24 Jun 2025
Date Analyzed:	25 Jun 2025

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
250624O001	1	Hall by Room 201-BF, Initial	0.001	<0.001	mg/L	
250624O002	2	Hall by Bathroom 7 Left-BF, Initial	0.001	<0.001	mg/L	
250624O003	3	Hall by Bathroom 7 Left-WF, Initial	0.001	<0.001	mg/L	
250624O004	4	Hall by Bathroom 7 Right-WF, Initial	0.001	<0.001	mg/L	
250624O005	5	Hall by Room 113-BF, Initial	0.001	<0.001	mg/L	
250624O006	6	Hall by Nurse-BF, Initial	0.001	<0.001	mg/L	
250624O007	7	Nurse's Office -WC, Initial	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

Appendix G

Otsego Elementary School

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1001-1	Kitchen pot filler	PF	App		6/24/2025				Non-functional, sampling required before returning to service
1001-2	Kitchen bathroom @ A	SK	N/A		6/24/2025	-	-	-	Sign
1001-3	Kitchen bathroom @ B	SK	N/A		6/24/2025	-	-	-	Sign
1001-4	Kitchen sanitizer station @ A	SK	N/A		6/24/2025	-	-	-	Sign
1001-5	Kitchen sanitizer station	SPY	N/A		6/24/2025	-	-	-	Sign
1001-6	Kitchen sanitizer station @ B	SK	N/A		6/24/2025	-	-	-	Sign
1001-7	Kitchen handwash	SK	N/A		6/24/2025	-	-	-	Sign
1001-8	Kitchen canwash closet	SS	N/A		6/24/2025	-	-	-	Sign
1001-9	Kitchen 2-bay Prep	SK	App	4.0	6/24/2025	-	-	-	-
1001-10	Kitchen dishwashing station	SPY	N/A		6/24/2025	-	-	-	Sign
1001-11	Kitchen dishwashing station	SK	N/A		6/24/2025	-	-	-	Sign
1001-12	Kitchen spigot by fire extinguisher	SP	N/A		6/24/2025	-	-	-	Sign
1002-1	Faculty room	SK	N/A		6/24/2025	-	-	-	Sign
1003-1	Receiving area bathroom	SK	N/A		6/24/2025	-	-	-	Sign
1004-1	Women faculty bathroom by exit 4	SK	N/A		6/24/2025	-	-	-	Sign
1005-1	Men faculty bathroom by exit 4	SK	N/A		6/24/2025	-	-	-	Sign
1006-1	Copy room bathroom	SK	N/A		6/24/2025	-	-	-	Sign
1006-2	Copy room custodial closet	SS	N/A		6/24/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1007-1	Main office kitchenett	SK	N/A		6/24/2025	-	-	-	Sign
1008-1	Pricipal's office bathroom	SK	N/A		6/24/2025	-	-	-	Sign
1009-1	Hallway by Nurse's office	WF	N/A		6/24/2025	-	-	-	Removed from Service
1010-1	Nurse's office	SK	App	3.0	6/24/2025	-	-	-	-
1010-2	Nurse's office bathroom	SK	N/A		6/24/2025	-	-	-	Sign
1011-1	Room 108	SK	N/A		6/24/2025	-	-	-	Sign
1011-2	Room 108	WF	N/A		6/24/2025	-	-	-	Removed from Service
1012-1	Room 107	SK	N/A		6/24/2025	-	-	-	Sign
1012-2	Room 107	WF	N/A		6/24/2025	-	-	-	Removed from Service
1013-1	Room 106	SK	N/A		6/24/2025	-	-	-	Sign
1013-2	Room 106	WF	N/A		6/24/2025	-	-	-	Removed from Service
1014-1	Room 105	SK	N/A		6/24/2025	-	-	-	Sign
1015-1	Custodial closet by Room 105	SS	N/A		6/24/2025	-	-	-	Sign
1016-1	Hallway by Room 105	WF	N/A		6/24/2025	-	-	-	Removed from Service
1016-1	Hallway by Room 105	BF	App	<1.0	6/24/2025	-	-	-	-
1017-1	Room 104	WF	N/A		6/24/2025	-	-	-	Removed from Service
1017-2	Room 104	SK	N/A		6/24/2025	-	-	-	Sign
1017-3	Room 104 bathroom	SK	N/A		6/24/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1018-1	Room 103	WF	N/A		6/24/2025	-	-	-	Removed from Service
1018-2	Room 103	SK	N/A		6/24/2025	-	-	-	Sign
1018-3	Room 103 bathroom	SK	N/A		6/24/2025	-	-	-	Sign
1019-1	Room 102	SK	N/A		6/24/2025	-	-	-	Sign
1019-2	Room 102	WF	N/A		6/24/2025	-	-	-	Removed from Service
1019-3	Room 102 bathroom	SK	N/A		6/24/2025	-	-	-	Sign
1020-1	Room 101	WF	N/A		6/24/2025	-	-	-	Removed from Service
1020-2	Room 101	SK	N/A		6/24/2025	-	-	-	Sign
1020-3	Room 101 bathroom	SK	N/A		6/24/2025	-	-	-	Sign
1021-1	Room 109	SK	N/A		6/24/2025	-	-	-	Sign
1021-2	Room 109	WF	N/A		6/24/2025	-	-	-	Removed from Service
1022-1	Girl's bathroom by Room 109 @ A	SK	N/A		6/24/2025	-	-	-	Sign
1022-2	Girl's bathroom by Room 109 @ B	SK	N/A		6/24/2025	-	-	-	Sign
1023-1	Faculty bathroom by Room 109	SK	N/A		6/24/2025	-	-	-	Sign
1024-1	Hallway by Room 110	WF	N/A		6/24/2025	-	-	-	Removed from Service
1025-1	Server closet	SK	N/A		6/24/2025	-	-	-	Sign
1026-1	Boy's bathroom by Room 111 @ A	SK	N/A		6/24/2025	-	-	-	Sign
1026-2	Boy's bathroom by Room 111 @ B	SK	N/A		6/24/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1026-3	Boy's bathroom by Room 111 @ C	SK	N/A		6/24/2025	-	-	-	Sign
1027-1	Room 110	SK	N/A		6/24/2025	-	-	-	Sign
1027-2	Room 110	WF	N/A		6/24/2025	-	-	-	Removed from Service
1028-1	Room 111	SK	N/A		6/24/2025	-	-	-	Sign
1028-2	Room 111	WF	N/A		6/24/2025	-	-	-	Removed from Service
1029-1	Room 112	SK	N/A		6/24/2025	-	-	-	Sign
1029-2	Room 112	WF	N/A		6/24/2025	-	-	-	Removed from Service
1030-1	Room 113	SK	N/A		6/24/2025	-	-	-	Sign
1030-2	Room 113	WF	N/A		6/24/2025	-	-	-	Removed from Service
1031-1	Room 114	SK	N/A		6/24/2025	-	-	-	Sign
1032-1	Room 116	SK	N/A		6/24/2025	-	-	-	Sign
1032-2	Room 116	WF	N/A		6/24/2025	-	-	-	Removed from Service
1033-1	Girl's bathroom by Room 116 @ A	SK	N/A		6/24/2025	-	-	-	Sign
1033-2	Girl's bathroom by Room 116 @ B	SK	N/A		6/24/2025	-	-	-	Sign
1033-3	Girl's bathroom by Room 116 @ C	SK	N/A		6/24/2025	-	-	-	Sign
1033-4	Girl's bathroom by Room 116 @ D	SK	N/A		6/24/2025	-	-	-	Sign
1033-5	Girl's bathroom by Room 116 @ E	SK	N/A		6/24/2025	-	-	-	Sign
1034-1	Faculty bathroom by Room 116	SK	N/A		6/24/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1035-1	Hallway by Room 116 (left)	BF	App	<1.0	6/24/2025	-	-	-	-
1035-2	Hallway by Room 116 (left)	WF	App	<1.0	6/24/2025	-	-	-	-
1035-3	Hallway by Room 116 (right)	WF	App	<1.0	6/24/2025	-	-	-	-
1036-1	Custodial closet by Room 116	SS	N/A		6/24/2025	-	-	-	Sign
1037-1	Boy's bathroom by Room 117 @ A	SK	N/A		6/24/2025	-	-	-	Sign
1037-2	Boy's bathroom by Room 117 @ B	SK	N/A		6/24/2025	-	-	-	Sign
1037-3	Boy's bathroom by Room 117 @ C	SK	N/A		6/24/2025	-	-	-	Sign
1037-4	Boy's bathroom by Room 117 @ D	SK	N/A		6/24/2025	-	-	-	Sign
1037-5	Boy's bathroom by Room 117 @ E	SK	N/A		6/24/2025	-	-	-	Sign
1038-1	Room 117	SK	N/A		6/24/2025	-	-	-	Sign
1038-2	Room 117	WF	N/A		6/24/2025	-	-	-	Removed from Service
1039-1	Room 118	SK	N/A		6/24/2025	-	-	-	Sign
1039-2	Room 118	WF	N/A		6/24/2025	-	-	-	Removed from Service
1040-1	Room 119	SK	N/A		6/24/2025	-	-	-	Sign
1040-2	Room 119	WF	N/A		6/24/2025	-	-	-	Removed from Service
1041-1	Room 120	SK	N/A		6/24/2025	-	-	-	Sign
1041-2	Room 120	WF	N/A		6/24/2025	-	-	-	Removed from Service
1042-1	Hallway by Room 200A	BF	App	<1.0	6/24/2025	-	-	-	-

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1042-2	Hallway by Room 200A	WF	N/A		6/24/2025	-	-	-	Removed from Service
1043-1	Room 201	SK	N/A		6/24/2025	-	-	-	Sign
1043-2	Room 201	WF	N/A		6/24/2025	-	-	-	Removed from Service
1044-1	Girl's bathroom by Room 201 @ A	SK	N/A		6/24/2025	-	-	-	Sign
1044-2	Girl's bathroom by Room 201 @ B	SK	N/A		6/24/2025	-	-	-	Sign
1044-3	Girl's bathroom by Room 201 @ C	SK	N/A		6/24/2025	-	-	-	Sign
1045-1	Custodial closet by Room 201	SS	N/A		6/24/2025	-	-	-	Sign
1046-1	Boy's bathroom by Room 201 @ A	SK	N/A		6/24/2025	-	-	-	Sign
1046-2	Boy's bathroom by Room 201 @ B	SK	N/A		6/24/2025	-	-	-	Sign
1046-3	Boy's bathroom by Room 201 @ C	SK	N/A		6/24/2025	-	-	-	Sign
1047-1	Physical Education office bathroom	SK	N/A		6/24/2025	-	-	-	Sign
1048-1	Room 202	SK	N/A		6/24/2025	-	-	-	Sign
1048-2	Room 202	WF	N/A		6/24/2025	-	-	-	Removed from Service
1049-1	Room 203	SK	N/A		6/24/2025	-	-	-	Sign
1049-2	Room 203	WF	N/A		6/24/2025	-	-	-	Removed from Service
1049-3	Room 203	SK	N/A		6/24/2025	-	-	-	Sign
1050-1	Room 204	SK	N/A		6/24/2025	-	-	-	Sign
1050-2	Room 204	WF	N/A		6/24/2025	-	-	-	Removed from Service

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1051-1	Room 205	SK	N/A		6/24/2025	-	-	-	Sign
1052-1	Room 206	SK	N/A		6/24/2025	-	-	-	Sign
1053-1	Room 207	SK	N/A		6/24/2025	-	-	-	Sign
1054-1	Room 208	SK	N/A		6/24/2025	-	-	-	Sign
1055-1	Room 209	SK	N/A		6/24/2025	-	-	-	Sign
1056-1	Room 210	SK	N/A		6/24/2025	-	-	-	Sign
1057-1	Room 211	SK	N/A		6/24/2025	-	-	-	Sign
1058-1	Hallway by Room 301	BF	App	<1.0	6/24/2025	-	-	-	-
1059-1	Girl's bathroom by Room 309 @ A	SK	N/A		6/24/2025	-	-	-	Sign
1059-2	Girl's bathroom by Room 309 @ B	SK	N/A		6/24/2025	-	-	-	Sign
1059-3	Girl's bathroom by Room 309 @ C	SK	N/A		6/24/2025	-	-	-	Sign
1060-1	Room 309	SK	N/A		6/24/2025	-	-	-	Sign
1061-1	Room 308	SK	N/A		6/24/2025	-	-	-	Sign
1062-1	Custodial closet by Room 308	SS	N/A		6/24/2025	-	-	-	Sign
1063-1	Room 307	SK	N/A		6/24/2025	-	-	-	Sign
1064-1	Boy's bathroom by Room 307 @ A	SK	N/A		6/24/2025	-	-	-	Sign
1064-2	Boy's bathroom by Room 307 @ B	SK	N/A		6/24/2025	-	-	-	Sign
1066-1	Hallway across from Room 305A	WF	N/A		6/24/2025	-	-	-	Removed from Service

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1067-1	Faculty bathroom by Room 305	SK	N/A		6/24/2025	-	-	-	Sign
1068-1	Room 305	SK	N/A		6/24/2025	-	-	-	Sign
1069-1	Room 304	SK	N/A		6/24/2025	-	-	-	Sign
1070-1	Room 303/302 (Library)	SK	N/A		6/24/2025	-	-	-	Sign
1071-1	Room 301	SK	N/A		6/24/2025	-	-	-	Sign
1072-1	Women faculty bathroom by Room 301	SK	N/A		6/24/2025	-	-	-	Sign

Laboratory Report

NYE Report #: 2503011-33717

June 25, 2025

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Half Hollow Hills Csd; Otsego Elementary School

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on June 24, 2025. New York Environmental analyzed the samples on June 25, 2025 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	24 Jun 2025
Date Received:	24 Jun 2025
Date Analyzed:	25 Jun 2025

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
250624O008	1	Kitchen 2-bay Prep-SK, Initial	0.001	0.004	mg/L	
250624O009	2	Nurse's office-SK, Initial	0.001	0.003	mg/L	
250624O010	3	Hallway by Room 105-BF, Initial	0.001	<0.001	mg/L	
250624O011	4	Hallway by Room 116 (left)-BF, Initial	0.001	<0.001	mg/L	
250624O012	5	Hallway by Room 116 (left)-WF, Initial	0.001	<0.001	mg/L	
250624O013	6	Hallway by Room 116 (right)-WF, Initial	0.001	<0.001	mg/L	
250624O014	7	Hallway by Room 200A-BF, Initial	0.001	<0.001	mg/L	
250624O015	8	Hallway by Room 301-BF, Initial	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

Appendix H

Sunquam Elementary School

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1001-1	Kitchen Handwash 1	SK	N/A		6/25/2025	-	-	-	Sign
1001-2	Kitchen 3-Bay @A	SK	N/A		6/25/2025	-	-	-	Sign
1001-3	Kitchen 3-Bay @B	SK	N/A		6/25/2025	-	-	-	Sign
1001-4	Kitchen 2-Bay	SK	App	<1.0	6/25/2025	-	-	-	-
1001-5	Kitchen Handwash 2	SK	N/A		6/25/2025	-	-	-	Sign
1001-6	Kitchen Island	SK	App	2.0	6/25/2025	-	-	-	-
1001-7	Kitchen Pot Filler	PF	App	2.0	6/25/2025	-	-	-	-
1001-8	Kitchen Handwash 3	SK	N/A		6/25/2025	-	-	-	Sign
1001-9	Kitchen Serving Line Handwash 1	SK	N/A		6/25/2025	-	-	-	Sign
1001-10	Kitchen Serving Line Handwash 2	SK	N/A		6/25/2025	-	-	-	Sign
1001-11	Kitchen Bathroom	SK	N/A		6/25/2025	-	-	-	Sign
1001-12	Kitchen Custodial Closet	SS	N/A		6/25/2025	-	-	-	Sign
1002-1	Faculty Room	SK	N/A		6/25/2025	-	-	-	Sign
1002-2	Faculty Room Bathroom	SK	N/A		6/25/2025	-	-	-	Sign
1003-1	Room 206	SK	N/A		6/25/2025	-	-	-	Sign
1004-1	Girl's Bathroom by Room 206 @ A	SK	N/A		6/25/2025	-	-	-	Sign
1004-2	Girl's Bathroom by Room 206 @ B	SK	N/A		6/25/2025	-	-	-	Sign
1004-3	Girl's Bathroom by Room 206 @ C	SK	N/A		6/25/2025	-	-	-	Sign
1005-1	Custodial Closet by Room 205	SS	N/A		6/25/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1006-1	Boy's Bathroom by Room 205 (left)	SK	N/A		6/25/2025	-	-	-	Sign
1006-2	Boy's Bathroom by Room 205 (right)	SK	N/A		6/25/2025	-	-	-	Sign
1007-1	Room 205	SK	N/A		6/25/2025	-	-	-	Sign
1008-1	Hall by Room 205	WF	App	<1.0	6/25/2025	-	-	-	-
1008-2	Hall by Room 205	BF	App	<1.0	6/25/2025	-	-	-	-
1009-1	Room 204	SK	N/A		6/25/2025	-	-	-	Sign
1010-1	Room 201	SK	N/A		6/25/2025	-	-	-	Sign
1011-1	Room 202	SK	N/A		6/25/2025	-	-	-	Sign
1012-1	Room 203	SK	N/A		6/25/2025	-	-	-	Sign
1013-1	Room 4	SK	N/A		6/25/2025	-	-	-	Sign
1014-1	Room 3	SK	N/A		6/25/2025	-	-	-	Sign
1016-1	Room 2	SK	N/A		6/25/2025	-	-	-	Sign
1017-1	Principal's Office Bathroom	SK	N/A		6/25/2025	-	-	-	Sign
1018-1	Girl's Bathroom by Room 301	SK	N/A		6/25/2025	-	-	-	Sign
1019-1	Custodial Closet by Room 301	SS	N/A		6/25/2025	-	-	-	Sign
1020-1	Faculty Bathroom by Room 301	SK	N/A		6/25/2025	-	-	-	Sign
1021-1	Hall by Room 302	WF	App	<1.0	6/25/2025	-	-	-	-
1021-2	Hall by Room 302	BF	App	<1.0	6/25/2025	-	-	-	-
1022-1	Room 301	SK	N/A		6/25/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1023-1	Room 302	SK	N/A		6/25/2025	-	-	-	Sign
1024-1	Room 303	SK	N/A		6/25/2025	-	-	-	Sign
1025-1	Room 304	SK	N/A		6/25/2025	-	-	-	Sign
1026-1	Custodial Closet by Room 105	SK	N/A		6/25/2025	-	-	-	Sign
1027-1	Room 105	SK	N/A		6/25/2025	-	-	-	Sign
1028-1	Room 106	SK	N/A		6/25/2025	-	-	-	Sign
1029-1	Room 107	SK	N/A		6/25/2025	-	-	-	Sign
1030-1	Room 108 Bathroom	SK	N/A		6/25/2025	-	-	-	Sign
1031-1	Room 109	SK	N/A		6/25/2025	-	-	-	Sign
1032-1	Room 110	SK	N/A		6/25/2025	-	-	-	Sign
1033-1	Room 111	SK	N/A		6/25/2025	-	-	-	Sign
1034-1	Hall by Room 112	BF	App	<1.0	6/25/2025	-	-	-	-
1035-1	Bathroom by Room 112	SK	N/A		6/25/2025	-	-	-	Sign
1036-1	Room 113	SK	N/A		6/25/2025	-	-	-	Sign
1037-1	Room 114	SK	N/A		6/25/2025	-	-	-	Sign
1038-1	Room 115	SK	N/A		6/25/2025	-	-	-	Sign
1039-1	Room 116	SK	N/A		6/25/2025	-	-	-	Sign
1040-1	Room 117	SK	N/A		6/25/2025	-	-	-	Sign
1041-1	Room 118	SK	N/A		6/25/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1042-1	Room 119	SK	N/A		6/25/2025	-	-	-	Sign
1043-1	Girl's Bathroom by Room 119 (left)	SK	N/A		6/25/2025	-	-	-	Sign
1043-2	Girl's Bathroom by Room 119 (right)	SK	N/A		6/25/2025	-	-	-	Sign
1044-1	Custodial Closet by Room 119	SS	N/A		6/25/2025	-	-	-	Sign
1045-1	Boy's Bathroom by Room 119 (left)	SK	N/A		6/25/2025	-	-	-	Sign
1045-2	Boy's Bathroom by Room 119 (right)	SK	N/A		6/25/2025	-	-	-	Sign
1046-1	Room 120	SK	N/A		6/25/2025	-	-	-	Sign
1048-1	Room 122	SK	N/A		6/25/2025	-	-	-	Sign
1049-1	Room 103	SK	N/A		6/25/2025	-	-	-	Sign
1050-1	Room 102	SK	N/A		6/25/2025	-	-	-	Sign
1051-1	Room 101	SK	N/A		6/25/2025	-	-	-	Sign
1052-1	Nurse's Office	SK	App	<1.0	6/25/2025	-	-	-	-
1052-2	Nurse's Office Exam Room	SK	N/A		6/25/2025	-	-	-	Sign
1053-1	Hall by Physical Education Office	WF	App		6/25/2025	-	-	-	Removed from service, sampling required before returning to service
1053-1	Hall by Physical Education Office	WF	App	<1.0	6/25/2025	-	-	-	-
1053-2	Hall by Physical Education Office	BF	App	<1.0	6/25/2025	-	-	-	-
1054-1	Physical Education Office Bathroom	SK	N/A		6/25/2025	-	-	-	Sign
1055-1	Music Room 1 Bathroom (left)	SK	N/A		6/25/2025	-	-	-	Sign
1055-2	Music Room 1 Bathroom (right)	SK	N/A		6/25/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1056-1	Physical Education Office (by Art)Bathroom	SK	N/A		6/25/2025	-	-	-	Sign
1057-1	Music Room 2 Bathroom	SK	N/A		6/25/2025	-	-	-	Sign
1058-1	Art Room (left)	SK	N/A		6/25/2025	-	-	-	Sign
1058-2	Art Room (right)	SK	N/A		6/25/2025	-	-	-	Sign
1059-1	Custodial Office	SS	N/A		6/25/2025	-	-	-	Sign
1060-1	Hill Vestibule	WF	App	<1.0	6/25/2025	-	-	-	-
1060-2	Hill Vestibule	BF	App	<1.0	6/25/2025	-	-	-	-
1060-3	Hill Vestibule Custodial Closet	SS	N/A		6/25/2025	-	-	-	Sign
1061-1	Room 410 (left)	SK	N/A		6/25/2025	-	-	-	Sign
1061-2	Room 410 (right)	SK	N/A		6/25/2025	-	-	-	Sign
1061-3	Room 410 Bathroom	SK	N/A		6/25/2025	-	-	-	Sign
1062-1	Room 402 (left)	SK	N/A		6/25/2025	-	-	-	Sign
1062-2	Room 402 (right)	SK	N/A		6/25/2025	-	-	-	Sign
1062-3	Room 402 Bathroom	SK	N/A		6/25/2025	-	-	-	Sign

Laboratory Report

NYE Report #: 2503018-33722

June 26, 2025

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Half Hollow Hills Csd; Sunquam Elementary School

Dear Project Manager,

Enclosed is the Laboratory Analytical Report for potable water sample(s) received on June 25, 2025. New York Environmental analyzed the samples on June 26, 2025 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	25 Jun 2025
Date Received:	25 Jun 2025
Date Analyzed:	26 Jun 2025

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
250625O011	1	Hall by Physical Education Office-BF, Initial	0.001	<0.001	mg/L	
250625O012	2	Hall by Physical Education Office-WF, Initial	0.001	<0.001	mg/L	
250625O013	3	Kitchen 2-Bay-SK, Initial	0.001	<0.001	mg/L	
250625O014	4	Kitchen Island-SK, Initial	0.001	0.002	mg/L	
250625O015	5	Kitchen Pot Filler-PF, Initial	0.001	0.002	mg/L	
250625O016	6	Hall by Room 205-BF, Initial	0.001	<0.001	mg/L	
250625O017	7	Hall by Room 205-WF, Initial	0.001	<0.001	mg/L	
250625O018	8	Hall by Room 302-BF, Initial	0.001	<0.001	mg/L	
250625O019	9	Hall by Room 302-WF, Initial	0.001	<0.001	mg/L	
250625O020	10	Hall by Room 112-BF, Initial	0.001	<0.001	mg/L	
250625O021	11	Nurse's Office-SK, Initial	0.001	<0.001	mg/L	
250625O022	12	Hill Vestibule-BF, Initial	0.001	<0.001	mg/L	
250625O023	13	Hill Vestibule-WF, Initial	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

Appendix I

Paumanok Elementary School

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1 st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1001-1	Kitchen-2 Sink Unit- Left	SK	App	<1.0	6/17/2025	-	-	-	-
1001-2	Kitchen-2 Sink Unit- Right	SK	App	<1.0	6/17/2025	-	-	-	-
1001-3	Kitchen-3 Sink Unit-Left	SK	N/A		6/17/2025	-	-	-	Sign
1001-4	Kitchen-3 Sink Unit-Middle	SK	N/A		6/17/2025	-	-	-	Sign
1001-5	Kitchen-3 Sink Unit-Right	SK	N/A		6/17/2025	-	-	-	Sign
1001-6	Kitchen Handwash	SK	N/A		6/17/2025	-	-	-	Sign
1001-7	Kitchen Bathroom	SK	N/A		6/17/2025	-	-	-	Sign
1001-8	Kitchen-Serving Area	SPY	N/A		6/17/2025	-	-	-	Sign
1001-9	Kitchen-Serving Area-Single Unit	SK	App	<1.0	8/22/2025	-	-	-	Remediation complete
				22.0	6/17/2025	-	-	-	Removed from service, pending remediation
1001-10	Kitchen-Custodial Closet	SS	N/A		6/17/2025	-	-	-	Sign
1001-11	Kitchen-Pot Filler	PF	App	<1.0	6/17/2025	-	-	-	-
1001-12	Kitchen-Prep Island	SK	App	2.0	6/17/2025	-	-	-	-
1001-13	Kitchen-Pot Filler Hose by Stove	PF	App	<1.0	8/22/2025	-	-	-	Remediation complete
				52.0	6/17/2025	-	-	-	Removed from service, pending remediation
1002-1	Cafeteria	WF	App	<1.0	6/17/2025	-	-	-	-
1002-2	Cafeteria	BF	App	1.0	6/17/2025	-	-	-	-
1003-1	Gender Neutral Bathroom by Cafeteria	SK	N/A		6/17/2025	-	-	-	Sign
1004-1	Women's Bathroom by Cafeteria	SK	N/A		6/17/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1005-1	Boy's Bathroom by Art Room 199-Left	SK	N/A		6/17/2025	-	-	-	Sign
1005-2	Boy's Bathroom by Art Room 199-Right	SK	N/A		6/17/2025	-	-	-	Sign
1006-1	Girl's Bathroom by Art Room 199-Left	SK	N/A		6/17/2025	-	-	-	Sign
1006-2	Girl's Bathroom by Art Room 199-Middle	SK	N/A		6/17/2025	-	-	-	Sign
1006-3	Girl's Bathroom by Art Room 199-Right	SK	N/A		6/17/2025	-	-	-	Sign
1007-1	Hallway by Art Room 199	WF	App		6/17/2025	-	-	-	Remove from service, sampling required before returning to service
1008-1	Art Room 199-Left	SK	N/A		6/17/2025	-	-	-	Sign
1008-2	Art Room 199-Right	SK	N/A		6/17/2025	-	-	-	Sign
1009-1	Boy's Coach's Office Bathroom-Left	SK	N/A		6/17/2025	-	-	-	Sign
1009-2	Boy's Coach's Office Bathroom-Right	SK	N/A		6/17/2025	-	-	-	Sign
1010-1	Girl's Coach's Office Bathroom	SK	N/A		6/17/2025	-	-	-	Sign
1011-1	Custodial Closet by Room 202	SS	N/A		6/17/2025	-	-	-	Sign
1012-1	Girl's Bathroom by Room 202-Left	SK	N/A		6/17/2025	-	-	-	Sign
1012-3	Girl's Bathroom by Room 202-Right	SK	N/A		6/17/2025	-	-	-	Sign
1013-1	Boy's Bathroom by Room 202-Left	SK	N/A		6/17/2025	-	-	-	Sign
1013-2	Boy's Bathroom by Room 202-Right	SK	N/A		6/17/2025	-	-	-	Sign
1014-1	Room 204	SK	N/A		6/17/2025	-	-	-	Sign
1014-2	Room 204	WF	App		6/17/2025	-	-	-	Remove from service, sampling required before returning to service
1015-1	Room 206	SK	N/A		6/17/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1015-2	Room 206	WF	App		6/17/2025	-	-	-	Remove from service, sampling required before returning to service
1016-1	Room 207	SK	N/A		6/17/2025	-	-	-	Sign
1016-2	Room 207	WF	App		6/17/2025	-	-	-	Remove from service, sampling required before returning to service
1017-1	Girl's Bathroom by Room 207 @A	SK	N/A		6/17/2025	-	-	-	Sign
1017-2	Girl's Bathroom by Room 207 @B	SK	N/A		6/17/2025	-	-	-	Sign
1017-3	Girl's Bathroom by Room 207 @C	SK	N/A		6/17/2025	-	-	-	Sign
1017-4	Girl's Bathroom by Room 207 @D	SK	N/A		6/17/2025	-	-	-	Sign
1017-5	Girl's Bathroom by Room 207 @E	SK	N/A		6/17/2025	-	-	-	Sign
1018-1	Faculty Bathroom by Room 207	SK	N/A		6/17/2025	-	-	-	Sign
1019-1	Hallway by Room 305-Left	WF	App	<1.0	6/17/2025	-	-	-	-
1019-2	Hallway by Room 305-Left	BF	App	<1.0	6/17/2025	-	-	-	-
1019-3	Hallway by Room 305-Right	WF	App	<1.0	6/17/2025	-	-	-	-
1020-1	Custodial Closet by Room 305	SS	N/A		6/17/2025	-	-	-	Sign
1021-1	Boy's Bathroom by Room 305 @A	SK	N/A		6/17/2025	-	-	-	Sign
1021-2	Boy's Bathroom by Room 305 @B	SK	N/A		6/17/2025	-	-	-	Sign
1021-3	Boy's Bathroom by Room 305 @C	SK	N/A		6/17/2025	-	-	-	Sign
1021-4	Boy's Bathroom by Room 305 @D	SK	N/A		6/17/2025	-	-	-	Sign
1021-5	Boy's Bathroom by Room 305 @E	SK	N/A		6/17/2025	-	-	-	Sign
1022-1	Room 305	SK	N/A		6/17/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1022-2	Room 305	WF	App		6/17/2025	-	-	-	Remove from service, sampling required before returning to service
1023-1	Room 306	SK	N/A		6/17/2025	-	-	-	Sign
1023-2	Room 306	WF	App		6/17/2025	-	-	-	Remove from service, sampling required before returning to service
1024-1	Room 307	SK	N/A		6/17/2025	-	-	-	Sign
1024-2	Room 307	WF	App		6/17/2025	-	-	-	Remove from service, sampling required before returning to service
1025-1	Room 308	SK	N/A		6/17/2025	-	-	-	Sign
1025-2	Room 308	WF	App		6/17/2025	-	-	-	Remove from service, sampling required before returning to service
1026-1	Room 304	SK	N/A		6/17/2025	-	-	-	Sign
1026-2	Room 304	WF	App		6/17/2025	-	-	-	Remove from service, sampling required before returning to service
1027-2	Room 303	WF	App		6/17/2025	-	-	-	Remove from service, sampling required before returning to service
1028-1	Room 302	SK	N/A		6/17/2025	-	-	-	Sign
1028-2	Room 302	WF	App		6/17/2025	-	-	-	Remove from service, sampling required before returning to service
1029-1	Room 301	SK	N/A		6/17/2025	-	-	-	Sign
1029-2	Room 301	WF	App		6/17/2025	-	-	-	Remove from service, sampling required before returning to service
1030-1	Room 205	SK	N/A		6/17/2025	-	-	-	Sign
1030-2	Room 205	WF	App		6/17/2025	-	-	-	Remove from service, sampling required before returning to service
1031-1	Room 203	SK	N/A		6/17/2025	-	-	-	Sign
1031-2	Room 203	WF	App		6/17/2025	-	-	-	Remove from service, sampling required before returning to service
1032-1	Room 202	SK	N/A		6/17/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1032-2	Room 202	WF	App		6/17/2025	-	-	-	Remove from service, sampling required before returning to service
1033-1	Room 201	SK	N/A		6/17/2025	-	-	-	Sign
1033-2	Room 201	WF	App		6/17/2025	-	-	-	Remove from service, sampling required before returning to service
1034-1	Room 109	SK	N/A		6/17/2025	-	-	-	Sign
1034-2	Room 109	WF	App		6/17/2025	-	-	-	Remove from service, sampling required before returning to service
1035-1	Room 121	SK	N/A		6/17/2025	-	-	-	Sign
1035-2	Room 121	WF	App		6/17/2025	-	-	-	Remove from service, sampling required before returning to service
1036-1	Room 122	SK	N/A		6/17/2025	-	-	-	Sign
1036-2	Room 122	WF	App		6/17/2025	-	-	-	Remove from service, sampling required before returning to service
1037-1	Room 123	SK	N/A		6/17/2025	-	-	-	Sign
1037-2	Room 123	WF	App		6/17/2025	-	-	-	Remove from service, sampling required before returning to service
1038-1	Room 124	SK	N/A		6/17/2025	-	-	-	Sign
1038-2	Room 124	WF	App		6/17/2025	-	-	-	Remove from service, sampling required before returning to service
1039-1	Room 111	SK	N/A		6/17/2025	-	-	-	Sign
1039-2	Room 111	WF	App		6/17/2025	-	-	-	Remove from service, sampling required before returning to service
1040-1	Room 115	SK	N/A		6/17/2025	-	-	-	Sign
1040-2	Room 115	WF	App		6/17/2025	-	-	-	Remove from service, sampling required before returning to service
1040-3	Room 115 Bathroom	SK	N/A		6/17/2025	-	-	-	Sign
1041-1	Room 114	SK	N/A		6/17/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1041-2	Room 114	WF	App		6/17/2025	-	-	-	Remove from service, sampling required before returning to service
1041-3	Room 114 Bathroom	SK	N/A		6/17/2025	-	-	-	Sign
1042-1	Girl's Bathroom by Room 114-Left	SK	N/A		6/17/2025	-	-	-	Sign
1042-2	Girl's Bathroom by Room 114-Right	SK	N/A		6/17/2025	-	-	-	Sign
1043-1	Boy's Bathroom by Room 114-Left	SK	N/A		6/17/2025	-	-	-	Sign
1043-2	Boy's Bathroom by Room 114-Right	SK	N/A		6/17/2025	-	-	-	Sign
1044-1	Women's Bathroom by Room 114-Left	SK	N/A		6/17/2025	-	-	-	Sign
1044-2	Women's Bathroom by Room 114-Right	SK	N/A		6/17/2025	-	-	-	Sign
1045-1	Custodial Closet by Room 113	SS	N/A		6/17/2025	-	-	-	Sign
1057-2	Hallway by Room 114	BF	App	<1.0	6/17/2025	-	-	-	-
1046-1	Room 113	SK	N/A		6/17/2025	-	-	-	Sign
1046-2	Room 113	WF	App		6/17/2025	-	-	-	Remove from service, sampling required before returning to service
1046-3	Room 113 Bathroom	SK	N/A		6/17/2025	-	-	-	Sign
1047-1	Room 112	SK	N/A		6/17/2025	-	-	-	Sign
1047-2	Room 112	WF	App		6/17/2025	-	-	-	Remove from service, sampling required before returning to service
1047-3	Room 112 Bathroom	SK	N/A		6/17/2025	-	-	-	Sign
1048-1	Room 107	SK	N/A		6/17/2025	-	-	-	Sign
1048-2	Room 107	WF	App		6/17/2025	-	-	-	Remove from service, sampling required before returning to service
1049-1	Room 110	SK	N/A		6/17/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1049-2	Room 110	WF	App		6/17/2025	-	-	-	Remove from service, sampling required before returning to service
1050-1	Room 106	SK	N/A		6/17/2025	-	-	-	Sign
1050-2	Room 106	WF	App		6/17/2025	-	-	-	Remove from service, sampling required before returning to service
1051-1	Room 105	SK	N/A		6/17/2025	-	-	-	Sign
1051-2	Room 105	WF	App		6/17/2025	-	-	-	Remove from service, sampling required before returning to service
1052-1	Room 104	SK	N/A		6/17/2025	-	-	-	Sign
1052-2	Room 104	WF	App		6/17/2025	-	-	-	Remove from service, sampling required before returning to service
1053-1	Room 108	SK	N/A		6/17/2025	-	-	-	Sign
1053-2	Room 108	WF	App		6/17/2025	-	-	-	Remove from service, sampling required before returning to service
1054-1	Room 103	SK	N/A		6/17/2025	-	-	-	Sign
1054-2	Room 103	WF	App		6/17/2025	-	-	-	Remove from service, sampling required before returning to service
1055-1	Gender Neutral Bathroom by Room 103	SK	N/A		6/17/2025	-	-	-	Sign
1056-1	Women's Bathroom by Room 103-Left	SK	N/A		6/17/2025	-	-	-	Sign
1057-1	Hallway by Speech Room 100	WF	App		6/17/2025	-	-	-	Remove from service, sampling required before returning to service
1058-1	Library Server Room	SK	N/A		6/17/2025	-	-	-	Sign
1059-1	Room 102	SK	N/A		6/17/2025	-	-	-	Sign
1059-2	Room 102	WF	App		6/17/2025	-	-	-	Remove from service, sampling required before returning to service
1060-1	Room 101	SK	N/A		6/17/2025	-	-	-	Sign
1060-2	Room 101	WF	App		6/17/2025	-	-	-	Remove from service, sampling required before returning to service

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1 st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1061-1	Principle's Office bathroom	SK	N/A		6/17/2025	-	-	-	Sign
1062-1	Main Office Kitchenette	SK	N/A		6/17/2025	-	-	-	Sign
1063-1	Nurse's Office Bathroom	SK	N/A		6/17/2025	-	-	-	Sign
1063-2	Nurse's Office Exam Room	SK	N/A		6/17/2025	-	-	-	Sign
1063-3	Nurse's Office	SK	App	<1.0	6/17/2025	-	-	-	-
1064-1	Custodial Closet by Nurse's Office	SS	N/A		6/17/2025	-	-	-	Sign
1065-1	Hallway by Nurse's Office	BF	App	<1.0	6/17/2025	-	-	-	-
1066-1	Room 116	SK	N/A		6/17/2025	-	-	-	Sign
1066-2	Room 116	WF	App		6/17/2025	-	-	-	Remove from service, sampling required before returning to service
1067-1	Room 117	SK	N/A		6/17/2025	-	-	-	Sign
1067-2	Room 117	WF	App		6/17/2025	-	-	-	Remove from service, sampling required before returning to service
1068-1	Room 118	SK	N/A		6/17/2025	-	-	-	Sign
1068-2	Room 118	WF	App		6/17/2025	-	-	-	Remove from service, sampling required before returning to service
1069-1	Room 119	SK	N/A		6/17/2025	-	-	-	Sign
1069-2	Room 119	WF	App		6/17/2025	-	-	-	Remove from service, sampling required before returning to service
1070-1	Room 120	SK	N/A		6/17/2025	-	-	-	Sign
1070-2	Room 120	WF	App		6/17/2025	-	-	-	Remove from service, sampling required before returning to service
1071-1	Boy's Bathroom by Room 120 @A	SK	N/A		6/17/2025	-	-	-	Sign
1071-2	Boy's Bathroom by Room 120 @B	SK	N/A		6/17/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1071-3	Boy's Bathroom by Room 120 @C	SK	N/A		6/17/2025	-	-	-	Sign
1071-4	Boy's Bathroom by Room 120 @D	SK	N/A		6/17/2025	-	-	-	Sign
1071-5	Boy's Bathroom by Room 120 @E	SK	N/A		6/17/2025	-	-	-	Sign
1072-1	Hallway by Room 120	WF	App		6/17/2025	-	-	-	Remove from service, sampling required before returning to service
1073-1	Girl's Bathroom by Room 120 @A	SK	N/A		6/17/2025	-	-	-	Sign
1073-2	Girl's Bathroom by Room 120 @B	SK	N/A		6/17/2025	-	-	-	Sign
1073-3	Girl's Bathroom by Room 120 @C	SK	N/A		6/17/2025	-	-	-	Sign
1073-4	Girl's Bathroom by Room 120 @D	SK	N/A		6/17/2025	-	-	-	Sign
1074-1	Faculty Room Kitchenette	SK	N/A		6/17/2025	-	-	-	Sign
1074-2	Faculty Room Kitchenette	SPY	N/A		6/17/2025	-	-	-	Sign
1075-1	Custodial Office	SS	N/A		6/17/2025	-	-	-	Sign
1075-2	Custodial Office Bathroom	SK	N/A		6/17/2025	-	-	-	Sign

Laboratory Report

NYE Report #: 2502970-33689

June 24, 2025

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Half Hollow Hills CSD; Paumanok Elementary School

Dear Project Manager,

Enclosed is the Laboratory Analytical Report for potable water sample(s) received on June 20, 2025. New York Environmental analyzed the samples on June 23, 2025 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	17 Jun 2025
Date Received:	20 Jun 2025
Date Analyzed:	23 Jun 2025

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
250620S074	1	Kitchen-2 Sink Unit- Left-SK, Initial	0.001	<0.001	mg/L	
250620S075	2	Kitchen-2 Sink Unit- Right-SK, Initial	0.001	<0.001	mg/L	
250620S076	3	Kitchen-Pot Filler-PF, Initial	0.001	<0.001	mg/L	
250620S077	4	Kitchen-Serving Area-Single Unit-SK, Initial	0.001	0.022	mg/L	H
250620S078	5	Kitchen-Prep Island-SK, Initial	0.001	0.002	mg/L	
250620S079	6	Kitchen-Pot Filler Hose by Stove-PF, Initial	0.001	0.052	mg/L	E,H
250620S080	7	Cafeteria-BF, Initial	0.001	0.001	mg/L	
250620S081	8	Cafeteria-WF, Initial	0.001	<0.001	mg/L	
250620S082	9	Hallway by Room 305-Left-BF, Initial	0.001	<0.001	mg/L	
250620S083	10	Hallway by Room 305-Left-WF, Initial	0.001	<0.001	mg/L	
250620S084	11	Hallway by Room 305-Right-WF, Initial	0.001	<0.001	mg/L	
250620S085	12	Hallway by Room 114-BF, Initial	0.001	<0.001	mg/L	
250620S086	13	Hallway by Nurse's Office-BF, Initial	0.001	<0.001	mg/L	
250620S087	14	Nurse's Office-SK, Initial	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

E: Sample result exceeds instrument calibration, value is estimated.

H: Sample result exceeds applicable regulatory limit.

Laboratory Report

August 27, 2025

Annabelle Godzieba
Enviroscience Consultants, Inc.
2150 Smithtown Ave.
Ronkonkoma, NY, 11779

Project: Half Hollow Hills
Project Address: Paumonok Elementary
Report ID: 250822021
Sample IDs: 250822021-301 - 250822021-302

New York Environmental is a NELAC accredited laboratory. Attached reported results meet the requirements of the NELAC standard unless otherwise noted.

Samples' analytical results relate only to the parameters tested for the samples received in the condition received by the laboratory, as noted on the Chain of Custody. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	22-Aug-25
Date Received:	22-Aug-25
Date Analyzed:	25-Aug-25

Analytical Method:	EPA 200.9
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
250822021-301	1	Serving area - SK, Initial	0.001	<0.001	mg/L	
250822021-302	2	PF by stove - PF, Initial	0.001	<0.001	mg/L	

Comment(s):

LOQ: Limit of Quantitation
CID: Client ID



Appendix J

Signal Hill Elementary School

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1001-1	Kitchen-Pot Filler Hose	PF	App	2.0	6/18/2025	-	-	-	-
1001-2	Kitchen-Pot Filler	SK	App	1.0	8/22/2025				Remediation complete
				6.0	6/18/2025	-	-	-	Removed From service, pending remediation
1001-3	Kitchen Bathroom-Left	SK	N/A		6/18/2025	-	-	-	Sign
1001-4	Kitchen Bathroom-Right	SK	N/A		6/18/2025	-	-	-	Sign
1001-5	Kitchen 3-Bay-Left	SK	N/A		6/18/2025	-	-	-	Sign
1001-6	Kitchen 3-Bay-Right	SK	N/A		6/18/2025	-	-	-	Sign
1001-7	Kitchen 3-Bay	SPY	N/A		6/18/2025	-	-	-	Sign
1001-8	Kitchen-Handwash	SK	N/A		6/18/2025	-	-	-	Sign
1001-9	Kitchen- Custodial Closet	SS	N/A		6/18/2025	-	-	-	Sign
1001-10	Kitchen-2 Bay	SK	App	1.0	6/18/2025	-	-	-	-
1001-11	Kitchen-Serving Area-Handwash	SK	N/A		6/18/2025	-	-	-	Sign
1002-1	Cafeteria	BF	App	<1.0	6/18/2025	-	-	-	-
1003-1	Faculty Room	SK	N/A		6/18/2025	-	-	-	Sign
1004-1	Men's Bathroom by Kitchen	SK	N/A		6/18/2025	-	-	-	Sign
1005-1	Women's Bathroom by Kitchen	SK	N/A		6/18/2025	-	-	-	Sign
1006-1	Custodial Office Bathroom	SK	N/A		6/18/2025	-	-	-	Sign
1007-1	Band Room Custodial Closet	SS	N/A		6/18/2025	-	-	-	Sign
1008-1	Coach's Office Bathroom	SK	N/A		6/18/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1009-1	Main Office Kitchenette	SK	N/A		6/18/2025	-	-	-	Sign
1010-1	Principle's Office Bathroom	SK	N/A		6/18/2025	-	-	-	Sign
1011-1	Hallway by Nurse's Office	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1012-1	Nurse's Office	SK	App	4.0	6/18/2025	-	-	-	-
1012-2	Nurse's Office Bathroom	SK	N/A		6/18/2025	-	-	-	Sign
1013-1	Room 201 Coach's Office Bathroom	SK	N/A		6/18/2025	-	-	-	Sign
1014-1	Room 201 Bathroom	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1014-2	Room 201 Bathroom-Left	SK	N/A		6/18/2025	-	-	-	Sign
1014-3	Room 201 Bathroom-Right	SK	N/A		6/18/2025	-	-	-	Sign
1015-1	Room 203	SK	N/A		6/18/2025	-	-	-	Sign
1016-1	Room 206	SK	N/A		6/18/2025	-	-	-	Sign
1016-2	Room 206	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1017-2	Room 208	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1018-1	Room 210	SK	N/A		6/18/2025	-	-	-	Sign
1018-2	Room 210	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1019-1	Room 211	SK	N/A		6/18/2025	-	-	-	Sign
1019-2	Room 211	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1020-1	Room 209	SK	N/A		6/18/2025	-	-	-	Sign
1020-2	Room 209	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1021-1	Room 207	SK	N/A		6/18/2025	-	-	-	Sign
1021-2	Room 207	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1022-1	Room 205	SK	N/A		6/18/2025	-	-	-	Sign
1022-2	Room 205	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1023-1	Room 204	SK	N/A		6/18/2025	-	-	-	Sign
1023-2	Room 204	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1024-1	Room 202	SK	N/A		6/18/2025	-	-	-	Sign
1024-2	Room 202	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1025-1	Boy's Bathroom by Room 201 @A	SK	N/A		6/18/2025	-	-	-	Sign
1025-2	Boy's Bathroom by Room 201 @B	SK	N/A		6/18/2025	-	-	-	Sign
1025-3	Boy's Bathroom by Room 201 @C	SK	N/A		6/18/2025	-	-	-	Sign
1025-4	Boy's Bathroom by Room 201 @D	SK	N/A		6/18/2025	-	-	-	Sign
1026-1	Custodial Closet by Room 201	SK	N/A		6/18/2025	-	-	-	Sign
1027-1	Girl's Bathroom by Room 201 @A	SK	N/A		6/18/2025	-	-	-	Sign
1027-2	Girl's Bathroom by Room 201 @B	SK	N/A		6/18/2025	-	-	-	Sign
1027-3	Girl's Bathroom by Room 201 @C	SK	N/A		6/18/2025	-	-	-	Sign
1027-4	Girl's Bathroom by Room 201 @D	SK	N/A		6/18/2025	-	-	-	Sign
1028-1	Hallway by Gym	BF	App	<1.0	6/18/2025	-	-	-	-
1029-1	Library	SK	N/A		6/18/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1030-1	Girl's Bathroom by Room 109 @A	SK	N/A		6/18/2025	-	-	-	Sign
1030-2	Girl's Bathroom by Room 109 @B	SK	N/A		6/18/2025	-	-	-	Sign
1030-3	Girl's Bathroom by Room 109 @C	SK	N/A		6/18/2025	-	-	-	Sign
1031-1	Faculty Bathroom by Room 109	SK	N/A		6/18/2025	-	-	-	Sign
1032-1	Custodial Closet by Room 110	SS	N/A		6/18/2025	-	-	-	Sign
1033-1	Boy's Bathroom by Room 110 @A	SK	N/A		6/18/2025	-	-	-	Sign
1033-2	Boy's Bathroom by Room 110 @B	SK	N/A		6/18/2025	-	-	-	Sign
1033-3	Boy's Bathroom by Room 110 @C	SK	N/A		6/18/2025	-	-	-	Sign
1035-1	Room 111	SK	N/A		6/18/2025	-	-	-	Sign
1035-2	Room 111	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1036-1	Room 114	SK	N/A		6/18/2025	-	-	-	Sign
1036-2	Room 114	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1037-1	Room 116	SK	N/A		6/18/2025	-	-	-	Sign
1037-2	Room 116	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1038-1	Room 118	SK	N/A		6/18/2025	-	-	-	Sign
1038-2	Room 118	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1039-1	Room 119	SK	N/A		6/18/2025	-	-	-	Sign
1039-2	Room 119	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1040-1	Room 121	SK	N/A		6/18/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1 st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1040-2	Room 121	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1041-1	Girl's Bathroom by Room 122 @A	SK	N/A		6/18/2025	-	-	-	Sign
1041-2	Girl's Bathroom by Room 122 @B	SK	N/A		6/18/2025	-	-	-	Sign
1041-3	Girl's Bathroom by Room 122 @C	SK	N/A		6/18/2025	-	-	-	Sign
1041-4	Girl's Bathroom by Room 122 @D	SK	N/A		6/18/2025	-	-	-	Sign
1041-5	Girl's Bathroom by Room 122 @E	SK	N/A		6/18/2025	-	-	-	Sign
1042-1	Faculty Bathroom by Room 122	SK	N/A		6/18/2025	-	-	-	Sign
1043-1	Hallway by Room 122-Left	WF	App	<1.0	6/18/2025	-	-	-	
1043-2	Hallway by Room 122-Left	BF	App	<1.0	6/18/2025	-	-	-	-
1043-3	Hallway by Room 122-Right	WF	App	<1.0	6/18/2025	-	-	-	
1044-1	Custodial Closet by Room 122	SS	N/A		6/18/2025	-	-	-	Sign
1045-1	Boy's Bathroom by Room 123 @A	SK	N/A		6/18/2025	-	-	-	Sign
1045-2	Boy's Bathroom by Room 123 @B	SK	N/A		6/18/2025	-	-	-	Sign
1045-3	Boy's Bathroom by Room 123 @C	SK	N/A		6/18/2025	-	-	-	Sign
1045-4	Boy's Bathroom by Room 123 @D	SK	N/A		6/18/2025	-	-	-	Sign
1045-5	Boy's Bathroom by Room 123 @E	SK	N/A		6/18/2025	-	-	-	Sign
1046-1	Room 123	SK	N/A		6/18/2025	-	-	-	Sign
1046-2	Room 123	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1047-1	Room 125	SK	N/A		6/18/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1 st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1047-2	Room 125	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1048-1	Room 126	SK	N/A		6/18/2025	-	-	-	Sign
1048-2	Room 126	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1049-1	Room 124	SK	N/A		6/18/2025	-	-	-	Sign
1049-2	Room 124	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1050-1	Room 122	SK	N/A		6/18/2025	-	-	-	Sign
1050-2	Room 122	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1051-1	Room 120	SK	N/A		6/18/2025	-	-	-	Sign
1051-2	Room 120	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1052-1	Room 117	SK	N/A		6/18/2025	-	-	-	Sign
1052-2	Room 117	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1053-1	Room 115	SK	N/A		6/18/2025	-	-	-	Sign
1053-2	Room 115	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1054-1	Room 113	SK	N/A		6/18/2025	-	-	-	Sign
1054-2	Room 113	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1055-1	Room 112	SK	N/A		6/18/2025	-	-	-	Sign
1055-2	Room 112	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1056-1	Room 110	SK	N/A		6/18/2025	-	-	-	Sign
1056-2	Room 110	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1057-1	Room 109	SK	N/A		6/18/2025	-	-	-	Sign
1057-2	Room 109	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1058-1	Room 108A	SK	N/A		6/18/2025	-	-	-	Sign
1058-2	Room 108A	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1059-1	Room 106	SK	N/A		6/18/2025	-	-	-	Sign
1059-2	Room 106	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1060-1	Custodial Closet by Room 104	SS	N/A		6/18/2025	-	-	-	Sign
1061-1	Room 104 Bathroom	SK	N/A		6/18/2025	-	-	-	Sign
1061-2	Room 104	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1061-3	Room 104	SK	N/A		6/18/2025	-	-	-	Sign
1062-1	Hallway by Room 104	WF	N/A		6/18/2025	-	-	-	Sign
1062-1	Hallway by Room 104	BF	App	<1.0	6/18/2025	-	-	-	-
1063-2	Room 105	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1064-1	Room 107	SK	N/A		6/18/2025	-	-	-	Sign
1064-2	Room 107	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1065-1	Room 103 Bathroom	SK	N/A		6/18/2025	-	-	-	Sign
1065-2	Room 103	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1065-3	Room 103	SK	N/A		6/18/2025	-	-	-	Sign
1066-1	Room 102	SK	N/A		6/18/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1066-2	Room 102 Bathroom	SK	N/A		6/18/2025	-	-	-	Sign
1066-3	Room 102	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1067-1	Room 101	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1067-2	Room 101 Bathroom	SK	N/A		6/18/2025	-	-	-	Sign
1067-3	Room 101	SK	N/A		6/18/2025	-	-	-	Sign

Laboratory Report

NYE Report #: 2502962-33683

June 23, 2025

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Half Hollow Hills CSD; Signal Hill Elementary School

Dear Project Manager,

Enclosed is the Laboratory Analytical Report for potable water sample(s) received on June 20, 2025. New York Environmental analyzed the samples on June 23, 2025 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	18 Jun 2025
Date Received:	20 Jun 2025
Date Analyzed:	23 Jun 2025

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
250620R001	1	Kitchen-Pot Filler Hose-PF, Initial	0.001	0.002	mg/L	
250620R002	2	Kitchen-Pot Filler-SK, Initial	0.001	0.006	mg/L	H
250620R003	3	Kitchen-2 Bay-SK, Initial	0.001	0.001	mg/L	
250620R004	4	Cafeteria-BF, Initial	0.001	<0.001	mg/L	
250620R005	5	Nurse's Office-SK, Initial	0.001	0.004	mg/L	
250620R006	6	Hallway by Gym-BF, Initial	0.001	<0.001	mg/L	
250620R007	7	Hallway by Room 104-BF, Initial	0.001	<0.001	mg/L	
250620R008	8	Hallway by Room 122-Left-BF, Initial	0.001	<0.001	mg/L	
250620R009	9	Hallway by Room 122-Left-WF, Initial	0.001	<0.001	mg/L	
250620R010	10	Hallway by Room 122-Right-WF, Initial	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

H: Sample result exceeds applicable regulatory limit.

Laboratory Report

August 26, 2025

Pam Chadderton
Enviroscience Consultants, Inc.
2150 Smithtown Ave.
Ronkonkoma, NY, 11779


Project: Half Hollow Hills
Project Address: Signal Elementary
Report ID: 250822019
Sample IDs: 250822019-292 - 250822019-294

New York Environmental is a NELAC accredited laboratory. Attached reported results meet the requirements of the NELAC standard unless otherwise noted.

Samples' analytical results relate only to the parameters tested for the samples received in the condition received by the laboratory, as noted on the Chain of Custody. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	22-Aug-25
Date Received:	22-Aug-25
Date Analyzed:	25-Aug-25

Analytical Method:	EPA 200.9
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
250822019-292	1	Kitchen pot filler - PF, Initial	0.001	0.001	mg/L	
250822019-293	2	Kitchen pot filler - PF, 15 Second Flush	0.001	N/A	mg/L	
250822019-294	3	Kitchen pot filler - PF, 60 Second Flush	0.001	N/A	mg/L	

Comment(s):

LOQ: Limit of Quantitation

CID: Client ID

NA: Samples not analyzed as per customer request.



Appendix K

Vanderbilt Elementary School

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1001-1	Kitchen canwash closet	SS	N/A		6/18/2025	-	-	-	Sign
1001-2	Kitchen 2-bay prep @ A	SK	App	2.0	8/22/2025				Remediation complete
				180.0	6/18/2025	-	-	-	Removed From Services; Pending Remediation
1001-3	Kitchen 2-bay prep @ B	SK	App	2.0	8/22/2025				-
				5.0	6/18/2025	-	-	-	-
1001-4	Kitchen handwash @ A	SK	N/A		6/18/2025	-	-	-	Sign
1001-5	Kitchen sanitizer station @ A	SK	N/A		6/18/2025	-	-	-	Sign
1001-6	Kitchen sanitizer station @ B	SK	N/A		6/18/2025	-	-	-	Sign
1001-7	Kitchen sanitizer station	SPY	N/A		6/18/2025	-	-	-	Sign
1001-8	Kitchen sanitizer station @ C	SK	N/A		6/18/2025	-	-	-	Sign
1001-9	Kitchen pot filler	PF	App	1.0	6/18/2025	-	-	-	-
1001-10	Kitchen handwash @ B	SK	App	1.0	6/18/2025	-	-	-	-
1001-11	Kitchen Island	SK	N/A		6/18/2025	-	-	-	Sign
1001-12	Kitchen bathroom	SK	N/A		6/18/2025	-	-	-	Sign
1002-1	Cafeteria	WF	App	<1.0	6/18/2025	-	-	-	-
1002-2	Cafeteria	BF	App	<1.0	6/18/2025	-	-	-	-
1003-1	Custodial office closet	SS	N/A		6/18/2025	-	-	-	Sign
1003-2	Custodial office bathroom	SK	N/A		6/18/2025	-	-	-	Sign
1004-1	Men faculty bathroom by Room 201	SK	N/A		6/18/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1005-1	Women faculty bathroom by Room 201	SK	N/A		6/18/2025	-	-	-	Sign
1006-1	Boys bathroom by Room 201 @ A	SK	N/A		6/18/2025	-	-	-	Sign
1006-2	Boys bathroom by Room 201 @ B	SK	N/A		6/18/2025	-	-	-	Sign
1007-1	Hallway by Room 201	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1008-1	Girls bathroom by Room 201 @ A	SK	N/A		6/18/2025	-	-	-	Sign
1008-2	Girls bathroom by Room 201 @ B	SK	N/A		6/18/2025	-	-	-	Sign
1008-3	Girls bathroom by Room 201 @ C	SK	N/A		6/18/2025	-	-	-	Sign
1009-1	Room 201	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1009-2	Room 201	SK	N/A		6/18/2025	-	-	-	Sign
1010-1	Physical Education office bathroom @ A	SK	N/A		6/18/2025	-	-	-	Sign
1010-2	Physical Education office bathroom @ B	SK	N/A		6/18/2025	-	-	-	Sign
1011-1	Band & Orchestra office bathroom	SK	N/A		6/18/2025	-	-	-	Sign
1012-1	Room 205	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1013-1	Room 210	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1013-2	Room 210	SK	N/A		6/18/2025	-	-	-	Sign
1014-1	Room 206	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1014-2	Room 206	SK	N/A		6/18/2025	-	-	-	Sign
1015-1	Room 209	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1015-2	Room 209	SK	N/A		6/18/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1016-1	Room 208	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1016-2	Room 208	SK	N/A		6/18/2025	-	-	-	Sign
1017-1	Room 207	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1017-2	Room 207	SK	N/A		6/18/2025	-	-	-	Sign
1018-1	Custodial closet by Room 210	SS	N/A		6/18/2025	-	-	-	Sign
1019-1	Printer room by Room 210	SK	N/A		6/18/2025	-	-	-	Sign
1020-1	Girls bathroom by Room 301 @ A	SK	N/A		6/18/2025	-	-	-	Sign
1020-2	Girls bathroom by Room 301 @ B	SK	N/A		6/18/2025	-	-	-	Sign
1020-3	Girls bathroom by Room 301 @ C	SK	N/A		6/18/2025	-	-	-	Sign
1020-4	Girls bathroom by Room 301 @ D	SK	N/A		6/18/2025	-	-	-	Sign
1020-5	Girls bathroom by Room 301 @ E	SK	N/A		6/18/2025	-	-	-	Sign
1021-1	Faculty unisex bathroom by Room 301	SK	N/A		6/18/2025	-	-	-	Sign
1022-1	Hallway by Room 301 (left)	WF	App	<1.0	6/18/2025	-	-	-	-
1022-2	Hallway by Room 301 (right)	BF	App	<1.0	6/18/2025	-	-	-	-
1022-3	Hallway by Room 301 (right)	WF	App	<1.0	6/18/2025	-	-	-	-
1023-1	Custodial closet by Room 301	SS	N/A		6/18/2025	-	-	-	Sign
1024-1	Boys bathroom by Room 301 @ A	SK	N/A		6/18/2025	-	-	-	Sign
1024-2	Boys bathroom by Room 301 @ B	SK	N/A		6/18/2025	-	-	-	Sign
1024-3	Boys bathroom by Room 301 @ C	SK	N/A		6/18/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1024-4	Boys bathroom by Room 301 @ D	SK	N/A		6/18/2025	-	-	-	Sign
1024-5	Boys bathroom by Room 301 @ E	SK	N/A		6/18/2025	-	-	-	Sign
1025-1	Room 301	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1025-2	Room 301	SK	N/A		6/18/2025	-	-	-	Sign
1026-1	Room 302	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1026-2	Room 302	SK	N/A		6/18/2025	-	-	-	Sign
1027-1	Room 303	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1027-2	Room 303	SK	N/A		6/18/2025	-	-	-	Sign
1028-1	Room 304	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1029-1	Room 202	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1029-2	Room 202	SK	N/A		6/18/2025	-	-	-	Sign
1030-1	Faculty room	SK	N/A		6/18/2025	-	-	-	Sign
1031-1	Room 123	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1031-2	Room 123	SK	N/A		6/18/2025	-	-	-	Sign
1032-1	Room 124	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1032-2	Room 124	SK	N/A		6/18/2025	-	-	-	Sign
1033-1	Custodial closet by Room 124	SS	N/A		6/18/2025	-	-	-	Sign
1034-1	Hallway by Nurse's office	BF	App	<1.0	6/18/2025	-	-	-	-
1035-1	Nurse's office	SK	N/A		6/18/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1035-2	Nurse's office bathroom	SK	N/A		6/18/2025	-	-	-	Sign
1036-1	Main office kitchenett	SK	N/A		6/18/2025	-	-	-	Sign
1037-1	Principal's office bathroom	SK	N/A		6/18/2025	-	-	-	Sign
1038-1	Room 101	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1038-2	Room 101	SK	N/A		6/18/2025	-	-	-	Sign
1039-1	Room 102	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1039-2	Room 102	SK	N/A		6/18/2025	-	-	-	Sign
1040-1	Hallway by Room 103	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1041-1	Room 103	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1041-2	Room 103	SK	N/A		6/18/2025	-	-	-	Sign
1042-1	Men faculty bathroom by Room 103	SK	N/A		6/18/2025	-	-	-	Sign
1043-1	Women faculty bathroom by Room 103 @ A	SK	N/A		6/18/2025	-	-	-	Sign
1043-2	Women faculty bathroom by Room 103 @ B	SK	N/A		6/18/2025	-	-	-	Sign
1044-1	Room 109	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1044-2	Room 109	SK	N/A		6/18/2025	-	-	-	Sign
1045-1	Room 104	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1045-2	Room 104	SK	N/A		6/18/2025	-	-	-	Sign
1046-1	Room 105	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1046-2	Room 105	SK	N/A		6/18/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1047-1	Room 106	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1047-2	Room 106	SK	N/A		6/18/2025	-	-	-	Sign
1048-1	Room 107	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1048-2	Room 107	SK	N/A		6/18/2025	-	-	-	Sign
1049-1	Room 110	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1049-2	Room 110	SK	N/A		6/18/2025	-	-	-	Sign
1050-1	Room 112	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1050-2	Room 112	SK	N/A		6/18/2025	-	-	-	Sign
1050-3	Room 112 bathroom	SK	N/A		6/18/2025	-	-	-	Sign
1051-1	Room 113	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1051-2	Room 113	SK	N/A		6/18/2025	-	-	-	Sign
1051-3	Room 113 bathroom	SK	N/A		6/18/2025	-	-	-	Sign
1052-1	Custodial closet by Room 113	SS	N/A		6/18/2025	-	-	-	Sign
1053-1	Hallway by Room 113	WF	N/A		6/18/2025	-	-	-	Sign
1053-1	Hallway by Room 113	BF	App	<1.0	6/18/2025	-	-	-	-
1054-1	Women faculty bathroom by Room 113 @ A	SK	N/A		6/18/2025	-	-	-	Sign
1054-2	Women faculty bathroom by Room 113 @ B	SK	N/A		6/18/2025	-	-	-	Sign
1055-1	Boys bathroom by Room 113 @ A	SK	N/A		6/18/2025	-	-	-	Sign
1055-2	Boys bathroom by Room 113 @ B	SK	N/A		6/18/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1056-1	Girls bathroom by Room 114 @ A	SK	N/A		6/18/2025	-	-	-	Sign
1056-2	Girls bathroom by Room 114 @ B	SK	N/A		6/18/2025	-	-	-	Sign
1057-1	Room 114	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1057-2	Room 114	SK	N/A		6/18/2025	-	-	-	Sign
1057-3	Room 114 bathroom	SK	N/A		6/18/2025	-	-	-	Sign
1058-1	Room 115	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1058-2	Room 115	SK	N/A		6/18/2025	-	-	-	Sign
1058-3	Room 115 bathroom	SK	N/A		6/18/2025	-	-	-	Sign
1059-1	Room 111 unit @ A	SK	N/A		6/18/2025	-	-	-	Sign
1059-2	Room 111 unit @ B	SK	N/A		6/18/2025	-	-	-	Sign
1059-3	Room 111 unit @ C	SK	N/A		6/18/2025	-	-	-	Sign
1059-4	Room 111 unit @ D	SK	N/A		6/18/2025	-	-	-	Sign
1059-5	Room 111 unit @ E	SK	N/A		6/18/2025	-	-	-	Sign
1060-1	Room 116	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1060-2	Room 116	SK	N/A		6/18/2025	-	-	-	Sign
1061-1	Room 117	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1061-2	Room 117	SK	N/A		6/18/2025	-	-	-	Sign
1062-1	Room 118	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1062-2	Room 118	SK	N/A		6/18/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1063-1	Room 119	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1063-2	Room 119	SK	N/A		6/18/2025	-	-	-	Sign
1064-1	Girls bathroom by Room 120 @ A	SK	N/A		6/18/2025	-	-	-	Sign
1064-2	Girls bathroom by Room 120 @ B	SK	N/A		6/18/2025	-	-	-	Sign
1064-3	Girls bathroom by Room 120 @ C	SK	N/A		6/18/2025	-	-	-	Sign
1065-1	Hallway by Room 120	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1066-1	Boys bathroom by Room 120 @ A	SK	N/A		6/18/2025	-	-	-	Sign
1066-2	Boys bathroom by Room 120 @ B	SK	N/A		6/18/2025	-	-	-	Sign
1066-3	Boys bathroom by Room 120 @ C	SK	N/A		6/18/2025	-	-	-	Sign
1066-4	Boys bathroom by Room 120 @ D	SK	N/A		6/18/2025	-	-	-	Sign
1067-1	Room 120	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1067-2	Room 120	SK	N/A		6/18/2025	-	-	-	Sign
1068-1	Room 121	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1068-2	Room 121	SK	N/A		6/18/2025	-	-	-	Sign
1069-1	Room 122	WF	App		6/18/2025	-	-	-	Removed from service, sampling required before returning to service
1069-2	Room 122	SK	N/A		6/18/2025	-	-	-	Sign

Laboratory Report

NYE Report #: 2502965-33684

June 23, 2025

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Half Hollow Hills CSD; Vanderbilt Elementary School

Dear Project Manager,

Enclosed is the Laboratory Analytical Report for potable water sample(s) received on June 20, 2025. New York Environmental analyzed the samples on June 23, 2025 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	18 Jun 2025
Date Received:	20 Jun 2025
Date Analyzed:	23 Jun 2025

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
250620R011	1	Kitchen 2-bay prep @ A-SK, Initial	0.001	0.180	mg/L	E,H
250620R012	2	Kitchen 2-bay prep @ B-SK, Initial	0.001	0.005	mg/L	
250620R013	3	Kitchen pot filler-PF, Initial	0.001	0.001	mg/L	
250620R014	4	Kitchen handwash @ B-SK, Initial	0.001	0.001	mg/L	
250620R015	5	Cafeteria-BF, Initial	0.001	<0.001	mg/L	
250620R016	6	Cafeteria-WF, Initial	0.001	<0.001	mg/L	
250620R017	7	Hallway by Room 301 (left)-WF, Initial	0.001	<0.001	mg/L	
250620R018	8	Hallway by Room 301 (right)-BF, Initial	0.001	<0.001	mg/L	
250620R019	9	Hallway by Room 301 (right)-WF, Initial	0.001	<0.001	mg/L	
250620R020	10	Hallway by Room 113-BF, Initial	0.001	<0.001	mg/L	
250620R021	11	Hallway by Nurse's office-BF, Initial	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

E: Sample result exceeds instrument calibration, value is estimated.

H: Sample result exceeds applicable regulatory limit.

Laboratory Report

August 26, 2025

Pam Chadderton
Enviroscience Consultants, Inc.
2150 Smithtown Ave.
Ronkonkoma, NY, 11779


Project: Half Hollow Hills
Project Address: Vanderbilt
Report ID: 250822020
Sample IDs: 250822020-297 - 250822020-298

New York Environmental is a NELAC accredited laboratory. Attached reported results meet the requirements of the NELAC standard unless otherwise noted.

Samples' analytical results relate only to the parameters tested for the samples received in the condition received by the laboratory, as noted on the Chain of Custody. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	22-Aug-25
Date Received:	22-Aug-25
Date Analyzed:	25-Aug-25

Analytical Method:	EPA 200.9
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
250822020-297	1	2 Bay Left - SK, Initial	0.001	0.002	mg/L	
250822020-298	2	2 Bay Right - SK, initial	0.001	0.002	mg/L	

Comment(s):

LOQ: Limit of Quantitation

CID: Client ID



Appendix L

Fran Greenspan Administration Building

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1001-1	Lounge (left)	SK	N/A		6/17/2025	-	-	-	Sign
1001-2	Lounge (right)	SK	N/A		6/17/2025	-	-	-	Sign
1001-3	Lounge Ice Machine	IM	N/A		6/17/2025	-	-	-	Removed
1002-1	Mail Room Office Kitchenette	SK	App	20.0	6/17/2025	-	-	-	Removed from service, pending remediation
1002-2	Mail Room Office Kitchenette	SPY	App	6.0	6/17/2025	-	-	-	Removed from service, pending remediation
1003-1	Office Kitchenette	SK	N/A		6/17/2025	-	-	-	Sign
1003-2	Office Kitchenette	SPY	N/A		6/17/2025	-	-	-	Sign
1004-1	Custodial Closet by Lounge	SK	N/A		6/17/2025	-	-	-	Sign
1005-1	Lounge Bathroom (left)	SK	N/A		6/17/2025	-	-	-	Sign
1005-2	Lounge Bathroom (right)	SK	N/A		6/17/2025	-	-	-	Sign
1006-1	Custodial Office Toilet	SK	N/A		6/17/2025	-	-	-	Sign
1006-2	Custodial Office Toilet	SS	N/A		6/17/2025	-	-	-	Sign
1007-1	Hall by Conference Room	WF	App	<1.0	6/17/2025	-	-	-	-
1007-2	Hall by Conference Room	BF	App	<1.0	6/17/2025	-	-	-	-
1008-1	Conference Room Bathroom	SK	N/A		6/17/2025	-	-	-	Sign
1009-1	Superintendent's Office Bathroom	SK	N/A		6/17/2025	-	-	-	Sign
1010-1	Main Office Kitchenette	SK	N/A		6/17/2025	-	-	-	Sign
1010-2	Main Office Kitchenette	SPY	N/A		6/17/2025	-	-	-	Sign
1011-1	Hall by Room 102	WF	App	<1.0	6/17/2025	-	-	-	-

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1011-2	Hall by Room 102	BF	App	<1.0	6/17/2025	-	-	-	-
1012-1	Office 102 Kitchenette	SK	N/A		6/17/2025	-	-	-	Sign
1012-2	Office 102 Kitchenette	SPY	N/A		6/17/2025	-	-	-	Sign
1013-1	Office 104 Kitchenette	SK	N/A		6/17/2025	-	-	-	Sign
1014-1	D.W.A. Office Kitchenette	SK	N/A		6/17/2025	-	-	-	Sign
1014-2	D.W.A. Office Kitchenette	SPY	N/A		6/17/2025	-	-	-	Sign
1014-3	D.W.A. Office Kitchenette Bathroom	SK	N/A		6/17/2025	-	-	-	Sign
1015-1	Assistant Superintendant's Office Bathroom	SK	N/A		6/17/2025	-	-	-	Sign
1016-1	Secretary's Office Kitchenette	SK	N/A		6/17/2025	-	-	-	Sign
1017-1	M.I.S Secretary's Office Kitchenette	SK	N/A		6/17/2025	-	-	-	Sign
1017-2	M.I.S Secretary's Office Kitchenette	SPY	N/A		6/17/2025	-	-	-	Sign
1018-2	Women's Bathroom by Room 106 @ B	SK	N/A		6/17/2025	-	-	-	Sign
1018-3	Women's Bathroom by Room 106 @ C	SK	N/A		6/17/2025	-	-	-	Sign
1019-1	Hall by Room 106	WF	N/A		6/17/2025	-	-	-	Removed from service, sampling required before returning to service
1020-1	Custodial Closet by Room 106	SK	N/A		6/17/2025	-	-	-	Sign
1021-1	Men's Bathroom by Room 106 @ A	SK	N/A		6/17/2025	-	-	-	Sign
1021-2	Men's Bathroom by Room 106 @ B	SK	N/A		6/17/2025	-	-	-	Sign
1021-3	Men's Bathroom by Room 106 @ C	SK	N/A		6/17/2025	-	-	-	Sign
1022-1	Room 107 Kitchenette	SK	N/A		6/17/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1023-1	Room 108 Kitchenette	SK	N/A		6/17/2025	-	-	-	Sign
1024-1	Room 111 Kitchenette	SK	N/A		6/17/2025	-	-	-	Sign
1025-1	Boardroom Kitchenette	SK	N/A		6/17/2025	-	-	-	Sign
1026-1	Unisex Faculty Bathroom	SK	N/A		6/17/2025	-	-	-	Sign
1027-1	Women's Bathroom by Board Room @ A	SK	N/A		6/17/2025	-	-	-	Sign
1027-2	Women's Bathroom by Board Room @ B	SK	N/A		6/17/2025	-	-	-	Sign
1027-3	Women's Bathroom by Board Room @ C	SK	N/A		6/17/2025	-	-	-	Sign
1027-4	Women's Bathroom by Board Room @ D	SK	N/A		6/17/2025	-	-	-	Sign
1028-1	Custodial Closet by Board Room	SK	N/A		6/17/2025	-	-	-	Sign
1029-1	Men's Bathroom by Board Room @ A	SK	N/A		6/17/2025	-	-	-	Sign
1029-2	Men's Bathroom by Board Room @ B	SK	N/A		6/17/2025	-	-	-	Sign
1029-3	Men's Bathroom by Board Room @ C	SK	N/A		6/17/2025	-	-	-	Sign
1030-1	Office Bathroom by Gym	SK	N/A		6/17/2025	-	-	-	Sign
1031-1	Room 203 Kitchenette	SK	N/A		6/17/2025	-	-	-	Sign
1032-1	Hall by Room 204	WF	App	<1.0	6/17/2025	-	-	-	-
1032-2	Hall by Room 204	BF	App	<1.0	6/17/2025	-	-	-	-
1033-1	Room 211 Kitchenette	SK	N/A		6/17/2025	-	-	-	Sign

Laboratory Report

NYE Report #: 2502972-33691

June 24, 2025

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Half Hollow Hills CSD; Fran Greenspan Administration Building

Dear Project Manager,

Enclosed is the Laboratory Analytical Report for potable water sample(s) received on June 20, 2025. New York Environmental analyzed the samples on June 23, 2025 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	17 Jun 2025
Date Received:	20 Jun 2025
Date Analyzed:	23 Jun 2025

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
250620S120	1	Mail Room Office Kitchenette-SK, Initial	0.001	0.020	mg/L	H
250620S121	2	Mail Room Office Kitchenette-SPY, Initial	0.001	0.006	mg/L	H
250620S122	3	Hall by Conference Room-BF, Initial	0.001	<0.001	mg/L	
250620S123	4	Hall by Conference Room-WF, Initial	0.001	<0.001	mg/L	
250620S124	5	Hall by Room 204-BF, Initial	0.001	<0.001	mg/L	
250620S125	6	Hall by Room 204-WF, Initial	0.001	<0.001	mg/L	
250620S126	7	Hall by Room 102-BF, Initial	0.001	<0.001	mg/L	
250620S127	8	Hall by Room 102-WF, Initial	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

H: Sample result exceeds applicable regulatory limit.

Appendix M

Half Hollow Hills Natatorium Transportation Garage Facilities Building

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1001-1	Lobby	WF	App	<1.0	6/7/2025	-	-	-	-
1001-2	Lobby	BF	App	<1.0	6/7/2025	-	-	-	-
1002-1	Pool (Near Girl's Locker Room)	WF	App		6/7/2025	-	-	-	Removed from service, sampling required before returning to service
1003-2	Pool (Near Boy's Locker Room)	WF	App		6/7/2025	-	-	-	Removed from service, sampling required before returning to service
1004-1	Women's Bathroom (left)	SK	N/A		6/7/2025	-	-	-	Sign
1004-2	Women's Bathroom (right)	SK	N/A		6/7/2025	-	-	-	Sign
1005-1	Girl's Locker Room Bathroom (left)	SK	N/A		6/7/2025	-	-	-	Sign
1005-2	Girl's Locker Room Bathroom (right)	SK	N/A		6/7/2025	-	-	-	Sign
1006-1	Men's Bathroom (left)	SK	N/A		6/7/2025	-	-	-	Sign
1006-2	Men's Bathroom (right)	SK	N/A		6/7/2025	-	-	-	Sign
1007-1	Boy's Locker Room (left)	SK	N/A		6/7/2025	-	-	-	Sign
1007-2	Boy's Locker Room (right)	SK	N/A		6/7/2025	-	-	-	Sign
1008-1	Girl's Coach's Office Bathroom	SK	N/A		6/7/2025	-	-	-	Sign
1009-1	Boy's Coach's Office Bathroom	SK	N/A		6/7/2025	-	-	-	Sign
1010-1	Pump Room	SS	N/A		6/7/2025	-	-	-	Sign

Laboratory Report

NYE Report #: 2502826-33596

June 13, 2025

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Half Hollow Hills Csd; Half Hollow Hills Natatorium

Dear Project Manager,

Enclosed is the Laboratory Analytical Report for potable water sample(s) received on June 12, 2025. New York Environmental analyzed the samples on June 13, 2025 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	07 Jun 2025
Date Received:	12 Jun 2025
Date Analyzed:	13 Jun 2025

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
250612Q119	1	Lobby - WF, Initial	0.001	<0.001	mg/L	
250612Q120	2	Lobby - BF, Initial	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
Transportation Garage									
1001-1	Driver's Lounge	WF	App	<1.0		-	-	-	
1001-1	Driver's Lounge	BF	App	<1.0		-	-	-	
1002-1	Men's Bathroom (left)	SK	N/A			-	-	-	Sign
1002-2	Men's Bathroom (right)	SK	N/A			-	-	-	Sign
1003-1	Custodial Closet	SS	N/A			-	-	-	Sign
1004-1	Women's Bathroom (left)	SK	N/A			-	-	-	Sign
1004-2	Women's Bathroom (right)	SK	N/A			-	-	-	Sign
1005-1	Secretary's Office Bathroom	SK	N/A			-	-	-	Sign
1006-1	Kitchenette	SK	N/A			-	-	-	Sign
1007-1	Maintenance Area	SK	N/A			-	-	-	Sign
Facilities Building									
1001-1	Maintenance Shop	SS	N/A			-	-	-	Sign
1001-2	Maintenance Shop	WF	App	<1.0		-	-	-	
1001-3	Maintenance Shop	BF	App	<1.0		-	-	-	
1001-4	Maintenance Shop	IM	App			-	-	-	Removed from service, sampling required before returning to service
1002-1	Unisex Locker Room Bathroom	SK	N/A			-	-	-	Sign
1003-1	Men's Locker Room Bathroom	SK	N/A			-	-	-	Sign
1004-1	Electrical/Custodial Closet	SS	N/A			-	-	-	Sign

Laboratory Report

NYE Report #: 2503037-33737

June 27, 2025

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Half Hollow Hills Csd; Transportation Garage

Dear Project Manager,

Enclosed is the Laboratory Analytical Report for potable water sample(s) received on June 27, 2025. New York Environmental analyzed the samples on June 27, 2025 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	20 Jun 2025
Date Received:	27 Jun 2025
Date Analyzed:	27 Jun 2025

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
250627N003	1	Transportation Garage - BF, Initial	0.001	<0.001	mg/L	
250627N004	2	Transportation Garage - WF, Initial	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

Laboratory Report

NYE Report #: 2503036-33736

June 27, 2025

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Half Hollow Hills Csd; Facilities Building

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on June 27, 2025. New York Environmental analyzed the samples on June 27, 2025 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	20 Jun 2025
Date Received:	27 Jun 2025
Date Analyzed:	27 Jun 2025

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
250627N001	1	Facilities Building - BF, Initial	0.001	<0.001	mg/L	
250627N002	2	Facilities Building - WF, Initial	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation