



2024 Water Testing Remediation Plan-last updated 6/11/25

CT	104.5-38	Nurse Office Lav	Sink	8.2	6/6/24	8/15/24	n/a	Hand Wash Only, Filter to be installed.	10/31/24	installed filter	4/5/25	6/2/25	2.0 - Cleared	6/9/25	n/a	n/a	n/a	n/a
CT	104.5-45	Room 132	Bubbler	5.4	6/6/24	8/15/24	8/27/24	Taken out of service	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
CT	104.5-61	Room 129	sink	5.9	6/6/24	8/15/24	n/a	Hand Wash Only	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
CT	104.5-64	Room 126	Sink	6.5	6/6/24	8/15/24	n/a	Hand Wash Only	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
CT	104.5-67	Room 128	Sink	6.1	6/6/24	8/15/24	n/a	Hand Wash Only	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
CT	104.5-69	Room 127	Bubbler	5.3	6/6/24	8/15/24	8/27/24	Taken out of service	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
CT	104.5-74	Room 118B	Sink	28.6	6/6/24	8/15/24	n/a	Hand Wash Only	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
HV	104.6-1	Kitchen 3 Bay Left	Sink	7.2	6/7/24	8/15/24	n/a	Hand/Dish Wash Only, Filter to be installed.	12/12/24	installed filter	4/5/25	6/2/25	6.5	n/a	6/27/25	10/21/25	2.8 - Cleared	10/22/25
HV	104.6-3	Kitchen Staff Lav	Sink	5.5	6/7/24	8/15/24	n/a	Hand Wash Only	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
HV	104.6-5	Cafeteria Fountain	Drinking Fountain	6.6	6/7/24	8/15/24	8/27/24	Replace	10/1/24	installed new bottle filler	4/5/25	6/2/25	<1 - Cleared	6/6/25	n/a	n/a	n/a	n/a
HV	104.6-11	Principal's Office Lavatory	Sink	17.6	6/7/24	8/15/24	n/a	Hand Wash Only	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
HV	104.6-14	Room 1 Lavatory	Sink	29.4	6/7/24	8/15/24	n/a	Hand Wash Only	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
HV	104.6-26	Room 5 Lavatory	Sink	18.8	6/7/24	8/15/24	n/a	Hand Wash Only	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
HV	104.6-29	Room 4 Lavatory	Sink	5.4	6/7/24	8/15/24	n/a	Hand Wash Only	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
HV	104.6-33	Room 9 Main	Bubbler	6.3	6/7/24	8/15/24	8/27/24	Taken out of service	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
HV	104.6-36	Nurse Exam	Sink	7.5	6/7/24	8/15/24	n/a	Hand Wash Only	NO	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
HV	104.6-43	Room 32 Art Office Right	Sink	5.3	6/7/24	8/15/24	n/a	Hand Wash Only	NO	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
HV	104.6-52	Room 11	Sink	7.7	6/7/24	8/15/24	n/a	Hand Wash Only	NO	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
HV	104.6-53	Room 11	Bubbler	6	6/7/24	8/15/24	8/27/24	Taken out of service	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
HV	104.6-63	Girls Locker Coach Office	Sink	7.3	6/7/24	8/15/24	n/a	Hand Wash Only	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
HV	104.6-64	Girls Locker Room	Sink	24.2	6/7/24	8/15/24	n/a	Hand Wash Only	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
HV	104.6-67	Boys Gym Office	Sink	5.3	6/7/24	8/15/24	n/a	Hand Wash Only	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
HV	104.6-74	Room 17	Sink	5.6	6/7/24	8/15/24	n/a	Hand Wash Only	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
HV	104.6-98	Basement	Sink	10.4	6/7/24	8/15/24	n/a	Hand Wash Only	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
JAS	104.7-2	Room 1	Sink	20.1	6/14/24	6/28/24	n/a	New faucet in construction updates, Summe	8/27/24	New Faucet Installed	4/5/25	6/2/25	4.3 - Cleared	6/6/25	n/a	n/a	n/a	n/a
JAS	104.7-3	Room 4	Sink	7.3	6/14/24	8/15/24	n/a	Hand Wash Only. Faucet to be replaced Sun	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
JAS	104.7-4	Room 3	Sink	10.8	6/14/24	6/28/24	n/a	New faucet in construction updates, Summe	8/27/24	New Faucet Installed	4/5/25	6/2/25	3.7 - Cleared	6/6/25	n/a	n/a	n/a	n/a
JAS	104.7-5	Room 6	Sink	11.7	6/14/24	8/15/24	n/a	Hand Wash Only. Faucet to be replaced Sun	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
JAS	104.7-6	Room 5	Sink	5.9	6/14/24	6/28/24	n/a	New faucet in construction updates, Summe	8/27/24	New Faucet Installed	4/5/25	6/2/25	3.4 - Cleared	6/6/25	n/a	n/a	n/a	n/a
JAS	104.7-7	Room 8	Sink	5.7	6/14/24	8/15/24	n/a	Hand Wash Only. Faucet to be replaced Sun	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
JAS	104.7-8	Room 7	Sink	10	6/14/24	6/28/24	n/a	New faucet in construction updates, Summe	8/27/24	New Faucet Installed	4/5/25	6/2/25	3.4 - Cleared	6/6/25	n/a	n/a	n/a	n/a
JAS	104.7-9	Room 10	Sink	7.3	6/14/24	8/15/24	n/a	Hand Wash Only. Faucet to be replaced Sun	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
JAS	104.7-10	Room 9	Sink	7.7	6/14/24	6/28/24	n/a	New faucet in construction updates, Summe	8/27/24	New Faucet Installed	4/5/25	6/2/25	16.4	n/a	6/27/25	10/21/25	12.4	n/a
JAS	104.7-12	Room 11	Sink	6.5	6/14/24	6/28/24	n/a	New faucet in construction updates, Summe	8/27/24	New Faucet Installed	4/5/25	6/2/25	1.9 - Cleared	6/6/25	n/a	n/a	n/a	n/a
JAS	104.7-24	Library Media Center	Sink	6.9	6/14/24	8/15/24	n/a	Hand Wash Only	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
JAS	104.7-30	Room 13	Sink	6.2	6/14/24	8/15/24	n/a	Hand Wash Only	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
JAS	104.7-39	Room 24	Sink	7.6	6/14/24	8/15/24	n/a	Hand Wash Only	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
JAS	104.7-40	Room 23	Sink	8.7	6/14/24	8/15/24	n/a	Hand Wash Only	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
JAS	104.7-41	Art Room West Side Left Single Handle Fixtur	Sink	9	6/14/24	8/15/24	n/a	Hand Wash Only	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
JAS	104.7-46	Art Room East Side Right Single Handle Fixtur	Sink	35.1	6/14/24	8/15/24	n/a	Hand Wash Only	8/27/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
JAS	104.7-55	Kitchen Handwash	Sink	6.6	6/14/24	8/15/24	n/a	Hand/Dish Wash Only, Filter to be installed.	9/26/24	installed filter	4/5/25	6/2/25	3.7 - Cleared	6/9/25	n/a	n/a	n/a	n/a
JAS	104.7-56	Kitchen Prep Table Single Bay	Sink	5.2	6/14/24	8/15/24	n/a	Hand/Dish Wash Only, Filter to be installed.	9/26/24	installed filter	4/5/25	6/2/25	7.5	n/a	6/27/25	10/21/25	<1 - Cleared	10/22/25
JAS	104.7-57	Kitchen Pan Fill	Sink	107	6/14/24	8/15/24	n/a	Hand/Dish Wash Only	12/15/20	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
JAS	104.7-58	Kitchen 3 Bay Left Sink	Sink	9.9	6/14/24	8/15/24	n/a	Hand/Dish Wash Only, Filter to be installed.	9/26/24	installed filter	4/5/25	6/2/25	5.3	n/a	6/27/25	10/21/25	<1 - Cleared	10/22/25
JAS	104.7-59	Kitchen 3 Bay Right Sink	Sink	11.1	6/14/24	8/15/24	n/a	Hand/Dish Wash Only, Filter to be installed.	9/26/24	installed filter	4/5/25	6/2/25	1.9 - Cleared	6/9/25	n/a	n/a	n/a	n/a
DO	104.8-1	Basement Men's Lav	Sink	7.2	6/7/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
DO	104.8-3	Basement Kitchen	Sink	7.9	6/7/24	8/15/24	n/a	Hand Wash Only, Filter to be installed.	9/26/24	installed filter	4/5/25	6/2/25	<1 - Cleared	6/9/25	n/a	n/a	n/a	n/a
DO	104.8-5	Superintendent's Office Lav	Sink	6.2	6/7/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
295 Pleasant View	104.11-5	Men's Lav Right	Sink	23.6	6/6/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
295 Pleasant View	104.11-6	Women's Lav Left	Sink	29.8	6/6/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
295 Pleasant View	104.11-7	Women's Lav Middle	Sink	20.1	6/6/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
295 Pleasant View	104.11-8	Women's Lav Right	Sink	12.6	6/6/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
295 Pleasant View	104.11-10	Locker Room Middle	Sink	19.4	6/6/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
295 Pleasant View	104.11-11	Locker Room Back	Sink	7.7	6/6/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
295 Pleasant View	104.11-13	Back Break Room Front	Sink	11.4	6/6/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
295 Pleasant View	104.11-15	Back Break Room Left	Sink	13.3	6/6/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
295 Pleasant View	104.11-16	Back Break Room Right	Sink	15.5	6/6/24	8/15/24	n/a	Hand Wash Only	8/26/24	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Central Ave	104.10-1	Kitchen Sink	Sink	8.7	6/7/24	8/15/24	n/a	Hand Wash Only, Filter to be installed.	9/26/24	installed filter	4/5/25	6/2/25	<1 - Cleared	6/9/25	n/a	n/a	n/a	n/a

