

ADDENDUM

Addendum No:	03
Project:	Livonia Public Schools Central Office Generator Upgrades Livonia, MI
Project No:	2025-044
Owner:	Livonia Public Schools
Documents Issued:	September 10, 2025
Addendum Issued:	October 27, 2025

This Addendum is issued before the receiving of bids to clarify or to include certain revisions to the plans or specifications. All work required by this Addendum shall be in accordance with the original plans and apply to this project.

It is requested to include the work hereinafter described, in the proposal by the contractor for the complete work.

Drawing Changes:

ELECTRICAL

- 1. Refer to Sheet E100 – LOWER LEVEL ELECTRICAL PLAN (re-issued):**
 - a. Added space name for MDF Room to dictate location for cabling.

- 2. Refer to Sheet E501 – ELECTRICAL SCHEDULES AND DETAILS (re-issued):**
 - a. Added note #6 to Generator Solution Summary Notes for contractor to provide separate quote for all inclusive short circuit, coordination, and arc flash study for owner to review.