REGIONAL SCHOOL DISTRICT NO. 17
BOARD OF EDUCATION
BOARD OF EDUCATION SPECIAL MEETING AGENDA

DATE: **Tuesday, October 28, 2025**
LOCATION: **Central Office Board Room**
TIME: **5:30 PM**

1. **Call to Order/Opening of Meeting**
2. **Appointment of Superintendent of Schools Discussion and Possible Board Action (Proposed for Executive Session)**
3. **KES Boiler Replacement Discussion and Possible Board Action**
4. **Adjournment**

DATE: October 27, 2025

TO: Members of the RSD 17 Board of Education

FROM: Paul K. Smith, Interim Superintendent of Schools

RE: KES Boiler

Boiler #2 at KES has failed. This boiler was added in 1989 and has been included in Capital Planning documents, designated for replacement in FY 2028.

There is no way to repair as interior panels are cracked and replacements are no longer available. At this time, a full replacement is necessary.

I have started assembling quotes and I have one that is available for our Tuesday evening meeting in the amount of $57,750. The total with connection to the building automation system will be about $60,000. I am hoping that you will support a "not to exceed" amount based on that quote to give us time to order and install as the cold weather approaches. Waiting to order after your November facilities subcommittee and regular business meeting could be problematic.

A picture is included on the next page.

Paul K. Smith

CT 49585
#2
HB Smith

Central Mechanical Services, Inc

11 Progress Drive
Cromwell, CT 06416

Voice: 860-632-5500
Fax: 860-632-5544

QUOTATION

Quote Number: 27863
Quote Date: Oct 27, 2025
Page: 1

Quoted To:

REGIONAL SCHOOL DISTRICT #17
57 LITTLE CITY ROAD
Higganum, CT 06441

REGIONAL SCHOOL DISTRICT #17
57 LITTLE CITY ROAD
Higganum, CT 06441

Customer ID	Good Thru	Payment Terms	Sales Rep
REGIONAL SCHOOL #17	11/26/25	Net 30 Days	080-WMadey, Jr

Quantity	Item	Description	Unit Price	Amount
		KILLINGWORTH ELEMENTARY LABOR, MATERIAL AND EQUIPMENT NECESSARY TO REPLACE CRACKED HB SMITH BOILER WITH NEW BURNHAM V11 BOILER WITH BECKETT BURNER. RE-CONNECT BREACHING, PIPING, AND ELECTRICAL AT NEAREST FEASIBLE POINT. BMS TIE IN BY OTHERS AND NOT INCLUDED IN THIS QUOTE. 3-4 WEEK LEAD TIME		
1.00	Firm Price DAS CONTRACT	FIRM PRICE DAS CONTRACT 23PSX0243	57,750.00	57,750.00

*This quote does not include, setup on our building Automation System.

Subtotal	57,750.00
Sales Tax	
TOTAL	**57,750.00**