

Sample Location	Fixture Type	App or N/A	1 st Draw Results (ppb)	1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
JFK Elementary								
Kitchen Kettle	PF	App	5.0	10/9/2025				Remediation Complete
			7.0	3/4/2025	1.0	<1.0	3/20/2025	Removed from service pending fixture replacement
Room 4	WF	App	5.0	10/9/2025				Remediation Complete
			6.0	3/4/2025	2.0	2.0	3/20/2025	Removed from service pending fixture replacement
Room 62	WF	App	<1.0	10/24/2025				Remediation Complete
			6.0	10/9/2025				Ongoing
			7.0	3/4/2025	<1.0	<1.0	3/20/2025	Removed from service pending fixture replacement
Room 34	SK	App	2.0	10/24/2025				Remediation Complete
			8.0	10/9/2025				Ongoing
			9.0	3/4/2025	1.0	<1.0	3/20/2025	Removed from service pending fixture replacement
Room 31B	SK	App	4.0	10/24/2025				Remediation Complete
			10.0	10/9/2025				Ongoing
			15.0	3/4/2025	2.0	1.0	3/20/2025	Removed from service pending fixture replacement
Brewster High School								
Knee Sink	SK	NA	6.0	3/4/2025				Remediation Complete; Signed
CV Starr Intermediate School								
No exceedances								
HH Wells Middle School								
Kitchen Left Side Handwash	SK	NA	8.0	3/5/2025				Remediation Complete; Signed
Kitchen Steamer	OS	App	5.0	7/10/2025	2.0	2.0	7/10/2025	Remediation Complete
			183.0	3/5/2025	72.0	3.0	3/20/2025	Removed from service pending remediation
Kitchen Sink by Ovens	SK	NA	14.0	3/5/2025				Remediation Complete; Signed
Boy's Locker Room-porcelain	WF	App	7.0	3/5/2025				New WF/BF installed and passed 7/10/25
Girl's Locker Room-porcelain	WF	App	10.0	3/5/2025				New WF/BF installed and passed 7/10/25
Nurse's Office Sink	SK	App	8.0	3/5/2025	1.0	1.0	3/20/2025	Bottled water provided and sign posted

Key

WF-Water Fountain

BF-Bottle Filler

SK-Sink

OS-Other Source

PF-Pot Filler

SP-Spigot

App-currently considered an applicable/potable source