Technical Report

prepared for:

Parkway School
c/o Greenwich Public Schools, 290 Greenwich Ave
Greenwich, CT 06830
Attention: Elisa Gonzalez

Report Date: 10/29/2025
Client Project ID: PWS ID CT0570212
York Project (SDG) No.: N5J0069

CT Cert. No. PH-0800

New York Cert. No. 11706

56 Church Hill Road #2 ▪ Newtown, CT 06470

www.YORKLAB.com (203) 270-9973 FAX (203) 270-3348 ClientServices@yorklab.com

Report Date: 10/29/2025
Client Project ID: PWS ID CT0570212
York Project (SDG) No.: N5J0069

Parkway School
c/o Greenwich Public Schools, 290 Greenwich Ave
Greenwich, CT 06830
Attention: Elisa Gonzalez

Purpose and Results

This report contains the analytical data for the sample(s) identified on the attached chain-of-custody received in our laboratory on October 02, 2025 and listed below. The project was identified as your project: **PWS ID CT0570212**.

The analyses were conducted utilizing appropriate EPA, Standard Methods, and ASTM methods as detailed in the data summary tables.

All samples were received in proper condition meeting the customary acceptance requirements for environmental samples except those indicated under the Sample and Analysis Qualifiers section of this report.

All analyses met the method and laboratory standard operating procedure requirements except as indicated by any data flags, the meaning of which are explained in the Sample and Data Qualifiers Relating to This Work Order section of this report and case narrative if applicable.

Please contact Client Services at 203-270-9973 with any questions regarding this report.

York Sample ID	Client Sample ID	Matrix	Date Collected	Date Received
N5J0069-01	PS017- Teachers Lounge	Drinking Water	10/02/2025	10/02/2025

Sample Information

Client Sample ID: **PS017- Teachers Lounge**

York Sample ID: **N5J0069-01**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
N5J0069	PWS ID CT0570212	Drinking Water	October 2, 2025 1:10 pm	10/02/2025

Field Analyses:

Log-in/Sample Notes:

Results

Parameter	Result	Units	Qualifier	RL	MCL	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
Alkalinity, total, as CaCO3	**210**	mg/L		10	-	SM 21-23 2320B (-97)	10/03/2025 13:29	10/03/2025 14:16	SMD
						Certifications:	CTDPH-PH-0800,NYSDOH-NY11706		

Definitions and Other Information

* Analyte is not certified or the state of the samples origination does not offer certification for the Analyte.

MCL The Maximum Contaminant Level (MCL) is the maximum concentration of a chemical that is allowed in public drinking water systems. The MCL is established by the U.S. Environmental Protection Agency (EPA). Some states have MCLs that are equal to or less than the Federally established MCL. The listed MCL value reflects the MCL established by the State where the sample was taken.

General Notes for

1. The RLs and MDLs (Reporting Limit and Method Detection Limit respectively) reported are adjusted for any dilution necessary due to the levels of target and/or non-target analytes and matrix interference. The RL(REPORTING LIMIT) is based upon the lowest standard utilized for the calibration where applicable.
2. Samples are retained for a period of thirty days after submittal of report, unless other arrangements are made.
3. York's liability for the above data is limited to the dollar value paid to York for the referenced project.
4. This report shall not be reproduced without the written approval of York Analytical Laboratories, Inc.
5. All analyses conducted met method or Laboratory SOP requirements. See the Sample and Data Qualifiers Section for further information.
6. It is noted that no analyses reported herein were subcontracted to another laboratory, unless noted in the report.
7. This report reflects results that relate only to the samples submitted on the attached chain-of-custody form(s) received by York.

Approved By:

Cassie Mosher
Chemistry Director



Phil Murphy
Interim Microbiology Director



Date: October 29, 2025

AQUA ENVIRONMENTAL LAB
56 Church Hill Road • Newtown, CT 06470 • (203) 270-9973
A York Analytical Company
YORK

Company Name:	Parkway Elementary
Address:	141 Lower Cross Rd., Greenwich
PWSID	CT0570212

(LAB USE ONLY)	Client Sample ID	Type	Collection Date & Time	Analyses Requested: Total Coliform	Physical Parameters	Lead and Copper	Asbestos		ALK	Nits	PFAS	E. Coli	Field Parameters: CL2	pH	Temp		Comments
			10/2/25														
N5J0069-9	PS017 - Teachers Lounge		1:10PM						X								
	PS017 - Teachers Lounge																
	In Between Filters																
	POE 00700																
	Well 2 - 53226																
	Well 3 - 53228																

Sample ID's

POE 00700
Well 2 - 53226
Well 3 - 53228

Bi Weekly ALK from PS017

PS017 Teachers Lounge

Sampler: Erik Madden

Sampler's Signature:

Received On Ice Y / N

Released By:

Received BY:

Date/Time: 4:10PM

Temp: 2 i