

## **ENVIRONMENTAL LABWORKS, INC.**

October 23, 2025

Mr. Kyle Harjes  
Onteora Central School District  
Buildings & Grounds Department  
4166 Route 28  
Boiceville, NY 12412

Dear Mr. Harjes,

The following are results of the analyses performed on water samples from **Woodstock Elementary School** received at the laboratory on 10/07/25.

Date/Time Collected: 10/07/25 7:25-7:42am First Draw  
Collected By: Ulster BOCES  
Project ID: 10072514  
Secondary ID: WS254237-48

| LOCATION/<br>SAMPLE ID                           | PARAMETER         | RESULTS       | ACTION LEVEL | ANALYZED |
|--------------------------------------------------|-------------------|---------------|--------------|----------|
| Kitchen Sink 1<br>10072514-1                     | EPA 200.8<br>Lead | 0.000471 mg/L | 0.005 mg/L   | 10/10/25 |
| Kitchen Sink 2<br>10072514-2                     | EPA 200.8<br>Lead | 0.000443 mg/L | 0.005 mg/L   | 10/10/25 |
| Back Hall Bottle Filler<br>10072514-3            | EPA 200.8<br>Lead | <0.00040 mg/L | 0.005 mg/L   | 10/10/25 |
| Back Hall Fountain<br>10072514-4                 | EPA 200.8<br>Lead | <0.00040 mg/L | 0.005 mg/L   | 10/10/25 |
| Cafeteria Hall Fountain<br>10072514-5            | EPA 200.8<br>Lead | <0.00040 mg/L | 0.005 mg/L   | 10/10/25 |
| Cafeteria Hall Bottle<br>Filler<br>10072514-6    | EPA 200.8<br>Lead | <0.00040 mg/L | 0.005 mg/L   | 10/10/25 |
| Front Hall by Rm 19<br>Fountain<br>10072514-7    | EPA 200.8<br>Lead | <0.00040 mg/L | 0.005 mg/L   | 10/10/25 |
| Front Hall by Rm 19 Bottle<br>Fill<br>10072514-8 | EPA 200.8<br>Lead | <0.00040 mg/L | 0.005 mg/L   | 10/10/25 |
| Hallway by Rm 24 Fountain<br>10072514-9          | EPA 200.8<br>Lead | <0.00040 mg/L | 0.005 mg/L   | 10/17/25 |


## **ENVIRONMENTAL LABWORKS, INC.**

**Woodstock Elementary School - 10072514**

| LOCATION/<br>SAMPLE ID                         | PARAMETER         | RESULTS       | ACTION LEVEL | ANALYZED |
|------------------------------------------------|-------------------|---------------|--------------|----------|
| Hallway by Rm 24 Bottle<br>Fill<br>10072514-10 | EPA 200.8<br>Lead | <0.00040 mg/L | 0.005 mg/L   | 10/17/25 |
| Faculty Room Sink<br>10072514-11               | EPA 200.8<br>Lead | <0.00040 mg/L | 0.005 mg/L   | 10/17/25 |
| Nurse's Sink<br>10072514-12                    | EPA 200.8<br>Lead | <0.00040 mg/L | 0.005 mg/L   | 10/17/25 |

The data contained in this report were obtained using EPA or other approved methodologies. This laboratory or any outside laboratory used are NYSDOH certified for these analyses. Vendor laboratory used was ELAP #12150. The results in this report apply to the samples received by the laboratory, analyzed in accordance with the chain of custody document. This analytical report may only be reproduced in its entirety.

Thank you,



for Michael F. Lupi  
Technical Director