



May 27, 2025

Zach Nannestad
Douglas County School District
2812 N. Highway 85
Castle Rock, CO 80109

**Re: DCSD Northeast Elementary School
6598 N Highway 83, Parker, CO 80134,
Radon Sampling Assessment**

Dear Mr. Nannestad:

Quality Environmental Services & Technologies Inc. (QUEST) is pleased to assist Douglas County School District with the ongoing radon survey of its schools. At your request, QUEST conducted radon testing at Northeast Elementary School, located at 6598 N Highway 83, Parker, CO 80134.

Fifty (50) AirChek radon test kits were placed on May 19, 2025, and Fifty (50) were retrieved on May 21, 2025. The attached laboratory results specify radon concentrations to be all within the EPA guideline of 4 pCi/L for acceptable radon concentrations. The laboratory also noted that kit #12051129 Room id 106 possessed a manufactural defect and thus could not be interpreted by the lab. Room 106 contained a duplicate sample #12051127 Room id 106 (D), which was within the EPA guideline of 4 pCi/L for acceptable radon concentrations.

If you have any questions, or if we may be of additional assistance, please contact QUEST, Inc. at 303-935-1573. We look forward to our continued association.

Sincerely,

A handwritten signature in black ink, appearing to read 'Robert A. Woellner', is written above the printed name.

Robert A. Woellner
President/Industrial Hygienist
NEHA: NRPP Certification #105324RT

Attachment: Laboratory Report

Radon test result report for:**NORTHEAST ELEMENTARY
MAIN**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
12051129	106	2025-05-19 @ 11:00 am	2025-05-21 @ 12:00 pm	???? IA8	2025-05-23
12051127	106 (B)	2025-05-19 @ 11:00 am	2025-05-21 @ 12:00 pm	< 0.3	2025-05-23
12051128	106 (D)	2025-05-19 @ 11:00 am	2025-05-21 @ 12:00 pm	< 0.3	2025-05-23
12074000	110A	2025-05-19 @ 11:00 am	2025-05-21 @ 12:00 pm	< 0.3	2025-05-23
12051115	121	2025-05-19 @ 11:00 am	2025-05-21 @ 12:00 pm	< 0.3	2025-05-23
12051118	122 N	2025-05-19 @ 11:00 am	2025-05-21 @ 12:00 pm	< 0.3	2025-05-23
12051117	122 S	2025-05-19 @ 11:00 am	2025-05-21 @ 12:00 pm	< 0.3	2025-05-23
12051116	122 S (D)	2025-05-19 @ 11:00 am	2025-05-21 @ 12:00 pm	< 0.3	2025-05-23
12051130	123	2025-05-19 @ 11:00 am	2025-05-21 @ 12:00 pm	< 0.3	2025-05-23
12051103	124	2025-05-19 @ 11:00 am	2025-05-21 @ 12:00 pm	0.5	2025-05-23
12051108	128	2025-05-19 @ 11:00 am	2025-05-21 @ 12:00 pm	< 0.3	2025-05-23
12051102	141	2025-05-19 @ 11:00 am	2025-05-21 @ 12:00 pm	< 0.3	2025-05-23
12051106	142	2025-05-19 @ 11:00 am	2025-05-21 @ 12:00 pm	< 0.3	2025-05-23
12051101	142	2025-05-19 @ 11:00 am	2025-05-21 @ 12:00 pm	< 0.3	2025-05-23
12051104	142 (B)	2025-05-19 @ 11:00 am	2025-05-21 @ 12:00 pm	< 0.3	2025-05-23
12051105	142 (D)	2025-05-19 @ 11:00 am	2025-05-21 @ 12:00 pm	< 0.3	2025-05-23
12051107	143	2025-05-19 @ 11:00 am	2025-05-21 @ 12:00 pm	< 0.3	2025-05-23
12051109	144	2025-05-19 @ 11:00 am	2025-05-21 @ 12:00 pm	0.8	2025-05-23
12051110	145	2025-05-19 @ 11:00 am	2025-05-21 @ 12:00 pm	< 0.3	2025-05-23
12051121	150	2025-05-19 @ 11:00 am	2025-05-21 @ 12:00 pm	< 0.3	2025-05-23
12051120	151	2025-05-19 @ 11:00 am	2025-05-21 @ 12:00 pm	< 0.3	2025-05-23
12051113	152	2025-05-19 @ 11:00 am	2025-05-21 @ 12:00 pm	0.7	2025-05-23
12051114	153	2025-05-19 @ 11:00 am	2025-05-21 @ 12:00 pm	< 0.3	2025-05-23
12051112	154	2025-05-19 @ 11:00 am	2025-05-21 @ 12:00 pm	0.6	2025-05-23
12051111	155	2025-05-19 @ 11:00 am	2025-05-21 @ 12:00 pm	0.6	2025-05-23
12051126	160	2025-05-19 @ 11:00 am	2025-05-21 @ 12:00 pm	0.5	2025-05-23
12051125	161	2025-05-19 @ 11:00 am	2025-05-21 @ 12:00 pm	0.6	2025-05-23
12051124	162	2025-05-19 @ 11:00 am	2025-05-21 @ 12:00 pm	< 0.3	2025-05-23
12051123	163	2025-05-19 @ 11:00 am	2025-05-21 @ 12:00 pm	0.7	2025-05-23
12051119	166	2025-05-19 @ 11:00 am	2025-05-21 @ 12:00 pm	< 0.3	2025-05-23
12051149	210	2025-05-19 @ 11:00 am	2025-05-21 @ 12:00 pm	< 0.3	2025-05-23
12051146	211	2025-05-19 @ 11:00 am	2025-05-21 @ 12:00 pm	< 0.3	2025-05-23
12051145	212	2025-05-19 @ 11:00 am	2025-05-21 @ 12:00 pm	0.7	2025-05-23
12051148	213	2025-05-19 @ 11:00 am	2025-05-21 @ 12:00 pm	< 0.3	2025-05-23
12051147	215	2025-05-19 @ 11:00 am	2025-05-21 @ 12:00 pm	< 0.3	2025-05-23
12051133	224B	2025-05-19 @ 11:00 am	2025-05-21 @ 12:00 pm	0.6	2025-05-23
12051140	225	2025-05-19 @ 11:00 am	2025-05-21 @ 12:00 pm	< 0.3	2025-05-23

May 23, 2025

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:

**NORTHEAST ELEMENTARY
MAIN**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
12051139	226 (D)	2025-05-19 @ 11:00 am	2025-05-21 @ 12:00 pm	< 0.3	2025-05-23
12051142	250 E	2025-05-19 @ 11:00 am	2025-05-21 @ 12:00 pm	< 0.3	2025-05-23
12051141	250 W	2025-05-19 @ 11:00 am	2025-05-21 @ 12:00 pm	0.6	2025-05-23
12051136	260	2025-05-19 @ 11:00 am	2025-05-21 @ 12:00 pm	< 0.3	2025-05-23
12051137	260	2025-05-19 @ 11:00 am	2025-05-21 @ 12:00 pm	< 0.3	2025-05-23
12051135	261	2025-05-19 @ 11:00 am	2025-05-21 @ 12:00 pm	< 0.3	2025-05-23
12051134	263	2025-05-19 @ 11:00 am	2025-05-21 @ 12:00 pm	< 0.3	2025-05-23
12051132	265	2025-05-19 @ 11:00 am	2025-05-21 @ 12:00 pm	< 0.3	2025-05-23
12051131	ART	2025-05-19 @ 11:00 am	2025-05-21 @ 12:00 pm	< 0.3	2025-05-23
12051122	EAGLES NEST	2025-05-19 @ 11:00 am	2025-05-21 @ 12:00 pm	0.5	2025-05-23
12051144	MAIL	2025-05-19 @ 11:00 am	2025-05-21 @ 12:00 pm	< 0.3	2025-05-23

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498