



May 13, 2025

Zach Nannestad
Douglas County School District
2812 N. Highway 85
Castle Rock, CO 80109

**Re: Stone Canyon Outdoor EdVentures
12163 S Perry Park Rd, Sedalia, CO 80118
Radon Sampling Assessment**

Dear Mr. Nannestad:

Quality Environmental Services & Technologies Inc. (QUEST) is pleased to assist Douglas County School District with the ongoing radon survey of its schools. At your request, QUEST conducted radon testing at Stone Canyon Outdoor EdVentures, located at 12163 S Perry Park Rd in Sedalia, Colorado.

Forty-eight (48) AirChek radon test kits were placed on May 13, 2025, and were retrieved on May 15, 2025. The attached laboratory results specify radon concentrations to be all within the EPA guideline of 4 pCi/L for acceptable radon concentrations. Any that show IA8 are kits with manufacturer defects.

If you have any questions, or if we may be of additional assistance, please contact QUEST, Inc. at 303-935-1573. We look forward to our continued association.

Sincerely,

A handwritten signature in black ink, appearing to read "Robert A. Woellner".

Robert A. Woellner
Founder/Industrial Hygienist
NEHA: NRPP Certification #105324RT

A handwritten signature in black ink, appearing to read "Larry Head".

Larry Head
CEO

Attachment: Laboratory Report

Radon test result report for:**STONE CANYON OUTDOOR EDVENTURES**
100

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
12051170	1	2025-05-13 @ 11:00 am	2025-05-15 @ 12:00 pm	???? IA8	2025-05-16
12051200	100	2025-05-13 @ 11:00 am	2025-05-15 @ 12:00 pm	0.7	2025-05-16
12051194	101	2025-05-13 @ 11:00 am	2025-05-15 @ 12:00 pm	0.9	2025-05-16
12051195	102	2025-05-13 @ 11:00 am	2025-05-15 @ 12:00 pm	0.7	2025-05-16
12051199	103	2025-05-13 @ 11:00 am	2025-05-15 @ 12:00 pm	0.8	2025-05-16
12051197	104	2025-05-13 @ 11:00 am	2025-05-15 @ 12:00 pm	0.6	2025-05-16
12051193	109	2025-05-13 @ 11:00 am	2025-05-15 @ 12:00 pm	0.6	2025-05-16
12051192	110	2025-05-13 @ 11:00 am	2025-05-15 @ 12:00 pm	0.5	2025-05-16
12051191	111	2025-05-13 @ 11:00 am	2025-05-15 @ 12:00 pm	< 0.3	2025-05-16
12051190	112	2025-05-13 @ 11:00 am	2025-05-15 @ 12:00 pm	0.6	2025-05-16
12051189	113	2025-05-13 @ 11:00 am	2025-05-15 @ 12:00 pm	< 0.3	2025-05-16
12051188	113 (D)	2025-05-13 @ 11:00 am	2025-05-15 @ 12:00 pm	0.7	2025-05-16
12051187	114	2025-05-13 @ 11:00 am	2025-05-15 @ 12:00 pm	< 0.3	2025-05-16
12051185	121 N	2025-05-13 @ 11:00 am	2025-05-15 @ 12:00 pm	< 0.3	2025-05-16
12051186	121 S	2025-05-13 @ 11:00 am	2025-05-15 @ 12:00 pm	0.5	2025-05-16
12051169	2	2025-05-13 @ 11:00 am	2025-05-15 @ 12:00 pm	1.1	2025-05-16
12051168	3	2025-05-13 @ 11:00 am	2025-05-15 @ 12:00 pm	1.1	2025-05-16

Radon test result report for:**STONE CANYON OUTDOOR EDVENTURES
102**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
12051161	1	2025-05-13 @ 12:00 pm	2025-05-15 @ 1:00 pm	0.6	2025-05-16
12051151	10	2025-05-13 @ 12:00 pm	2025-05-15 @ 1:00 pm	0.7	2025-05-16
12051150	11	2025-05-13 @ 12:00 pm	2025-05-15 @ 1:00 pm	< 0.3	2025-05-16
12051160	2	2025-05-13 @ 12:00 pm	2025-05-15 @ 1:00 pm	< 0.3	2025-05-16
12051159	3	2025-05-13 @ 12:00 pm	2025-05-15 @ 1:00 pm	< 0.3	2025-05-16
12051158	4	2025-05-13 @ 12:00 pm	2025-05-15 @ 1:00 pm	< 0.3	2025-05-16
12051157	5	2025-05-13 @ 12:00 pm	2025-05-15 @ 1:00 pm	0.5	2025-05-16
12051156	7	2025-05-13 @ 12:00 pm	2025-05-15 @ 1:00 pm	1.2	2025-05-16
12051154	7 (B)	2025-05-13 @ 12:00 pm	2025-05-15 @ 1:00 pm	< 0.3	2025-05-16
12051155	7 (D)	2025-05-13 @ 12:00 pm	2025-05-15 @ 1:00 pm	0.8	2025-05-16
12051153	8	2025-05-13 @ 12:00 pm	2025-05-15 @ 1:00 pm	0.7	2025-05-16
12051152	9	2025-05-13 @ 12:00 pm	2025-05-15 @ 1:00 pm	0.6	2025-05-16
12051162	NURSE	2025-05-13 @ 12:00 pm	2025-05-15 @ 1:00 pm	< 0.3	2025-05-16
12051163	OFFICE	2025-05-13 @ 12:00 pm	2025-05-15 @ 1:00 pm	0.6	2025-05-16

May 20, 2025

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:

**STONE CANYON OUTDOOR EDVENTURES
106**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
12051184	1	2025-05-13 @ 11:00 am	2025-05-15 @ 12:00 pm	???? IA8	2025-05-16
12051183	2	2025-05-13 @ 11:00 am	2025-05-15 @ 12:00 pm	0.6	2025-05-16
12051182	3	2025-05-13 @ 11:00 am	2025-05-15 @ 12:00 pm	1.3	2025-05-16

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

May 20, 2025

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:

**STONE CANYON OUTDOOR EDVENTURES
108**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
12051181	1	2025-05-13 @ 11:00 am	2025-05-15 @ 12:00 pm	< 0.3	2025-05-16
12051180	2	2025-05-13 @ 11:00 am	2025-05-15 @ 12:00 pm	0.6	2025-05-16
12051179	3	2025-05-13 @ 11:00 am	2025-05-15 @ 12:00 pm	0.6	2025-05-16
12051175	4	2025-05-13 @ 11:00 am	2025-05-15 @ 12:00 pm	0.9	2025-05-16
12051174	5	2025-05-13 @ 11:00 am	2025-05-15 @ 12:00 pm	0.5	2025-05-16
12051173	6	2025-05-13 @ 11:00 am	2025-05-15 @ 12:00 pm	< 0.3	2025-05-16
12051172	INSTRUCTOR	2025-05-13 @ 11:00 am	2025-05-15 @ 12:00 pm	< 0.3	2025-05-16
12051178	MAIN	2025-05-13 @ 11:00 am	2025-05-15 @ 12:00 pm	< 0.3	2025-05-16
12051176	MAIN (B)	2025-05-13 @ 11:00 am	2025-05-15 @ 12:00 pm	< 0.3	2025-05-16
12051177	MAIN (D)	2025-05-13 @ 11:00 am	2025-05-15 @ 12:00 pm	0.6	2025-05-16

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

May 20, 2025

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:
STONE CANYON OUTDOOR EDVENTURES
110

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
12051171	MAIN	2025-05-13 @ 11:00 am	2025-05-15 @ 12:00 pm	0.6	2025-05-16

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

May 20, 2025

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:

**STONE CANYON OUTDOOR EDVENTURES
CANYON**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
12051165	1 (D)	2025-05-13 @ 11:00 am	2025-05-15 @ 12:00 pm	1.9	2025-05-16
12051164	2	2025-05-13 @ 12:00 pm	2025-05-15 @ 12:00 pm	2.2	2025-05-16
12051167	MAIN	2025-05-13 @ 11:00 am	2025-05-15 @ 12:00 pm	1.8	2025-05-16

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498