Technical Report

prepared for:

QuES & T
1376 Rt. 9
Wappingers Falls NY, 12590
Attention: Zachary P. Timpano

Report Date: 10/10/2025
Client Project ID: 256977 Mamaroneck UFSD- Central Avenue Elementary School
York Project (SDG) No.: 25J0320

Stratford, CT Laboratory IDs:
NY:10854, NJ: CT005, PA: 68-0440, CT: PH-0723

Richmond Hill, NY Laboratory IDs:
NY:12058, NJ: NY037, CT: PH-0721, NH: 2097,
EPA: NY01600

120 RESEARCH DRIVE STRATFORD, CT 06615 ■ 132-02 89th AVENUE RICHMOND HILL, NY 11418
www.YORKLAB.com (203) 325-1371 FAX (203) 357-0166 ClientServices@yorklab.com

Report Date: 10/10/2025
Client Project ID: 256977 Mamaroneck UFSD- Central Avenue Elementary School
York Project (SDG) No.: 25J0320

QuES & T
1376 Rt. 9
Wappingers Falls NY, 12590
Attention: Zachary P. Timpano

Purpose and Results

This report contains the analytical data for the sample(s) identified on the attached chain-of-custody received in our laboratory on October 06, 2025 and listed below. The project was identified as your project: **256977 Mamaroneck UFSD- Central Avenue Elementary School**.

The analyses were conducted utilizing appropriate EPA, Standard Methods, and ASTM methods as detailed in the data summary tables.

All samples were received in proper condition meeting the customary acceptance requirements for environmental samples except those indicated under the Sample and Analysis Qualifiers section of this report.

All analyses met the method and laboratory standard operating procedure requirements except as indicated by any data flags, the meaning of which are explained in the Sample and Data Qualifiers Relating to This Work Order section of this report and case narrative if applicable.

The results of the analyses, which are all reported on dry weight basis (soils) unless otherwise noted, are detailed in the following pages.

Please contact Client Services at 203.325.1371 with any questions regarding this report.

York Sample ID	Client Sample ID	Matrix	Date Collected	Date Received
25J0320-01	C-01 Sink in 351	Drinking Water	10/02/2025	10/06/2025
25J0320-02	C-02 Sink in 352	Drinking Water	10/02/2025	10/06/2025
25J0320-03	C-03 Sink in 353	Drinking Water	10/02/2025	10/06/2025
25J0320-04	C-04 Water fountain across 353	Drinking Water	10/02/2025	10/06/2025
25J0320-05	C-05 Bottle filler across 353	Drinking Water	10/02/2025	10/06/2025
25J0320-06	C-06 Sink in 354	Drinking Water	10/02/2025	10/06/2025
25J0320-07	C-07 Water fountain across 357	Drinking Water	10/02/2025	10/06/2025
25J0320-08	C-08 Bottle filler across 357	Drinking Water	10/02/2025	10/06/2025
25J0320-09	C-09 Sink in 357	Drinking Water	10/02/2025	10/06/2025
25J0320-10	C-10 Sink in 356	Drinking Water	10/02/2025	10/06/2025
25J0320-11	C-11 Sink in 355	Drinking Water	10/02/2025	10/06/2025
25J0320-12	C-12 Sink in 358	Drinking Water	10/02/2025	10/06/2025
25J0320-13	C-13 Water fountain across 358	Drinking Water	10/02/2025	10/06/2025
25J0320-14	C-14 Bottle filler across 358	Drinking Water	10/02/2025	10/06/2025
25J0320-15	C-15 Sink in 359	Drinking Water	10/02/2025	10/06/2025
25J0320-16	C-16 Sink in 360	Drinking Water	10/02/2025	10/06/2025
25J0320-17	C-17 Sink in 361	Drinking Water	10/02/2025	10/06/2025
25J0320-18	C-18 Sink in 350	Drinking Water	10/02/2025	10/06/2025
25J0320-19	C-19 Sink in 251	Drinking Water	10/02/2025	10/06/2025
25J0320-20	C-20 Sink in 252	Drinking Water	10/02/2025	10/06/2025
25J0320-21	C-21 Sink in 253	Drinking Water	10/02/2025	10/06/2025
25J0320-22	C-22 Sink in 250	Drinking Water	10/02/2025	10/06/2025

York Sample ID	Client Sample ID	Matrix	Date Collected	Date Received
25J0320-23	C-23 Water fountain across 253	Drinking Water	10/02/2025	10/06/2025
25J0320-24	C-24 Bottle filler across 253	Drinking Water	10/02/2025	10/06/2025
25J0320-25	C-25 Water fountain across 257	Drinking Water	10/02/2025	10/06/2025
25J0320-26	C-26 Bottle filler across 257	Drinking Water	10/02/2025	10/06/2025
25J0320-27	C-27 Sink in 254	Drinking Water	10/02/2025	10/06/2025
25J0320-28	C-28 Sink in 257	Drinking Water	10/02/2025	10/06/2025
25J0320-29	C-29 Sink in 256	Drinking Water	10/02/2025	10/06/2025
25J0320-30	C-30 Sink in 255	Drinking Water	10/02/2025	10/06/2025
25J0320-31	C-31 Water fountain across Library	Drinking Water	10/02/2025	10/06/2025
25J0320-32	C-32 Bottle filler across Library	Drinking Water	10/02/2025	10/06/2025
25J0320-33	C-33 Sink in 201 (Faculty lounge)	Drinking Water	10/02/2025	10/06/2025
25J0320-34	C-34 Water fountain across 308	Drinking Water	10/02/2025	10/06/2025
25J0320-35	C-35 Bottle filler across 308	Drinking Water	10/02/2025	10/06/2025
25J0320-36	C-36 Sink in 303	Drinking Water	10/02/2025	10/06/2025
25J0320-37	C-37 Sink in 302	Drinking Water	10/02/2025	10/06/2025
25J0320-38	C-38 Sink in 301	Drinking Water	10/02/2025	10/06/2025
25J0320-39	C-39 Water fountain outside 310	Drinking Water	10/02/2025	10/06/2025
25J0320-40	C-40 Bottle filler outside 310	Drinking Water	10/02/2025	10/06/2025
25J0320-41	C-41 Water fountain in 312	Drinking Water	10/02/2025	10/06/2025
25J0320-42	C-42 Bottle filler in 312	Drinking Water	10/02/2025	10/06/2025
25J0320-43	C-43 Sink in 101	Drinking Water	10/02/2025	10/06/2025
25J0320-44	C-44 Water fountain outside 101	Drinking Water	10/02/2025	10/06/2025
25J0320-45	C-45 Bottle fill outside 101	Drinking Water	10/02/2025	10/06/2025
25J0320-46	C-46 Water fountain across 156	Drinking Water	10/02/2025	10/06/2025
25J0320-47	C-47 Bottle filler across 156	Drinking Water	10/02/2025	10/06/2025
25J0320-48	C-48 Sink in 153	Drinking Water	10/02/2025	10/06/2025
25J0320-49	C-49 Sink in 155	Drinking Water	10/02/2025	10/06/2025
25J0320-50	C-50 Sink in 160	Drinking Water	10/02/2025	10/06/2025
25J0320-51	C-51 Water fountain across 160	Drinking Water	10/02/2025	10/06/2025
25J0320-52	C-52 Bottle filler across 160	Drinking Water	10/02/2025	10/06/2025
25J0320-53	C-53 Sink in 165	Drinking Water	10/02/2025	10/06/2025

General Notes for York Project (SDG) No.: 25J0320

1. The RLs and MDLs (Reporting Limit and Method Detection Limit respectively) reported are adjusted for any dilution necessary due to the levels of target and/or non-target analytes and matrix interference. The RL(REPORTING LIMIT) is based upon the lowest standard utilized for the calibration where applicable.
2. Samples are retained for a period of thirty days after submittal of report, unless other arrangements are made.
3. York's liability for the above data is limited to the dollar value paid to York for the referenced project.
4. This report shall not be reproduced without the written approval of York Analytical Laboratories, Inc.
5. All analyses conducted met method or Laboratory SOP requirements. See the Sample and Data Qualifiers Section for further information.
6. It is noted that no analyses reported herein were subcontracted to another laboratory, unless noted in the report.
7. This report reflects results that relate only to the samples submitted on the attached chain-of-custody form(s) received by York.
8. Analyses conducted at York Analytical Laboratories, Inc. Stratford, CT are indicated by NY Cert. No. 10854, NJ Cert No. CT005, PA Cert No. 68-04440, CT Cert No. PH-0723; those conducted at York Analytical Laboratories, Inc., Richmond Hill, NY are indicated by NY Cert. No. 12058, NJ Cert No. NY037, CT Cert No. PH-0721, NH Cert No. 2097, EPA Cert No. NY01600.

Approved By: Cassie L. Mosher

Cassie L. Mosher
Laboratory Manager

Date: 10/10/2025

Sample Information

Client Sample ID: C-01 Sink in 351 **York Sample ID:** 25J0320-01

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 11:00 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**2.90**		ug/L	1.00	1	EPA 200.8	10/09/2025 09:21	10/09/2025 10:18	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-(		

Sample Information

Client Sample ID: C-02 Sink in 352 **York Sample ID:** 25J0320-02

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 11:01 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**2.17**		ug/L	1.00	1	EPA 200.8	10/09/2025 09:21	10/09/2025 10:22	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-(		

Sample Information

Client Sample ID: C-03 Sink in 353 **York Sample ID:** 25J0320-03

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 11:01 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**1.87**		ug/L	1.00	1	EPA 200.8	10/09/2025 09:21	10/09/2025 10:24	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-(		

Sample Information

Client Sample ID: C-04 Water fountain across 353 **York Sample ID:** 25J0320-04

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 11:03 am	10/06/2025

Sample Information

Client Sample ID: C-04 Water fountain across 353 **York Sample ID:** 25J0320-04

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 11:03 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	10/09/2025 09:21	10/09/2025 10:26	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: C-05 Bottle filler across 353 **York Sample ID:** 25J0320-05

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 11:03 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	10/09/2025 09:21	10/09/2025 10:27	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: C-06 Sink in 354 **York Sample ID:** 25J0320-06

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 11:04 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**2.53**		ug/L	1.00	1	EPA 200.8	10/09/2025 09:21	10/09/2025 10:31	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-(		

Sample Information

Client Sample ID: C-07 Water fountain across 357 **York Sample ID:** 25J0320-07

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 11:05 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Information

Client Sample ID: C-07 Water fountain across 357 **York Sample ID:** 25J0320-07

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 11:05 am	10/06/2025

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	10/09/2025 09:21	10/09/2025 10:32	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: C-08 Bottle filler across 357 **York Sample ID:** 25J0320-08

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 11:05 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	10/09/2025 09:21	10/09/2025 10:33	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: C-09 Sink in 357 **York Sample ID:** 25J0320-09

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 11:07 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**1.28**		ug/L	1.00	1	EPA 200.8	10/09/2025 09:21	10/09/2025 10:35	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: C-10 Sink in 356 **York Sample ID:** 25J0320-10

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 11:08 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst

Sample Information

Client Sample ID: C-10 Sink in 356 **York Sample ID:** 25J0320-10

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 11:08 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**10.6**	M-PbE X	ug/L	1.00	1	EPA 200.8	10/09/2025 09:21	10/09/2025 10:36	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-(		

Sample Information

Client Sample ID: C-11 Sink in 355 **York Sample ID:** 25J0320-11

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 11:10 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**5.17**	M-PbE X	ug/L	1.00	1	EPA 200.8	10/09/2025 09:21	10/09/2025 10:37	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-(		

Sample Information

Client Sample ID: C-12 Sink in 358 **York Sample ID:** 25J0320-12

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 11:11 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**3.57**		ug/L	1.00	1	EPA 200.8	10/09/2025 09:21	10/09/2025 10:39	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-(		

Sample Information

Client Sample ID: C-13 Water fountain across 358 **York Sample ID:** 25J0320-13

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 11:13 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Information

Client Sample ID: C-13 Water fountain across 358 **York Sample ID:** 25J0320-13

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 11:13 am	10/06/2025

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**1.90**		ug/L	1.00	1	EPA 200.8	10/09/2025 09:21	10/09/2025 10:40	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-(		

Sample Information

Client Sample ID: C-14 Bottle filler across 358 **York Sample ID:** 25J0320-14

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 11:13 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**2.19**		ug/L	1.00	1	EPA 200.8	10/09/2025 09:21	10/09/2025 10:41	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-(		

Sample Information

Client Sample ID: C-15 Sink in 359 **York Sample ID:** 25J0320-15

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 11:15 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**3.37**		ug/L	1.00	1	EPA 200.8	10/09/2025 09:21	10/09/2025 10:43	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-(		

Sample Information

Client Sample ID: C-16 Sink in 360 **York Sample ID:** 25J0320-16

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 11:16 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst

Sample Information

Client Sample ID: C-16 Sink in 360 **York Sample ID:** 25J0320-16

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 11:16 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**2.53**		ug/L	1.00	1	EPA 200.8	10/09/2025 09:21	10/09/2025 10:47	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-(		

Sample Information

Client Sample ID: C-17 Sink in 361 **York Sample ID:** 25J0320-17

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 11:17 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**2.29**		ug/L	1.00	1	EPA 200.8	10/09/2025 09:21	10/09/2025 10:48	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-(		

Sample Information

Client Sample ID: C-18 Sink in 350 **York Sample ID:** 25J0320-18

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 11:20 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**2.33**		ug/L	1.00	1	EPA 200.8	10/09/2025 09:23	10/09/2025 10:53	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-(		

Sample Information

Client Sample ID: C-19 Sink in 251 **York Sample ID:** 25J0320-19

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 11:25 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Information

Client Sample ID: C-19 Sink in 251 **York Sample ID:** 25J0320-19

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 11:25 am	10/06/2025

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**2.49**		ug/L	1.00	1	EPA 200.8	10/09/2025 09:23	10/09/2025 10:58	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-(		

Sample Information

Client Sample ID: C-20 Sink in 252 **York Sample ID:** 25J0320-20

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 11:26 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**1.73**		ug/L	1.00	1	EPA 200.8	10/09/2025 09:23	10/09/2025 11:01	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-(		

Sample Information

Client Sample ID: C-21 Sink in 253 **York Sample ID:** 25J0320-21

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 11:27 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**1.94**		ug/L	1.00	1	EPA 200.8	10/09/2025 09:23	10/09/2025 11:06	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-(		

Sample Information

Client Sample ID: C-22 Sink in 250 **York Sample ID:** 25J0320-22

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 11:29 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst

Sample Information

Client Sample ID: C-22 Sink in 250 **York Sample ID:** 25J0320-22

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 11:29 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**1.06**		ug/L	1.00	1	EPA 200.8	10/09/2025 09:23	10/09/2025 11:07	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-(		

Sample Information

Client Sample ID: C-23 Water fountain across 253 **York Sample ID:** 25J0320-23

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 11:30 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	10/09/2025 09:23	10/09/2025 11:08	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: C-24 Bottle filler across 253 **York Sample ID:** 25J0320-24

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 11:30 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	10/09/2025 09:23	10/09/2025 11:10	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: C-25 Water fountain across 257 **York Sample ID:** 25J0320-25

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 11:33 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Information

Client Sample ID: C-25 Water fountain across 257 **York Sample ID:** 25J0320-25

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 11:33 am	10/06/2025

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	10/09/2025 09:23	10/09/2025 11:11	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: C-26 Bottle filler across 257 **York Sample ID:** 25J0320-26

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 11:33 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	10/09/2025 09:23	10/09/2025 11:12	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: C-27 Sink in 254 **York Sample ID:** 25J0320-27

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 11:35 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**1.21**		ug/L	1.00	1	EPA 200.8	10/09/2025 09:23	10/09/2025 11:14	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: C-28 Sink in 257 **York Sample ID:** 25J0320-28

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 11:38 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst

Sample Information

Client Sample ID: C-28 Sink in 257 **York Sample ID:** 25J0320-28

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 11:38 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	10/09/2025 09:23	10/09/2025 11:15	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: C-29 Sink in 256 **York Sample ID:** 25J0320-29

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 11:39 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**1.06**		ug/L	1.00	1	EPA 200.8	10/09/2025 09:23	10/09/2025 11:16	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: C-30 Sink in 255 **York Sample ID:** 25J0320-30

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 11:40 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**1.72**		ug/L	1.00	1	EPA 200.8	10/09/2025 09:23	10/09/2025 11:18	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: C-31 Water fountain across Library **York Sample ID:** 25J0320-31

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 11:42 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Information

Client Sample ID: C-31 Water fountain across Library **York Sample ID:** 25J0320-31

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 11:42 am	10/06/2025

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	10/09/2025 09:23	10/09/2025 11:22	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: C-32 Bottle filler across Library **York Sample ID:** 25J0320-32

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 11:42 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	10/09/2025 09:23	10/09/2025 11:23	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: C-33 Sink in 201 (Faculty lounge) **York Sample ID:** 25J0320-33

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 11:48 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**2.49**		ug/L	1.00	1	EPA 200.8	10/09/2025 09:23	10/09/2025 11:24	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: C-34 Water fountain across 308 **York Sample ID:** 25J0320-34

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 12:00 pm	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst

Sample Information

Client Sample ID: C-34 Water fountain across 308 **York Sample ID:** 25J0320-34

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 12:00 pm	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	10/09/2025 09:23	10/09/2025 11:26	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: C-35 Bottle filler across 308 **York Sample ID:** 25J0320-35

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 12:00 pm	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	10/09/2025 09:23	10/09/2025 11:27	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: C-36 Sink in 303 **York Sample ID:** 25J0320-36

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 12:04 pm	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**2.44**		ug/L	1.00	1	EPA 200.8	10/09/2025 09:23	10/09/2025 11:28	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: C-37 Sink in 302 **York Sample ID:** 25J0320-37

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 12:04 pm	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Information

Client Sample ID: C-37 Sink in 302 **York Sample ID:** 25J0320-37

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 12:04 pm	10/06/2025

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**2.61**		ug/L	1.00	1	EPA 200.8	10/09/2025 09:23	10/09/2025 11:30	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-(		

Sample Information

Client Sample ID: C-38 Sink in 301 **York Sample ID:** 25J0320-38

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 12:05 pm	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**3.66**		ug/L	1.00	1	EPA 200.8	10/09/2025 09:26	10/09/2025 11:34	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-(		

Sample Information

Client Sample ID: C-39 Water fountain outside 310 **York Sample ID:** 25J0320-39

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 12:07 pm	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	10/09/2025 09:26	10/09/2025 11:40	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: C-40 Bottle filler outside 310 **York Sample ID:** 25J0320-40

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 12:07 pm	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst

Sample Information

Client Sample ID: **C-40 Bottle filler outside 310** **York Sample ID:** **25J0320-40**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 12:07 pm	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	10/09/2025 09:26	10/09/2025 11:43	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: **C-41 Water fountain in 312** **York Sample ID:** **25J0320-41**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 12:10 pm	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**3.08**		ug/L	1.00	1	EPA 200.8	10/09/2025 09:26	10/09/2025 11:44	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: **C-42 Bottle filler in 312** **York Sample ID:** **25J0320-42**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 12:10 pm	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**2.85**		ug/L	1.00	1	EPA 200.8	10/09/2025 09:26	10/09/2025 11:46	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: **C-43 Sink in 101** **York Sample ID:** **25J0320-43**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 12:18 pm	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Information

Client Sample ID: C-43 Sink in 101 **York Sample ID:** 25J0320-43

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 12:18 pm	10/06/2025

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**4.08**		ug/L	1.00	1	EPA 200.8	10/09/2025 09:26	10/09/2025 11:47	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-(		

Sample Information

Client Sample ID: C-44 Water fountain outside 101 **York Sample ID:** 25J0320-44

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 12:19 pm	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	10/09/2025 09:26	10/09/2025 11:48	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: C-45 Bottle fill outside 101 **York Sample ID:** 25J0320-45

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 12:20 pm	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	10/09/2025 09:26	10/09/2025 11:50	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: C-46 Water fountain across 156 **York Sample ID:** 25J0320-46

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 12:22 pm	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst

Sample Information

Client Sample ID: C-46 Water fountain across 156 **York Sample ID:** 25J0320-46

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 12:22 pm	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	10/09/2025 09:26	10/09/2025 11:54	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: C-47 Bottle filler across 156 **York Sample ID:** 25J0320-47

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 12:22 pm	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	10/09/2025 09:26	10/09/2025 11:55	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: C-48 Sink in 153 **York Sample ID:** 25J0320-48

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 12:24 pm	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**18.4**	M-PbE X	ug/L	1.00	1	EPA 200.8	10/09/2025 09:26	10/09/2025 11:56	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-(		

Sample Information

Client Sample ID: C-49 Sink in 155 **York Sample ID:** 25J0320-49

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 12:26 pm	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Information

Client Sample ID: C-49 Sink in 155 **York Sample ID:** 25J0320-49

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 12:26 pm	10/06/2025

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	10/09/2025 09:26	10/09/2025 11:58	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: C-50 Sink in 160 **York Sample ID:** 25J0320-50

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 12:28 pm	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**6.36**	M-PbE X	ug/L	1.00	1	EPA 200.8	10/09/2025 09:26	10/09/2025 11:59	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-(		

Sample Information

Client Sample ID: C-51 Water fountain across 160 **York Sample ID:** 25J0320-51

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 12:29 pm	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	10/09/2025 09:26	10/09/2025 12:00	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: C-52 Bottle filler across 160 **York Sample ID:** 25J0320-52

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 12:29 pm	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst

Sample Information

Client Sample ID: **C-52 Bottle filler across 160** **York Sample ID:** **25J0320-52**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 12:29 pm	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	10/09/2025 09:26	10/09/2025 12:02	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: **C-53 Sink in 165** **York Sample ID:** **25J0320-53**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0320	256977 Mamaroneck UFSD- Central Avenue Elementary School	Drinking Water	October 2, 2025 12:32 pm	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**5.98**	M-PbE X	ug/L	1.00	1	EPA 200.8	10/09/2025 09:26	10/09/2025 12:03	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Analytical Batch Summary

Batch ID: BJ50589 **Preparation Method:** EPA 200.8 **Prepared By:** JWT

YORK Sample ID	Client Sample ID	Preparation Date
25J0320-01	C-01 Sink in 351	10/09/25
25J0320-02	C-02 Sink in 352	10/09/25
25J0320-03	C-03 Sink in 353	10/09/25
25J0320-04	C-04 Water fountain across 353	10/09/25
25J0320-05	C-05 Bottle filler across 353	10/09/25
25J0320-06	C-06 Sink in 354	10/09/25
25J0320-07	C-07 Water fountain across 357	10/09/25
25J0320-08	C-08 Bottle filler across 357	10/09/25
25J0320-09	C-09 Sink in 357	10/09/25
25J0320-10	C-10 Sink in 356	10/09/25
25J0320-11	C-11 Sink in 355	10/09/25
25J0320-12	C-12 Sink in 358	10/09/25
25J0320-13	C-13 Water fountain across 358	10/09/25
25J0320-14	C-14 Bottle filler across 358	10/09/25
25J0320-15	C-15 Sink in 359	10/09/25
25J0320-16	C-16 Sink in 360	10/09/25
25J0320-17	C-17 Sink in 361	10/09/25
BJ50589-BLK1	Blank	10/09/25
BJ50589-BS1	LCS	10/09/25
BJ50589-DUP1	Duplicate	10/09/25
BJ50589-MS1	Matrix Spike	10/09/25
BJ50589-MS2	Matrix Spike	10/09/25

Batch ID: BJ50590 **Preparation Method:** EPA 200.8 **Prepared By:** JWT

YORK Sample ID	Client Sample ID	Preparation Date
25J0320-18	C-18 Sink in 350	10/09/25
25J0320-19	C-19 Sink in 251	10/09/25
25J0320-20	C-20 Sink in 252	10/09/25
25J0320-21	C-21 Sink in 253	10/09/25
25J0320-22	C-22 Sink in 250	10/09/25
25J0320-23	C-23 Water fountain across 253	10/09/25
25J0320-24	C-24 Bottle filler across 253	10/09/25
25J0320-25	C-25 Water fountain across 257	10/09/25
25J0320-26	C-26 Bottle filler across 257	10/09/25
25J0320-27	C-27 Sink in 254	10/09/25
25J0320-28	C-28 Sink in 257	10/09/25
25J0320-29	C-29 Sink in 256	10/09/25
25J0320-30	C-30 Sink in 255	10/09/25
25J0320-31	C-31 Water fountain across Libı	10/09/25
25J0320-32	C-32 Bottle filler across Library	10/09/25
25J0320-33	C-33 Sink in 201 (Faculty loun	10/09/25
25J0320-34	C-34 Water fountain across 308	10/09/25
25J0320-35	C-35 Bottle filler across 308	10/09/25
25J0320-36	C-36 Sink in 303	10/09/25
25J0320-37	C-37 Sink in 302	10/09/25

BJ50590-BLK1	Blank	10/09/25
BJ50590-BS1	LCS	10/09/25
BJ50590-DUP1	Duplicate	10/09/25
BJ50590-MS1	Matrix Spike	10/09/25
BJ50590-MS2	Matrix Spike	10/09/25

Batch ID: BJ50591 **Preparation Method:** EPA 200.8 **Prepared By:** JWT

YORK Sample ID	Client Sample ID	Preparation Date
25J0320-38	C-38 Sink in 301	10/09/25
25J0320-39	C-39 Water fountain outside 31(	10/09/25
25J0320-40	C-40 Bottle filler outside 310	10/09/25
25J0320-41	C-41 Water fountain in 312	10/09/25
25J0320-42	C-42 Bottle filler in 312	10/09/25
25J0320-43	C-43 Sink in 101	10/09/25
25J0320-44	C-44 Water fountain outside 10	10/09/25
25J0320-45	C-45 Bottle fill outside 101	10/09/25
25J0320-46	C-46 Water fountain across 156	10/09/25
25J0320-47	C-47 Bottle filler across 156	10/09/25
25J0320-48	C-48 Sink in 153	10/09/25
25J0320-49	C-49 Sink in 155	10/09/25
25J0320-50	C-50 Sink in 160	10/09/25
25J0320-51	C-51 Water fountain across 160	10/09/25
25J0320-52	C-52 Bottle filler across 160	10/09/25
25J0320-53	C-53 Sink in 165	10/09/25
BJ50591-BLK1	Blank	10/09/25
BJ50591-BS1	LCS	10/09/25
BJ50591-DUP1	Duplicate	10/09/25
BJ50591-MS1	Matrix Spike	10/09/25
BJ50591-MS2	Matrix Spike	10/09/25

Metals by ICP/MS - Quality Control Data

York Analytical Laboratories, Inc.

Analyte	Result	Reporting Limit	Units	Spike Level	Source* Result	%REC	%REC Limits	Flag	RPD	RPD Limit	Flag
Batch BJ50589 - EPA 200.8											
Blank (BJ50589-BLK1)								Prepared & Analyzed: 10/09/2025			
Lead	ND	1.00	ug/L								
LCS (BJ50589-BS1)								Prepared & Analyzed: 10/09/2025			
Lead	53.0		ug/L	50.0		106	85-115				
Duplicate (BJ50589-DUP1)	*Source sample: 25J0320-01 (C-01 Sink in 351)							Prepared & Analyzed: 10/09/2025			
Lead	2.92	1.00	ug/L		2.90				0.447	20	
Matrix Spike (BJ50589-MS1)	*Source sample: 25J0320-01 (C-01 Sink in 351)							Prepared & Analyzed: 10/09/2025			
Lead	55.5		ug/L	50.0	2.90	105	75-125				
Matrix Spike (BJ50589-MS2)	*Source sample: 25J0320-02 (C-02 Sink in 352)							Prepared & Analyzed: 10/09/2025			
Lead	55.6		ug/L	50.0	2.17	107	75-125				
Batch BJ50590 - EPA 200.8											
Blank (BJ50590-BLK1)								Prepared & Analyzed: 10/09/2025			
Lead	ND	1.00	ug/L								
LCS (BJ50590-BS1)								Prepared & Analyzed: 10/09/2025			
Lead	51.7		ug/L	50.0		103	85-115				
Duplicate (BJ50590-DUP1)	*Source sample: 25J0320-18 (C-18 Sink in 350)							Prepared & Analyzed: 10/09/2025			
Lead	2.26	1.00	ug/L		2.33				2.88	20	
Matrix Spike (BJ50590-MS1)	*Source sample: 25J0320-18 (C-18 Sink in 350)							Prepared & Analyzed: 10/09/2025			
Lead	55.7		ug/L	50.0	2.33	107	75-125				

Metals by ICP/MS - Quality Control Data

York Analytical Laboratories, Inc.

Analyte	Result	Reporting Limit	Units	Spike Level	Source* Result	%REC	%REC Limits	Flag	RPD	RPD Limit	Flag
Batch BJ50590 - EPA 200.8											
Matrix Spike (BJ50590-MS2)	*Source sample: 25J0320-19 (C-19 Sink in 251)							Prepared & Analyzed: 10/09/2025			
Lead	55.5		ug/L	50.0	2.49	106	75-125				
Batch BJ50591 - EPA 200.8											
Blank (BJ50591-BLK1)								Prepared & Analyzed: 10/09/2025			
Lead	ND	1.00	ug/L								
LCS (BJ50591-BS1)								Prepared & Analyzed: 10/09/2025			
Lead	51.9		ug/L	50.0		104	85-115				
Duplicate (BJ50591-DUP1)	*Source sample: 25J0320-38 (C-38 Sink in 301)							Prepared & Analyzed: 10/09/2025			
Lead	3.63	1.00	ug/L		3.66				0.822	20	
Matrix Spike (BJ50591-MS1)	*Source sample: 25J0320-38 (C-38 Sink in 301)							Prepared & Analyzed: 10/09/2025			
Lead	56.4		ug/L	50.0	3.66	106	75-125				
Matrix Spike (BJ50591-MS2)	*Source sample: 25J0320-39 (C-39 Water fountain outside 310)							Prepared & Analyzed: 10/09/2025			
Lead	52.6		ug/L	50.0	0.190	105	75-125				

Sample and Data Qualifiers Relating to This Work Order

M-PbEX Lead result exceeds regulatory limit

Definitions and Other Explanations

*	Analyte is not certified or the state of the samples origination does not offer certification for the Analyte.
ND	NOT DETECTED - the analyte is not detected at the Reported to level (LOQ/RL or LOD/MDL)
RL	REPORTING LIMIT - the minimum reportable value based upon the lowest point in the analyte calibration curve.
LOQ	LIMIT OF QUANTITATION - the minimum concentration of a target analyte that can be reported within a specified degree of confidence. This is the lowest point in an analyte calibration curve that has been subjected to all steps of the processing/analysis and verified to meet defined criteria. This is based upon NELAC 2009 Standards and applies to all analyses.
LOD	LIMIT OF DETECTION - a verified estimate of the minimum concentration of a substance in a given matrix that an analytical process can reliably detect. This is based upon NELAC 2009 Standards and applies to all analyses conducted under the auspices of EPA SW-846.
MDL	METHOD DETECTION LIMIT - a statistically derived estimate of the minimum amount of a substance an analytical system can reliably detect with a 99% confidence that the concentration of the substance is greater than zero. This is based upon 40 CFR Part 136 Appendix B and applies only to EPA 600 and 200 series methods.
Reported to	This indicates that the data for a particular analysis is reported to either the LOD/MDL, or the LOQ/RL. In cases where the "Reported to" is located above the LOD/MDL, any value between this and the LOQ represents an estimated value which is "J" flagged accordingly. This applies to volatile and semi-volatile target compounds only.
NR	Not reported
RPD	Relative Percent Difference
Wet	The data has been reported on an as-received (wet weight) basis
Low Bias	Low Bias flag indicates that the recovery of the flagged analyte is below the laboratory or regulatory lower control limit. The data user should take note that this analyte may be biased low but should evaluate multiple lines of evidence including the LCS and site-specific MS/MSD data to draw bias conclusions. In cases where no site-specific MS/MSD was requested, only the LCS data can be used to evaluate such bias.
High Bias	High Bias flag indicates that the recovery of the flagged analyte is above the laboratory or regulatory upper control limit. The data user should take note that this analyte may be biased high but should evaluate multiple lines of evidence including the LCS and site-specific MS/MSD data to draw bias conclusions. In cases where no site-specific MS/MSD was requested, only the LCS data can be used to evaluate such bias.
Non-Dir.	Non-dir. flag (Non-Directional Bias) indicates that the Relative Percent Difference (RPD) (a measure of precision) among the MS and MSD data is outside the laboratory or regulatory control limit. This alerts the data user where the MS and MSD are from site-specific samples that the RPD is high due to either non-homogeneous distribution of target analyte between the MS/MSD or indicates poor reproducibility for other reasons.

If EPA SW-846 method 8270 is included herein it is noted that the target compound N-nitrosodiphenylamine (NDPA) decomposes in the gas chromatographic inlet and cannot be separated from diphenylamine (DPA). These results could actually represent 100% DPA, 100% NDPA or some combination of the two. For this reason, York reports the combined result for n-nitrosodiphenylamine and diphenylamine for either of these compounds as a combined concentration as Diphenylamine.

If Total PCBs are detected and the target aroclors reported are "Not detected", the Total PCB value is reported due to the presence of either or both Aroclors 1262 and 1268 which are non-target aroclors for some regulatory lists.

2-chloroethylvinyl ether readily breaks down under acidic conditions. Samples that are acid preserved, including standards will exhibit breakdown. The data user should take note.

Certification for pH is no longer offered by NYDOH ELAP.

Semi-Volatile and Volatile analyses are reported down to the LOD/MDL, with values between the LOD/MDL and the LOQ being "J" flagged as estimated results.

For analyses by EPA SW-846-8270D, the Limit of Quantitation (LOQ) reported for benzidine is based upon the lowest standard used for calibration and is not a verified LOQ due to this compound's propensity for oxidative losses during extraction/concentration procedures and non-reproducible chromatographic performance.

Field Chain-of-Custody Record

YORK ANALYTICAL LABORATORIES INC

York Analytical Laboratories, Inc. (YORK)'s Standard Terms & Conditions are listed on the back side of this document. This legal document serves as your written authorization for YORK to proceed with the analyses requested below. Your signature binds you to YORK's Standard Terms & Conditions.

120 Research Drive Stratford, CT 06615 132-02 89th Ave Queens, NY 11418 56 Church Hill Rd. #2 Newtown, CT 06470 2161 Whitesville Rd Toms River, NJ 08755 clientservices@yorklab.com 800-306-YORK

YORK Project Number: 25J0320

Report To:	Invoice To:
Company: QuES&T	Company: Same
Address: 1376 US-9, Wappingers Falls, NY 12590	Address:
Phone.: 845-298-6031	Phone.:
Contact: Zach Timpano	Contact:
E-mail: lab@qualityenv.com	E-mail: ap@qualityenv.com

YOUR Project Name / Number: 256977 Mamaroneck UFSD-Central Avenue Elementary School

PO Number:

Samples Collected From: NY [X] CT [ ] Other: (please specify) NJ [ ] PA [ ]

Turn-Around Time

RUSH - Next Day	
RUSH - Two Day	
RUSH - Three Day	
RUSH - Four Day	
RUSH - Five Day	
Standard (6-9 Day)	x
PFAS Standard 7-10 Day	

Please print clearly and legibly. All information must be complete. Samples will not be logged in and the turn-around-time clock will not begin until any questions by YORK are resolved.

caroline annesi

Caroline Annesi

Samples Collected by: (print AND sign your name)

Matrix Codes

S - soil/solid/sludge
GW - groundwater
DW - drinking water
SW - surface water
WW - wastewater
O - Oil
Other

Preservative (please list number of containers)

Analyses Requested

Sample Identification	Date	Time	Matrix	Unpreserved	HCl (hydrochloric acid)	MeOH (methanol)	HNO_3 (nitric acid)	H_2SO_4 (sulfuric acid)	NaOH (sodium hydroxide)	$Na_2S_2O_3$ (sodium thio.)	Trizma	Ammonium Acetate	Other:	Lead	Grab or Comp.
C-01 Sink in 351	10/2	1100	DW				X							X	G
C-02 Sink in 352	10/2	1101	DW				X							X	G
C-03 Sink in 353	10/2	1101	DW				X							X	G
C-04 Water fountain across 353	10/2	1103	DW				X							X	G
C-05 Bottle filler across 353	10/2	1103	DW				X							X	G
C-06 Sink in 354	10/2	1104	DW				X							X	G
C-07 Water fountain across 357	10/2	1105	DW				X							X	G
C-08 Bottle filler across 357	10/2	1105	DW				X							X	G
C-09 Sink in 357	10/2	1107	DW				X							X	G
C-10 Sink in 356	10/2	1108	DW				X							X	G
C-11 Sink in 355	10/2	1110	DW				X							X	G
C-12 Sink in 358	10/2	1111	DW				X							X	G
C-13 Water fountain across 358	10/2	1113	DW				X							X	G
C-14 Bottle filler across 358	10/2	1113	DW				X							X	G
C-15 Sink in 359	10/2	1115	DW				X							X	G

Report Type (circle)
QA Report
Summary (Results Only)
NY ASP B Package
NJ Reduced
NJ DKQP
NJ Full
CT RCP

EDD Type (circle)
EQuIS (standard)
NYSDEC EQuIS
NJDEP SRP Haz Site
Standard Excel
CMDP
Other:

Regulatory Comparative
Compared to the following Regulation(s): (please fill in)

Field Filtered
Lab Filtered

Comments:

Samples iced/chilled at time of lab pickup? circle Yes or No

Lab Sample Receiving Checklist (to be completed by the receiving laboratory only) Circle Y / N

Custody Seals: Y / N Containers Intact: Y / N COC/Labels Agree: Y / N Preservation Confirmed: Y / N
COC Complete: Y / N COC Received: Y / N Appropriate Sample Volumes: Y / N Appropriate Sample Containers: Y / N
Cooler Temperature Confirmed: Y / N Samples Submitted within Holding Times: Y / N Corrective Action Form Required: Y / N

Samples Relinquished by / Company	Date/Time	1. Samples Received by / Company	Date/Time	2. Samples Relinquished by / Company	Date/Time
Caroline Annesi	10/6/25	Chris C	10-6-25 13:00	Chris C	10-6-25 1530
Samples Received by / Company	Date/Time	3. Samples Relinquished by / Company	Date/Time	3. Samples Received by / Company	Date/Time
Samples Relinquished by / Company	Date/Time	4. Samples Received by / Company	Date/Time	Samples Received in LAB by	Date/Time / Temperature
					10/6/25 1530 Degrees C 19.0

Field Chain-of-Custody Record

YORK ANALYTICAL LABORATORIES INC

York Analytical Laboratories, Inc. (YORK)'s Standard Terms & Conditions are listed on the back side of this document. This legal document serves as your written authorization for YORK to proceed with the analyses requested below. Your signature binds you to YORK's Standard Terms & Conditions.

120 Research Drive Stratford, CT 06615 132-02 89th Ave Queens, NY 11418 56 Church Hill Rd. #2 Newtown, CT 06470 2161 Whitesville Rd Toms River, NJ 08755 clientservices@yorklab.com 800-306-YORK

YORK Project Number: 25J0320

Report To:	Invoice To:
Company: QuES&T	Company: Same
Address: 1376 US-9, Wappingers Falls, NY 12590	Address:
Phone.: 845-298-6031	Phone.:
Contact: Zach Timpano	Contact:
E-mail: lab@qualityenv.com	E-mail: ap@qualityenv.com

YOUR Project Name / Number: 256977 Mamaroneck UFSD-Central Avenue Elementary School

PO Number:

Samples Collected From: NY X, NJ, CT, PA, Other: (please specify)

Please print clearly and legibly. All information must be complete. Samples will not be logged in and the turn-around-time clock will not begin until any questions by YORK are resolved.

Caroline Annese

Samples Collected by: (print AND sign your name)

Matrix Codes: S - soil/solid/sludge; GW - groundwater; DW - drinking water; SW - surface water; WW - wastewater; O - Oil; Other

Preservative (please list number of containers)

Analyses Requested

Sample Identification	Date	Time	Matrix	Unpreserved	HCl (hydrochloric acid)	MeOH (methanol)	HNO_3 (nitric acid)	H_2SO_4 (sulfuric acid)	NaOH (sodium hydroxide)	$Na_2S_2O_3$ (sodium thio.)	Trizma	Ammonium Acetate	Other:	Lead	Grab or Comp.
C-16 Sink in 360	10/2	1116	DW				X							X	G
C-17 Sink in 361	10/2	1117	DW				X							X	G
C-18 Sink in 350	10/2	1120	DW				X							X	G
C-19 Sink in 251	10/2	1125	DW				X							X	G
C-20 Sink in 252	10/2	1126	DW				X							X	G
C-21 Sink in 253	10/2	1127	DW				X							X	G
C-22 Sink in 250	10/2	1129	DW				X							X	G
C-23 Water fountain across 253	10/2	1130	DW				X							X	G
C-24 Bottle filler across 253	10/2	1130	DW				X							X	G
C-25 Water fountain across 257	10/2	1133	DW				X							X	G
C-26 Bottle filler across 257	10/2	1133	DW				X							X	G
C-27 Sink in 254	10/2	1135	DW				X							X	G
C-28 Sink in 257	10/2	1138	DW				X							X	G
C-29 Sink in 256	10/2	1139	DW				X							X	G
C-30 Sink in 255	10/2	1140	DW				X							X	G

Turn-Around Time

- RUSH - Next Day
- RUSH - Two Day
- RUSH - Three Day
- RUSH - Four Day
- RUSH - Five Day
- Standard (6-9 Day) x
- PFAS Standard 7-10 Day

Report Type (circle)

QA Report; Summary (Results Only); NY ASP B Package; NJ Reduced; NJ DKQP; NJ Full; CT RCP

EDD Type (circle)

EQuIS (standard); NYSDEC EQuIS; NJDEP SRP Haz Site; Standard Excel; CMDP; Other:

Regulatory Comparative

Compared to the following Regulation(s): (please fill in)

- Field Filtered
- Lab Filtered

Comments:

Samples iced/chilled at time of lab pickup? circle Yes or No

Lab Sample Receiving Checklist (to be completed by the receiving laboratory only) Circle Y / N

Custody Seals: Y / N Containers Intact: Y / N COC/Labels Agree: Y / N Preservation Confirmed: Y / N
COC Complete: Y / N COC Received: Y / N Appropriate Sample Volumes: Y / N Appropriate Sample Containers: Y / N
Cooler Temperature Confirmed: Y / N Samples Submitted within Holding Times: Y / N Corrective Action Form Required: Y / N

1. Samples Relinquished by / Company: Caroline Annese — Date/Time: 10/6/25	1. Samples Received by / Company: Cheri C — Date/Time: 10-6-25 17:00	2. Samples Relinquished by / Company: Cheri C — Date/Time: 10-6-25 15:30
2. Samples Received by / Company — Date/Time	3. Samples Relinquished by / Company — Date/Time	3. Samples Received by / Company — Date/Time
3. Samples Relinquished by / Company — Date/Time	4. Samples Received by / Company — Date/Time	Samples Received in LAB by — Date/Time: 10/6/25 15:30 — Temperature: Degrees C 19.0

Field Chain-of-Custody Record

YORK
ANALYTICAL LABORATORIES INC

York Analytical Laboratories, Inc. (YORK)'s Standard Terms & Conditions are listed on the back side of this document. This legal document serves as your written authorization for YORK to proceed with the analyses requested below. Your signature binds you to YORK's Standard Terms & Conditions.

120 Research Drive Stratford, CT 06615 132-02 89th Ave Queens, NY 11418 56 Church Hill Rd. #2 Newtown, CT 06470 2161 Whitesville Rd Toms River, NJ 08755 clientservices@yorklab.com 800-306-YORK

YORK Project Number: 25J0320

Report To:	Invoice To:
Company: QuES&T	Company: Same
Address: 1376 US-9, Wappingers Falls, NY 12590	Address:
Phone.: 845-298-6031	Phone.:
Contact: Zach Timpano	Contact:
E-mail: lab@qualityenv.com	E-mail: ap@qualityenv.com

YOUR Project Name / Number: 256977 Mamaroneck UFSD- Central Avenue Elemetary School

PO Number:

Samples Collected From: NY X, NJ, CT, PA, Other: (please specify)

Please print clearly and legibly. All information must be complete. Samples will not be logged in and the turn-around-time clock will not begin until any questions by YORK are resolved.

Caroline Annesi

Caroline Annesi

Samples Collected by: (print AND sign your name)

Matrix Codes: S - soil/solid/sludge; GW - groundwater; DW - drinking water; SW - surface water; WW - wastewater; O - Oil; Other

Preservative (please list number of containers)

Analyses Requested

Sample Identification	Date	Time	Matrix	Unpreserved	HCl (hydrochloric acid)	MeOH (methanol)	HNO_3 (nitric acid)	H_2SO_4 (sulfuric acid)	NaOH (sodium hydroxide)	$Na_2S_2O_3$ (sodium thio.)	Trizma	Ammonium Acetate	Other:	Lead	Grab or Comp.
C-31 Water fountain across Library	10/2	1142	DW				X							X	G
C-32 Bottle filler across Library	10/2	1142	DW				X							X	G
C-33 Sink in 201 (Faculty lounge)	10/2	1148	DW				X							X	G
C-34 Water fountain across 308	10/2	1200	DW				X							X	G
C-35 Bottle filler across 308	10/2	1200	DW				X							X	G
C-36 Sink in 303	10/2	1204	DW				X							X	G
C-37 Sink in 302	10/2	1204	DW				X							X	G
C-38 Sink in 301	10/2	1205	DW				X							X	G
C-39 Water fountain outside 310	10/2	1207	DW				X							X	G
C-40 Bottle filler outside 310	10/2	1207	DW				X							X	G
C-41 Water fountain in 312	10/2	1210	DW				X							X	G
C-42 Bottle filler in 312	10/2	1210	DW				X							X	G
C-43 Sink in 101	10/2	1218	DW				X							X	G
C-44 Water fountain outside 101	10/2	1219	DW				X							X	G
C-45 Bottle fill outside 101	10/2	1220	DW				X							X	G

Turn-Around Time

- RUSH - Next Day
- RUSH - Two Day
- RUSH - Three Day
- RUSH - Four Day
- RUSH - Five Day
- Standard (6-9 Day) x
- PFAS Standard 7-10 Day

Report Type (circle)

- QA Report
- Summary (Results Only)
- NY ASP B Package
- NJ Reduced
- NJ DKQP
- NJ Full
- CT RCP

EDD Type (circle)

- EQuIS (standard)
- NYSDEC EQuIS
- NJDEP SRP Haz Site
- Standard Excel
- CMDP
- Other:

Regulatory Comparative

Compared to the following Regulation(s): (please fill in)

- Field Filtered
- Lab Filtered

Comments:

Lab Sample Receiving Checklist (to be completed by the receiving laboratory only) Circle Y / N

Custody Seals: Y / N Containers Intact: Y / N COC/Labels Agree: Y / N Preservation Confirmed: Y / N
COC Complete: Y / N COC Received: Y / N Appropriate Sample Volumes: Y / N Appropriate Sample Containers: Y / N
Cooler Temperature Confirmed: Y / N Samples Submitted within Holding Times: Y / N Corrective Action Form Required: Y / N

Samples iced/chilled at time of lab pickup? circle Yes or No

	Samples Relinquished by / Company	Date/Time	Samples Received by / Company	Date/Time	Samples Relinquished by / Company	Date/Time
1	Caroline Annesi	10/6/25	1. Chris C	10.6.25 13:00	2. Chris C	10.6.25 15:30
2	Samples Received by / Company	Date/Time	3. Samples Relinquished by / Company	Date/Time	3. Samples Received by / Company	Date/Time
3						
4	Samples Relinquished by / Company	Date/Time	4. Samples Received by / Company	Date/Time	Samples Received in LAB by	Date/Time / Temperature
						10/6/25 15:30 / Degrees C 19.0

Field Chain-of-Custody Record

YORK ANALYTICAL LABORATORIES INC

York Analytical Laboratories, Inc. (YORK)'s Standard Terms & Conditions are listed on the back side of this document. This legal document serves as your written authorization for YORK to proceed with the analyses requested below. Your signature binds you to YORK's Standard Terms & Conditions.

120 Research Drive Stratford, CT 06615 132-02 89th Ave Queens, NY 11418 56 Church Hill Rd. #2 Newtown, CT 06470 2161 Whitesville Rd Toms River, NJ 08755 clientservices@yorklab.com 800-306-YORK

YORK Project Number: 25J0320

Report To:	Invoice To:
Company: QuES&T	Company: Same
Address: 1376 US-9, Wappingers Falls, NY 12590	Address:
Phone.: 845-298-6031	Phone.:
Contact: Zach Timpano	Contact:
E-mail: lab@qualityenv.com	E-mail: ap@qualityenv.com

YOUR Project Name / Number: 256977 Mamaroneck UFSD-Central Avenue Elementary School

PO Number:

Samples Collected From: NY X, NJ, CT, PA, Other: (please specify)

Turn-Around Time: RUSH - Next Day; RUSH - Two Day; RUSH - Three Day; RUSH - Four Day; RUSH - Five Day; Standard (6-9 Day) x; PFAS Standard 7-10 Day

Please print clearly and legibly. All information must be complete. Samples will not be logged in and the turn-around-time clock will not begin until any questions by YORK are resolved.

Caroline Annesi

Samples Collected by: (print AND sign your name)

Matrix Codes: S - soil/solid/sludge; GW - groundwater; DW - drinking water; SW - surface water; WW - wastewater; O - Oil; Other

Preservative (please list number of containers)

Analyses Requested

Sample Identification	Date	Time	Matrix	Unpreserved	HCl (hydrochloric acid)	MeOH (methanol)	HNO_3 (nitric acid)	H_2SO_4 (sulfuric acid)	NaOH (sodium hydroxide)	$Na_2S_2O_3$ (sodium thio.)	Trizma	Ammonium Acetate	Other:	Lead	Grab or Comp.
C-46 Water fountain across 156	10/2	1222	DW				X							X	G
C-47 Bottle filler across 156	10/2	1222	DW				X							X	G
C-48 Sink in 153	10/2	1224	DW				X							X	G
C-49 Sink in 155	10/2	1226	DW				X							X	G
C-50 Sink in 160	10/2	1228	DW				X							X	G
C-51 Water fountain across 160	10/2	1229	DW				X							X	G
C-52 Bottle filler across 160	10/2	1229	DW				X							X	G
C-53 Sink in 165	10/2	1232	DW				X							X	G

Report Type (circle): QA Report; Summary (Results Only); NY ASP B Package; NJ Reduced; NJ DKQP; NJ Full; CT RCP

EDD Type (circle): EQuIS (standard); NYSDEC EQuIS; NJDEP SRP Haz Site; Standard Excel; CMDP; Other:

Regulatory Comparative

Compared to the following Regulation(s): (please fill in)

Field Filtered

Lab Filtered

Comments:

Lab Sample Receiving Checklist (to be completed by the receiving laboratory only) Circle Y / N

Custody Seals: Y / N Containers Intact: Y / N COC/Labels Agree: Y / N Preservation Confirmed: Y / N

COC Complete: Y / N COC Received: Y / N Appropriate Sample Volumes: Y / N Appropriate Sample Containers: Y / N

Cooler Temperature Confirmed: Y / N Samples Submitted within Holding Times: Y / N Corrective Action Form Required: Y / N

Samples iced/chilled at time of lab pickup? circle Yes or No

Samples Relinquished by / Company	Date/Time	1. Samples Received by / Company	Date/Time	2. Samples Relinquished by / Company	Date/Time
Annesi	10/6/25	Chris C	10-6-25 13:00	Chris C	10-6-25 15:30
Samples Received by / Company	Date/Time	3. Samples Relinquished by / Company	Date/Time	3. Samples Received by / Company	Date/Time
Samples Relinquished by / Company	Date/Time	4. Samples Received by / Company	Date/Time	Samples Received in LAB by	Date/Time: 10/6/25 15:30 Temperature: Degrees C 19.0