Technical Report

prepared for:

QuES & T
1376 Rt. 9
Wappingers Falls NY, 12590
Attention: Zachary P. Timpano

Report Date: 10/10/2025
Client Project ID: 256977-Mamaroneck UFSD-Chatsworth Ave Elementary School
York Project (SDG) No.: 25J0322

Stratford, CT Laboratory IDs:
NY:10854, NJ: CT005, PA: 68-0440, CT: PH-0723

Richmond Hill, NY Laboratory IDs:
NY:12058, NJ: NY037, CT: PH-0721, NH: 2097,
EPA: NY01600

120 RESEARCH DRIVE STRATFORD, CT 06615 ■ 132-02 89th AVENUE RICHMOND HILL, NY 11418
www.YORKLAB.com (203) 325-1371 FAX (203) 357-0166 ClientServices@yorklab.com

Report Date: 10/10/2025
Client Project ID: 256977-Mamaroneck UFSD-Chatsworth Ave Elementary School
York Project (SDG) No.: 25J0322

QuES & T
1376 Rt. 9
Wappingers Falls NY, 12590
Attention: Zachary P. Timpano

Purpose and Results

This report contains the analytical data for the sample(s) identified on the attached chain-of-custody received in our laboratory on October 06, 2025 and listed below. The project was identified as your project: **256977-Mamaroneck UFSD-Chatsworth Ave Elementary School**.

The analyses were conducted utilizing appropriate EPA, Standard Methods, and ASTM methods as detailed in the data summary tables.

All samples were received in proper condition meeting the customary acceptance requirements for environmental samples except those indicated under the Sample and Analysis Qualifiers section of this report.

All analyses met the method and laboratory standard operating procedure requirements except as indicated by any data flags, the meaning of which are explained in the Sample and Data Qualifiers Relating to This Work Order section of this report and case narrative if applicable.

The results of the analyses, which are all reported on dry weight basis (soils) unless otherwise noted, are detailed in the following pages.

Please contact Client Services at 203.325.1371 with any questions regarding this report.

York Sample ID	Client Sample ID	Matrix	Date Collected	Date Received
25J0322-01	CH-01 Water fountain outside 102	Drinking Water	10/02/2025	10/06/2025
25J0322-02	CH-02 Bottle Filler outside 102	Drinking Water	10/02/2025	10/06/2025
25J0322-03	CH-03 Left dish sink in Kitchen	Drinking Water	10/02/2025	10/06/2025
25J0322-04	CH-04 Rightt dish sink in Kitchen	Drinking Water	10/02/2025	10/06/2025
25J0322-05	CH-05 Handwashing sink in Kitchen	Drinking Water	10/02/2025	10/06/2025
25J0322-06	CH-06 Island sink in Kitchen	Drinking Water	10/02/2025	10/06/2025
25J0322-07	CH-07 Island sink in Kitchen	Drinking Water	10/02/2025	10/06/2025
25J0322-08	CH-08 Water fountain in Cafeteria	Drinking Water	10/02/2025	10/06/2025
25J0322-09	CH-09 Water fountain in Cafeteria	Drinking Water	10/02/2025	10/06/2025
25J0322-10	CH-10 Bottle Filler in Cafeteria	Drinking Water	10/02/2025	10/06/2025
25J0322-11	CH-11 Sink in Office 101	Drinking Water	10/02/2025	10/06/2025
25J0322-12	CH-12 Water fountain outside 106	Drinking Water	10/02/2025	10/06/2025
25J0322-13	CH-13 Bottle filler outside 106	Drinking Water	10/02/2025	10/06/2025
25J0322-14	CH-14 Sink in music room	Drinking Water	10/02/2025	10/06/2025
25J0322-15	CH-15 Sink in strings room	Drinking Water	10/02/2025	10/06/2025
25J0322-16	CH-16 Sink Library storage	Drinking Water	10/02/2025	10/06/2025
25J0322-17	CH-17 Sink in classroom 10	Drinking Water	10/02/2025	10/06/2025
25J0322-18	CH-18 Sink in classroom 11	Drinking Water	10/02/2025	10/06/2025
25J0322-19	CH-19 Sink in classroom 12	Drinking Water	10/02/2025	10/06/2025
25J0322-20	CH-20 Water fountain outside classroom 12	Drinking Water	10/02/2025	10/06/2025
25J0322-21	CH-21 Bottle filler outside classroom 12	Drinking Water	10/02/2025	10/06/2025
25J0322-22	CH-22 Sink in classroom 14	Drinking Water	10/02/2025	10/06/2025

York Sample ID	Client Sample ID	Matrix	Date Collected	Date Received
25J0322-23	CH-23 Sink in classroom 15	Drinking Water	10/02/2025	10/06/2025
25J0322-24	CH-24 Water fountain between classroom 15/16	Drinking Water	10/02/2025	10/06/2025
25J0322-25	CH-25 Bottle filler between classroom 15/16	Drinking Water	10/02/2025	10/06/2025
25J0322-26	CH-26 Sink in classroom 16	Drinking Water	10/02/2025	10/06/2025
25J0322-27	CH-27 Sink in classroom 17	Drinking Water	10/02/2025	10/06/2025
25J0322-28	CH-28 Water fountain outside classroom 202	Drinking Water	10/02/2025	10/06/2025
25J0322-29	CH-29 Bottle filler outside classroom 202	Drinking Water	10/02/2025	10/06/2025
25J0322-30	CH-30 Sink in classroom 201	Drinking Water	10/02/2025	10/06/2025
25J0322-31	CH-31 Sink in Nurses Office	Drinking Water	10/02/2025	10/06/2025
25J0322-32	CH-32 Water fountain outside nurses office	Drinking Water	10/02/2025	10/06/2025
25J0322-33	CH-33 Bottle filler outside nurses office	Drinking Water	10/02/2025	10/06/2025
25J0322-34	CH-34 Sink in classroom 27	Drinking Water	10/02/2025	10/06/2025
25J0322-35	CH-35 Sink in classroom 26	Drinking Water	10/02/2025	10/06/2025
25J0322-36	CH-36 Water fountain between 26/27	Drinking Water	10/02/2025	10/06/2025
25J0322-37	CH-37 Bottle filler between 26/27	Drinking Water	10/02/2025	10/06/2025
25J0322-38	CH-38 Sink in classroom 25	Drinking Water	10/02/2025	10/06/2025
25J0322-39	CH-39 Sink in classroom 28	Drinking Water	10/02/2025	10/06/2025
25J0322-40	CH-40 Water fountain near classroom 21	Drinking Water	10/02/2025	10/06/2025
25J0322-41	CH-41 Bottle filler near classroom 21	Drinking Water	10/02/2025	10/06/2025
25J0322-42	CH-42 Water fountain between classroom 22/23	Drinking Water	10/02/2025	10/06/2025
25J0322-43	CH-43 Bottle filler between classroom 22/23	Drinking Water	10/02/2025	10/06/2025
25J0322-44	CH-44 Sink in classroom 24	Drinking Water	10/02/2025	10/06/2025
25J0322-45	CH-45 Sink in classroom 22	Drinking Water	10/02/2025	10/06/2025
25J0322-46	CH-46 Water fountain across from upper aud.	Drinking Water	10/02/2025	10/06/2025
25J0322-47	CH-47 Bottle Filler across from upper aud.	Drinking Water	10/02/2025	10/06/2025
25J0322-48	CH-48 Water fountain across from 310	Drinking Water	10/02/2025	10/06/2025
25J0322-49	CH-49 Bottle filler across from 310	Drinking Water	10/02/2025	10/06/2025
25J0322-50	CH-50 Water fountain in front of sky gym	Drinking Water	10/02/2025	10/06/2025
25J0322-51	CH-51 Bottle filler in front of sky gym	Drinking Water	10/02/2025	10/06/2025

General Notes for York Project (SDG) No.: 25J0322

1. The RLs and MDLs (Reporting Limit and Method Detection Limit respectively) reported are adjusted for any dilution necessary due to the levels of target and/or non-target analytes and matrix interference. The RL(REPORTING LIMIT) is based upon the lowest standard utilized for the calibration where applicable.
2. Samples are retained for a period of thirty days after submittal of report, unless other arrangements are made.
3. York's liability for the above data is limited to the dollar value paid to York for the referenced project.
4. This report shall not be reproduced without the written approval of York Analytical Laboratories, Inc.
5. All analyses conducted met method or Laboratory SOP requirements. See the Sample and Data Qualifiers Section for further information.
6. It is noted that no analyses reported herein were subcontracted to another laboratory, unless noted in the report.
7. This report reflects results that relate only to the samples submitted on the attached chain-of-custody form(s) received by York.
8. Analyses conducted at York Analytical Laboratories, Inc. Stratford, CT are indicated by NY Cert. No. 10854, NJ Cert No. CT005, PA Cert No. 68-04440, CT Cert No. PH-0723; those conducted at York Analytical Laboratories, Inc., Richmond Hill, NY are indicated by NY Cert. No. 12058, NJ Cert No. NY037, CT Cert No. PH-0721, NH Cert No. 2097, EPA Cert No. NY01600.

Approved By: Cassie L. Mosher

Cassie L. Mosher
Laboratory Manager

Date: 10/10/2025

Sample Information

Client Sample ID: **CH-01 Water fountain outside 102** **York Sample ID:** **25J0322-01**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 11:05 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	10/09/2025 09:26	10/09/2025 12:04	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: **CH-02 Bottle Filler outside 102** **York Sample ID:** **25J0322-02**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 11:05 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	10/09/2025 09:26	10/09/2025 12:06	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: **CH-03 Left dish sink in Kitchen** **York Sample ID:** **25J0322-03**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 11:08 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	10/09/2025 09:26	10/09/2025 12:10	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: **CH-04 Rightt dish sink in Kitchen** **York Sample ID:** **25J0322-04**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 11:08 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Information

Client Sample ID: **CH-04 Rightt dish sink in Kitchen** **York Sample ID:** **25J0322-04**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 11:08 am	10/06/2025

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	10/09/2025 09:26	10/09/2025 12:11	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: **CH-05 Handwashing sink in Kitchen** **York Sample ID:** **25J0322-05**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 11:08 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	10/09/2025 10:45	10/09/2025 12:15	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: **CH-06 Island sink in Kitchen** **York Sample ID:** **25J0322-06**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 11:08 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	10/09/2025 10:45	10/09/2025 12:19	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: **CH-07 Island sink in Kitchen** **York Sample ID:** **25J0322-07**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 11:08 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst

Sample Information

Client Sample ID: **CH-07 Island sink in Kitchen** **York Sample ID:** **25J0322-07**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 11:08 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	10/09/2025 10:45	10/09/2025 12:22	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: **CH-08 Water fountain in Cafeteria** **York Sample ID:** **25J0322-08**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 11:11 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	10/09/2025 10:45	10/09/2025 12:26	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: **CH-09 Water fountain in Cafeteria** **York Sample ID:** **25J0322-09**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 11:11 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	10/09/2025 10:45	10/09/2025 12:27	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: **CH-10 Bottle Filler in Cafeteria** **York Sample ID:** **25J0322-10**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 11:11 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Information

Client Sample ID: **CH-10 Bottle Filler in Cafeteria** **York Sample ID:** **25J0322-10**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 11:11 am	10/06/2025

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	10/09/2025 10:45	10/09/2025 12:28	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: **CH-11 Sink in Office 101** **York Sample ID:** **25J0322-11**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 11:15 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	10/09/2025 10:45	10/09/2025 12:30	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: **CH-12 Water fountain outside 106** **York Sample ID:** **25J0322-12**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 11:19 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	10/09/2025 10:45	10/09/2025 12:31	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: **CH-13 Bottle filler outside 106** **York Sample ID:** **25J0322-13**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 11:19 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst

Sample Information

Client Sample ID: **CH-13 Bottle filler outside 106** **York Sample ID:** **25J0322-13**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 11:19 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	10/09/2025 10:45	10/09/2025 12:32	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: **CH-14 Sink in music room** **York Sample ID:** **25J0322-14**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 11:25 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**71.2**	M-PbE X	ug/L	1.00	1	EPA 200.8	10/09/2025 10:45	10/09/2025 12:34	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: **CH-15 Sink in strings room** **York Sample ID:** **25J0322-15**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 11:26 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**11.2**	M-PbE X	ug/L	1.00	1	EPA 200.8	10/09/2025 10:45	10/09/2025 12:35	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: **CH-16 Sink Library storage** **York Sample ID:** **25J0322-16**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 11:28 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Information

Client Sample ID: **CH-16 Sink Library storage** **York Sample ID:** **25J0322-16**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 11:28 am	10/06/2025

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**2.16**		ug/L	1.00	1	EPA 200.8	10/09/2025 10:45	10/09/2025 12:36	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-(		

Sample Information

Client Sample ID: **CH-17 Sink in classroom 10** **York Sample ID:** **25J0322-17**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 11:34 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**1.00**		ug/L	1.00	1	EPA 200.8	10/09/2025 10:45	10/09/2025 12:38	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-(		

Sample Information

Client Sample ID: **CH-18 Sink in classroom 11** **York Sample ID:** **25J0322-18**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 11:35 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**1.25**		ug/L	1.00	1	EPA 200.8	10/09/2025 10:45	10/09/2025 12:42	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-(		

Sample Information

Client Sample ID: **CH-19 Sink in classroom 12** **York Sample ID:** **25J0322-19**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 11:36 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst

Sample Information

Client Sample ID: **CH-19 Sink in classroom 12** **York Sample ID:** **25J0322-19**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 11:36 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**1.75**		ug/L	1.00	1	EPA 200.8	10/09/2025 10:45	10/09/2025 12:43	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-(		

Sample Information

Client Sample ID: **CH-20 Water fountain outside classroom 12** **York Sample ID:** **25J0322-20**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 11:36 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	10/09/2025 10:45	10/09/2025 12:44	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: **CH-21 Bottle filler outside classroom 12** **York Sample ID:** **25J0322-21**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 11:36 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	10/09/2025 10:45	10/09/2025 12:46	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: **CH-22 Sink in classroom 14** **York Sample ID:** **25J0322-22**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 11:38 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Information

Client Sample ID: CH-22 Sink in classroom 14 **York Sample ID:** 25J0322-22

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 11:38 am	10/06/2025

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**6.32**	M-PbE X	ug/L	1.00	1	EPA 200.8	10/09/2025 10:45	10/09/2025 12:47	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-(		

Sample Information

Client Sample ID: CH-23 Sink in classroom 15 **York Sample ID:** 25J0322-23

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 11:40 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**2.09**		ug/L	1.00	1	EPA 200.8	10/09/2025 10:45	10/09/2025 12:48	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-(		

Sample Information

Client Sample ID: CH-24 Water fountain between classroom 15/16 **York Sample ID:** 25J0322-24

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 11:41 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	10/09/2025 10:45	10/09/2025 12:50	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: CH-25 Bottle filler between classroom 15/16 **York Sample ID:** 25J0322-25

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 11:41 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst

Sample Information

Client Sample ID: **CH-25 Bottle filler between classroom 15/16** **York Sample ID:** **25J0322-25**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 11:41 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	10/09/2025 10:48	10/09/2025 12:54	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: **CH-26 Sink in classroom 16** **York Sample ID:** **25J0322-26**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 11:42 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**1.11**		ug/L	1.00	1	EPA 200.8	10/09/2025 10:48	10/09/2025 13:00	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-(		

Sample Information

Client Sample ID: **CH-27 Sink in classroom 17** **York Sample ID:** **25J0322-27**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 11:43 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**1.12**		ug/L	1.00	1	EPA 200.8	10/09/2025 10:48	10/09/2025 13:03	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-(		

Sample Information

Client Sample ID: **CH-28 Water fountain outside classroom 202** **York Sample ID:** **25J0322-28**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 11:46 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Information

Client Sample ID: **CH-28 Water fountain outside classroom 202** **York Sample ID:** **25J0322-28**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 11:46 am	10/06/2025

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	10/09/2025 10:48	10/09/2025 13:04	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: **CH-29 Bottle filler outside classroom 202** **York Sample ID:** **25J0322-29**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 11:46 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	10/09/2025 10:48	10/09/2025 13:06	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: **CH-30 Sink in classroom 201** **York Sample ID:** **25J0322-30**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 11:47 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**3.91**		ug/L	1.00	1	EPA 200.8	10/09/2025 10:48	10/09/2025 13:07	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: **CH-31 Sink in Nurses Office** **York Sample ID:** **25J0322-31**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 11:51 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst

Sample Information

Client Sample ID: **CH-31 Sink in Nurses Office** **York Sample ID:** **25J0322-31**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 11:51 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**1.60**		ug/L	1.00	1	EPA 200.8	10/09/2025 10:48	10/09/2025 13:08	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-(		

Sample Information

Client Sample ID: **CH-32 Water fountain outside nurses office** **York Sample ID:** **25J0322-32**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 11:52 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	10/09/2025 10:48	10/09/2025 13:10	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: **CH-33 Bottle filler outside nurses office** **York Sample ID:** **25J0322-33**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 11:53 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	10/09/2025 10:48	10/09/2025 13:14	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: **CH-34 Sink in classroom 27** **York Sample ID:** **25J0322-34**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 11:58 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Information

Client Sample ID: **CH-34 Sink in classroom 27** **York Sample ID:** **25J0322-34**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 11:58 am	10/06/2025

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**4.93**		ug/L	1.00	1	EPA 200.8	10/09/2025 10:48	10/09/2025 13:15	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-(		

Sample Information

Client Sample ID: **CH-35 Sink in classroom 26** **York Sample ID:** **25J0322-35**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 11:59 am	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**1.42**		ug/L	1.00	1	EPA 200.8	10/09/2025 10:48	10/09/2025 13:16	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-(		

Sample Information

Client Sample ID: **CH-36 Water fountain between 26/27** **York Sample ID:** **25J0322-36**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 12:05 pm	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	10/09/2025 10:48	10/09/2025 13:18	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: **CH-37 Bottle filler between 26/27** **York Sample ID:** **25J0322-37**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 12:05 pm	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst

Sample Information

Client Sample ID: **CH-37 Bottle filler between 26/27** **York Sample ID:** **25J0322-37**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 12:05 pm	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	10/09/2025 10:48	10/09/2025 13:19	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: **CH-38 Sink in classroom 25** **York Sample ID:** **25J0322-38**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 12:06 pm	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**36.4**	M-PbE X	ug/L	1.00	1	EPA 200.8	10/09/2025 10:48	10/09/2025 13:20	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: **CH-39 Sink in classroom 28** **York Sample ID:** **25J0322-39**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 12:07 pm	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**3.89**		ug/L	1.00	1	EPA 200.8	10/09/2025 10:48	10/09/2025 13:22	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: **CH-40 Water fountain near classroom 21** **York Sample ID:** **25J0322-40**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 12:07 pm	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Information

Client Sample ID: **CH-40 Water fountain near classroom 21** **York Sample ID:** **25J0322-40**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 12:07 pm	10/06/2025

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	10/09/2025 10:48	10/09/2025 13:23	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: **CH-41 Bottle filler near classroom 21** **York Sample ID:** **25J0322-41**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 12:07 pm	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	10/09/2025 10:48	10/09/2025 13:24	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: **CH-42 Water fountain between classroom 22/23** **York Sample ID:** **25J0322-42**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 12:10 pm	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	10/09/2025 10:48	10/09/2025 13:26	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: **CH-43 Bottle filler between classroom 22/23** **York Sample ID:** **25J0322-43**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 12:10 pm	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst

Sample Information

Client Sample ID: **CH-43 Bottle filler between classroom 22/23** **York Sample ID:** **25J0322-43**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 12:10 pm	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	10/09/2025 10:48	10/09/2025 13:30	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: **CH-44 Sink in classroom 24** **York Sample ID:** **25J0322-44**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 12:11 pm	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**8.78**	M-PbE X	ug/L	1.00	1	EPA 200.8	10/09/2025 10:48	10/09/2025 13:31	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: **CH-45 Sink in classroom 22** **York Sample ID:** **25J0322-45**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 12:12 pm	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	**Lead**	**3.41**		ug/L	1.00	1	EPA 200.8	10/09/2025 11:10	10/09/2025 13:35	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: **CH-46 Water fountain across from upper aud.** **York Sample ID:** **25J0322-46**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 12:15 pm	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Information

Client Sample ID: **CH-46 Water fountain across from upper aud.** **York Sample ID:** **25J0322-46**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 12:15 pm	10/06/2025

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	10/09/2025 11:10	10/09/2025 13:39	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: **CH-47 Bottle Filler across from upper aud.** **York Sample ID:** **25J0322-47**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 12:15 pm	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	10/09/2025 11:10	10/09/2025 13:42	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: **CH-48 Water fountain across from 310** **York Sample ID:** **25J0322-48**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 12:19 pm	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	10/09/2025 11:10	10/09/2025 13:46	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: **CH-49 Bottle filler across from 310** **York Sample ID:** **25J0322-49**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 12:19 pm	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst

Sample Information

Client Sample ID: **CH-49 Bottle filler across from 310** **York Sample ID:** **25J0322-49**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 12:19 pm	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	10/09/2025 11:10	10/09/2025 13:47	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: **CH-50 Water fountain in front of sky gym** **York Sample ID:** **25J0322-50**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 12:24 pm	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	10/09/2025 11:10	10/09/2025 13:48	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Sample Information

Client Sample ID: **CH-51 Bottle filler in front of sky gym** **York Sample ID:** **25J0322-51**

York Project (SDG) No.	Client Project ID	Matrix	Collection Date/Time	Date Received
25J0322	256977-Mamaroneck UFSD-Chatsworth Ave Elementary School	Drinking Water	October 2, 2025 12:24 pm	10/06/2025

Lead by EPA 200.8 **Log-in Notes:** **Sample Notes:**

Sample Prepared by Method: EPA 200.8

CAS No.	Parameter	Result	Flag	Units	Reported to LOQ	Dilution	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
7439-92-1	Lead	ND		ug/L	1.00	1	EPA 200.8	10/09/2025 11:10	10/09/2025 13:50	JWT
							Certifications:	CTDPH-PH-0840,NYSDOH-NY10854,NJDEP-CT005,PADEP-68-0		

Analytical Batch Summary

Batch ID: BJ50591 **Preparation Method:** EPA 200.8 **Prepared By:** JWT

YORK Sample ID	Client Sample ID	Preparation Date
25J0322-01	CH-01 Water fountain outside 1	10/09/25
25J0322-02	CH-02 Bottle Filler outside 102	10/09/25
25J0322-03	CH-03 Left dish sink in Kitcher	10/09/25
25J0322-04	CH-04 Rightt dish sink in Kitch	10/09/25
BJ50591-BLK1	Blank	10/09/25
BJ50591-BS1	LCS	10/09/25

Batch ID: BJ50604 **Preparation Method:** EPA 200.8 **Prepared By:** JWT

YORK Sample ID	Client Sample ID	Preparation Date
25J0322-05	CH-05 Handwashing sink in Ki	10/09/25
25J0322-06	CH-06 Island sink in Kitchen	10/09/25
25J0322-07	CH-07 Island sink in Kitchen	10/09/25
25J0322-08	CH-08 Water fountain in Cafete	10/09/25
25J0322-09	CH-09 Water fountain in Cafete	10/09/25
25J0322-10	CH-10 Bottle Filler in Cafeteria	10/09/25
25J0322-11	CH-11 Sink in Office 101	10/09/25
25J0322-12	CH-12 Water fountain outside 1	10/09/25
25J0322-13	CH-13 Bottle filler outside 106	10/09/25
25J0322-14	CH-14 Sink in music room	10/09/25
25J0322-15	CH-15 Sink in strings room	10/09/25
25J0322-16	CH-16 Sink Library storage	10/09/25
25J0322-17	CH-17 Sink in classroom 10	10/09/25
25J0322-18	CH-18 Sink in classroom 11	10/09/25
25J0322-19	CH-19 Sink in classroom 12	10/09/25
25J0322-20	CH-20 Water fountain outside c	10/09/25
25J0322-21	CH-21 Bottle filler outside clas	10/09/25
25J0322-22	CH-22 Sink in classroom 14	10/09/25
25J0322-23	CH-23 Sink in classroom 15	10/09/25
25J0322-24	CH-24 Water fountain between	10/09/25
BJ50604-BLK1	Blank	10/09/25
BJ50604-BS1	LCS	10/09/25
BJ50604-DUP1	Duplicate	10/09/25
BJ50604-MS1	Matrix Spike	10/09/25
BJ50604-MS2	Matrix Spike	10/09/25

Batch ID: BJ50605 **Preparation Method:** EPA 200.8 **Prepared By:** JWT

YORK Sample ID	Client Sample ID	Preparation Date
25J0322-25	CH-25 Bottle filler between cla	10/09/25
25J0322-26	CH-26 Sink in classroom 16	10/09/25
25J0322-27	CH-27 Sink in classroom 17	10/09/25
25J0322-28	CH-28 Water fountain outside c	10/09/25
25J0322-29	CH-29 Bottle filler outside clas	10/09/25
25J0322-30	CH-30 Sink in classroom 201	10/09/25

25J0322-31	CH-31 Sink in Nurses Office	10/09/25
25J0322-32	CH-32 Water fountain outside n	10/09/25
25J0322-33	CH-33 Bottle filler outside nurs	10/09/25
25J0322-34	CH-34 Sink in classroom 27	10/09/25
25J0322-35	CH-35 Sink in classroom 26	10/09/25
25J0322-36	CH-36 Water fountain between	10/09/25
25J0322-37	CH-37 Bottle filler between 26/	10/09/25
25J0322-38	CH-38 Sink in classroom 25	10/09/25
25J0322-39	CH-39 Sink in classroom 28	10/09/25
25J0322-40	CH-40 Water fountain near clas	10/09/25
25J0322-41	CH-41 Bottle filler near classro	10/09/25
25J0322-42	CH-42 Water fountain between	10/09/25
25J0322-43	CH-43 Bottle filler between cla	10/09/25
25J0322-44	CH-44 Sink in classroom 24	10/09/25
BJ50605-BLK1	Blank	10/09/25
BJ50605-BS1	LCS	10/09/25
BJ50605-DUP1	Duplicate	10/09/25
BJ50605-MS1	Matrix Spike	10/09/25
BJ50605-MS2	Matrix Spike	10/09/25

Batch ID: BJ50606 **Preparation Method:** EPA 200.8 **Prepared By:** JWT

YORK Sample ID	Client Sample ID	Preparation Date
25J0322-45	CH-45 Sink in classroom 22	10/09/25
25J0322-46	CH-46 Water fountain across fr	10/09/25
25J0322-47	CH-47 Bottle Filler across from	10/09/25
25J0322-48	CH-48 Water fountain across fr	10/09/25
25J0322-49	CH-49 Bottle filler across from	10/09/25
25J0322-50	CH-50 Water fountain in front c	10/09/25
25J0322-51	CH-51 Bottle filler in front of sl	10/09/25
BJ50606-BLK1	Blank	10/09/25
BJ50606-BS1	LCS	10/09/25
BJ50606-DUP1	Duplicate	10/09/25
BJ50606-MS1	Matrix Spike	10/09/25
BJ50606-MS2	Matrix Spike	10/09/25

Metals by ICP/MS - Quality Control Data

York Analytical Laboratories, Inc.

Analyte	Result	Reporting Limit	Units	Spike Level	Source* Result	%REC	%REC Limits	Flag	RPD	RPD Limit	Flag
Batch BJ50591 - EPA 200.8											
Blank (BJ50591-BLK1)								Prepared & Analyzed: 10/09/2025			
Lead	ND	1.00	ug/L								
LCS (BJ50591-BS1)								Prepared & Analyzed: 10/09/2025			
Lead	51.9		ug/L	50.0		104	85-115				
Batch BJ50604 - EPA 200.8											
Blank (BJ50604-BLK1)								Prepared & Analyzed: 10/09/2025			
Lead	ND	1.00	ug/L								
LCS (BJ50604-BS1)								Prepared & Analyzed: 10/09/2025			
Lead	52.4		ug/L	50.0		105	85-115				
Duplicate (BJ50604-DUP1)	*Source sample: 25J0322-05 (CH-05 Handwashing sink in Kitchen)							Prepared & Analyzed: 10/09/2025			
Lead	ND	1.00	ug/L		ND					20	
Matrix Spike (BJ50604-MS1)	*Source sample: 25J0322-05 (CH-05 Handwashing sink in Kitchen)							Prepared & Analyzed: 10/09/2025			
Lead	52.9		ug/L	50.0	0.398	105	75-125				
Matrix Spike (BJ50604-MS2)	*Source sample: 25J0322-06 (CH-06 Island sink in Kitchen)							Prepared & Analyzed: 10/09/2025			
Lead	54.7		ug/L	50.0	0.958	107	75-125				
Batch BJ50605 - EPA 200.8											
Blank (BJ50605-BLK1)								Prepared & Analyzed: 10/09/2025			
Lead	ND	1.00	ug/L								

Metals by ICP/MS - Quality Control Data

York Analytical Laboratories, Inc.

Analyte	Result	Reporting Limit	Units	Spike Level	Source* Result	%REC	%REC Limits	Flag	RPD	RPD Limit	Flag
Batch BJ50605 - EPA 200.8											
LCS (BJ50605-BS1)								Prepared & Analyzed: 10/09/2025			
Lead	53.1		ug/L	50.0		106	85-115				
Duplicate (BJ50605-DUP1)	*Source sample: 25J0322-25 (CH-25 Bottle filler between classroom 15/16)							Prepared & Analyzed: 10/09/2025			
Lead	ND	1.00	ug/L		ND					20	
Matrix Spike (BJ50605-MS1)	*Source sample: 25J0322-25 (CH-25 Bottle filler between classroom 15/16)							Prepared & Analyzed: 10/09/2025			
Lead	51.9		ug/L	50.0	0.059	104	75-125				
Matrix Spike (BJ50605-MS2)	*Source sample: 25J0322-26 (CH-26 Sink in classroom 16)							Prepared & Analyzed: 10/09/2025			
Lead	53.2		ug/L	50.0	1.11	104	75-125				
Batch BJ50606 - EPA 200.8											
Blank (BJ50606-BLK1)								Prepared & Analyzed: 10/09/2025			
Lead	ND	1.00	ug/L								
LCS (BJ50606-BS1)								Prepared & Analyzed: 10/09/2025			
Lead	53.5		ug/L	50.0		107	85-115				
Duplicate (BJ50606-DUP1)	*Source sample: 25J0322-45 (CH-45 Sink in classroom 22)							Prepared & Analyzed: 10/09/2025			
Lead	3.42	1.00	ug/L		3.41				0.176	20	
Matrix Spike (BJ50606-MS1)	*Source sample: 25J0322-45 (CH-45 Sink in classroom 22)							Prepared & Analyzed: 10/09/2025			
Lead	56.3		ug/L	50.0	3.41	106	75-125				
Matrix Spike (BJ50606-MS2)	*Source sample: 25J0322-46 (CH-46 Water fountain across from upper aud.)							Prepared & Analyzed: 10/09/2025			
Lead	52.3		ug/L	50.0	0.028	105	75-125				

Sample and Data Qualifiers Relating to This Work Order

M-PbEX Lead result exceeds regulatory limit

Definitions and Other Explanations

*	Analyte is not certified or the state of the samples origination does not offer certification for the Analyte.
ND	NOT DETECTED - the analyte is not detected at the Reported to level (LOQ/RL or LOD/MDL)
RL	REPORTING LIMIT - the minimum reportable value based upon the lowest point in the analyte calibration curve.
LOQ	LIMIT OF QUANTITATION - the minimum concentration of a target analyte that can be reported within a specified degree of confidence. This is the lowest point in an analyte calibration curve that has been subjected to all steps of the processing/analysis and verified to meet defined criteria. This is based upon NELAC 2009 Standards and applies to all analyses.
LOD	LIMIT OF DETECTION - a verified estimate of the minimum concentration of a substance in a given matrix that an analytical process can reliably detect. This is based upon NELAC 2009 Standards and applies to all analyses conducted under the auspices of EPA SW-846.
MDL	METHOD DETECTION LIMIT - a statistically derived estimate of the minimum amount of a substance an analytical system can reliably detect with a 99% confidence that the concentration of the substance is greater than zero. This is based upon 40 CFR Part 136 Appendix B and applies only to EPA 600 and 200 series methods.
Reported to	This indicates that the data for a particular analysis is reported to either the LOD/MDL, or the LOQ/RL. In cases where the "Reported to" is located above the LOD/MDL, any value between this and the LOQ represents an estimated value which is "J" flagged accordingly. This applies to volatile and semi-volatile target compounds only.
NR	Not reported
RPD	Relative Percent Difference
Wet	The data has been reported on an as-received (wet weight) basis
Low Bias	Low Bias flag indicates that the recovery of the flagged analyte is below the laboratory or regulatory lower control limit. The data user should take note that this analyte may be biased low but should evaluate multiple lines of evidence including the LCS and site-specific MS/MSD data to draw bias conclusions. In cases where no site-specific MS/MSD was requested, only the LCS data can be used to evaluate such bias.
High Bias	High Bias flag indicates that the recovery of the flagged analyte is above the laboratory or regulatory upper control limit. The data user should take note that this analyte may be biased high but should evaluate multiple lines of evidence including the LCS and site-specific MS/MSD data to draw bias conclusions. In cases where no site-specific MS/MSD was requested, only the LCS data can be used to evaluate such bias.
Non-Dir.	Non-dir. flag (Non-Directional Bias) indicates that the Relative Percent Difference (RPD) (a measure of precision) among the MS and MSD data is outside the laboratory or regulatory control limit. This alerts the data user where the MS and MSD are from site-specific samples that the RPD is high due to either non-homogeneous distribution of target analyte between the MS/MSD or indicates poor reproducibility for other reasons.

If EPA SW-846 method 8270 is included herein it is noted that the target compound N-nitrosodiphenylamine (NDPA) decomposes in the gas chromatographic inlet and cannot be separated from diphenylamine (DPA). These results could actually represent 100% DPA, 100% NDPA or some combination of the two. For this reason, York reports the combined result for n-nitrosodiphenylamine and diphenylamine for either of these compounds as a combined concentration as Diphenylamine.

If Total PCBs are detected and the target aroclors reported are "Not detected", the Total PCB value is reported due to the presence of either or both Aroclors 1262 and 1268 which are non-target aroclors for some regulatory lists.

2-chloroethylvinyl ether readily breaks down under acidic conditions. Samples that are acid preserved, including standards will exhibit breakdown. The data user should take note.

Certification for pH is no longer offered by NYDOH ELAP.

Semi-Volatile and Volatile analyses are reported down to the LOD/MDL, with values between the LOD/MDL and the LOQ being "J" flagged as estimated results.

For analyses by EPA SW-846-8270D, the Limit of Quantitation (LOQ) reported for benzidine is based upon the lowest standard used for calibration and is not a verified LOQ due to this compound's propensity for oxidative losses during extraction/concentration procedures and non-reproducible chromatographic performance.

Field Chain-of-Custody Record

YORK ANALYTICAL LABORATORIES INC

York Analytical Laboratories, Inc. (YORK)'s Standard Terms & Conditions are listed on the back side of this document. This legal document serves as your written authorization for YORK to proceed with the analyses requested below. Your signature binds you to YORK's Standard Terms & Conditions.

120 Research Drive Stratford, CT 06615 132-02 89th Ave Queens, NY 11418 56 Church Hill Rd. #2 Newtown, CT 06470 2161 Whitesville Rd Toms River, NJ 08755 clientservices@yorklab.com 800-306-YORK

YORK Project Number: 25J0322

Report To:
Company: QuES&T
Address: 1376 US-9,
Wappingers Falls, NY 12590
Phone.: 845-298-6031
Contact: Zach Timpano
E-mail: lab@qualityenv.com

Invoice To:
Company: Same
Address:
Phone.:
Contact:
E-mail: ap@qualityenv.com

YOUR Project Name / Number: 256977- Mamaroneck UFSD- Chatsworth Avenue Elementary School

PO Number:

Samples Collected From: NY X, NJ, CT, PA, Other: (please specify)

Please print clearly and legibly. All information must be complete. Samples will not be logged in and the turn-around-time clock will not begin until any questions by YORK are resolved.

Caroline Annesi

Samples Collected by: (print AND sign your name)

Matrix Codes: S - soil/solid/sludge; GW - groundwater; DW - drinking water; SW - surface water; WW - wastewater; O - Oil; Other

Preservative (please list number of containers)

Analyses Requested

Sample Identification	Date	Time	Matrix	Unpreserved	HCl (hydrochloric acid)	MeOH (methanol)	HNO_3 (nitric acid)	H_2SO_4 (sulfuric acid)	NaOH (sodium hydroxide)	$Na_2S_2O_3$ (sodium thio.)	Trizma	Ammonium Acetate	Other:	Lead	Grab or Comp.
CH-01 Water fountain outside 102	10/2	1105	DW				X							X	G
CH-02 Bottle filler outside 102	10/2	1105	DW				X							X	G
CH-03 Left dish sink in Kitchen	10/2	1108	DW				X							X	G
CH-04 Right dish sink in Kitchen	10/2	1108	DW				X							X	G
CH-05 Handwashing sink in Kitchen	10/2	1108	DW				X							X	G
CH-06 Island sink in Kitchen	10/2	1108	DW				X							X	G
CH-07 Island sink in Kitchen	10/2	1108	DW				X							X	G
CH-08 Water fountain in Cafeteria	10/2	1111	DW				X							X	G
CH-09 Water fountain in Cafeteria	10/2	1111	DW				X							X	G
CH-10 Bottle Filler in Cafeteria	10/2	1111	DW				X							X	G
CH-11 Sink in Office 101	10/2	1115	DW				X							X	G
CH-12 Water fountain outside 106	10/2	1119	DW				X							X	G
CH-13 Bottle filler outside 106	10/2	1119	DW				X							X	G
CH-14 Sink in music room	10/2	1125	DW				X							X	G
CH-15 Sink in strings room	10/2	1126	DW				X							X	G

Turn-Around Time
- RUSH - Next Day
- RUSH - Two Day
- RUSH - Three Day
- RUSH - Four Day
- RUSH - Five Day
- Standard (6-9 Day) X
- PFAS Standard 7-10 Day

Report Type (circle)
- QA Report
- Summary (Results Only)
- NY ASP B Package
- NJ Reduced
- NJ DKQP
- NJ Full
- CT RCP

EDD Type (circle)
- EQuIS (standard)
- NYSDEC EQuIS
- NJDEP SRP Haz Site
- Standard Excel
- CMDP
- Other:

Regulatory Comparative
Compared to the following Regulation(s): (please fill in)

- Field Filtered
- Lab Filtered

Comments:

Samples iced/chilled at time of lab pickup? circle Yes or No

Lab Sample Receiving Checklist (to be completed by the receiving laboratory only) Circle Y / N

Custody Seals: Y / N Containers Intact: Y / N COC/Labels Agree: Y / N Preservation Confirmed: Y / N
COC Complete: Y / N COC Received: Y / N Appropriate Sample Volumes: Y / N Appropriate Sample Containers: Y / N
Cooler Temperature Confirmed: Y / N Samples Submitted within Holding Times: Y / N Corrective Action Form Required: Y / N

Samples Relinquished by / Company	Date/Time	Samples Received by / Company	Date/Time	Samples Relinquished by / Company	Date/Time
Caroline Annesi	10/6/25	Alexi C	10-6-25 13:00	Alexi C	10-6-25 15:30
Samples Received by / Company	Date/Time	Samples Relinquished by / Company	Date/Time	Samples Received by / Company	Date/Time
Samples Relinquished by / Company	Date/Time	Samples Received by / Company	Date/Time	Samples Received in LAB by	Date/Time / Temperature
					10/6/25 1500 Degrees C 17.0

Field Chain-of-Custody Record

YORK ANALYTICAL LABORATORIES INC

York Analytical Laboratories, Inc. (YORK)'s Standard Terms & Conditions are listed on the back side of this document. This legal document serves as your written authorization for YORK to proceed with the analyses requested below. Your signature binds you to YORK's Standard Terms & Conditions.

120 Research Drive Stratford, CT 06615 132-02 89th Ave Queens, NY 11418 56 Church Hill Rd. #2 Newtown, CT 06470 2161 Whitesville Rd Toms River, NJ 08755 clientservices@yorklab.com 800-306-YORK

YORK Project Number: 25 50322

Report To:	Invoice To:
Company: QuES&T	Company: Same
Address: 1376 US-9, Wappingers Falls, NY 12590	Address:
Phone.: 845-298-6031	Phone.:
Contact: Zach Timpano	Contact:
E-mail: lab@qualityenv.com	E-mail: ap@qualityenv.com

YOUR Project Name / Number: 256977 Mamaroneck UFSD-Chatsworth Avenue Elementary School

PO Number:

Samples Collected From: NY X, NJ, CT, PA, Other: (please specify)

Please print clearly and legibly. All information must be complete. Samples will not be logged in and the turn-around-time clock will not begin until any questions by YORK are resolved.

Caroline Annesi

Samples Collected by: (print AND sign your name)

Matrix Codes: S - soil/solid/sludge; GW - groundwater; DW - drinking water; SW - surface water; WW - wastewater; O - Oil; Other

Preservative (please list number of containers)

Analyses Requested

Sample Identification	Date	Time	Matrix	Unpreserved	HCl (hydrochloric acid)	MeOH (methanol)	HNO_3 (nitric acid)	H_2SO_4 (sulfuric acid)	NaOH (sodium hydroxide)	$Na_2S_2O_3$ (sodium thio.)	Trizma	Ammonium Acetate	Other:	Lead	Grab or Comp.
CH-16 Sink in Library storage	10/2	1128	DW				X							X	G
CH-17 Sink in classroom 10	10/2	1134	DW				X							X	G
CH-18 Sink in classroom 11	10/2	1135	DW				X							X	G
CH-19 Sink in classroom 12	10/2	1136	DW				X							X	G
CH-20 Water fountain outside classroom 12	10/2	1136	DW				X							X	G
CH-21 Bottle filler outside classroom 12	10/2	1136	DW				X							X	G
CH-22 Sink in classroom 14	10/2	1138	DW				X							X	G
CH-23 Sink in Classroom 15	10/2	1140	DW				X							X	G
CH-24 Water fountain between classroom 15/16	10/2	1141	DW				X							X	G
CH-25 Bottle filler between classroom 15/16	10/2	1141	DW				X							X	G
CH-26 Sink in classroom 16	10/2	1142	DW				X							X	G
CH-27 Sink in classroom 17	10/2	1143	DW				X							X	G
CH-28 Water fountain outside classroom 202	10/2	1146	DW				X							X	G
CH-29 Bottle filler outside classroom 202	10/2	1146	DW				X							X	G
CH-30 Sink in classrom 201	10/2	1147	DW				X							X	G

Turn-Around Time

- RUSH - Next Day
- RUSH - Two Day
- RUSH - Three Day
- RUSH - Four Day
- RUSH - Five Day
- Standard (6-9 Day) X
- PFAS Standard 7-10 Day

Report Type (circle)

- QA Report
- Summary (Results Only)
- NY ASP B Package
- NJ Reduced
- NJ DKQP
- NJ Full
- CT RCP

EDD Type (circle)

- EQuIS (standard)
- NYSDEC EQuIS
- NJDEP SRP Haz Site
- Standard Excel
- CMDP
- Other:

Regulatory Comparative

Compared to the following Regulation(s): (please fill in)

- Field Filtered
- Lab Filtered

Comments:

Samples iced/chilled at time of lab pickup? circle Yes or No

Lab Sample Receiving Checklist (to be completed by the receiving laboratory only) Circle Y / N

Custody Seals: Y / N Containers Intact: Y / N COC/Labels Agree: Y / N Preservation Confirmed: Y / N
COC Complete: Y / N COC Received: Y / N Appropriate Sample Volumes: Y / N Appropriate Sample Containers: Y / N
Cooler Temperature Confirmed: Y / N Samples Submitted within Holding Times: Y / N Corrective Action Form Required: Y / N

Samples Relinquished by / Company	Date/Time	1. Samples Received by / Company	Date/Time	2. Samples Relinquished by / Company	Date/Time
Caroline Annesi	10/6/25	Chris C	10-6-25 13:00	Chris C	10-6-25 15:30
Samples Received by / Company	Date/Time	3. Samples Relinquished by / Company	Date/Time	3. Samples Received by / Company	Date/Time
Samples Relinquished by / Company	Date/Time	4. Samples Received by / Company	Date/Time	Samples Received in LAB by	Date/Time: 10/6/25 15:30 Temperature Degrees C: 17.0

Field Chain-of-Custody Record

YORK
ANALYTICAL LABORATORIES INC

York Analytical Laboratories, Inc. (YORK)'s Standard Terms & Conditions are listed on the back side of this document. This legal document serves as your written authorization for YORK to proceed with the analyses requested below. Your signature binds you to YORK's Standard Terms & Conditions.

120 Research Drive Stratford, CT 06615 132-02 89th Ave Queens, NY 11418 56 Church Hill Rd. #2 Newtown, CT 06470 2161 Whitesville Rd Toms River, NJ 08755 clientservices@yorklab.com 800-306-YORK

YORK Project Number: 25D0327

Report To:	Invoice To:
Company: QuES&T	Company: Same
Address: 1376 US-9, Wappingers Falls, NY 12590	Address:
Phone.: 845-298-6031	Phone.:
Contact: Zach Timpano	Contact:
E-mail: lab@qualityenv.com	E-mail: ap@qualityenv.com

YOUR Project Name / Number: 256977 Mamaroneck UFSD-Chatsworth Avenue Elementary School

PO Number:

Samples Collected From: NY [X] CT [ ] Other: (please specify) NJ [ ] PA [ ]

Turn-Around Time

RUSH - Next Day	
RUSH - Two Day	
RUSH - Three Day	
RUSH - Four Day	
RUSH - Five Day	
Standard (6-9 Day)	X
PFAS Standard 7-10 Day	

Please print clearly and legibly. All information must be complete. Samples will not be logged in and the turn-around-time clock will not begin until any questions by YORK are resolved.

Caroline Annesi

Samples Collected by: (print AND sign your name)

Matrix Codes

S - soil/solid/sludge
GW - groundwater
DW - drinking water
SW - surface water
WW - wastewater
O - Oil
Other

Preservative (please list number of containers)

Analyses Requested

Sample Identification	Date	Time	Matrix	Unpreserved	HCl (hydrochloric acid)	MeOH (methanol)	HNO_3 (nitric acid)	H_2SO_4 (sulfuric acid)	NaOH (sodium hydroxide)	$Na_2S_2O_3$ (sodium thio.)	Trizma	Ammonium Acetate	Other:	Lead	Grab or Comp.
CH-31 Sink in Nurses Office	10/2	1151	DW				X							X	G
CH-32 Water fountain outside nurses office	10/2	1152	DW				X							X	G
CH-33 Bottle filler outside nurses office	10/2	1153	DW				X							X	G
CH-34 Sink in classroom 27	10/2	1158	DW				X							X	G
CH-35 Sink in classroom 26	10/2	1159	DW				X							X	G
CH-36 Water fountain between 26/27	10/2	1205	DW				X							X	G
CH-37 Bottle filler between 26/27	10/2	1205	DW				X							X	G
CH-38 Sink in classroom 25	10/2	1206	DW				X							X	G
CH-39 Sink in classroom 28	10/2	1207	DW				X							X	G
CH-40 Water fountain near classroom 21	10/2	1207	DW				X							X	G
CH-41 Bottle filler near classroom 21	10/2	1207	DW				X							X	G
CH-42 Water fountain between classroom 22/23	10/2	1210	DW				X							X	G
CH-43 Bottle filler between classroom 22/23	10/2	1210	DW				X							X	G
CH-44 Sink in classroom 24	10/2	1211	DW				X							X	G
CH-45 Sink in classroom 22	10/2	1212	DW				X							X	G

Report Type (circle)
QA Report
Summary (Results Only)
NY ASP B Package
NJ Reduced
NJ DKQP
NJ Full
CT RCP

EDD Type (circle)
EQuIS (standard)
NYSDEC EQuIS
NJDEP SRP Haz Site
Standard Excel
CMDP
Other:

Regulatory Comparative
Compared to the following Regulation(s): (please fill in)

Field Filtered
Lab Filtered

Comments:

Lab Sample Receiving Checklist (to be completed by the receiving laboratory only) Circle Y / N

Custody Seals: Y / N Containers Intact: Y / N COC/Labels Agree: Y / N Preservation Confirmed: Y / N
COC Complete: Y / N COC Received: Y / N Appropriate Sample Volumes: Y / N Appropriate Sample Containers: Y / N
Cooler Temperature Confirmed: Y / N Samples Submitted within Holding Times: Y / N Corrective Action Form Required: Y / N

Samples iced/chilled at time of lab pickup? circle Yes or No

Samples Relinquished by / Company	Date/Time	1. Samples Received by / Company	Date/Time	2. Samples Relinquished by / Company	Date/Time
Caroline Annesi	10/6/25	Chris C	10.6.25 13:00	Chris C	10.6.25 15:30
Samples Received by / Company	Date/Time	3. Samples Relinquished by / Company	Date/Time	3. Samples Received by / Company	Date/Time
Samples Relinquished by / Company	Date/Time	4. Samples Received by / Company	Date/Time	Samples Received in LAB by	Date/Time / Temperature Degrees C
					10/6/25 15:35 / 17.0

Field Chain-of-Custody Record

YORK
ANALYTICAL LABORATORIES INC

York Analytical Laboratories, Inc. (YORK)'s Standard Terms & Conditions are listed on the back side of this document. This legal document serves as your written authorization for YORK to proceed with the analyses requested below. Your signature binds you to YORK's Standard Terms & Conditions.

120 Research Drive Stratford, CT 06615 132-02 89th Ave Queens, NY 11418 56 Church Hill Rd. #2 Newtown, CT 06470 2161 Whitesville Rd Toms River, NJ 08755 clientservices@yorklab.com 800-306-YORK

YORK Project Number: 25J0322

Report To:	Invoice To:	YOUR Project Name / Number
Company: QuES&T	Company: Same	256977 Mamaroneck UFSD- Chatsworth Avenue Elementary School
Address: 1376 US-9, Wappingers Falls, NY 12590	Address:	
Phone.: 845-298-6031	Phone.:	PO Number
Contact: Zach Timpano	Contact:	
E-mail: lab@qualityenv.com	E-mail: ap@qualityenv.com	

Samples Collected From: NY X, NJ, CT, PA, Other: (please specify)

Turn-Around Time: RUSH - Next Day; RUSH - Two Day; RUSH - Three Day; RUSH - Four Day; RUSH - Five Day; Standard (6-9 Day) X; PFAS Standard 7-10 Day

Please print clearly and legibly. All information must be complete. Samples will not be logged in and the turn-around-time clock will not begin until any questions by YORK are resolved.

Caroline Annesi

Samples Collected by: (print AND sign your name)

Matrix Codes: S - soil/solid/sludge; GW - groundwater; DW - drinking water; SW - surface water; WW - wastewater; O - Oil; Other

Preservative (please list number of containers)

Analyses Requested

Sample Identification	Date	Time	Matrix	Unpreserved	HCl (hydrochloric acid)	MeOH (methanol)	HNO_3 (nitric acid)	H_2SO_4 (sulfuric acid)	NaOH (sodium hydroxide)	$Na_2S_2O_3$ (sodium thio.)	Trizma	Ammonium Acetate	Other:	Lead	Grab or Comp.
CH-46 Water fountain across from upper aud.	10/2	1215	DW				X							X	G
CH-47 Bottle Filler across from upper aud.	10/2	1215	DW				X							X	G
CH-48 Water fountain across from 310	10/2	1219	DW				X							X	G
CH-49 Bottle filler across from 310	10/2	1219	DW				X							X	G
CH-50 Water fountain in front of sky gym	10/2	1224	DW				X							X	G
CH-51 Bottle filler in front of sky gym	10/2	1224	DW				X							X	G

Report Type (circle): QA Report; Summary (Results Only); NY ASP B Package; NJ Reduced; NJ DKQP; NJ Full; CT RCP

EDD Type (circle): EQuIS (standard); NYSDEC EQuIS; NJDEP SRP Haz Site; Standard Excel; CMDP; Other:

Regulatory Comparative

Compared to the following Regulation(s): (please fill in)

Field Filtered

Lab Filtered

Comments:

Samples iced/chilled at time of lab pickup? circle Yes or No

Lab Sample Receiving Checklist (to be completed by the receiving laboratory only) Circle Y / N

Custody Seals: Y / N Containers Intact: Y / N COC/Labels Agree: Y / N Preservation Confirmed: Y / N

COC Complete: Y / N COC Received: Y / N Appropriate Sample Volumes: Y / N Appropriate Sample Containers: Y / N

Cooler Temperature Confirmed: Y / N Samples Submitted within Holding Times: Y / N Corrective Action Form Required: Y / N

Samples Relinquished by / Company	Date/Time	1. Samples Received by / Company	Date/Time	2. Samples Relinquished by / Company	Date/Time
Caroline Annesi	10/6/25	Chris C	10-6-25 13:40	Chris C	10-6-25 15:30
Samples Received by / Company	Date/Time	3. Samples Relinquished by / Company	Date/Time	3. Samples Received by / Company	Date/Time
Samples Relinquished by / Company	Date/Time	4. Samples Received by / Company	Date/Time	Samples Received in LAB by	Date/Time: 10/6/25 15:30 Temperature: 17.0 Degrees C