

Lead in School Drinking Water Report

Meadowdale Middle School



EXPLANATION OF TESTING AND RESULTS

Results in this report represent sampling conducted by Washington State Department of Health (DOH). Per [RCW 28A.210.410](#) sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols.

[RCW 28A.210.410](#) does not require remediation for fixtures testing at 5 ppb and under. DOH offers post-remediation testing only for outlets that initially tested above 5 ppb. After a school completes remediation, DOH will provide up to two post-remediation sampling visits. If after the second post-remediation sampling, outlets test above 5 ppb, the district will be responsible for finding a contractor to conduct additional sampling and testing. For questions regarding sampling, testing, and results, please email: leadfreekids@doh.wa.gov.

DEFINITIONS

Fixture Housing
Location

Room/space where
fixture is located
(i.e. room number,
gym, playground)

Fixture Housing Type

Structure that contains
the individual fixtures
where water samples
were collected from.
Fixture housing may
contain one or more
individual fixture for
sampling.

Fixture Location
Details

Location within a
room or space where
fixture housing is
located, starting to the
left of the entrance and
rotating clockwise, of
the total number of
fixture housings in a
room or space
(e.g. 1/5, 2/5)

Fixture Type

Tap, Sprayer, Water
Fountain, Water Bottle
Filler, Ice maker

Fixture Position

Left, Center, Right

Date(s) collected: 2025-10-04

Date(s) analyzed: 2025-10-09

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
1	412133	Unit A - Main Building	Pot Filler	Kitchen	3 of 6 between pot fillers	Sprayer	center	16
2	412134	Unit A - Main Building	Pot Filler	Kitchen	3 of 6 between pot fillers	Tap	center	5
3	412154	Unit A - Main Building	Sink	D13	1 of 1	Tap	left	3
4	412130	Unit A - Main Building	Sink - Multi-Compartment	Kitchen	1 of 6 across freezer	Tap	center	2
5	412155	Unit A - Main Building	Fountain/Tap Combo	D13	1 of 1	Tap	center	2
6	412136	Unit A - Main Building	Sink	Kitchen	5 of 6 right of ice machine	Tap	center	1
7	412147	Unit A - Main Building	Sink	A11	1 of 1	Tap	center	1

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
8	412156	Unit A - Main Building	Sink	D13	1 of 1	Tap	right	1
9	412163	Unit A - Main Building	Sink	F15	1 of 2 right	Tap	center	1
10	412169	Unit A - Main Building	Sink	E25	1 of 1	Tap	center	1
11	412171	Unit A - Main Building	Sink	F25	1 of 1	Tap	left	1
12	412172	Unit A - Main Building	Sink	F25	1 of 1	Tap	center	1
13	412129	Unit A - Main Building	Fountain	Between C11-C12	1 of 1	Water Fountain	center	<1
14	412131	Unit A - Main Building	Sink - Multi-Compartment	Kitchen	1 of 6 across freezer	Sprayer	center	<1
15	412132	Unit A - Main Building	Pot Filler	Kitchen	2 of 6 left	Tap	center	<1
16	412135	Unit A - Main Building	Pot Filler	Kitchen	4 of 6 right pot filler	Tap	center	<1
17	412137	Unit A - Main Building	Ice Machine	Kitchen	6 of 6	Ice Machine	center	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
18	412138	Unit A - Main Building	Fountain - Multi-Level with Bottle Filler	Between Commons Restrooms	1 of 1	Water Fountain	left	<1
19	412139	Unit A - Main Building	Fountain - Multi-Level with Bottle Filler	Between Commons Restrooms	1 of 1	Water Bottle Filler	left	<1
20	412140	Unit A - Main Building	Fountain - Multi-Level with Bottle Filler	Between Commons Restrooms	1 of 1	Water Fountain	right	<1
21	412141	Unit A - Main Building	Fountain/Tap Combo	C10	1 of 1	Tap	left	<1
22	412142	Unit A - Main Building	Fountain/Tap Combo	C10	1 of 1	Water Fountain	right	<1
23	412143	Unit A - Main Building	Fountain/Tap Combo	A13	1 of 1	Tap	left	<1
24	412144	Unit A - Main Building	Fountain/Tap Combo	A13	1 of 1	Water Fountain	right	<1
25	412145	Unit A - Main Building	Fountain/Tap Combo	A12	1 of 1	Tap	left	<1
26	412146	Unit A - Main Building	Fountain/Tap Combo	A12	1 of 1	Water Fountain	right	<1
27	412148	Unit A - Main Building	Fountain/Tap Combo	Health Room	1 of 1	Tap	left	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
28	412149	Unit A - Main Building	Fountain/Tap Combo	Health Room	1 of 1	Water Fountain	right	<1
29	412150	Unit A - Main Building	Fountain/Tap Combo	Workroom	1 of 1	Tap	left	<1
30	412151	Unit A - Main Building	Fountain/Tap Combo	Workroom	1 of 1	Water Fountain	right	<1
31	412152	Unit A - Main Building	Sink	B15b	1 of 1	Tap	center	<1
32	412153	Unit A - Main Building	Sink	B14a	1 of 1	Tap	center	<1
33	412157	Unit A - Main Building	Sink - Multi-Compartment	D16	1 of 1	Tap	center	<1
34	412158	Unit A - Main Building	Fountain - Multi-Level	Across D16	1 of 1	Water Fountain	left	<1
35	412159	Unit A - Main Building	Fountain - Multi-Level	Across D16	1 of 1	Water Fountain	right	<1
36	412160	Unit A - Main Building	Sink	E100 Flex	1 of 1	Tap	center	<1
37	412161	Unit A - Main Building	Sink	E15	1 of 1	Tap	center	<1
38	412162	Unit A - Main Building	Sink	F100 Flex	1 of 1	Tap	center	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
39	412164	Unit A - Main Building	Sink - Multi-Compartment	Teacher Lounge	1 of 1	Tap	center	<1
40	412165	Unit A - Main Building	Sink	D200 Flex	1 of 1	Tap	center	<1
41	412166	Unit A - Main Building	Fountain - Multi-Level	Across D26	1 of 1	Water Fountain	left	<1
42	412167	Unit A - Main Building	Fountain - Multi-Level	Across D26	1 of 1	Water Fountain	right	<1
43	412168	Unit A - Main Building	Sink	E200 Flex	1 of 1	Tap	center	<1
44	412170	Unit A - Main Building	Sink	F200 Flex	1 of 1	Tap	center	<1
45	412173	Unit A - Main Building	Sink	F25	1 of 1	Tap	right	<1
46	412174	Unit A - Main Building	Sink	F15	2 of 2 left	Tap	center	<1