

# Shive-Hattery

2839 Northgate Drive

Iowa City IA 52445

319-354-3040 / 319-248-3405 / 319-530-2456 (cell)

<http://www.shive-hattery.com/> / [sbecker@shive-hattery.com](mailto:sbecker@shive-hattery.com)

## Radon Test Report

December 06, 2024

Batch #: 120524-3

### Customer:

Iowa City Community School District  
1155 S. Riverside Drive  
Iowa City IA 52246

### Test Site:

3571 Sycamore Street Bldg.- Alexander  
Elementary  
Iowa City IA 52240

E-PERM® Electret Ion Chambers were used for radon screening measurements that were conducted at the above referenced test site by: Shive-Hattery

### The Results are as follows:

Serial	Type	Location	Test Start Date	Test End Date	Results (pCi/L)
SML545	SST	Music 194	02-Dec-2024 6:15 AM	05-Dec-2024 6:30 AM	0.8
SNL401	SST	140	02-Dec-2024 6:15 AM	05-Dec-2024 6:30 AM	<LLD
SNL439	SST	Nurse 162	02-Dec-2024 6:15 AM	05-Dec-2024 6:30 AM	0.5
SNL458	SST	221	02-Dec-2024 6:15 AM	05-Dec-2024 6:30 AM	3.0
SNL469	SST	Principal 164	02-Dec-2024 6:15 AM	05-Dec-2024 6:30 AM	1.2
SNL504	SST	Lessons 196	02-Dec-2024 6:15 AM	05-Dec-2024 6:30 AM	0.8
SNL508	SST	144	02-Dec-2024 6:15 AM	05-Dec-2024 6:30 AM	2.9
SNL537	SST	134	02-Dec-2024 6:15 AM	05-Dec-2024 6:30 AM	<LLD
SNL570	SST	138	02-Dec-2024 6:15 AM	05-Dec-2024 6:30 AM	<LLD
SNM860	SST	Cafeteria 161	02-Dec-2024 6:15 AM	05-Dec-2024 6:30 AM	<LLD
SNM966	SST	145	02-Dec-2024 6:15 AM	05-Dec-2024 6:30 AM	0.7
SNT780	SST	147	02-Dec-2024 6:15 AM	05-Dec-2024 6:30 AM	0.5
SNU349	SST	111	02-Dec-2024 6:15 AM	05-Dec-2024 6:30 AM	<LLD
SNU490	SST	Counselor	02-Dec-2024 6:15 AM	05-Dec-2024 6:30 AM	0.6
SNU544	SST	Family Resource 174	02-Dec-2024 6:15 AM	05-Dec-2024 6:30 AM	0.8
SNU566	SST	127	02-Dec-2024 6:15 AM	05-Dec-2024 6:30 AM	0.6
SNU582	SST	Gym 171	02-Dec-2024 6:15 AM	05-Dec-2024 6:30 AM	0.8
SNU608	SST	208	02-Dec-2024 6:15 AM	05-Dec-2024 6:30 AM	0.5
SNU633	SST	113	02-Dec-2024 6:15 AM	05-Dec-2024 6:30 AM	0.8
SNU737	SST	149	02-Dec-2024 6:15 AM	05-Dec-2024 6:30 AM	1.7
SNU750	SST	129	02-Dec-2024 6:15 AM	05-Dec-2024 6:30 AM	3.8
SNW991	SST	141	02-Dec-2024 6:15 AM	05-Dec-2024 6:30 AM	<LLD
SNW994	SST	Gym 171	02-Dec-2024 6:15 AM	05-Dec-2024 6:30 AM	0.6
SNX007	SST	180	02-Dec-2024 6:15 AM	05-Dec-2024 6:30 AM	<LLD
SNX015	SST	Custodian 186	02-Dec-2024 6:15 AM	05-Dec-2024 6:30 AM	1.3
SNX022	SST	Library 105	02-Dec-2024 6:15 AM	05-Dec-2024 6:30 AM	0.8
SNX032	SST	Library 105	02-Dec-2024 6:15 AM	05-Dec-2024 6:30 AM	1.6
SNX053	SST	PE Office 175	02-Dec-2024 6:15 AM	05-Dec-2024 6:30 AM	0.6
SNX060	SST	Reception 160	02-Dec-2024 6:15 AM	05-Dec-2024 6:30 AM	1.0
SNX136	SST	Library Office 105A	02-Dec-2024 6:15 AM	05-Dec-2024 6:30 AM	0.5
SNX233	SST	Work Room	02-Dec-2024 6:15 AM	05-Dec-2024 6:30 AM	0.6
SNX240	SST	148	02-Dec-2024 6:15 AM	05-Dec-2024 6:30 AM	1.6
SNX250	SST	142	02-Dec-2024 6:15 AM	05-Dec-2024 6:30 AM	1.1
SNX254	SST	136	02-Dec-2024 6:15 AM	05-Dec-2024 6:30 AM	0.5
SNX259	SST	104	02-Dec-2024 6:15 AM	05-Dec-2024 6:30 AM	0.5
SNX267	SST	106	02-Dec-2024 6:15 AM	05-Dec-2024 6:30 AM	<LLD
SNX269	SST	BASP 182	02-Dec-2024 6:15 AM	05-Dec-2024 6:30 AM	0.8

# Shive-Hattery

2839 Northgate Drive  
Iowa City IA 52445  
319-354-3040 / 319-248-3405 / 319-530-2456 (cell)  
<http://www.shive-hattery.com/> / [sbecker@shive-hattery.com](mailto:sbecker@shive-hattery.com)

## Radon Test Report

December 06, 2024

Batch #: 120524-3

### Customer:

Iowa City Community School District  
1155 S. Riverside Drive  
Iowa City IA 52246

### Test Site:

3571 Sycamore Street Bldg.- Alexander  
Elementary  
Iowa City IA 52240

Serial	Type	Location	Test Start Date	Test End Date	Results (pCi/L)
SNX282	SST	Computer Lab 103	02-Dec-2024 6:15 AM	05-Dec-2024 6:30 AM	2.3
SNX501	SST	Office 168	02-Dec-2024 6:15 AM	05-Dec-2024 6:30 AM	1.6
SOA537	SST	Conference 166	02-Dec-2024 6:15 AM	05-Dec-2024 6:30 AM	1.0
SOA644	SST	Gym 171	02-Dec-2024 6:15 AM	05-Dec-2024 6:30 AM	1.1
SNL688	SST	Art 188	02-Dec-2024 6:15 AM	05-Dec-2024 6:30 AM	1.9
SNX100	SST	Art 188	02-Dec-2024 6:15 AM	05-Dec-2024 6:30 AM	1.0
<b>Average Radon Concentration in:</b>			<b>Art 188</b>		<b>1.4 pCi/L</b>
SNX050	SST	108	02-Dec-2024 6:15 AM	05-Dec-2024 6:30 AM	<LLD
SNX104	SST	108	02-Dec-2024 6:15 AM	05-Dec-2024 6:30 AM	0.6
<b>Average Radon Concentration in:</b>			<b>108</b>		<b>&lt;LLD pCi/L</b>
SNM933	SST	109	02-Dec-2024 6:15 AM	05-Dec-2024 6:30 AM	<LLD
SNX027	SST	109	02-Dec-2024 6:15 AM	05-Dec-2024 6:30 AM	0.5
<b>Average Radon Concentration in:</b>			<b>109</b>		<b>0.4 pCi/L</b>
SNK609	SST	143	02-Dec-2024 6:15 AM	05-Dec-2024 6:30 AM	<LLD
SNX184	SST	143	02-Dec-2024 6:15 AM	05-Dec-2024 6:30 AM	<LLD
<b>Average Radon Concentration in:</b>			<b>143</b>		<b>&lt;LLD pCi/L</b>
SNM865	SST	146	02-Dec-2024 6:15 AM	05-Dec-2024 6:30 AM	1.4
SNX115	SST	146	02-Dec-2024 6:15 AM	05-Dec-2024 6:30 AM	1.5
<b>Average Radon Concentration in:</b>			<b>146</b>		<b>1.4 pCi/L</b>

**Deployed By:** Sam Becker RNTST10096  
**Retrieved By:** Sam Becker RNTST10096  
**Analyzed By:** Sam Becker RNTST10096  
**Reader S/N:** E0747 **Reader Calibration Due:** 11/2/2024  
**Conditions:** Requirements for Closed-Building Met  
**Weather:** No Abnormal Weather Conditions / windy for 12 hours during testing period  
**Vents:** Open / Fan Auto  
**Mitigation:** No System Installed

**Note:** <LLD = Less than the Lower Limit of Detection (LLD) of the Radon Detector.

### Radon Health Risk Information

Radon is the second leading cause of lung cancer after smoking. The U.S. Environmental Protection Agency (EPA) and the Surgeon General strongly recommend that further action be taken when a home's radon test results are 4.0 pCi/L or greater. The national average indoor radon level is about 1.3 pCi/L. The higher the home's radon level, the greater the health risk to you and your family. Reducing your radon levels can be done easily, effectively and fairly inexpensively. Even homes with very high radon levels can be reduced below 4.0 pCi/L. Please refer to the EPA website at [www.epa.gov/radon](http://www.epa.gov/radon) for further information to assist you in evaluating your test results or deciding if further action is needed.

# Shive-Hattery

2839 Northgate Drive  
Iowa City IA 52445  
319-354-3040 / 319-248-3405 / 319-530-2456 (cell)  
<http://www.shive-hattery.com/> / [sbecker@shive-hattery.com](mailto:sbecker@shive-hattery.com)

## Radon Test Report

December 06, 2024

Batch #: 120524-3

**Customer:**

Iowa City Community School District  
1155 S. Riverside Drive  
Iowa City IA 52246

**Test Site:**

3571 Sycamore Street Bldg.- Alexander  
Elementary  
Iowa City IA 52240

---

Signature: \_\_\_\_\_ Date: \_\_\_\_\_

# Shive-Hattery

2839 Northgate Drive  
Iowa City IA 52445  
319-354-3040 / 319-248-3405 / 319-530-2456 (cell)  
<http://www.shive-hattery.com/> / [sbecker@shive-hattery.com](mailto:sbecker@shive-hattery.com)

## Radon Test Report

December 09, 2024

Batch #: 120524-2

### Customer:

Iowa City Community School District  
1155 S. Riverside Drive  
Iowa City IA 52246

### Test Site:

1000 Kennedy Parkway Bldg.- Borlaug  
Elementary  
Coralville IA 52241

E-PERM® Electret Ion Chambers were used for radon screening measurements that were conducted at the above referenced test site by: Shive-Hattery

### The Results are as follows:

Serial	Type	Location	Test Start Date	Test End Date	Results (pCi/L)
SML578	SST	1807	02-Dec-2024 7:30 AM	05-Dec-2024 7:20 AM	2.1
SNE903	SST	1102	02-Dec-2024 7:30 AM	05-Dec-2024 7:20 AM	5.2
SNL326	SST	1104	02-Dec-2024 7:30 AM	05-Dec-2024 7:20 AM	2.9
SNL331	SST	1103	02-Dec-2024 7:30 AM	05-Dec-2024 7:20 AM	2.5
SNL352	SST	1202	02-Dec-2024 7:30 AM	05-Dec-2024 7:20 AM	2.1
SNL364	SST	1802	02-Dec-2024 7:30 AM	05-Dec-2024 7:20 AM	2.4
SNL376	SST	Gym	02-Dec-2024 7:30 AM	05-Dec-2024 7:20 AM	2.1
SNL434	SST	1503	02-Dec-2024 7:30 AM	05-Dec-2024 7:20 AM	2.0
SNL436	SST	Gym	02-Dec-2024 7:30 AM	05-Dec-2024 7:20 AM	0.9
SNL441	SST	1504	02-Dec-2024 7:30 AM	05-Dec-2024 7:20 AM	1.7
SNL465	SST	2305	02-Dec-2024 7:30 AM	05-Dec-2024 7:20 AM	2.0
SNL468	SST	2401	02-Dec-2024 7:30 AM	05-Dec-2024 7:20 AM	2.2
SNL475	SST	1101	02-Dec-2024 7:30 AM	05-Dec-2024 7:20 AM	2.5
SNL491	SST	1606	02-Dec-2024 7:30 AM	05-Dec-2024 7:20 AM	1.8
SNL514	SST	1205	02-Dec-2024 7:30 AM	05-Dec-2024 7:20 AM	2.7
SNL555	SST	1203	02-Dec-2024 7:30 AM	05-Dec-2024 7:20 AM	2.5
SNL562	SST	Gym	02-Dec-2024 7:30 AM	05-Dec-2024 7:20 AM	2.4
SNL567	SST	1809	02-Dec-2024 7:30 AM	05-Dec-2024 7:20 AM	1.4
SNL577	SST	1607	02-Dec-2024 7:30 AM	05-Dec-2024 7:20 AM	2.1
SNL673	SST	1105	02-Dec-2024 7:30 AM	05-Dec-2024 7:20 AM	2.6
SNM720	SST	1204	02-Dec-2024 7:30 AM	05-Dec-2024 7:20 AM	<LLD
SNU156	SST	1201	02-Dec-2024 7:30 AM	05-Dec-2024 7:20 AM	2.0
SNU504	SST	1513	02-Dec-2024 7:30 AM	05-Dec-2024 7:20 AM	1.8
SNU522	SST	1808	02-Dec-2024 7:30 AM	05-Dec-2024 7:20 AM	1.7
SNU559	SST	1603	02-Dec-2024 7:30 AM	05-Dec-2024 7:20 AM	1.7
SNU578	SST	1907	02-Dec-2024 7:30 AM	05-Dec-2024 7:20 AM	2.0
SNU611	SST	1506	02-Dec-2024 7:30 AM	05-Dec-2024 7:20 AM	1.7
SNU657	SST	1708	02-Dec-2024 7:30 AM	05-Dec-2024 7:20 AM	1.8
SNU710	SST	1501	02-Dec-2024 7:30 AM	05-Dec-2024 7:20 AM	1.8
SNX031	SST	1206	02-Dec-2024 7:30 AM	05-Dec-2024 7:20 AM	2.3
SNX105	SST	1706/1707	02-Dec-2024 7:30 AM	05-Dec-2024 7:20 AM	2.0
SNX176	SST	1209	02-Dec-2024 7:30 AM	05-Dec-2024 7:20 AM	2.0
SNX256	SST	1512	02-Dec-2024 7:30 AM	05-Dec-2024 7:20 AM	2.2
SNL515	SST	1507	02-Dec-2024 7:30 AM	05-Dec-2024 7:20 AM	1.9
SNU534	SST	1507	02-Dec-2024 7:30 AM	05-Dec-2024 7:20 AM	2.4

Average Radon Concentration in:

1507

2.2 pCi/L

# Shive-Hattery

2839 Northgate Drive  
Iowa City IA 52445  
319-354-3040 / 319-248-3405 / 319-530-2456 (cell)  
<http://www.shive-hattery.com/> / [sbecker@shive-hattery.com](mailto:sbecker@shive-hattery.com)

## Radon Test Report

December 09, 2024

Batch #: 120524-2

### Customer:

Iowa City Community School District  
1155 S. Riverside Drive  
Iowa City IA 52246

### Test Site:

1000 Kennedy Parkway Bldg.- Borlaug  
Elementary  
Coralville IA 52241

Serial	Type	Location	Test Start Date	Test End Date	Results (pCi/L)
SNU638	SST	1106	02-Dec-2024 7:30 AM	05-Dec-2024 7:20 AM	2.7
SNX000	SST	1106	02-Dec-2024 7:30 AM	05-Dec-2024 7:20 AM	2.3
<b>Average Radon Concentration in:</b>			<b>1106</b>		<b>2.5 pCi/L</b>
SML533	SST	1806	02-Dec-2024 7:30 AM	05-Dec-2024 7:20 AM	2.4
SNU551	SST	1806	02-Dec-2024 7:30 AM	05-Dec-2024 7:20 AM	2.2
<b>Average Radon Concentration in:</b>			<b>1806</b>		<b>2.3 pCi/L</b>
SNE899	SST	1702	02-Dec-2024 7:30 AM	05-Dec-2024 7:20 AM	2.2
SNL470	SST	1702	02-Dec-2024 7:30 AM	05-Dec-2024 7:20 AM	2.6
<b>Average Radon Concentration in:</b>			<b>1702</b>		<b>2.4 pCi/L</b>
SIE461	SST	1207	02-Dec-2024 7:30 AM	05-Dec-2024 7:20 AM	2.1
SML581	SST	1207	02-Dec-2024 7:30 AM	05-Dec-2024 7:20 AM	
<b>Average Radon Concentration in:</b>			<b>1207</b>		<b>2.1 pCi/L</b>

Deployed By: Sam Becker RNTST10096  
Retrieved By: Sam Becker RNTST10096  
Analyzed By: Sam Becker RNTST10096  
Reader S/N: E0747 Reader Calibration Due: 11/2/2024  
Conditions: Requirements for Closed-Building Met  
Weather: No Abnormal Weather Conditions / higher winds for a 12 hour period.  
Vents: Open / Fan Auto  
Mitigation: No System Installed

Note: <LLD = Less than the Lower Limit of Detection (LLD) of the Radon Detector.

### Radon Health Risk Information

Radon is the second leading cause of lung cancer after smoking. The U.S. Environmental Protection Agency (EPA) and the Surgeon General strongly recommend that further action be taken when a home's radon test results are 4.0 pCi/L or greater. The national average indoor radon level is about 1.3 pCi/L. The higher the home's radon level, the greater the health risk to you and your family. Reducing your radon levels can be done easily, effectively and fairly inexpensively. Even homes with very high radon levels can be reduced below 4.0 pCi/L. Please refer to the EPA website at [www.epa.gov/radon](http://www.epa.gov/radon) for further information to assist you in evaluating your test results or deciding if further action is needed.

# Shive-Hattery

2839 Northgate Drive  
Iowa City IA 52445  
319-354-3040 / 319-248-3405 / 319-530-2456 (cell)  
<http://www.shive-hattery.com/> / [sbecker@shive-hattery.com](mailto:sbecker@shive-hattery.com)

## Radon Test Report

March 07, 2025

Batch #: 030725-1

**Customer:**

Iowa City Community School District  
1155 S. Riverside Drive  
Iowa City IA 52246

**Test Site:**

1000 Kennedy Parkway Bldg.- Borlaug  
Elementary  
Coralville IA 52241

E-PERM® Electret Ion Chambers were used for radon screening measurements that were conducted at the above referenced test site by: Shive-Hattery

**The Results are as follows:**

Serial	Type	Location	Test Start Date	Test End Date	Results (pCi/L)
SNL731	SST	1102 Kindergarten	04-Mar-2025 6:05 AM	06-Mar-2025 6:10 AM	1.1
SNN813	SST	1102 Kindergarten	04-Mar-2025 6:05 AM	06-Mar-2025 6:10 AM	2.7
<b>Average Radon Concentration in:</b>			<b>1102 Kindergarten</b>	<b>1.9 pCi/L</b>	

**Deployed By:** Sam Becker RNTST10096  
**Retrieved By:** Sam Becker RNTST10096  
**Analyzed By:** Sam Becker RNTST10096  
**Reader S/N:** E0747 **Reader Calibration Due:** 11/2/2024  
**Conditions:** Requirements for Closed-Building Met  
**Weather:** No Abnormal Weather Conditions  
**Vents:** Open / Fan Auto  
**Mitigation:** No System Installed

### Radon Health Risk Information

Radon is the second leading cause of lung cancer after smoking. The U.S. Environmental Protection Agency (EPA) and the Surgeon General strongly recommend that further action be taken when a home's radon test results are 4.0 pCi/L or greater. The national average indoor radon level is about 1.3 pCi/L. The higher the home's radon level, the greater the health risk to you and your family. Reducing your radon levels can be done easily, effectively and fairly inexpensively. Even homes with very high radon levels can be reduced below 4.0 pCi/L. Please refer to the EPA website at [www.epa.gov/radon](http://www.epa.gov/radon) for further information to assist you in evaluating your test results or deciding if further action is needed.

Signature: \_\_\_\_\_ Date: \_\_\_\_\_

# Shive-Hattery

2839 Northgate Drive  
Iowa City IA 52445  
319-354-3040 / 319-248-3405 / 319-530-2456 (cell)  
<http://www.shive-hattery.com/> / [sbecker@shive-hattery.com](mailto:sbecker@shive-hattery.com)

## Radon Test Report

December 09, 2024

Batch #: 120624-1

### Customer:

Iowa City Community School District  
1155 S. Riverside Drive  
Iowa City IA 52246

### Test Site:

501 6th Street Bldg.- Coralville Central  
Elementary  
Coralville IA 52241

E-PERM® Electret Ion Chambers were used for radon screening measurements that were conducted at the above referenced test site by: Shive-Hattery

### The Results are as follows:

Serial	Type	Location	Test Start Date	Test End Date	Results (pCi/L)
SML530	SST	130	03-Dec-2024 6:00 AM	06-Dec-2024 8:01 AM	1.6
SNF012	SST	167	03-Dec-2024 6:00 AM	06-Dec-2024 8:01 AM	1.5
SNK456	SST	102	03-Dec-2024 6:00 AM	06-Dec-2024 8:01 AM	1.2
SNK478	SST	130	03-Dec-2024 6:00 AM	06-Dec-2024 8:01 AM	1.6
SNL319	SST	137	03-Dec-2024 6:00 AM	06-Dec-2024 8:01 AM	1.3
SNL357	SST	135	03-Dec-2024 6:00 AM	06-Dec-2024 8:01 AM	1.3
SNL397	SST	018	03-Dec-2024 6:00 AM	06-Dec-2024 8:01 AM	1.5
SNL490	SST	181	03-Dec-2024 6:00 AM	06-Dec-2024 8:01 AM	1.8
SNL497	SST	135	03-Dec-2024 6:00 AM	06-Dec-2024 8:01 AM	0.8
SNL538	SST	221	03-Dec-2024 6:00 AM	06-Dec-2024 8:01 AM	1.0
SNL539	SST	146	03-Dec-2024 6:00 AM	06-Dec-2024 8:01 AM	2.3
SNL540	SST	186	03-Dec-2024 6:00 AM	06-Dec-2024 8:01 AM	2.0
SNL559	SST	019	03-Dec-2024 6:00 AM	06-Dec-2024 8:01 AM	2.0
SNN771	SST	157	03-Dec-2024 6:00 AM	06-Dec-2024 8:01 AM	2.6
SNT909	SST	182	03-Dec-2024 6:00 AM	06-Dec-2024 8:01 AM	1.6
SNU469	SST	151	03-Dec-2024 6:00 AM	06-Dec-2024 8:01 AM	1.3
SNU489	SST	007	03-Dec-2024 6:00 AM	06-Dec-2024 8:01 AM	2.6
SNU524	SST	014	03-Dec-2024 6:00 AM	06-Dec-2024 8:01 AM	1.4
SNU553	SST	146	03-Dec-2024 6:00 AM	06-Dec-2024 8:01 AM	1.4
SNU568	SST	153	03-Dec-2024 6:00 AM	06-Dec-2024 8:01 AM	2.1
SNU573	SST	132	03-Dec-2024 6:00 AM	06-Dec-2024 8:01 AM	2.1
SNU609	SST	016	03-Dec-2024 6:00 AM	06-Dec-2024 8:01 AM	1.1
SNU630	SST	136	03-Dec-2024 6:00 AM	06-Dec-2024 8:01 AM	2.3
SNU695	SST	140	03-Dec-2024 6:00 AM	06-Dec-2024 8:01 AM	2.6
SNX121	SST	184	03-Dec-2024 6:00 AM	06-Dec-2024 8:01 AM	1.1
SNX283	SST	136	03-Dec-2024 6:00 AM	06-Dec-2024 8:01 AM	1.4
SNT758	SST	162	03-Dec-2024 6:00 AM	06-Dec-2024 8:01 AM	2.1
SNU584	SST	162	03-Dec-2024 6:00 AM	06-Dec-2024 8:01 AM	1.1
<b>Average Radon Concentration in:</b>			<b>162</b>	<b>1.6 pCi/L</b>	
SNM817	SST	147	03-Dec-2024 6:00 AM	06-Dec-2024 8:01 AM	1.6
SNU778	SST	147	03-Dec-2024 6:00 AM	06-Dec-2024 8:01 AM	1.4
<b>Average Radon Concentration in:</b>			<b>147</b>	<b>1.5 pCi/L</b>	
SNL360	SST	185	03-Dec-2024 6:00 AM	06-Dec-2024 8:01 AM	1.6
SNU548	SST	185	03-Dec-2024 6:00 AM	06-Dec-2024 8:01 AM	1.9
<b>Average Radon Concentration in:</b>			<b>185</b>	<b>1.8 pCi/L</b>	

# Shive-Hattery

2839 Northgate Drive  
Iowa City IA 52445  
319-354-3040 / 319-248-3405 / 319-530-2456 (cell)  
<http://www.shive-hattery.com/> / [sbecker@shive-hattery.com](mailto:sbecker@shive-hattery.com)

## Radon Test Report

December 09, 2024  
Batch #: 120624-1

### Customer:

Iowa City Community School District  
1155 S. Riverside Drive  
Iowa City IA 52246

### Test Site:

501 6th Street Bldg.- Coralville Central  
Elementary  
Coralville IA 52241

Serial	Type	Location	Test Start Date	Test End Date	Results (pCi/L)
SNF027	SST	013	03-Dec-2024 6:00 AM	06-Dec-2024 8:01 AM	1.5
SNL580	SST	013	03-Dec-2024 6:00 AM	06-Dec-2024 8:01 AM	1.8
<b>Average Radon Concentration in:</b>			<b>013</b>	<b>1.7 pCi/L</b>	

**Deployed By:** Sam Becker RNTST10096  
**Retrieved By:** Sam Becker RNTST10096  
**Analyzed By:** Sam Becker RNTST10096  
**Reader S/N:** E0747 **Reader Calibration Due:** 11/2/2024  
**Conditions:** Requirements for Closed-Building Met  
**Weather:** No Abnormal Weather Conditions  
**Vents:** Vent Fan Auto / Fan Auto  
**Mitigation:** No System Installed

### Radon Health Risk Information

Radon is the second leading cause of lung cancer after smoking. The U.S. Environmental Protection Agency (EPA) and the Surgeon General strongly recommend that further action be taken when a home's radon test results are 4.0 pCi/L or greater. The national average indoor radon level is about 1.3 pCi/L. The higher the home's radon level, the greater the health risk to you and your family. Reducing your radon levels can be done easily, effectively and fairly inexpensively. Even homes with very high radon levels can be reduced below 4.0 pCi/L. Please refer to the EPA website at [www.epa.gov/radon](http://www.epa.gov/radon) for further information to assist you in evaluating your test results or deciding if further action is needed.

Signature: \_\_\_\_\_

Date: \_\_\_\_\_

# Shive-Hattery

2839 Northgate Drive  
Iowa City IA 52445  
319-354-3040 / 319-248-3405 / 319-530-2456 (cell)  
<http://www.shive-hattery.com/> / [sbecker@shive-hattery.com](mailto:sbecker@shive-hattery.com)

## Radon Test Report

December 31, 2024

Batch #: 123124-3

### Customer:

Iowa City Community School District  
1155 S. Riverside Drive  
Iowa City IA 52246

### Test Site:

3100 E Washington Street Bldg.-  
Lemme Elementary  
Iowa City IA 52245

E-PERM® Electret Ion Chambers were used for radon screening measurements that were conducted at the above referenced test site by: Shive-Hattery

### The Results are as follows:

Serial	Type	Location	Test Start Date	Test End Date	Results (pCi/L)
SML413	SST	106	16-Dec-2024 6:17 AM	18-Dec-2024 6:18 AM	6.5
SMV427	SST	139	16-Dec-2024 6:17 AM	18-Dec-2024 6:18 AM	6.8
SNE751	SST	123	16-Dec-2024 6:17 AM	18-Dec-2024 6:18 AM	2.8
SNE904	SST	140	16-Dec-2024 6:17 AM	18-Dec-2024 6:18 AM	5.4
SNF023	SST	134H	16-Dec-2024 6:17 AM	18-Dec-2024 6:18 AM	3.2
SNK324	SST	132	16-Dec-2024 6:17 AM	18-Dec-2024 6:18 AM	3.7
SNK350	SST	134F	16-Dec-2024 6:17 AM	18-Dec-2024 6:18 AM	5.7
SNK501	SST	126	16-Dec-2024 6:17 AM	18-Dec-2024 6:18 AM	4.6
SNL305	SST	105	16-Dec-2024 6:17 AM	18-Dec-2024 6:18 AM	14.4
SNL313	SST	115	16-Dec-2024 6:17 AM	18-Dec-2024 6:18 AM	6.2
SNL322	SST	103	16-Dec-2024 6:17 AM	18-Dec-2024 6:18 AM	7.0
SNL329	SST	114	16-Dec-2024 6:17 AM	18-Dec-2024 6:18 AM	5.8
SNL335	SST	129	16-Dec-2024 6:17 AM	18-Dec-2024 6:18 AM	7.9
SNL337	SST	134C Principal Mangan	16-Dec-2024 6:17 AM	18-Dec-2024 6:18 AM	2.7
SNL380	SST	134D	16-Dec-2024 6:17 AM	18-Dec-2024 6:18 AM	3.9
SNL393	SST	102	16-Dec-2024 6:17 AM	18-Dec-2024 6:18 AM	11.2
SNL404	SST	125	16-Dec-2024 6:17 AM	18-Dec-2024 6:18 AM	6.3
SNL447	SST	128	16-Dec-2024 6:17 AM	18-Dec-2024 6:18 AM	4.2
SNL460	SST	122 Kitchen	16-Dec-2024 6:17 AM	18-Dec-2024 6:18 AM	4.5
SNL462	SST	134B Health	16-Dec-2024 6:17 AM	18-Dec-2024 6:18 AM	5.1
SNL473	SST	112	16-Dec-2024 6:17 AM	18-Dec-2024 6:18 AM	5.6
SNL478	SST	113	16-Dec-2024 6:17 AM	18-Dec-2024 6:18 AM	5.2
SNL505	SST	128	16-Dec-2024 6:17 AM	18-Dec-2024 6:18 AM	5.9
SNL510	SST	110	16-Dec-2024 6:17 AM	18-Dec-2024 6:18 AM	5.2
SNL513	SST	101	16-Dec-2024 6:17 AM	18-Dec-2024 6:18 AM	6.7
SNL523	SST	133	16-Dec-2024 6:17 AM	18-Dec-2024 6:18 AM	3.3
SNL525	SST	134 Main Office	16-Dec-2024 6:17 AM	18-Dec-2024 6:18 AM	4.6
SNL553	SST	107	16-Dec-2024 6:17 AM	18-Dec-2024 6:18 AM	5.9
SNL558	SST	145	16-Dec-2024 6:17 AM	18-Dec-2024 6:18 AM	6.6
SNL560	SST	117 Multimedia	16-Dec-2024 6:17 AM	18-Dec-2024 6:18 AM	6.6
SNL574	SST	117A	16-Dec-2024 6:17 AM	18-Dec-2024 6:18 AM	7.4
SNL592	SST	108	16-Dec-2024 6:17 AM	18-Dec-2024 6:18 AM	8.7
SNM776	SST	111	16-Dec-2024 6:17 AM	18-Dec-2024 6:18 AM	5.1
SNN813	SST	130	16-Dec-2024 6:17 AM	18-Dec-2024 6:18 AM	10.5
SNU241	SST	117 Multimedia	16-Dec-2024 6:17 AM	18-Dec-2024 6:18 AM	4.6
SNU292	SST	134A	16-Dec-2024 6:17 AM	18-Dec-2024 6:18 AM	7.3
SNU615	SST	135A Gym	16-Dec-2024 6:17 AM	18-Dec-2024 6:18 AM	6.0

# Shive-Hattery

2839 Northgate Drive  
Iowa City IA 52445  
319-354-3040 / 319-248-3405 / 319-530-2456 (cell)  
<http://www.shive-hattery.com/> / [sbecker@shive-hattery.com](mailto:sbecker@shive-hattery.com)

## Radon Test Report

December 31, 2024

Batch #: 123124-3

### Customer:

Iowa City Community School District  
1155 S. Riverside Drive  
Iowa City IA 52246

### Test Site:

3100 E Washington Street Bldg.-  
Lemme Elementary  
Iowa City IA 52245

Serial	Type	Location	Test Start Date		Test End Date		Results (pCi/L)
SNU637	SST	144	16-Dec-2024	6:17 AM	18-Dec-2024	6:18 AM	8.3
SNL477	SST	131	16-Dec-2024	6:17 AM	18-Dec-2024	6:18 AM	6.1
SNL557	SST	131	16-Dec-2024	6:17 AM	18-Dec-2024	6:18 AM	5.7
<b>Average Radon Concentration in:</b>			<b>131</b>		<b>5.9 pCi/L</b>		
SNL430	SST	104	16-Dec-2024	6:17 AM	18-Dec-2024	6:18 AM	7.4
SNL606	SST	104	16-Dec-2024	6:17 AM	18-Dec-2024	6:18 AM	7.1
<b>Average Radon Concentration in:</b>			<b>104</b>		<b>7.2 pCi/L</b>		
SNL474	SST	109	16-Dec-2024	6:17 AM	18-Dec-2024	6:18 AM	5.8
SNL548	SST	109	16-Dec-2024	6:17 AM	18-Dec-2024	6:18 AM	5.9
<b>Average Radon Concentration in:</b>			<b>109</b>		<b>5.8 pCi/L</b>		
SNL535	SST	143 Art	16-Dec-2024	6:17 AM	18-Dec-2024	6:18 AM	7.8
SNU800	SST	143 Art	16-Dec-2024	6:17 AM	18-Dec-2024	6:18 AM	6.0
<b>Average Radon Concentration in:</b>			<b>143 Art</b>		<b>6.9 pCi/L</b>		

**Deployed By:** Sam Becker RNTST10096  
**Retrieved By:** Sam Becker RNTST10096  
**Analyzed By:** Sam Becker RNTST10096  
**Reader S/N:** E0747 **Reader Calibration Due:** 11/2/2024  
**Conditions:** Requirements for Closed-Building Met  
**Weather:** No Abnormal Weather Conditions  
**Vents:** Open / Fan Auto  
**Mitigation:** No System Installed

### Radon Health Risk Information

Radon is the second leading cause of lung cancer after smoking. The U.S. Environmental Protection Agency (EPA) and the Surgeon General strongly recommend that further action be taken when a home's radon test results are 4.0 pCi/L or greater. The national average indoor radon level is about 1.3 pCi/L. The higher the home's radon level, the greater the health risk to you and your family. Reducing your radon levels can be done easily, effectively and fairly inexpensively. Even homes with very high radon levels can be reduced below 4.0 pCi/L. Please refer to the EPA website at [www.epa.gov/radon](http://www.epa.gov/radon) for further information to assist you in evaluating your test results or deciding if further action is needed.

Signature: \_\_\_\_\_ Date: \_\_\_\_\_

# Shive-Hattery

2839 Northgate Drive

Iowa City IA 52445

319-354-3040 / 319-248-3405 / 319-530-2456 (cell)

<http://www.shive-hattery.com/> / [sbecker@shive-hattery.com](mailto:sbecker@shive-hattery.com)

## Radon Test Report

March 11, 2025

Batch #: 031125-1

### Customer:

Iowa City Community School District  
1155 S. Riverside Drive  
Iowa City IA 52246

### Test Site:

Jarod Tylee  
3100 East Washington Street Bldg.-  
Lemme Elementary  
Iowa City IA 52245

E-PERM® Electret Ion Chambers were used for radon screening measurements that were conducted at the above referenced test site by: Shive-Hattery

### The Results are as follows:

Serial	Type	Location	Test Start Date	Test End Date	Results (pCi/L)
SML544	SST	115	07-Mar-2025 6:15 AM	11-Mar-2025 6:16 AM	0.5
SNL357	SST	Main Office 134	07-Mar-2025 6:15 AM	11-Mar-2025 6:16 AM	1.6
SNL376	SST	117 Media Center	07-Mar-2025 6:15 AM	11-Mar-2025 6:16 AM	0.9
SNU509	SST	117 Media Center	07-Mar-2025 6:15 AM	11-Mar-2025 6:16 AM	0.6
SNU544	SST	145	07-Mar-2025 6:15 AM	11-Mar-2025 6:16 AM	2.5
SOV230	SST	144	07-Mar-2025 6:15 AM	11-Mar-2025 6:16 AM	4.6
SOV751	SST	128 Multipurpose	07-Mar-2025 6:15 AM	11-Mar-2025 6:16 AM	2.5
SOV754	SST	134B Health Office	07-Mar-2025 6:15 AM	11-Mar-2025 6:16 AM	2.0
SOV871	SST	114	07-Mar-2025 6:15 AM	11-Mar-2025 6:16 AM	<LLD
SOV876	SST	104	07-Mar-2025 6:15 AM	11-Mar-2025 6:16 AM	0.8
SOV992	SST	128 Multipurpose	07-Mar-2025 6:15 AM	11-Mar-2025 6:16 AM	2.4
SOW051	SST	107	07-Mar-2025 6:15 AM	11-Mar-2025 6:16 AM	0.8
SOW078	SST	109	07-Mar-2025 6:15 AM	11-Mar-2025 6:16 AM	<LLD
SOW095	SST	139	07-Mar-2025 6:15 AM	11-Mar-2025 6:16 AM	1.3
SOW125	SST	106	07-Mar-2025 6:15 AM	11-Mar-2025 6:16 AM	0.4
SOW142	SST	117 Media Center	07-Mar-2025 6:15 AM	11-Mar-2025 6:16 AM	0.7
SOW170	SST	111	07-Mar-2025 6:15 AM	11-Mar-2025 6:16 AM	0.7
SOW174	SST	113	07-Mar-2025 6:15 AM	11-Mar-2025 6:16 AM	0.7
SOW182	SST	134F	07-Mar-2025 6:15 AM	11-Mar-2025 6:16 AM	2.1
SOW183	SST	122 Kitchen	07-Mar-2025 6:15 AM	11-Mar-2025 6:16 AM	1.8
SOW199	SST	132	07-Mar-2025 6:15 AM	11-Mar-2025 6:16 AM	1.3
SOW222	SST	117A MC Office	07-Mar-2025 6:15 AM	11-Mar-2025 6:16 AM	1.7
SOW234	SST	103	07-Mar-2025 6:15 AM	11-Mar-2025 6:16 AM	<LLD
SOW243	SST	108	07-Mar-2025 6:15 AM	11-Mar-2025 6:16 AM	0.8
SOW284	SST	131	07-Mar-2025 6:15 AM	11-Mar-2025 6:16 AM	2.4
SOW286	SST	110	07-Mar-2025 6:15 AM	11-Mar-2025 6:16 AM	0.7
SOW288	SST	112	07-Mar-2025 6:15 AM	11-Mar-2025 6:16 AM	<LLD
SOW309	SST	125	07-Mar-2025 6:15 AM	11-Mar-2025 6:16 AM	2.1
SOW333	SST	134A	07-Mar-2025 6:15 AM	11-Mar-2025 6:16 AM	2.8
SOW359	SST	134D	07-Mar-2025 6:15 AM	11-Mar-2025 6:16 AM	1.5
SOW368	SST	134H	07-Mar-2025 6:15 AM	11-Mar-2025 6:16 AM	2.6
SOW369	SST	124 Custodian	07-Mar-2025 6:15 AM	11-Mar-2025 6:16 AM	0.5
SOW396	SST	129	07-Mar-2025 6:15 AM	11-Mar-2025 6:16 AM	1.5
SOW452	SST	101	07-Mar-2025 6:15 AM	11-Mar-2025 6:16 AM	0.5
SOW457	SST	140	07-Mar-2025 6:15 AM	11-Mar-2025 6:16 AM	0.4
SOW472	SST	123	07-Mar-2025 6:15 AM	11-Mar-2025 6:16 AM	5.2

# Shive-Hattery

2839 Northgate Drive  
Iowa City IA 52445  
319-354-3040 / 319-248-3405 / 319-530-2456 (cell)  
<http://www.shive-hattery.com/> / [sbecker@shive-hattery.com](mailto:sbecker@shive-hattery.com)

## Radon Test Report

March 11, 2025  
Batch #: 031125-1

**Customer:**

Iowa City Community School District  
1155 S. Riverside Drive  
Iowa City IA 52246

**Test Site:**

Jarod Tylee  
3100 East Washington Street Bldg.-  
Lemme Elementary  
Iowa City IA 52245

Serial	Type	Location	Test Start Date		Test End Date		Results (pCi/L)
SOW477	SST	102	07-Mar-2025	6:15 AM	11-Mar-2025	6:16 AM	1.4
SOW483	SST	134C Principal	07-Mar-2025	6:15 AM	11-Mar-2025	6:16 AM	0.4
SOW508	SST	134I Mail Room	07-Mar-2025	6:15 AM	11-Mar-2025	6:16 AM	1.0
SOW509	SST	126	07-Mar-2025	6:15 AM	11-Mar-2025	6:16 AM	1.3
SOW354	SST	133 Work Room	07-Mar-2025	6:15 AM	11-Mar-2025	6:16 AM	0.9
SOW489	SST	133 Work Room	07-Mar-2025	6:15 AM	11-Mar-2025	6:16 AM	1.7
<b>Average Radon Concentration in:</b>			<b>133 Work Room</b>			<b>1.3 pCi/L</b>	
SOW250	SST	130 Kindergarten	07-Mar-2025	6:15 AM	11-Mar-2025	6:16 AM	2.6
SOW519	SST	130 Kindergarten	07-Mar-2025	6:15 AM	11-Mar-2025	6:16 AM	2.1
<b>Average Radon Concentration in:</b>			<b>130 Kindergarten</b>			<b>2.4 pCi/L</b>	
SOW336	SST	105	07-Mar-2025	6:15 AM	11-Mar-2025	6:16 AM	0.9
SOW383	SST	105	07-Mar-2025	6:15 AM	11-Mar-2025	6:16 AM	0.9
<b>Average Radon Concentration in:</b>			<b>105</b>			<b>0.9 pCi/L</b>	
SOV872	SST	143 Art	07-Mar-2025	6:15 AM	11-Mar-2025	6:16 AM	2.5
SOW169	SST	143 Art	07-Mar-2025	6:15 AM	11-Mar-2025	6:16 AM	1.8
<b>Average Radon Concentration in:</b>			<b>143 Art</b>			<b>2.1 pCi/L</b>	
SNL469	SST	135A Gym Office	07-Mar-2025	6:15 AM	11-Mar-2025	6:16 AM	1.4
SNX196	SST	135A Gym Office	07-Mar-2025	6:15 AM	11-Mar-2025	6:16 AM	1.4
<b>Average Radon Concentration in:</b>			<b>135A Gym Office</b>			<b>1.4 pCi/L</b>	

**Deployed By:** Sam Becker RNTST10096  
**Retrieved By:** Sam Becker RNTST10096  
**Analyzed By:** Sam Becker RNTST10096  
**Reader S/N:** E0747 **Reader Calibration Due:** 11/2/2024  
**Conditions:** Requirements for Closed-Building Met  
**Weather:** No Abnormal Weather Conditions  
**Vents:** Open / Fan Auto  
**Mitigation:** No System Installed

**Note:** <LLD = Less than the Lower Limit of Detection (LLD) of the Radon Detector.

### Radon Health Risk Information

Radon is the second leading cause of lung cancer after smoking. The U.S. Environmental Protection Agency (EPA) and the Surgeon General strongly recommend that further action be taken when a home's radon test results are 4.0 pCi/L or greater. The national average indoor radon level is about 1.3 pCi/L. The higher the home's radon level, the greater the health risk to you and your family. Reducing your radon levels can be done easily, effectively and fairly inexpensively. Even homes with very high radon levels can be reduced below 4.0 pCi/L. Please refer to the EPA website at

# Shive-Hattery

2839 Northgate Drive

Iowa City IA 52445

319-354-3040 / 319-248-3405 / 319-530-2456 (cell)

<http://www.shive-hattery.com/> / [sbecker@shive-hattery.com](mailto:sbecker@shive-hattery.com)

## Radon Test Report

March 11, 2025

Batch #: 031125-1

**Customer:**

Iowa City Community School District  
1155 S. Riverside Drive  
Iowa City IA 52246

**Test Site:**

Jarod Tylee  
3100 East Washington Street Bldg.-  
Lemme Elementary  
Iowa City IA 52245

---

[www.epa.gov/radon](http://www.epa.gov/radon) for further information to assist you in evaluating your test results or deciding if further action is needed.

Signature: \_\_\_\_\_ Date: \_\_\_\_\_

# Shive-Hattery

2839 Northgate Drive  
 Iowa City IA 52445  
 319-354-3040 / 319-248-3405 / 319-530-2456 (cell)  
<http://www.shive-hattery.com/> / [sbecker@shive-hattery.com](mailto:sbecker@shive-hattery.com)

## Radon Test Report

December 31, 2024

Batch #: 123024-6

**Customer:**

Iowa City Community School District  
 1155 S. Riverside Drive  
 Iowa City IA 52246

**Test Site:**

521 N Dodge St Bldg.- Mann Elementary  
 Iowa City IA 52245

E-PERM® Electret Ion Chambers were used for radon screening measurements that were conducted at the above referenced test site by: Shive-Hattery

**The Results are as follows:**

Serial	Type	Location	Test Start Date	Test End Date	Results (pCi/L)
SIE461	SST	101A	17-Dec-2024 6:30 AM	20-Dec-2024 6:30 AM	0.4
SML457	SST	001	17-Dec-2024 6:30 AM	20-Dec-2024 6:30 AM	0.6
SML533	SST	044	17-Dec-2024 6:30 AM	20-Dec-2024 6:30 AM	0.7
SNE903	SST	019	17-Dec-2024 6:30 AM	20-Dec-2024 6:30 AM	1.0
SNK328	SST	015 Office	17-Dec-2024 6:30 AM	20-Dec-2024 6:30 AM	1.4
SNK572	SST	040	17-Dec-2024 6:30 AM	20-Dec-2024 6:30 AM	1.8
SNL326	SST	135 Computer Lab	17-Dec-2024 6:30 AM	20-Dec-2024 6:30 AM	1.3
SNL352	SST	028A	17-Dec-2024 6:30 AM	20-Dec-2024 6:30 AM	0.9
SNL379	SST	021B	17-Dec-2024 6:30 AM	20-Dec-2024 6:30 AM	0.9
SNL475	SST	017 Gym	17-Dec-2024 6:30 AM	20-Dec-2024 6:30 AM	1.2
SNL554	SST	017A PE Office	17-Dec-2024 6:30 AM	20-Dec-2024 6:30 AM	0.7
SNL555	SST	003 Principal	17-Dec-2024 6:30 AM	20-Dec-2024 6:30 AM	<LLD
SNL561	SST	017 Gym	17-Dec-2024 6:30 AM	20-Dec-2024 6:30 AM	<LLD
SNL576	SST	035	17-Dec-2024 6:30 AM	20-Dec-2024 6:30 AM	1.5
SNL673	SST	007	17-Dec-2024 6:30 AM	20-Dec-2024 6:30 AM	0.7
SNU210	SST	028	17-Dec-2024 6:30 AM	20-Dec-2024 6:30 AM	0.6
SNU522	SST	032	17-Dec-2024 6:30 AM	20-Dec-2024 6:30 AM	3.0
SNU534	SST	101 Media Center	17-Dec-2024 6:30 AM	20-Dec-2024 6:30 AM	<LLD
SNU638	SST	229	17-Dec-2024 6:30 AM	20-Dec-2024 6:30 AM	2.0
SNU657	SST	028	17-Dec-2024 6:30 AM	20-Dec-2024 6:30 AM	0.6
SNU735	SST	017 Gym	17-Dec-2024 6:30 AM	20-Dec-2024 6:30 AM	1.5
SNU749	SST	017 Gym	17-Dec-2024 6:30 AM	20-Dec-2024 6:30 AM	0.5
SNX102	SST	031	17-Dec-2024 6:30 AM	20-Dec-2024 6:30 AM	1.2
SNX105	SST	013 Health	17-Dec-2024 6:30 AM	20-Dec-2024 6:30 AM	0.6
SNX176	SST	233	17-Dec-2024 6:30 AM	20-Dec-2024 6:30 AM	1.3
SNX191	SST	005 Conference	17-Dec-2024 6:30 AM	20-Dec-2024 6:30 AM	<LLD
SNX199	SST	033	17-Dec-2024 6:30 AM	20-Dec-2024 6:30 AM	2.4
SNU498	SST	021 Music	17-Dec-2024 6:30 AM	20-Dec-2024 6:30 AM	<LLD
SOA027	SST	021 Music	17-Dec-2024 6:30 AM	20-Dec-2024 6:30 AM	0.5

**Average Radon Concentration in:** **021 Music** **<LLD pCi/L**

SML521	SST	039	17-Dec-2024 6:30 AM	20-Dec-2024 6:30 AM	1.9
SNX031	SST	039	17-Dec-2024 6:30 AM	20-Dec-2024 6:30 AM	2.0

**Average Radon Concentration in:** **039** **1.9 pCi/L**

# Shive-Hattery

2839 Northgate Drive  
Iowa City IA 52445  
319-354-3040 / 319-248-3405 / 319-530-2456 (cell)  
<http://www.shive-hattery.com/> / [sbecker@shive-hattery.com](mailto:sbecker@shive-hattery.com)

## Radon Test Report

December 31, 2024  
Batch #: 123024-6

### Customer:

Iowa City Community School District  
1155 S. Riverside Drive  
Iowa City IA 52246

### Test Site:

521 N Dodge St Bldg.- Mann Elementary  
Iowa City IA 52245

Serial	Type	Location	Test Start Date	Test End Date	Results (pCi/L)
SML513	SST	037	17-Dec-2024 6:30 AM	20-Dec-2024 6:30 AM	1.7
SNL470	SST	037	17-Dec-2024 6:30 AM	20-Dec-2024 6:30 AM	1.0
<b>Average Radon Concentration in:</b>			<b>037</b>		<b>1.4 pCi/L</b>
SML532	SST	029	17-Dec-2024 6:30 AM	20-Dec-2024 6:30 AM	2.3
SNX000	SST	029	17-Dec-2024 6:30 AM	20-Dec-2024 6:30 AM	2.0
<b>Average Radon Concentration in:</b>			<b>029</b>		<b>2.2 pCi/L</b>

**Deployed By:** Sam Becker RNTST10096  
**Retrieved By:** Sam Becker RNTST10096  
**Analyzed By:** Sam Becker RNTST10096  
**Reader S/N:** E0747 **Reader Calibration Due:** 11/2/2024  
**Conditions:** Requirements for Closed-Building Met  
**Weather:** No Abnormal Weather Conditions  
**Vents:** Open / Fan Auto  
**Mitigation:** No System Installed

**Note:** <LLD = Less than the Lower Limit of Detection (LLD) of the Radon Detector.

### Radon Health Risk Information

Radon is the second leading cause of lung cancer after smoking. The U.S. Environmental Protection Agency (EPA) and the Surgeon General strongly recommend that further action be taken when a home's radon test results are 4.0 pCi/L or greater. The national average indoor radon level is about 1.3 pCi/L. The higher the home's radon level, the greater the health risk to you and your family. Reducing your radon levels can be done easily, effectively and fairly inexpensively. Even homes with very high radon levels can be reduced below 4.0 pCi/L. Please refer to the EPA website at [www.epa.gov/radon](http://www.epa.gov/radon) for further information to assist you in evaluating your test results or deciding if further action is needed.

# Shive-Hattery

2839 Northgate Drive

Iowa City IA 52445

319-354-3040 / 319-248-3405 / 319-530-2456 (cell)

<http://www.shive-hattery.com/> / [sbecker@shive-hattery.com](mailto:sbecker@shive-hattery.com)

## Radon Test Report

December 16, 2024

Batch #: 121324-1

### Customer:

Iowa City Community School District  
1155 S. Riverside Drive  
Iowa City IA 52246

### Test Site:

1507, 8th Street Bldg.- North West  
Junior High School  
Coralville IA 52241

E-PERM® Electret Ion Chambers were used for radon screening measurements that were conducted at the above referenced test site by: Shive-Hattery

### The Results are as follows:

Serial	Type	Location	Test Start Date	Test End Date	Results (pCi/L)
SKF116	SST	278	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	2.5
SML367	SST	281	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	0.7
SML512	SST	164 Fitness	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	4.4
SML544	SST	102B	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	3.7
SNE890	SST	288c	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	5.1
SNK402	SST	282a	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	5.6
SNL299	SST	163E	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	3.8
SNL318	SST	145A	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	3.1
SNL320	SST	126	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	<LLD
SNL334	SST	267	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	2.4
SNL343	SST	217	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	2.4
SNL368	SST	250	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	1.4
SNL416	SST	288	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	3.7
SNL418	SST	117	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	2.8
SNL455	SST	259	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	1.2
SNL486	SST	202	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	2.4
SNL502	SST	111 Wrestling	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	1.4
SNL518	SST	139	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	3.1
SNL519	SST	201	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	1.2
SNL536	SST	286	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	3.6
SNL556	SST	274	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	3.0
SNL568	SST	156	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	1.6
SNL588	SST	265	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	3.7
SNL705	SST	138	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	3.1
SNL744	SST	205	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	1.2
SNL879	SST	260	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	1.1
SNN017	SST	102	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	2.6
SNN731	SST	103B	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	2.4
SNN778	SST	228	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	2.1
SNN844	SST	151C	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	4.0
SNN982	SST	166A	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	17.1
SNU462	SST	288d	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	4.8
SNU484	SST	284	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	2.9
SNU494	SST	105	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	4.1
SNU499	SST	266	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	2.4
SNU501	SST	125	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	1.2
SNU502	SST	118	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	2.2

# Shive-Hattery

2839 Northgate Drive

Iowa City IA 52445

319-354-3040 / 319-248-3405 / 319-530-2456 (cell)

<http://www.shive-hattery.com/> / [sbecker@shive-hattery.com](mailto:sbecker@shive-hattery.com)

## Radon Test Report

December 16, 2024

Batch #: 121324-1

### Customer:

Iowa City Community School District  
1155 S. Riverside Drive  
Iowa City IA 52246

### Test Site:

1507, 8th Street Bldg.- North West  
Junior High School  
Coralville IA 52241

Serial	Type	Location	Test Start Date	Test End Date	Results (pCi/L)
SNU510	SST	242	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	1.8
SNU533	SST	155	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	2.2
SNU547	SST	224	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	2.1
SNU555	SST	268	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	3.2
SNU574	SST	280	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	2.4
SNU577	SST	162 Gym	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	4.0
SNU603	SST	120	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	3.8
SNU610	SST	151F	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	3.0
SNU614	SST	207	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	1.1
SNU624	SST	117B	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	2.5
SNU634	SST	273	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	3.1
SNU772	SST	209	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	1.4
SNW987	SST	103	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	3.0
SNW993	SST	208	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	0.9
SNW997	SST	144	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	3.0
SNX002	SST	262	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	1.5
SNX005	SST	287	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	2.7
SNX008	SST	104	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	2.6
SNX019	SST	124	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	1.0
SNX020	SST	269	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	1.4
SNX029	SST	141	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	3.2
SNX039	SST	204	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	0.6
SNX054	SST	118A	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	2.0
SNX057	SST	252	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	1.2
SNX058	SST	150 Nurse	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	3.1
SNX062	SST	102D Principal	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	1.5
SNX063	SST	254	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	1.2
SNX070	SST	102C	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	2.9
SNX077	SST	162 Gym	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	3.7
SNX083	SST	283	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	2.3
SNX091	SST	144B	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	2.5
SNX092	SST	117C	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	2.1
SNX095	SST	122	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	1.0
SNX097	SST	227	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	1.3
SNX098	SST	144A	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	3.2
SNX106	SST	253	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	1.7
SNX116	SST	210	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	1.5
SNX137	SST	255	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	1.0
SNX148	SST	151A	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	3.4
SNX157	SST	256	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	0.9

# Shive-Hattery

2839 Northgate Drive  
Iowa City IA 52445  
319-354-3040 / 319-248-3405 / 319-530-2456 (cell)  
<http://www.shive-hattery.com/> / [sbecker@shive-hattery.com](mailto:sbecker@shive-hattery.com)

## Radon Test Report

December 16, 2024

Batch #: 121324-1

### Customer:

Iowa City Community School District  
1155 S. Riverside Drive  
Iowa City IA 52246

### Test Site:

1507, 8th Street Bldg.- North West  
Junior High School  
Coralville IA 52241

Serial	Type	Location	Test Start Date	Test End Date	Results (pCi/L)
SNX161	SST	206	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	0.7
SNX171	SST	162 Gym	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	3.9
SNX187	SST	140	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	3.1
SNX196	SST	154	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	1.9
SNX202	SST	282d	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	2.6
SNX221	SST	282	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	2.7
SNX228	SST	282c	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	2.2
SNX229	SST	103	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	2.9
SNX241	SST	111 Wrestling	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	0.5
SNX268	SST	270	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	3.0
SNX952	SST	282b	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	3.3
SOA113	SST	124	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	1.2
SOA200	SST	263	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	1.8
SOA602	SST	118B	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	2.4
SOA700	SST	285	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	3.1
SNF009	SST	151B	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	2.9
SNX016	SST	151B	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	2.6
<b>Average Radon Concentration in:</b>			<b>151B</b>	<b>2.8 pCi/L</b>	
SNL489	SST	272	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	3.1
SNX149	SST	272	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	3.4
<b>Average Radon Concentration in:</b>			<b>272</b>	<b>3.2 pCi/L</b>	
SNL385	SST	264	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	2.4
SNL605	SST	264	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	2.3
<b>Average Radon Concentration in:</b>			<b>264</b>	<b>2.4 pCi/L</b>	
SNU629	SST	251	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	1.6
SOA024	SST	251	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	1.2
<b>Average Radon Concentration in:</b>			<b>251</b>	<b>1.4 pCi/L</b>	
SNL456	SST	129	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	0.5
SNU540	SST	129	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	<LLD
<b>Average Radon Concentration in:</b>			<b>129</b>	<b>&lt;LLD pCi/L</b>	
SMV392	SST	123	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	1.7
SNU420	SST	123	10-Dec-2024 6:10 AM	13-Dec-2024 6:15 AM	1.1
<b>Average Radon Concentration in:</b>			<b>123</b>	<b>1.4 pCi/L</b>	

# Shive-Hattery

2839 Northgate Drive  
Iowa City IA 52445  
319-354-3040 / 319-248-3405 / 319-530-2456 (cell)  
<http://www.shive-hattery.com/> / [sbecker@shive-hattery.com](mailto:sbecker@shive-hattery.com)

## Radon Test Report

December 16, 2024

Batch #: 121324-1

### Customer:

Iowa City Community School District  
1155 S. Riverside Drive  
Iowa City IA 52246

### Test Site:

1507, 8th Street Bldg.- North West  
Junior High School  
Coralville IA 52241

Serial	Type	Location	Test Start Date		Test End Date		Results (pCi/L)
SNU509	SST	113 Main Gym	10-Dec-2024	6:10 AM	13-Dec-2024	6:15 AM	0.8
SNX036	SST	113 Main Gym	10-Dec-2024	6:10 AM	13-Dec-2024	6:15 AM	0.8
<b>Average Radon Concentration in:</b>			<b>113 Main Gym</b>			<b>0.8 pCi/L</b>	
SNU493	SST	118	10-Dec-2024	6:10 AM	13-Dec-2024	6:15 AM	2.1
SNX099	SST	118	10-Dec-2024	6:10 AM	13-Dec-2024	6:15 AM	1.7
<b>Average Radon Concentration in:</b>			<b>118</b>			<b>1.9 pCi/L</b>	
SNL494	SST	146 Work Room	10-Dec-2024	6:10 AM	13-Dec-2024	6:15 AM	2.8
SNU497	SST	146 Work Room	10-Dec-2024	6:10 AM	13-Dec-2024	6:15 AM	2.9
<b>Average Radon Concentration in:</b>			<b>146 Work Room</b>			<b>2.8 pCi/L</b>	
SNX008	SST	102A	10-Dec-2024	6:10 AM	13-Dec-2024	6:15 AM	2.5
SNX081	SST	102A	10-Dec-2024	6:10 AM	13-Dec-2024	6:15 AM	2.4
<b>Average Radon Concentration in:</b>			<b>102A</b>			<b>2.4 pCi/L</b>	
SNL405	SST	142	10-Dec-2024	6:10 AM	13-Dec-2024	6:15 AM	3.3
SNX138	SST	142	10-Dec-2024	6:10 AM	13-Dec-2024	6:15 AM	3.8
<b>Average Radon Concentration in:</b>			<b>142</b>			<b>3.5 pCi/L</b>	
SNU486	SST	203	10-Dec-2024	6:10 AM	13-Dec-2024	6:15 AM	1.4
SNU636	SST	203	10-Dec-2024	6:10 AM	13-Dec-2024	6:15 AM	0.8
<b>Average Radon Concentration in:</b>			<b>203</b>			<b>1.1 pCi/L</b>	
SNL569	SST	282e	10-Dec-2024	6:10 AM	13-Dec-2024	6:15 AM	2.6
SNX089	SST	282e	10-Dec-2024	6:10 AM	13-Dec-2024	6:15 AM	3.0
<b>Average Radon Concentration in:</b>			<b>282e</b>			<b>2.8 pCi/L</b>	

Deployed By: Sam Becker RNTST10096  
Retrieved By: Sam Becker RNTST10096  
Analyzed By: Sam Becker RNTST10096  
Reader S/N: E0747 Reader Calibration Due: 11/2/2024  
Conditions: Requirements for Closed-Building Met  
Weather: No Abnormal Weather Conditions  
Vents: Vent Fan Auto / Fan Auto  
Mitigation: No System Installed

Note: <LLD = Less than the Lower Limit of Detection (LLD) of the Radon Detector.

## Radon Health Risk Information

# Shive-Hattery

2839 Northgate Drive  
Iowa City IA 52445  
319-354-3040 / 319-248-3405 / 319-530-2456 (cell)  
<http://www.shive-hattery.com/> / [sbecker@shive-hattery.com](mailto:sbecker@shive-hattery.com)

## Radon Test Report

December 16, 2024

Batch #: 121324-1

**Customer:**

Iowa City Community School District  
1155 S. Riverside Drive  
Iowa City IA 52246

**Test Site:**

1507, 8th Street Bldg.- North West  
Junior High School  
Coralville IA 52241

---

Radon is the second leading cause of lung cancer after smoking. The U.S. Environmental Protection Agency (EPA) and the Surgeon General strongly recommend that further action be taken when a home's radon test results are 4.0 pCi/L or greater. The national average indoor radon level is about 1.3 pCi/L. The higher the home's radon level, the greater the health risk to you and your family. Reducing your radon levels can be done easily, effectively and fairly inexpensively. Even homes with very high radon levels can be reduced below 4.0 pCi/L. Please refer to the EPA website at [www.epa.gov/radon](http://www.epa.gov/radon) for further information to assist you in evaluating your test results or deciding if further action is needed.

Signature: \_\_\_\_\_ Date: \_\_\_\_\_

# Shive-Hattery

2839 Northgate Drive  
Iowa City IA 52445  
319-354-3040 / 319-248-3405 / 319-530-2456 (cell)  
<http://www.shive-hattery.com/> / [sbecker@shive-hattery.com](mailto:sbecker@shive-hattery.com)

## Radon Test Report

March 07, 2025

Batch #: 030725-3

### Customer:

Iowa City Community School District  
1155 S. Riverside Drive  
Iowa City IA 52246

### Test Site:

1507, 8th Street Bldg.- North West  
Junior High School  
Coralville IA 52241

E-PERM® Electret Ion Chambers were used for radon screening measurements that were conducted at the above referenced test site by: Shive-Hattery

### The Results are as follows:

Serial	Type	Location	Test Start Date	Test End Date	Results (pCi/L)
SNK324	SST	288C	04-Mar-2025 6:24 AM	06-Mar-2025 6:28 AM	4.6
SNL562	SST	105 Concessions	04-Mar-2025 6:24 AM	06-Mar-2025 6:28 AM	4.5
SNU553	SST	151C	04-Mar-2025 6:24 AM	06-Mar-2025 6:28 AM	3.6
SNU577	SST	288D	04-Mar-2025 6:24 AM	06-Mar-2025 6:28 AM	4.2
SNX013	SST	282A	04-Mar-2025 6:24 AM	06-Mar-2025 6:28 AM	2.0
SNX016	SST	164 Fitness	04-Mar-2025 6:24 AM	06-Mar-2025 6:28 AM	3.6
SNU710	SST	162 Gym	04-Mar-2025 6:24 AM	06-Mar-2025 6:28 AM	3.6
SOW120	SST	162 Gym	04-Mar-2025 6:24 AM	06-Mar-2025 6:28 AM	3.3

### Average Radon Concentration in:

162 Gym

3.4 pCi/L

SNL460	SST	166A	04-Mar-2025 6:24 AM	06-Mar-2025 6:28 AM	13.0
SNT780	SST	166A	04-Mar-2025 6:24 AM	06-Mar-2025 6:28 AM	10.4

### Average Radon Concentration in:

166A

11.7 pCi/L

**Deployed By:** Sam Becker RNTST10096  
**Retrieved By:** Sam Becker RNTST10096  
**Analyzed By:** Sam Becker RNTST10096  
**Reader S/N:** E0747 **Reader Calibration Due:** 11/2/2024  
**Conditions:** Requirements for Closed-Building Met  
**Weather:** No Abnormal Weather Conditions  
**Vents:** Open / Fan Auto  
**Mitigation:** No System Installed

## Radon Health Risk Information

Radon is the second leading cause of lung cancer after smoking. The U.S. Environmental Protection Agency (EPA) and the Surgeon General strongly recommend that further action be taken when a home's radon test results are 4.0 pCi/L or greater. The national average indoor radon level is about 1.3 pCi/L. The higher the home's radon level, the greater the health risk to you and your family. Reducing your radon levels can be done easily, effectively and fairly inexpensively. Even homes with very high radon levels can be reduced below 4.0 pCi/L. Please refer to the EPA website at [www.epa.gov/radon](http://www.epa.gov/radon) for further information to assist you in evaluating your test results or deciding if further action is needed.

Signature: \_\_\_\_\_ Date: \_\_\_\_\_

# Shive-Hattery

2839 Northgate Drive  
Iowa City IA 52445  
319-354-3040 / 319-248-3405 / 319-530-2456 (cell)  
<http://www.shive-hattery.com/> / [sbecker@shive-hattery.com](mailto:sbecker@shive-hattery.com)

## Radon Test Report

December 26, 2024

Batch #: 122624-2

### Customer:

Iowa City Community School District  
1155 S. Riverside Drive  
Iowa City IA 52246

### Test Site:

1400 Grissel Pl Bldg.- Shimek  
Elementary  
Iowa City IA 52245

E-PERM® Electret Ion Chambers were used for radon screening measurements that were conducted at the above referenced test site by: Shive-Hattery

### The Results are as follows:

Serial	Type	Location	Test Start Date	Test End Date	Results (pCi/L)
SKE965	SST	108	17-Dec-2024 6:40 AM	20-Dec-2024 6:35 AM	0.9
SMV420	SST	117	17-Dec-2024 6:40 AM	20-Dec-2024 6:35 AM	1.7
SNE905	SST	121	17-Dec-2024 6:40 AM	20-Dec-2024 6:35 AM	3.0
SNK538	SST	105	17-Dec-2024 6:40 AM	20-Dec-2024 6:35 AM	1.6
SNL308	SST	134	17-Dec-2024 6:40 AM	20-Dec-2024 6:35 AM	3.0
SNL310	SST	100D	17-Dec-2024 6:40 AM	20-Dec-2024 6:35 AM	1.5
SNL341	SST	102C	17-Dec-2024 6:40 AM	20-Dec-2024 6:35 AM	2.5
SNL412	SST	126C	17-Dec-2024 6:40 AM	20-Dec-2024 6:35 AM	1.5
SNL437	SST	104 Gym	17-Dec-2024 6:40 AM	20-Dec-2024 6:35 AM	1.9
SNL441	SST	126D	17-Dec-2024 6:40 AM	20-Dec-2024 6:35 AM	1.9
SNL480	SST	102A Custodial	17-Dec-2024 6:40 AM	20-Dec-2024 6:35 AM	2.0
SNL492	SST	104F	17-Dec-2024 6:40 AM	20-Dec-2024 6:35 AM	2.3
SNL501	SST	130	17-Dec-2024 6:40 AM	20-Dec-2024 6:35 AM	3.2
SNL524	SST	128	17-Dec-2024 6:40 AM	20-Dec-2024 6:35 AM	3.4
SNL546	SST	100A	17-Dec-2024 6:40 AM	20-Dec-2024 6:35 AM	2.2
SNL581	SST	119	17-Dec-2024 6:40 AM	20-Dec-2024 6:35 AM	1.8
SNL607	SST	140	17-Dec-2024 6:40 AM	20-Dec-2024 6:35 AM	3.4
SNL700	SST	138	17-Dec-2024 6:40 AM	20-Dec-2024 6:35 AM	2.5
SNM720	SST	126	17-Dec-2024 6:40 AM	20-Dec-2024 6:35 AM	2.4
SNM751	SST	126A	17-Dec-2024 6:40 AM	20-Dec-2024 6:35 AM	4.1
SNN861	SST	102 Lunch Room	17-Dec-2024 6:40 AM	20-Dec-2024 6:35 AM	1.8
SNU319	SST	100	17-Dec-2024 6:40 AM	20-Dec-2024 6:35 AM	2.4
SNU349	SST	129	17-Dec-2024 6:40 AM	20-Dec-2024 6:35 AM	1.3
SNU449	SST	104A	17-Dec-2024 6:40 AM	20-Dec-2024 6:35 AM	2.5
SNU504	SST	126	17-Dec-2024 6:40 AM	20-Dec-2024 6:35 AM	2.2
SNU552	SST	104 Gym	17-Dec-2024 6:40 AM	20-Dec-2024 6:35 AM	1.6
SNU558	SST	100C	17-Dec-2024 6:40 AM	20-Dec-2024 6:35 AM	2.8
SNU573	SST	123	17-Dec-2024 6:40 AM	20-Dec-2024 6:35 AM	2.8
SNU707	SST	136	17-Dec-2024 6:40 AM	20-Dec-2024 6:35 AM	4.9
SNX059	SST	133	17-Dec-2024 6:40 AM	20-Dec-2024 6:35 AM	1.5
SNX123	SST	100B	17-Dec-2024 6:40 AM	20-Dec-2024 6:35 AM	
SNX235	SST	102 Lunch Room	17-Dec-2024 6:40 AM	20-Dec-2024 6:35 AM	1.3
SNL493	SST	106	17-Dec-2024 6:40 AM	20-Dec-2024 6:35 AM	1.9
SNL579	SST	106	17-Dec-2024 6:40 AM	20-Dec-2024 6:35 AM	1.9

**Average Radon Concentration in:**

**106**

**1.9 pCi/L**

# Shive-Hattery

2839 Northgate Drive  
Iowa City IA 52445  
319-354-3040 / 319-248-3405 / 319-530-2456 (cell)  
<http://www.shive-hattery.com/> / [sbecker@shive-hattery.com](mailto:sbecker@shive-hattery.com)

## Radon Test Report

December 26, 2024

Batch #: 122624-2

### Customer:

Iowa City Community School District  
1155 S. Riverside Drive  
Iowa City IA 52246

### Test Site:

1400 Grissel Pl Bldg.- Shlmek  
Elementary  
Iowa City IA 52245

Serial	Type	Location	Test Start Date	Test End Date	Results (pCi/L)
SNL467	SST	132	17-Dec-2024 6:40 AM	20-Dec-2024 6:35 AM	1.9
SNU799	SST	132	17-Dec-2024 6:40 AM	20-Dec-2024 6:35 AM	3.0
<b>Average Radon Concentration in:</b>			<b>132</b>		<b>2.5 pCi/L</b>
SNL357	SST	127	17-Dec-2024 6:40 AM	20-Dec-2024 6:35 AM	<LLD
SNU804	SST	127	17-Dec-2024 6:40 AM	20-Dec-2024 6:35 AM	1.2
<b>Average Radon Concentration in:</b>			<b>127</b>		<b>0.7 pCi/L</b>
SNL488	SST	131	17-Dec-2024 6:40 AM	20-Dec-2024 6:35 AM	1.4
SNU572	SST	131	17-Dec-2024 6:40 AM	20-Dec-2024 6:35 AM	2.0
<b>Average Radon Concentration in:</b>			<b>131</b>		<b>1.7 pCi/L</b>
SNU621	SST	116	17-Dec-2024 6:40 AM	20-Dec-2024 6:35 AM	1.6
SNU745	SST	116	17-Dec-2024 6:40 AM	20-Dec-2024 6:35 AM	1.6
<b>Average Radon Concentration in:</b>			<b>116</b>		<b>1.6 pCi/L</b>
SNL491	SST	115 Art	17-Dec-2024 6:40 AM	20-Dec-2024 6:35 AM	0.9
SNU156	SST	115 Art	17-Dec-2024 6:40 AM	20-Dec-2024 6:35 AM	<LLD
<b>Average Radon Concentration in:</b>			<b>115 Art</b>		<b>0.4 pCi/L</b>

Deployed By: Sam Becker RNTST10096  
Retrieved By: Sam Becker RNTST10096  
Analyzed By: Sam Becker RNTST10096  
Reader S/N: E0747 Reader Calibration Due: 11/2/2024  
Conditions: Requirements for Closed-Building Met  
Weather: No Abnormal Weather Conditions  
Vents: Vent Fan Auto / Fan Auto  
Mitigation: No System Installed

Note: <LLD = Less than the Lower Limit of Detection (LLD) of the Radon Detector.

### Radon Health Risk Information

Radon is the second leading cause of lung cancer after smoking. The U.S. Environmental Protection Agency (EPA) and the Surgeon General strongly recommend that further action be taken when a home's radon test results are 4.0 pCi/L or greater. The national average indoor radon level is about 1.3 pCi/L. The higher the home's radon level, the greater the health risk to you and your family. Reducing your radon levels can be done easily, effectively and fairly inexpensively. Even homes with very high radon levels can be reduced below 4.0 pCi/L. Please refer to the EPA website at [www.epa.gov/radon](http://www.epa.gov/radon) for further information to assist you in evaluating your test results or deciding if further action is needed.

Signature: \_\_\_\_\_ Date: \_\_\_\_\_ Page 2 of 2

# Shive-Hattery

2839 Northgate Drive  
Iowa City IA 52445  
319-354-3040 / 319-248-3405 / 319-530-2456 (cell)  
<http://www.shive-hattery.com/> / [sbecker@shive-hattery.com](mailto:sbecker@shive-hattery.com)

## Radon Test Report

March 07, 2025

Batch #: 030725-4

**Customer:**

Iowa City Community School District  
1155 S. Riverside Drive  
Iowa City IA 52246

**Test Site:**

1400 Grissel Pl Bldg.- Shimek  
Elementary  
Iowa City IA 52245

E-PERM® Electret Ion Chambers were used for radon screening measurements that were conducted at the above referenced test site by: Shive-Hattery

**The Results are as follows:**

Serial	Type	Location	Test Start Date	Test End Date	Results (pCi/L)
SOW295	SST	126A	04-Mar-2025 7:15 AM	06-Mar-2025 7:16 AM	1.0
SNL404	SST	136	04-Mar-2025 7:15 AM	06-Mar-2025 7:16 AM	4.8
SNU470	SST	136	04-Mar-2025 7:15 AM	06-Mar-2025 7:16 AM	4.9

**Average Radon Concentration in:** **136** **4.9 pCi/L**

**Deployed By:** Sam Becker RNTST10096  
**Retrieved By:** Sam Becker RNTST10096  
**Analyzed By:** Sam Becker RNTST10096  
**Reader S/N:** E0747 **Reader Calibration Due:** 11/2/2024  
**Conditions:** Requirements for Closed-Building Met  
**Weather:** No Abnormal Weather Conditions  
**Vents:** Open / Fan Auto  
**Mitigation:** No System Installed

### Radon Health Risk Information

Radon is the second leading cause of lung cancer after smoking. The U.S. Environmental Protection Agency (EPA) and the Surgeon General strongly recommend that further action be taken when a home's radon test results are 4.0 pCi/L or greater. The national average indoor radon level is about 1.3 pCi/L. The higher the home's radon level, the greater the health risk to you and your family. Reducing your radon levels can be done easily, effectively and fairly inexpensively. Even homes with very high radon levels can be reduced below 4.0 pCi/L. Please refer to the EPA website at [www.epa.gov/radon](http://www.epa.gov/radon) for further information to assist you in evaluating your test results or deciding if further action is needed.

Signature: \_\_\_\_\_ Date: \_\_\_\_\_

# Shive-Hattery

2839 Northgate Drive  
Iowa City IA 52445  
319-354-3040 / 319-248-3405 / 319-530-2456 (cell)  
<http://www.shive-hattery.com/> / [sbecker@shive-hattery.com](mailto:sbecker@shive-hattery.com)

## Radon Test Report

December 30, 2024

Batch #: 122424-2

### Customer:

Iowa City Community School District  
1155 S. Riverside Drive  
Iowa City IA 52246

### Test Site:

1355 Deforest Ave Bldg.- Mark Twain  
Elementary School  
Iowa City IA 52240

E-PERM® Electret Ion Chambers were used for radon screening measurements that were conducted at the above referenced test site by: Shive-Hattery

### The Results are as follows:

Serial	Type	Location	Test Start Date	Test End Date	Results (pCi/L)
SML545	SST	31	16-Dec-2024 6:30 AM	19-Dec-2024 6:00 AM	3.6
SNK609	SST	1	16-Dec-2024 6:30 AM	19-Dec-2024 6:00 AM	2.7
SNL296	SST	39A	16-Dec-2024 6:30 AM	19-Dec-2024 6:00 AM	2.5
SNL399	SST	7	16-Dec-2024 6:30 AM	19-Dec-2024 6:00 AM	2.3
SNL401	SST	25.1	16-Dec-2024 6:30 AM	19-Dec-2024 6:00 AM	3.1
SNL439	SST	10	16-Dec-2024 6:30 AM	19-Dec-2024 6:00 AM	3.7
SNL469	SST	48	16-Dec-2024 6:30 AM	19-Dec-2024 6:00 AM	0.9
SNL504	SST	25	16-Dec-2024 6:30 AM	19-Dec-2024 6:00 AM	3.3
SNL537	SST	34A	16-Dec-2024 6:30 AM	19-Dec-2024 6:00 AM	1.5
SNL570	SST	33	16-Dec-2024 6:30 AM	19-Dec-2024 6:00 AM	2.5
SNL575	SST	47	16-Dec-2024 6:30 AM	19-Dec-2024 6:00 AM	2.7
SNL601	SST	11	16-Dec-2024 6:30 AM	19-Dec-2024 6:00 AM	1.5
SNL688	SST	8	16-Dec-2024 6:30 AM	19-Dec-2024 6:00 AM	3.7
SNM860	SST	24	16-Dec-2024 6:30 AM	19-Dec-2024 6:00 AM	1.3
SNM933	SST	13	16-Dec-2024 6:30 AM	19-Dec-2024 6:00 AM	1.7
SNU490	SST	28	16-Dec-2024 6:30 AM	19-Dec-2024 6:00 AM	2.5
SNU566	SST	4	16-Dec-2024 6:30 AM	19-Dec-2024 6:00 AM	1.8
SNU569	SST	25a	16-Dec-2024 6:30 AM	19-Dec-2024 6:00 AM	3.5
SNU608	SST	37	16-Dec-2024 6:30 AM	19-Dec-2024 6:00 AM	3.1
SNU737	SST	16	16-Dec-2024 6:30 AM	19-Dec-2024 6:00 AM	0.5
SNU750	SST	3	16-Dec-2024 6:30 AM	19-Dec-2024 6:00 AM	3.0
SNW991	SST	18	16-Dec-2024 6:30 AM	19-Dec-2024 6:00 AM	3.0
SNX007	SST	11	16-Dec-2024 6:30 AM	19-Dec-2024 6:00 AM	2.2
SNX015	SST	20	16-Dec-2024 6:30 AM	19-Dec-2024 6:00 AM	1.3
SNX022	SST	27	16-Dec-2024 6:30 AM	19-Dec-2024 6:00 AM	2.7
SNX027	SST	9	16-Dec-2024 6:30 AM	19-Dec-2024 6:00 AM	1.6
SNX032	SST	25	16-Dec-2024 6:30 AM	19-Dec-2024 6:00 AM	2.5
SNX050	SST	39	16-Dec-2024 6:30 AM	19-Dec-2024 6:00 AM	2.6
SNX053	SST	36	16-Dec-2024 6:30 AM	19-Dec-2024 6:00 AM	0.8
SNX100	SST	11A	16-Dec-2024 6:30 AM	19-Dec-2024 6:00 AM	
SNX104	SST	35	16-Dec-2024 6:30 AM	19-Dec-2024 6:00 AM	0.5
SNX184	SST	23	16-Dec-2024 6:30 AM	19-Dec-2024 6:00 AM	2.0
SNX233	SST	34	16-Dec-2024 6:30 AM	19-Dec-2024 6:00 AM	1.3
SNX240	SST	21	16-Dec-2024 6:30 AM	19-Dec-2024 6:00 AM	0.8
SNX250	SST	44	16-Dec-2024 6:30 AM	19-Dec-2024 6:00 AM	1.3
SNX254	SST	15	16-Dec-2024 6:30 AM	19-Dec-2024 6:00 AM	1.9
SNX267	SST	17	16-Dec-2024 6:30 AM	19-Dec-2024 6:00 AM	1.5

# Shive-Hattery

2839 Northgate Drive

Iowa City IA 52445

319-354-3040 / 319-248-3405 / 319-530-2456 (cell)

http://www.shive-hattery.com/ / sbecker@shive-hattery.com

## Radon Test Report

December 30, 2024

Batch #: 122424-2

### Customer:

Iowa City Community School District  
1155 S. Riverside Drive  
Iowa City IA 52246

### Test Site:

1355 Deforest Ave Bldg.- Mark Twain  
Elementary School  
Iowa City IA 52240

Serial	Type	Location	Test Start Date		Test End Date		Results (pCi/L)
SNX269	SST	39	16-Dec-2024	6:30 AM	19-Dec-2024	6:00 AM	2.9
SNX282	SST	36	16-Dec-2024	6:30 AM	19-Dec-2024	6:00 AM	0.7
SNX501	SST	2	16-Dec-2024	6:30 AM	19-Dec-2024	6:00 AM	3.0
SOA537	SST	22	16-Dec-2024	6:30 AM	19-Dec-2024	6:00 AM	0.7
SOA644	SST	38	16-Dec-2024	6:30 AM	19-Dec-2024	6:00 AM	1.3
SNU669	SST	43	16-Dec-2024	6:30 AM	19-Dec-2024	6:00 AM	2.9
SNX259	SST	43	16-Dec-2024	6:30 AM	19-Dec-2024	6:00 AM	2.2
<b>Average Radon Concentration in:</b>			<b>43</b>				<b>2.5 pCi/L</b>
SNL424	SST	49	16-Dec-2024	6:30 AM	19-Dec-2024	6:00 AM	1.5
SNX048	SST	49	16-Dec-2024	6:30 AM	19-Dec-2024	6:00 AM	1.8
<b>Average Radon Concentration in:</b>			<b>49</b>				<b>1.6 pCi/L</b>
SNU544	SST	26	16-Dec-2024	6:30 AM	19-Dec-2024	6:00 AM	2.7
SNX060	SST	26	16-Dec-2024	6:30 AM	19-Dec-2024	6:00 AM	2.4
<b>Average Radon Concentration in:</b>			<b>26</b>				<b>2.5 pCi/L</b>
SNL458	SST	5	16-Dec-2024	6:30 AM	19-Dec-2024	6:00 AM	2.4
SNN784	SST	5	16-Dec-2024	6:30 AM	19-Dec-2024	6:00 AM	1.7
<b>Average Radon Concentration in:</b>			<b>5</b>				<b>2.0 pCi/L</b>
SNM966	SST	19	16-Dec-2024	6:30 AM	19-Dec-2024	6:00 AM	3.3
SNU633	SST	19	16-Dec-2024	6:30 AM	19-Dec-2024	6:00 AM	3.3
<b>Average Radon Concentration in:</b>			<b>19</b>				<b>3.3 pCi/L</b>

**Deployed By:** Sam Becker RNTST10096  
**Retrieved By:** Sam Becker RNTST10096  
**Analyzed By:** Sam Becker RNTST10096  
**Reader S/N:** E0747 **Reader Calibration Due:** 11/2/2024  
**Conditions:** Requirements for Closed-Building Met  
**Weather:** No Abnormal Weather Conditions  
**Vents:** Vent Fan Auto / Fan Auto  
**Mitigation:** No System Installed

### Radon Health Risk Information

Radon is the second leading cause of lung cancer after smoking. The U.S. Environmental Protection Agency (EPA) and the Surgeon General strongly recommend that further action be taken when a home's radon test results are 4.0 pCi/L or greater. The national average indoor radon level is about 1.3 pCi/L. The higher the home's radon level, the greater the health risk to you and your family. Reducing your radon levels can be done easily, effectively and fairly inexpensively. Even homes with very high radon levels can be reduced below 4.0 pCi/L. Please refer to the EPA website at [www.epa.gov/radon](http://www.epa.gov/radon) for further information to assist you in evaluating your test results or deciding if further action is needed.

# Shive-Hattery

2839 Northgate Drive  
Iowa City IA 52445  
319-354-3040 / 319-248-3405 / 319-530-2456 (cell)  
<http://www.shive-hattery.com/> / [sbecker@shive-hattery.com](mailto:sbecker@shive-hattery.com)

## Radon Test Report

December 30, 2024

Batch #: 122424-2

**Customer:**

Iowa City Community School District  
1155 S. Riverside Drive  
Iowa City IA 52246

**Test Site:**

1355 Deforest Ave Bldg.- Mark Twain  
Elementary School  
Iowa City IA 52240

---

Signature: \_\_\_\_\_ Date: \_\_\_\_\_

# Shive-Hattery

2839 Northgate Drive  
Iowa City IA 52445  
319-354-3040 / 319-248-3405 / 319-530-2456 (cell)  
<http://www.shive-hattery.com/> / [sbecker@shive-hattery.com](mailto:sbecker@shive-hattery.com)

## Radon Test Report

December 18, 2024

Batch #: 121224-1

### Customer:

Iowa City Community School District  
1155 S. Riverside Drive  
Iowa City IA 52246

### Test Site:

2901 Melrose Ave Bldg. - West High  
School  
Iowa City IA 52246

E-PERM® Electret Ion Chambers were used for radon screening measurements that were conducted at the above referenced test site by: Shive-Hattery

### The Results are as follows:

Serial	Type	Location	Test Start Date	Test End Date	Results (pCi/L)
SIE643	SST	015	09-Dec-2024	6:00 AM 12-Dec-2024	6:00 AM 0.5
SML530	SST	275 Wrestling	09-Dec-2024	6:00 AM 12-Dec-2024	6:00 AM 3.0
SML589	SST	228	09-Dec-2024	6:00 AM 12-Dec-2024	6:00 AM 0.5
SML597	SST	019	09-Dec-2024	6:00 AM 12-Dec-2024	6:00 AM 1.3
SMV420	SST	031	09-Dec-2024	6:00 AM 12-Dec-2024	6:00 AM 0.8
SNF012	SST	Stage	09-Dec-2024	6:00 AM 12-Dec-2024	6:00 AM 3.7
SNF027	SST	Auditorium	09-Dec-2024	6:00 AM 12-Dec-2024	6:00 AM 3.2
SNK478	SST	179A Athletic Director Office	09-Dec-2024	6:00 AM 12-Dec-2024	6:00 AM 2.9
SNK538	SST	009	09-Dec-2024	6:00 AM 12-Dec-2024	6:00 AM <LLD
SNL306	SST	1037 Nurse Office	09-Dec-2024	6:00 AM 12-Dec-2024	6:00 AM 1.0
SNL310	SST	017	09-Dec-2024	6:00 AM 12-Dec-2024	6:00 AM
SNL319	SST	176A Training Office	09-Dec-2024	6:00 AM 12-Dec-2024	6:00 AM 3.7
SNL341	SST	1006	09-Dec-2024	6:00 AM 12-Dec-2024	6:00 AM 0.5
SNL364	SST	1124 South Band Room	09-Dec-2024	6:00 AM 12-Dec-2024	6:00 AM 5.6
SNL378	SST	157	09-Dec-2024	6:00 AM 12-Dec-2024	6:00 AM 1.0
SNL383	SST	123	09-Dec-2024	6:00 AM 12-Dec-2024	6:00 AM 1.0
SNL397	SST	176 Training Room	09-Dec-2024	6:00 AM 12-Dec-2024	6:00 AM 3.9
SNL412	SST	1026	09-Dec-2024	6:00 AM 12-Dec-2024	6:00 AM <LLD
SNL434	SST	1135 Work Room	09-Dec-2024	6:00 AM 12-Dec-2024	6:00 AM 3.6
SNL437	SST	027	09-Dec-2024	6:00 AM 12-Dec-2024	6:00 AM 1.1
SNL441	SST	Auditorium	09-Dec-2024	6:00 AM 12-Dec-2024	6:00 AM 3.1
SNL459	SST	155 Industrial Tech	09-Dec-2024	6:00 AM 12-Dec-2024	6:00 AM <LLD
SNL468	SST	1119 Band Office	09-Dec-2024	6:00 AM 12-Dec-2024	6:00 AM
SNL480	SST	1023	09-Dec-2024	6:00 AM 12-Dec-2024	6:00 AM 0.8
SNL488	SST	New Classroom	09-Dec-2024	6:00 AM 12-Dec-2024	6:00 AM <LLD
SNL492	SST	005	09-Dec-2024	6:00 AM 12-Dec-2024	6:00 AM 0.5
SNL493	SST	024	09-Dec-2024	6:00 AM 12-Dec-2024	6:00 AM <LLD
SNL499	SST	016	09-Dec-2024	6:00 AM 12-Dec-2024	6:00 AM
SNL503	SST	1021	09-Dec-2024	6:00 AM 12-Dec-2024	6:00 AM 0.5
SNL515	SST	186 Girl's Locker Room Office	09-Dec-2024	6:00 AM 12-Dec-2024	6:00 AM 3.8
SNU521	SST	Gym	09-Dec-2024	6:00 AM 12-Dec-2024	6:00 AM 0.8
SNL524	SST	West Wing Office Reception	09-Dec-2024	6:00 AM 12-Dec-2024	6:00 AM 1.4
SNL539	SST	Gym	09-Dec-2024	6:00 AM 12-Dec-2024	6:00 AM 3.1
SNL540	SST	167 Cafeteria	09-Dec-2024	6:00 AM 12-Dec-2024	6:00 AM 3.4
SNL546	SST	1010 Office	09-Dec-2024	6:00 AM 12-Dec-2024	6:00 AM 0.7
SNL547	SST	1025	09-Dec-2024	6:00 AM 12-Dec-2024	6:00 AM 1.2

# Shive-Hattery

2839 Northgate Drive

Iowa City IA 52445

319-354-3040 / 319-248-3405 / 319-530-2456 (cell)

<http://www.shive-hattery.com/> / [sbecker@shive-hattery.com](mailto:sbecker@shive-hattery.com)

## Radon Test Report

December 18, 2024

Batch #: 121224-1

### Customer:

Iowa City Community School District  
1155 S. Riverside Drive  
Iowa City IA 52246

### Test Site:

2901 Melrose Ave Bldg.- West High  
School  
Iowa City IA 52246

Serial	Type	Location	Test Start Date	Test End Date	Results (pCi/L)
SNL559	SST	167 Cafeteria	09-Dec-2024	6:00 AM 12-Dec-2024 6:00 AM	
SNL563	SST	Phil Keitel	09-Dec-2024	6:00 AM 12-Dec-2024 6:00 AM	1.7
SNL578	SST	158A Custodian	09-Dec-2024	6:00 AM 12-Dec-2024 6:00 AM	0.9
SNL580	SST	177 Weight Room	09-Dec-2024	6:00 AM 12-Dec-2024 6:00 AM	4.9
SNL590	SST	1013 Conference	09-Dec-2024	6:00 AM 12-Dec-2024 6:00 AM	1.5
SNL607	SST	201	09-Dec-2024	6:00 AM 12-Dec-2024 6:00 AM	<LLD
SNL700	SST	1002 Office	09-Dec-2024	6:00 AM 12-Dec-2024 6:00 AM	1.0
SNU713	SST	170 Girl's PE Locker Room Office	09-Dec-2024	6:00 AM 12-Dec-2024 6:00 AM	1.6
SNL731	SST	155 Industrial Tech	09-Dec-2024	6:00 AM 12-Dec-2024 6:00 AM	0.5
SNM720	SST	Gym	09-Dec-2024	6:00 AM 12-Dec-2024 6:00 AM	1.7
SNM751	SST	025D	09-Dec-2024	6:00 AM 12-Dec-2024 6:00 AM	2.1
SNM817	SST	180 South Gym	09-Dec-2024	6:00 AM 12-Dec-2024 6:00 AM	
SNN721	SST	011	09-Dec-2024	6:00 AM 12-Dec-2024 6:00 AM	0.5
SNN771	SST	167 Cafeteria	09-Dec-2024	6:00 AM 12-Dec-2024 6:00 AM	3.2
SNN806	SST	005	09-Dec-2024	6:00 AM 12-Dec-2024 6:00 AM	0.7
SNN861	SST	1022	09-Dec-2024	6:00 AM 12-Dec-2024 6:00 AM	0.7
SNT742	SST	1024	09-Dec-2024	6:00 AM 12-Dec-2024 6:00 AM	1.8
SNT909	SST	167 Cafeteria	09-Dec-2024	6:00 AM 12-Dec-2024 6:00 AM	3.2
SNU319	SST	012	09-Dec-2024	6:00 AM 12-Dec-2024 6:00 AM	0.5
SNU398	SST	214	09-Dec-2024	6:00 AM 12-Dec-2024 6:00 AM	0.6
SNU469	SST	171 Boy's PE Locker Room Office	09-Dec-2024	6:00 AM 12-Dec-2024 6:00 AM	2.3
SNU470	SST	155D Lactation	09-Dec-2024	6:00 AM 12-Dec-2024 6:00 AM	<LLD
SNU504	SST	1117 North Band Room	09-Dec-2024	6:00 AM 12-Dec-2024 6:00 AM	3.2
SNU523	SST	008	09-Dec-2024	6:00 AM 12-Dec-2024 6:00 AM	
SNU524	SST	278 Fitness	09-Dec-2024	6:00 AM 12-Dec-2024 6:00 AM	3.0
SNU548	SST	150 Little Theater Stage	09-Dec-2024	6:00 AM 12-Dec-2024 6:00 AM	3.3
SNU552	SST	1029	09-Dec-2024	6:00 AM 12-Dec-2024 6:00 AM	<LLD
SNU553	SST	180 South Gym	09-Dec-2024	6:00 AM 12-Dec-2024 6:00 AM	2.5
SNU557	SST	1113 Music Theory	09-Dec-2024	6:00 AM 12-Dec-2024 6:00 AM	1.6
SNU558	SST	021	09-Dec-2024	6:00 AM 12-Dec-2024 6:00 AM	1.2
SNU559	SST	1117 North Band Room	09-Dec-2024	6:00 AM 12-Dec-2024 6:00 AM	4.0
SNU562	SST	004	09-Dec-2024	6:00 AM 12-Dec-2024 6:00 AM	1.3
SNU568	SST	185E Boy's Locker Room Office	09-Dec-2024	6:00 AM 12-Dec-2024 6:00 AM	3.3
SNU572	SST	115B	09-Dec-2024	6:00 AM 12-Dec-2024 6:00 AM	0.7
SNU573	SST	180 South Gym (tampered)	09-Dec-2024	6:00 AM 12-Dec-2024 6:00 AM	3.3
SNU584	SST	178 Performance PE Dance	09-Dec-2024	6:00 AM 12-Dec-2024 6:00 AM	2.2
SNU609	SST	150 Little Theater Stage	09-Dec-2024	6:00 AM 12-Dec-2024 6:00 AM	3.0
SNU611	SST	1117 North Band Room	09-Dec-2024	6:00 AM 12-Dec-2024 6:00 AM	3.3

# Shive-Hattery

2839 Northgate Drive  
 Iowa City IA 52445  
 319-354-3040 / 319-248-3405 / 319-530-2456 (cell)  
<http://www.shive-hattery.com/> / [sbecker@shive-hattery.com](mailto:sbecker@shive-hattery.com)

## Radon Test Report

December 18, 2024

Batch #: 121224-1

**Customer:**

Iowa City Community School District  
 1155 S. Riverside Drive  
 Iowa City IA 52246

**Test Site:**

2901 Melrose Ave Bldg.- West High  
 School  
 Iowa City IA 52246

Serial	Type	Location	Test Start Date	Test End Date	Results (pCi/L)
SNU626	SST	022	09-Dec-2024 6:00 AM	12-Dec-2024 6:00 AM	<LLD
SNU630	SST	Auditorium	09-Dec-2024 6:00 AM	12-Dec-2024 6:00 AM	3.5
SNU661	SST	1028	09-Dec-2024 6:00 AM	12-Dec-2024 6:00 AM	0.8
SNU694	SST	1030 Office	09-Dec-2024 6:00 AM	12-Dec-2024 6:00 AM	
SNU695	SST	180 South Gym	09-Dec-2024 6:00 AM	12-Dec-2024 6:00 AM	3.0
SNU707	SST	023	09-Dec-2024 6:00 AM	12-Dec-2024 6:00 AM	1.5
SNU710	SST	1117 North Band Room	09-Dec-2024 6:00 AM	12-Dec-2024 6:00 AM	3.6
SNU730	SST	155 Industrial Tech	09-Dec-2024 6:00 AM	12-Dec-2024 6:00 AM	0.5
SNU745	SST	1001 Main Office	09-Dec-2024 6:00 AM	12-Dec-2024 6:00 AM	<LLD
SNU778	SST	184 Team	09-Dec-2024 6:00 AM	12-Dec-2024 6:00 AM	
SNU788	SST	Erik Nelson	09-Dec-2024 6:00 AM	12-Dec-2024 6:00 AM	1.0
SNU799	SST	006	09-Dec-2024 6:00 AM	12-Dec-2024 6:00 AM	1.8
SNU804	SST	1004 Office	09-Dec-2024 6:00 AM	12-Dec-2024 6:00 AM	<LLD
SNX023	SST	1124 South Band Room	09-Dec-2024 6:00 AM	12-Dec-2024 6:00 AM	2.6
SNX059	SST	131	09-Dec-2024 6:00 AM	12-Dec-2024 6:00 AM	1.6
SNX080	SST	151 Culinary Arts	09-Dec-2024 6:00 AM	12-Dec-2024 6:00 AM	2.5
SNX121	SST	178 Performance PE Dance	09-Dec-2024 6:00 AM	12-Dec-2024 6:00 AM	4.9
SNX123	SST	026	09-Dec-2024 6:00 AM	12-Dec-2024 6:00 AM	0.8
SNX130	SST	153 Textile	09-Dec-2024 6:00 AM	12-Dec-2024 6:00 AM	0.6
SNX154	SST	104	09-Dec-2024 6:00 AM	12-Dec-2024 6:00 AM	<LLD
SNX235	SST	001	09-Dec-2024 6:00 AM	12-Dec-2024 6:00 AM	
SNX276	SST	1008	09-Dec-2024 6:00 AM	12-Dec-2024 6:00 AM	<LLD
SNX281	SST	Stage	09-Dec-2024 6:00 AM	12-Dec-2024 6:00 AM	
SNL577	SST	1126 Band Office	09-Dec-2024 6:00 AM	12-Dec-2024 6:00 AM	4.5
SNU489	SST	1126 Band Office	09-Dec-2024 6:00 AM	12-Dec-2024 6:00 AM	5.0
<b>Average Radon Concentration in:</b>			<b>1126 Band Office</b>		<b>4.7 pCi/L</b>
SNE905	SST	018	09-Dec-2024 6:00 AM	12-Dec-2024 6:00 AM	0.8
SNL581	SST	018	09-Dec-2024 6:00 AM	12-Dec-2024 6:00 AM	<LLD
<b>Average Radon Concentration in:</b>			<b>018</b>		<b>0.4 pCi/L</b>
SNU449	SST	032	09-Dec-2024 6:00 AM	12-Dec-2024 6:00 AM	0.6
SNU621	SST	032	09-Dec-2024 6:00 AM	12-Dec-2024 6:00 AM	1.0
<b>Average Radon Concentration in:</b>			<b>032</b>		<b>0.8 pCi/L</b>
SNL490	SST	179 Athletic Director	09-Dec-2024 6:00 AM	12-Dec-2024 6:00 AM	3.6
SNL538	SST	179 Athletic Director	09-Dec-2024 6:00 AM	12-Dec-2024 6:00 AM	4.2
<b>Average Radon Concentration in:</b>			<b>179 Athletic Director</b>		<b>3.9 pCi/L</b>

# Shive-Hattery

2839 Northgate Drive  
Iowa City IA 52445  
319-354-3040 / 319-248-3405 / 319-530-2456 (cell)  
<http://www.shive-hattery.com/> / [sbecker@shive-hattery.com](mailto:sbecker@shive-hattery.com)

## Radon Test Report

December 18, 2024

Batch #: 121224-1

### Customer:

Iowa City Community School District  
1155 S. Riverside Drive  
Iowa City IA 52246

### Test Site:

2901 Melrose Ave Bldg.- West High  
School  
Iowa City IA 52246

Serial	Type	Location	Test Start Date		Test End Date		Results (pCi/L)
SNT758	SST	150 Little Theater	09-Dec-2024	6:00 AM	12-Dec-2024	6:00 AM	2.2
SNX283	SST	150 Little Theater	09-Dec-2024	6:00 AM	12-Dec-2024	6:00 AM	3.3
<b>Average Radon Concentration in:</b>			<b>150 Little Theater</b>			<b>2.7 pCi/L</b>	
SNL487	SST	152 Staff Lounge	09-Dec-2024	6:00 AM	12-Dec-2024	6:00 AM	1.7
SNX075	SST	152 Staff Lounge	09-Dec-2024	6:00 AM	12-Dec-2024	6:00 AM	2.9
<b>Average Radon Concentration in:</b>			<b>152 Staff Lounge</b>			<b>2.3 pCi/L</b>	
SNL497	SST	159 Engineering Lab	09-Dec-2024	6:00 AM	12-Dec-2024	6:00 AM	2.4
SNX120	SST	159 Engineering Lab	09-Dec-2024	6:00 AM	12-Dec-2024	6:00 AM	2.7
<b>Average Radon Concentration in:</b>			<b>159 Engineering Lab</b>			<b>2.5 pCi/L</b>	
SNU202	SST	1034 Health	09-Dec-2024	6:00 AM	12-Dec-2024	6:00 AM	0.5
SNU488	SST	1034 Health	09-Dec-2024	6:00 AM	12-Dec-2024	6:00 AM	0.6
<b>Average Radon Concentration in:</b>			<b>1034 Health</b>			<b>0.6 pCi/L</b>	
SNL501	SST	1020 Guidance	09-Dec-2024	6:00 AM	12-Dec-2024	6:00 AM	<LLD
SNX277	SST	1020 Guidance	09-Dec-2024	6:00 AM	12-Dec-2024	6:00 AM	0.5
<b>Average Radon Concentration in:</b>			<b>1020 Guidance</b>			<b>0.4 pCi/L</b>	
SML465	SST	002	09-Dec-2024	6:00 AM	12-Dec-2024	6:00 AM	<LLD
SNL308	SST	002	09-Dec-2024	6:00 AM	12-Dec-2024	6:00 AM	0.8
<b>Average Radon Concentration in:</b>			<b>002</b>			<b>0.4 pCi/L</b>	
SNE829	SST	013	09-Dec-2024	6:00 AM	12-Dec-2024	6:00 AM	0.9
SNU590	SST	013	09-Dec-2024	6:00 AM	12-Dec-2024	6:00 AM	<LLD
<b>Average Radon Concentration in:</b>			<b>013</b>			<b>0.6 pCi/L</b>	
<b>Deployed By:</b>	Sam Becker	108001 RT					
<b>Retrieved By:</b>	Sam Becker	108001 RT					
<b>Analyzed By:</b>	Sam Becker	108001 RT					
<b>Reader S/N:</b>	E0747		<b>Reader Calibration Due: 11/2/2024</b>				
<b>Conditions:</b>	Requirements for Closed-Building Met						
<b>Weather:</b>	No Abnormal Weather Conditions						
<b>Vents:</b>	Open / Fan Auto						
<b>Mitigation:</b>	No System Installed						
<b>Note: &lt;LLD = Less than the Lower Limit of Detection (LLD) of the Radon Detector.</b>							

## Radon Health Risk Information

# Shive-Hattery

2839 Northgate Drive

Iowa City IA 52445

319-354-3040 / 319-248-3405 / 319-530-2456 (cell)

<http://www.shive-hattery.com/> / [sbecker@shive-hattery.com](mailto:sbecker@shive-hattery.com)

## Radon Test Report

December 18, 2024

Batch #: 121224-1

**Customer:**

Iowa City Community School District  
1155 S. Riverside Drive  
Iowa City IA 52246

**Test Site:**

2901 Melrose Ave Bldg.- West High  
School  
Iowa City IA 52246

---

Radon is the second leading cause of lung cancer after smoking. The U.S. Environmental Protection Agency (EPA) and the Surgeon General strongly recommend that further action be taken when a home's radon test results are 4.0 pCi/L or greater. The national average indoor radon level is about 1.3 pCi/L. The higher the home's radon level, the greater the health risk to you and your family. Reducing your radon levels can be done easily, effectively and fairly inexpensively. Even homes with very high radon levels can be reduced below 4.0 pCi/L. Please refer to the EPA website at [www.epa.gov/radon](http://www.epa.gov/radon) for further information to assist you in evaluating your test results or deciding if further action is needed.

Signature: \_\_\_\_\_ Date: \_\_\_\_\_

# Shive-Hattery

2839 Northgate Drive  
Iowa City IA 52445  
319-354-3040 / 319-248-3405 / 319-530-2456 (cell)  
<http://www.shive-hattery.com/> / [sbecker@shive-hattery.com](mailto:sbecker@shive-hattery.com)

## Radon Test Report

December 26, 2024

Batch #: 122624-1

### Customer:

Iowa City Community School District  
1155 S. Riverside Drive  
Iowa City IA 52246

### Test Site:

1930 Lakeside Dr Bldg.- Grant Wood  
Elementary  
Iowa City IA 52240

E-PERM® Electret Ion Chambers were used for radon screening measurements that were conducted at the above referenced test site by: Shive-Hattery

### The Results are as follows:

Serial	Type	Location	Test Start Date	Test End Date	Results (pCi/L)
SML530	SST	116	16-Dec-2024 7:15 AM	19-Dec-2024 6:45 AM	2.3
SNE890	SST	110	16-Dec-2024 7:15 AM	19-Dec-2024 6:45 AM	0.8
SNF012	SST	124	16-Dec-2024 7:15 AM	19-Dec-2024 6:45 AM	3.6
SNK456	SST	157	16-Dec-2024 7:15 AM	19-Dec-2024 6:45 AM	1.8
SNL334	SST	153	16-Dec-2024 7:15 AM	19-Dec-2024 6:45 AM	2.8
SNL397	SST	168	16-Dec-2024 7:15 AM	19-Dec-2024 6:45 AM	3.9
SNL416	SST	113	16-Dec-2024 7:15 AM	19-Dec-2024 6:45 AM	0.6
SNL455	SST	132	16-Dec-2024 7:15 AM	19-Dec-2024 6:45 AM	0.7
SNL459	SST	151	16-Dec-2024 7:15 AM	19-Dec-2024 6:45 AM	3.4
SNL487	SST	114	16-Dec-2024 7:15 AM	19-Dec-2024 6:45 AM	2.6
SNL506	SST	206	16-Dec-2024 7:15 AM	19-Dec-2024 6:45 AM	0.6
SNL539	SST	157	16-Dec-2024 7:15 AM	19-Dec-2024 6:45 AM	2.1
SNL540	SST	144	16-Dec-2024 7:15 AM	19-Dec-2024 6:45 AM	2.6
SNL556	SST	207	16-Dec-2024 7:15 AM	19-Dec-2024 6:45 AM	0.9
SNL559	SST	119	16-Dec-2024 7:15 AM	19-Dec-2024 6:45 AM	1.6
SNL580	SST	128C	16-Dec-2024 7:15 AM	19-Dec-2024 6:45 AM	2.8
SNL588	SST	152	16-Dec-2024 7:15 AM	19-Dec-2024 6:45 AM	<LLD
SNL731	SST	203	16-Dec-2024 7:15 AM	19-Dec-2024 6:45 AM	1.7
SNL879	SST	102	16-Dec-2024 7:15 AM	19-Dec-2024 6:45 AM	0.6
SNM817	SST	161	16-Dec-2024 7:15 AM	19-Dec-2024 6:45 AM	3.3
SNM865	SST	115	16-Dec-2024 7:15 AM	19-Dec-2024 6:45 AM	0.7
SNN771	SST	128A	16-Dec-2024 7:15 AM	19-Dec-2024 6:45 AM	2.6
SNT758	SST	142	16-Dec-2024 7:15 AM	19-Dec-2024 6:45 AM	1.2
SNT909	SST	157D	16-Dec-2024 7:15 AM	19-Dec-2024 6:45 AM	2.9
SNU202	SST	141	16-Dec-2024 7:15 AM	19-Dec-2024 6:45 AM	2.0
SNU462	SST	210	16-Dec-2024 7:15 AM	19-Dec-2024 6:45 AM	1.2
SNU469	SST	164	16-Dec-2024 7:15 AM	19-Dec-2024 6:45 AM	3.6
SNU470	SST	143	16-Dec-2024 7:15 AM	19-Dec-2024 6:45 AM	3.2
SNU510	SST	209	16-Dec-2024 7:15 AM	19-Dec-2024 6:45 AM	<LLD
SNU521	SST	157	16-Dec-2024 7:15 AM	19-Dec-2024 6:45 AM	2.9
SNU555	SST	201	16-Dec-2024 7:15 AM	19-Dec-2024 6:45 AM	<LLD
SNU582	SST	128	16-Dec-2024 7:15 AM	19-Dec-2024 6:45 AM	0.8
SNU609	SST	171	16-Dec-2024 7:15 AM	19-Dec-2024 6:45 AM	2.5
SNU634	SST	131	16-Dec-2024 7:15 AM	19-Dec-2024 6:45 AM	0.9
SNU636	SST	154	16-Dec-2024 7:15 AM	19-Dec-2024 6:45 AM	2.4
SNU713	SST	157	16-Dec-2024 7:15 AM	19-Dec-2024 6:45 AM	3.7
SNU730	SST	129	16-Dec-2024 7:15 AM	19-Dec-2024 6:45 AM	2.9

# Shive-Hattery

2839 Northgate Drive

Iowa City IA 52445

319-354-3040 / 319-248-3405 / 319-530-2456 (cell)

<http://www.shive-hattery.com/> / [sbecker@shive-hattery.com](mailto:sbecker@shive-hattery.com)

## Radon Test Report

December 26, 2024

Batch #: 122624-1

### Customer:

Iowa City Community School District  
1155 S. Riverside Drive  
Iowa City IA 52246

### Test Site:

1930 Lakeside Dr Bldg.- Grant Wood  
Elementary  
Iowa City IA 52240

Serial	Type	Location	Test Start Date		Test End Date		Results (pCi/L)
SNU778	SST	160	16-Dec-2024	7:15 AM	19-Dec-2024	6:45 AM	4.6
SNW994	SST	120	16-Dec-2024	7:15 AM	19-Dec-2024	6:45 AM	0.8
SNX002	SST	128	16-Dec-2024	7:15 AM	19-Dec-2024	6:45 AM	1.2
SNX020	SST	200	16-Dec-2024	7:15 AM	19-Dec-2024	6:45 AM	1.4
SNX075	SST	123	16-Dec-2024	7:15 AM	19-Dec-2024	6:45 AM	1.3
SNX080	SST	155	16-Dec-2024	7:15 AM	19-Dec-2024	6:45 AM	3.3
SNX106	SST	111	16-Dec-2024	7:15 AM	19-Dec-2024	6:45 AM	1.1
SNX130	SST	155	16-Dec-2024	7:15 AM	19-Dec-2024	6:45 AM	3.5
SNX136	SST	104	16-Dec-2024	7:15 AM	19-Dec-2024	6:45 AM	2.2
SNX137	SST	121	16-Dec-2024	7:15 AM	19-Dec-2024	6:45 AM	1.2
SNX268	SST	137	16-Dec-2024	7:15 AM	19-Dec-2024	6:45 AM	1.2
SNX281	SST	134	16-Dec-2024	7:15 AM	19-Dec-2024	6:45 AM	2.0
SNX283	SST	163	16-Dec-2024	7:15 AM	19-Dec-2024	6:45 AM	3.8
SNL538	SST	167	16-Dec-2024	7:15 AM	19-Dec-2024	6:45 AM	2.3
SNX023	SST	167	16-Dec-2024	7:15 AM	19-Dec-2024	6:45 AM	3.3
<b>Average Radon Concentration in:</b>			<b>167</b>				<b>2.8 pCi/L</b>
SNL497	SST	140	16-Dec-2024	7:15 AM	19-Dec-2024	6:45 AM	2.6
SNL547	SST	140	16-Dec-2024	7:15 AM	19-Dec-2024	6:45 AM	4.2
<b>Average Radon Concentration in:</b>			<b>140</b>				<b>3.4 pCi/L</b>
SNL503	SST	133	16-Dec-2024	7:15 AM	19-Dec-2024	6:45 AM	2.1
SNU548	SST	133	16-Dec-2024	7:15 AM	19-Dec-2024	6:45 AM	2.4
<b>Average Radon Concentration in:</b>			<b>133</b>				<b>2.2 pCi/L</b>
SNX157	SST	130	16-Dec-2024	7:15 AM	19-Dec-2024	6:45 AM	0.5
SOA200	SST	130	16-Dec-2024	7:15 AM	19-Dec-2024	6:45 AM	0.7
<b>Average Radon Concentration in:</b>			<b>130</b>				<b>0.6 pCi/L</b>
SNU499	SST	122	16-Dec-2024	7:15 AM	19-Dec-2024	6:45 AM	1.0
SNX120	SST	122	16-Dec-2024	7:15 AM	19-Dec-2024	6:45 AM	3.0
<b>Average Radon Concentration in:</b>			<b>122</b>				<b>2.0 pCi/L</b>
SNK478	SST	112	16-Dec-2024	7:15 AM	19-Dec-2024	6:45 AM	2.1
SNX115	SST	112	16-Dec-2024	7:15 AM	19-Dec-2024	6:45 AM	1.0
<b>Average Radon Concentration in:</b>			<b>112</b>				<b>1.6 pCi/L</b>
SNL385	SST	202	16-Dec-2024	7:15 AM	19-Dec-2024	6:45 AM	<LLD
SNX149	SST	202	16-Dec-2024	7:15 AM	19-Dec-2024	6:45 AM	<LLD
<b>Average Radon Concentration in:</b>			<b>202</b>				<b>&lt;LLD pCi/L</b>

# Shive-Hattery

2839 Northgate Drive  
Iowa City IA 52445  
319-354-3040 / 319-248-3405 / 319-530-2456 (cell)  
<http://www.shive-hattery.com/> / [sbecker@shive-hattery.com](mailto:sbecker@shive-hattery.com)

## Radon Test Report

December 26, 2024

Batch #: 122624-1

### Customer:

Iowa City Community School District  
1155 S. Riverside Drive  
Iowa City IA 52246

### Test Site:

1930 Lakeside Dr Bldg.- Grant Wood  
Elementary  
Iowa City IA 52240

---

**Deployed By:** Sam Becker RNTST10096  
**Retrieved By:** Sam Becker RNTST10096  
**Analyzed By:** Sam Becker RNTST10096  
**Reader S/N:** E0747 **Reader Calibration Due:** 11/2/2024  
**Conditions:** Requirements for Closed-Building Met  
**Weather:** No Abnormal Weather Conditions  
**Vents:** Vent Fan Auto / Fan Auto  
**Mitigation:** No System Installed

**Note:** <LLD = Less than the Lower Limit of Detection (LLD) of the Radon Detector.

---

### Radon Health Risk Information

Radon is the second leading cause of lung cancer after smoking. The U.S. Environmental Protection Agency (EPA) and the Surgeon General strongly recommend that further action be taken when a home's radon test results are 4.0 pCi/L or greater. The national average indoor radon level is about 1.3 pCi/L. The higher the home's radon level, the greater the health risk to you and your family. Reducing your radon levels can be done easily, effectively and fairly inexpensively. Even homes with very high radon levels can be reduced below 4.0 pCi/L. Please refer to the EPA website at [www.epa.gov/radon](http://www.epa.gov/radon) for further information to assist you in evaluating your test results or deciding if further action is needed.

Signature: \_\_\_\_\_ Date: \_\_\_\_\_

# Shive-Hattery

2839 Northgate Drive  
Iowa City IA 52445  
319-354-3040 / 319-248-3405 / 319-530-2456 (cell)  
<http://www.shive-hattery.com/> / [sbecker@shive-hattery.com](mailto:sbecker@shive-hattery.com)

## Radon Test Report

March 07, 2025

Batch #: 030725-5

**Customer:**

Iowa City Community School District  
1155 S. Riverside Drive  
Iowa City IA 52246

**Test Site:**

1930 Lakeside Dr Bldg.- Grant Wood  
Elementary  
Iowa City IA 52240

---

E-PERM® Electret Ion Chambers were used for radon screening measurements that were conducted at the above referenced test site by: Shive-Hattery

**The Results are as follows:**

---

Serial	Type	Location	Test Start Date		Test End Date		Results (pCi/L)
SNL553	SST	160	04-Mar-2025	7:45 AM	06-Mar-2025	7:50 AM	2.9
SNT909	SST	160	04-Mar-2025	7:45 AM	06-Mar-2025	7:50 AM	4.2

---

**Average Radon Concentration in:** **160** **3.6 pCi/L**

---

**Deployed By:** Sam Becker RNTST10096  
**Retrieved By:** Sam Becker RNTST10096  
**Analyzed By:** Sam Becker RNTST10096  
**Reader S/N:** E0747 **Reader Calibration Due:** 11/2/2024  
**Conditions:** Requirements for Closed-Building Met  
**Weather:** No Abnormal Weather Conditions  
**Vents:** Open / Fan Auto  
**Mitigation:** No System Installed

---

### Radon Health Risk Information

Radon is the second leading cause of lung cancer after smoking. The U.S. Environmental Protection Agency (EPA) and the Surgeon General strongly recommend that further action be taken when a home's radon test results are 4.0 pCi/L or greater. The national average indoor radon level is about 1.3 pCi/L. The higher the home's radon level, the greater the health risk to you and your family. Reducing your radon levels can be done easily, effectively and fairly inexpensively. Even homes with very high radon levels can be reduced below 4.0 pCi/L. Please refer to the EPA website at [www.epa.gov/radon](http://www.epa.gov/radon) for further information to assist you in evaluating your test results or deciding if further action is needed.

**Signature:** \_\_\_\_\_ **Date:** \_\_\_\_\_