



April 30, 2025

Service Request No:R2504407

Mr. Ken Nelson
Rush-Henrietta Central School District
2034 Lehigh Station Road
Henrietta, NY 14467

Laboratory Results for: Fyle Elementary

Dear Mr.Nelson,

Enclosed are the results of the sample(s) submitted to our laboratory April 24, 2025
For your reference, these analyses have been assigned our service request number **R2504407**.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7476. You may also contact me via email at Chris.Leavy@alsglobal.com.

Respectfully submitted,

ALS Group USA, Corp. dba ALS Environmental

Christopher Leavy
Project Manager

ADDRESS 1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
PHONE +1 585 288 5380 | **FAX** +1 585 288 8475
ALS Group USA, Corp.
dba ALS Environmental



Narrative Documents

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Client: Rush-Henrietta Central School District
Project: Fyle Elementary
Sample Matrix: Drinking Water

Service Request: R2504407
Date Received: 04/24/2025

CASE NARRATIVE

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

Sample Receipt:

Fourteen drinking water samples were received for analysis at ALS Environmental on 04/24/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

Metals:

No significant anomalies were noted with this analysis.

A handwritten signature in black ink, appearing to be "WZ", is written over a horizontal line.

Approved by _____

Date 04/30/2025



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: Fyle-2 C-10 - Drinking Fountain Boy's Gym		Lab ID: R2504407-002				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.8			1.0	ug/L	200.8
CLIENT ID: Fyle-3 Adj. to C-10 - Drinking Fountain		Lab ID: R2504407-003				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	20.6			1.0	ug/L	200.8
CLIENT ID: Fyle-6 Opposite Main Office - Drinking Fountain		Lab ID: R2504407-006				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.6			1.0	ug/L	200.8
CLIENT ID: Fyle-7 Kitchen - Kitchen Island Sink Faucet		Lab ID: R2504407-007				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.7			1.0	ug/L	200.8
CLIENT ID: Fyle-8 Kitchen - Braising Pan Faucet		Lab ID: R2504407-008				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	10.2			1.0	ug/L	200.8
CLIENT ID: Fyle-9 Kitchen - Kitchen Island Sink Faucet (5Min		Lab ID: R2504407-009				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.0			1.0	ug/L	200.8
CLIENT ID: Fyle-10 Kitchen - Braising Pan Faucet (5Min Flush)		Lab ID: R2504407-010				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.1			1.0	ug/L	200.8
CLIENT ID: Fyle-11 Cafetorium - Drinking Fountain		Lab ID: R2504407-011				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.4			1.0	ug/L	200.8
CLIENT ID: Fyle-12 Faculty Lounge - Faculty Break Room Sink		Lab ID: R2504407-012				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	4.2			1.0	ug/L	200.8
CLIENT ID: Fyle-13 Faculty Lounge - Faculty Break Room		Lab ID: R2504407-013				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	8.9			1.0	ug/L	200.8



Sample Receipt Information

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Client: Rush-Henrietta Central School District
Project: Fyle Elementary

Service Request:R2504407

SAMPLE CROSS-REFERENCE

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2504407-001	Fyle-1 C-10 - Drinking Fountain Girl's Gym	4/24/2025	0602
R2504407-002	Fyle-2 C-10 - Drinking Fountain Boy's Gym	4/24/2025	0600
R2504407-003	Fyle-3 Adj. to C-10 - Drinking Fountain	4/24/2025	0556
R2504407-004	Fyle-4 A-11-Health Office Main Sink Faucet	4/24/2025	0540
R2504407-005	Fyle-5 A-11-Health Office Exam Room Sink	4/24/2025	0542
R2504407-006	Fyle-6 Opposite Main Office - Drinking Fountain	4/24/2025	0546
R2504407-007	Fyle-7 Kitchen - Kitchen Island Sink Faucet	4/24/2025	0410
R2504407-008	Fyle-8 Kitchen - Braising Pan Faucet	4/24/2025	0410
R2504407-009	Fyle-9 Kitchen - Kitchen Island Sink Faucet (5Min Flush)	4/24/2025	0416
R2504407-010	Fyle-10 Kitchen - Braising Pan Faucet (5Min Flush)	4/24/2025	0416
R2504407-011	Fyle-11 Cafetorium - Drinking Fountain	4/24/2025	0550
R2504407-012	Fyle-12 Faculty Lounge - Faculty Break Room Sink Faucet	4/24/2025	0525
R2504407-013	Fyle-13 Faculty Lounge - Faculty Break Room Instant Hot	4/24/2025	0558
R2504407-014	Fyle-15 Adj. to B-8 - Drinking Fountain	4/24/2025	0548



Chain of Custody / Analytical Request Form

1565 Jefferson Road, Building 300, Suite 360 • Rochester, NY 14623 • +1 585 288 5380 • alsglobal.com

SR#: _____
Page _____ of _____

Report To:		ALL SHADED AREAS <u>MUST</u> BE COMPLETED BY THE CLIENT / SAMPLER		Preservative										0. None				
Company: Rush-Henrietta CSD		Project Name: Fyle Elementary		Matrix	Number of Containers	MS/MSD?	200.8 Lead											1. HCl
Contact: Ken Nelson		Project Number:																2. HNO3
Email: knelson@rhnet.org		ALS Quote #: 38456																3. H2SO4
Phone: 585-738-8070		Sampler's Signature:																4. NAOH
Address: 2034 Lehigh Station Road Henrietta NY 14467		Email CC: slacey@rhnet.org jlschultz@rhnet.org																5. Zn Acet.
		State Samples Collected NY												6. MeOH				

Lab ID (ALS)	Sample Collection Information:			Matrix	Number of Containers	MS/MSD?	200.8 Lead											Notes:
	Sample ID:	Date	Time															
11	Cafetorium - Drinking Fountain	04/24/25	5:50	DW			X											
12	Faculty Lounge - Faculty Break Room Sink Faucet	04/24/25	5:55	DW			X											
13	Faculty Lounge - Faculty Break Room Instant Hot Water	04/24/25	5:58	DW			X											
14	A-9 - Instant Hot Water Dispenser	04/24/25		DW			X											Removed
15	Adj. to B-8 - Drinking Fountain	04/24/25	5:48	DW			X											
				DW			X											
				DW			X											
				DW			X											
				DW			X											

Special Instructions / Comments:	Turnaround Requirements	Report Requirements	Metals: RCRA 8•PP 13•TAL 23•TCLP•Other (List)
	<input type="checkbox"/> Rush (Surcharges Apply) <input type="checkbox"/> Subject to Availability* <input type="checkbox"/> Please Check with your PM* <input checked="" type="checkbox"/> Standard (10 Business Days)	<input checked="" type="checkbox"/> Tier II/Cat A - Results/QC <input type="checkbox"/> Tier IV/Cat B - Data Validation Report w/. Data	VOA/SVOA Report List: TCL • BTEX • TCLP • CP-51/Stars • THM • Other: _____
	Date Required:	EDD: <input type="checkbox"/> Yes <input type="checkbox"/> No EDD Type:	Invoice To: <input type="checkbox"/> Same as Report To
			PO #: 7225-01793 Company: Rush-Henrietta CSD

Relinquished By:	Received By:	Relinquished By:	Received By:	Relinquished By:	Received By:	Contact: Ken Nelson
Signature: <i>James Schultz</i>	Signature: <i>Alice Austin</i>					Email: knelson@rhnet.org
Printed Name: James Schultz	Printed Name: Alice Austin					Phone: 585-738-8070
Company: Rush-Henrietta CSD	Company: ALS					Address:
Date/Time: 4-24-25 8:38	Date/Time: 4/24/25 8:38					2034 Lehigh Station Rd. Henrietta, NY 14467



R2504407 5

Rush-Henrietta Central School District
Fyle Elementary



Cooler Receipt and Preservation Check

Project/Client Rush-Henrietta CSD Folder Number _____

Cooler received on 4/24/25 by: JE

COURIER: ALS UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	Y <u>N</u>
2	Custody papers properly completed (ink, signed)?	<u>Y</u> N
3	Did all bottles arrive in good condition (unbroken)?	Y N
4	Circle: Wet Ice Dry Ice Gel packs present?	Y <u>N</u>

5a	Did VOA vials have sig* bubbles?	Y N <u>NA</u>
5b	Sig* bubbles: Alk? Y N <u>NA</u> Sulfide? Y N <u>NA</u>	
6	Where did the bottles originate?	<u>ALS/ROC</u> CLIENT
7	Soil VOA received as: Bulk Encore 5035set	<u>NA</u>

8. Temperature Readings Date: 4/24/25 Time: 08:45 ID: IR#12 IR#11 From: Temp Blank Sample Bottle

Temp (°C)	<u>19.3</u>						
Within 0-6°C?	<u>Y</u> <u>N</u>	Y N	Y N	Y N	Y N	Y N	Y N
If <0°C, were samples frozen?	Y N	Y N	Y N	Y N	Y N	Y N	Y N

If out of Temperature, note packing/ice condition: _____ Ice melted Poorly Packed (described below) Same Day Rule
& Client Approval to Run Samples: _____ Standing Approval Client aware at drop-off Client notified by: _____

All samples held in storage location: SMD by JE on 4/24/25 at 08:150
5035 samples placed in storage location: _____ by _____ on _____ at _____ within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check**: Date: 4/24/25 Time: 12:44 by: JE

- 9. Were all bottle labels complete (i.e. analysis, preservation, etc.)? YES NO
- 10. Did all bottle labels and tags agree with custody papers? YES NO
- 11. Were correct containers used for the tests indicated? YES NO
- 12. Were 5035 vials acceptable (no extra labels, not leaking)? YES NO N/A
- 13. Were dissolved metals filtered in the field? YES NO N/A
- 14. Air Samples: Cassettes / Tubes Intact Y / N with MS Y / N Canisters Pressurized Tedlar® Bags Inflated N/A

pH	Lot of test paper	Reagent	Preserved?		Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
			Yes	No						
≥12		NaOH								
≤2	<u>226322</u>	HNO ₃		<u>X</u>	<u>None</u>		<u>All</u>	<u>4 ml each</u>	<u>239258</u>	<u>All 22</u>
≤2		H ₂ SO ₄								
<4		NaHSO ₄								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add Na ₂ S ₂ O ₃ (625, 608, CN), ascorbic (phenol).					
		Na ₂ S ₂ O ₃								
		ZnAcetate	-	-						
		HCl	**	**						

**VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers: 80419-65
Explain all Discrepancies/ Other Comments: _____

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: JE *significant air bubbles: VOA > 5-6 mm : WC > 1 in. diameter



Miscellaneous Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



REPORT QUALIFIERS AND DEFINITIONS

- U Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.
- J Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Aroclors).
- B Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.
- E Inorganics- Concentration is estimated due to the serial dilution was outside control limits.
- E Organics- Concentration has exceeded the calibration range for that specific analysis.
- D Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.
- * Indicates that a quality control parameter has exceeded laboratory limits. Under the "Notes" column of the Form I, this qualifier denotes analysis was performed out of Holding Time.
- H Analysis was performed out of hold time for tests that have an "immediate" hold time criteria.
- # Spike was diluted out.
- + Correlation coefficient for MSA is <0.995.
- N Inorganics- Matrix spike recovery was outside laboratory limits.
- N Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.
- S Concentration has been determined using Method of Standard Additions (MSA).
- W Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.
- P Concentration >40% difference between the two GC columns.
- C Confirmed by GC/MS
- Q DoD reports: indicates a pesticide/Aroclor is not confirmed ($\geq 100\%$ Difference between two GC columns).
- X See Case Narrative for discussion.
- MRL Method Reporting Limit. Also known as:
- LOQ Limit of Quantitation (LOQ)
The lowest concentration at which the method analyte may be reliably quantified under the method conditions.
- MDL Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).
- LOD Limit of Detection. A value at or above the MDL which has been verified to be detectable.
- ND Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.

Rochester Lab ID # for State Accreditations¹



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

¹ Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

ALS Laboratory Group

Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Rush-Henrietta Central School District
Project: Fyle Elementary/

Service Request: R2504407

Sample Name: Fyle-1 C-10 - Drinking Fountain Girl's
Lab Code: R2504407-001
Sample Matrix: Drinking Water

Date Collected: 04/24/25
Date Received: 04/24/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: Fyle-2 C-10 - Drinking Fountain Boy's
Lab Code: R2504407-002
Sample Matrix: Drinking Water

Date Collected: 04/24/25
Date Received: 04/24/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: Fyle-3 Adj. to C-10 - Drinking Fountain
Lab Code: R2504407-003
Sample Matrix: Drinking Water

Date Collected: 04/24/25
Date Received: 04/24/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: Fyle-4 A-11-Health Office Main Sink
Lab Code: R2504407-004
Sample Matrix: Drinking Water

Date Collected: 04/24/25
Date Received: 04/24/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: Fyle-5 A-11-Health Office Exam Room
Lab Code: R2504407-005
Sample Matrix: Drinking Water

Date Collected: 04/24/25
Date Received: 04/24/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Rush-Henrietta Central School District
Project: Fyle Elementary/

Service Request: R2504407

Sample Name: Fyle-6 Opposite Main Office - Drinking
Lab Code: R2504407-006
Sample Matrix: Drinking Water

Date Collected: 04/24/25
Date Received: 04/24/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: Fyle-7 Kitchen - Kitchen Island Sink
Lab Code: R2504407-007
Sample Matrix: Drinking Water

Date Collected: 04/24/25
Date Received: 04/24/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: Fyle-8 Kitchen - Braising Pan Faucet
Lab Code: R2504407-008
Sample Matrix: Drinking Water

Date Collected: 04/24/25
Date Received: 04/24/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: Fyle-9 Kitchen - Kitchen Island Sink
Lab Code: R2504407-009
Sample Matrix: Drinking Water

Date Collected: 04/24/25
Date Received: 04/24/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: Fyle-10 Kitchen - Braising Pan Faucet
Lab Code: R2504407-010
Sample Matrix: Drinking Water

Date Collected: 04/24/25
Date Received: 04/24/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Rush-Henrietta Central School District
Project: Fyle Elementary/

Service Request: R2504407

Sample Name: Fyle-11 Cafetorium - Drinking Fountain
Lab Code: R2504407-011
Sample Matrix: Drinking Water

Date Collected: 04/24/25
Date Received: 04/24/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: Fyle-12 Faculty Lounge - Faculty Break
Lab Code: R2504407-012
Sample Matrix: Drinking Water

Date Collected: 04/24/25
Date Received: 04/24/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: Fyle-13 Faculty Lounge - Faculty Break
Lab Code: R2504407-013
Sample Matrix: Drinking Water

Date Collected: 04/24/25
Date Received: 04/24/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: Fyle-15 Adj. to B-8 - Drinking Fountain
Lab Code: R2504407-014
Sample Matrix: Drinking Water

Date Collected: 04/24/25
Date Received: 04/24/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN



PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

INORGANIC

Water/Liquid Matrix

Analytical Method	Preparation Method
200.7	200.2
200.8	200.2
6010C or 6010D	3005A/3010A
6020A or 6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010C or 6010D	3050B
6020A or 6020B	3050B
6010C or 6010D TCLP (1311) extract	3005A/3010A
6010C or 6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

ORGANIC

Preparation Methods for Organic methods are listed in the header of the Results pages.

Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



Sample Results

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Rush-Henrietta Central School District
Project: Fyle Elementary
Sample Matrix: Drinking Water
Sample Name: Fyle-1 C-10 - Drinking Fountain Girl's Gym
Lab Code: R2504407-001

Service Request: R2504407
Date Collected: 04/24/25 06:02
Date Received: 04/24/25 08:38
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	04/28/25 17:33	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Rush-Henrietta Central School District
Project: Fyle Elementary
Sample Matrix: Drinking Water
Sample Name: Fyle-2 C-10 - Drinking Fountain Boy's Gym
Lab Code: R2504407-002

Service Request: R2504407
Date Collected: 04/24/25 06:00
Date Received: 04/24/25 08:38
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.8	ug/L	1.0	1	04/28/25 17:35	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Rush-Henrietta Central School District
Project: Fyle Elementary
Sample Matrix: Drinking Water
Sample Name: Fyle-3 Adj. to C-10 - Drinking Fountain
Lab Code: R2504407-003

Service Request: R2504407
Date Collected: 04/24/25 05:56
Date Received: 04/24/25 08:38
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	20.6	ug/L	1.0	1	04/28/25 17:37	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Rush-Henrietta Central School District
Project: Fyle Elementary
Sample Matrix: Drinking Water
Sample Name: Fyle-4 A-11-Health Office Main Sink Faucet
Lab Code: R2504407-004

Service Request: R2504407
Date Collected: 04/24/25 05:40
Date Received: 04/24/25 08:38
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	04/28/25 17:39	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Rush-Henrietta Central School District
Project: Fyle Elementary
Sample Matrix: Drinking Water
Sample Name: Fyle-5 A-11-Health Office Exam Room Sink
Lab Code: R2504407-005

Service Request: R2504407
Date Collected: 04/24/25 05:42
Date Received: 04/24/25 08:38
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	04/28/25 17:41	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Rush-Henrietta Central School District
Project: Fyle Elementary
Sample Matrix: Drinking Water

Service Request: R2504407
Date Collected: 04/24/25 05:46
Date Received: 04/24/25 08:38

Sample Name: Fyle-6 Opposite Main Office - Drinking Fountain
Lab Code: R2504407-006

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.6	ug/L	1.0	1	04/28/25 17:42	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Rush-Henrietta Central School District
Project: Fyle Elementary
Sample Matrix: Drinking Water
Sample Name: Fyle-7 Kitchen - Kitchen Island Sink Faucet
Lab Code: R2504407-007

Service Request: R2504407
Date Collected: 04/24/25 04:10
Date Received: 04/24/25 08:38
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.7	ug/L	1.0	1	04/28/25 17:44	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Rush-Henrietta Central School District
Project: Fyle Elementary
Sample Matrix: Drinking Water
Sample Name: Fyle-8 Kitchen - Braising Pan Faucet
Lab Code: R2504407-008

Service Request: R2504407
Date Collected: 04/24/25 04:10
Date Received: 04/24/25 08:38
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	10.2	ug/L	1.0	1	04/28/25 17:46	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Rush-Henrietta Central School District
Project: Fyle Elementary
Sample Matrix: Drinking Water

Service Request: R2504407
Date Collected: 04/24/25 04:16
Date Received: 04/24/25 08:38

Sample Name: Fyle-9 Kitchen - Kitchen Island Sink Faucet (5Min Flush)
Lab Code: R2504407-009

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0	ug/L	1.0	1	04/28/25 17:48	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Rush-Henrietta Central School District
Project: Fyle Elementary
Sample Matrix: Drinking Water
Sample Name: Fyle-10 Kitchen - Braising Pan Faucet (5Min Flush)
Lab Code: R2504407-010

Service Request: R2504407
Date Collected: 04/24/25 04:16
Date Received: 04/24/25 08:38
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.1	ug/L	1.0	1	04/28/25 17:53	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Rush-Henrietta Central School District
Project: Fyle Elementary
Sample Matrix: Drinking Water

Service Request: R2504407
Date Collected: 04/24/25 05:50
Date Received: 04/24/25 08:38

Sample Name: Fyle-11 Cafetorium - Drinking Fountain
Lab Code: R2504407-011

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.4	ug/L	1.0	1	04/28/25 17:55	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Rush-Henrietta Central School District
Project: Fyle Elementary
Sample Matrix: Drinking Water

Service Request: R2504407
Date Collected: 04/24/25 05:25
Date Received: 04/24/25 08:38

Sample Name: Fyle-12 Faculty Lounge - Faculty Break Room Sink Faucet
Lab Code: R2504407-012

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	4.2	ug/L	1.0	1	04/28/25 17:57	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Rush-Henrietta Central School District
Project: Fyle Elementary
Sample Matrix: Drinking Water
Sample Name: Fyle-13 Faculty Lounge - Faculty Break Room Instant Hot Water
Lab Code: R2504407-013

Service Request: R2504407
Date Collected: 04/24/25 05:58
Date Received: 04/24/25 08:38
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	8.9	ug/L	1.0	1	04/28/25 17:59	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Rush-Henrietta Central School District
Project: Fyle Elementary
Sample Matrix: Drinking Water
Sample Name: Fyle-15 Adj. to B-8 - Drinking Fountain
Lab Code: R2504407-014

Service Request: R2504407
Date Collected: 04/24/25 05:48
Date Received: 04/24/25 08:38
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	04/28/25 18:12	



QC Summary Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Rush-Henrietta Central School District
Project: Fyle Elementary
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2504407-MB1

Service Request: R2504407
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	04/28/25 17:09	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Rush-Henrietta Central School District
Project: Fyle Elementary
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2504407-MB2

Service Request: R2504407
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	04/28/25 18:08	

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Rush-Henrietta Central School District
Project: Fyle Elementary
Sample Matrix: Drinking Water

Service Request: R2504407
Date Collected: 04/24/25
Date Received: 04/24/25
Date Analyzed: 04/28/25

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name: Fyle-13 Faculty Lounge - Faculty Break Room
Instant Hot Water
Units: ug/L
Lab Code: R2504407-013
Basis: NA
Analysis Method: 200.8

Analyte Name	Sample Result	Result	Matrix Spike R2504407-013MS		Duplicate Matrix Spike R2504407-013DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	8.9	28.2	20.0	97	28.0	20.0	96	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Rush-Henrietta Central School District
Project: Fyle Elementary
Sample Matrix: Drinking Water

Service Request: R2504407
Date Analyzed: 04/28/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2504407-LCS1

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	19.7	20.0	99	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Rush-Henrietta Central School District
Project: Fyle Elementary
Sample Matrix: Drinking Water

Service Request: R2504407
Date Analyzed: 04/28/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2504407-LCS2

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	19.9	20.0	100	85-115