



April 30, 2025

Service Request No:R2504405

Mr. Ken Nelson  
Rush-Henrietta Central School District  
2034 Lehigh Station Road  
Henrietta, NY 14467

**Laboratory Results for: Leary Elementary**

Dear Mr.Nelson,

Enclosed are the results of the sample(s) submitted to our laboratory April 24, 2025  
For your reference, these analyses have been assigned our service request number **R2504405**.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7476. You may also contact me via email at [Chris.Leavy@alsglobal.com](mailto:Chris.Leavy@alsglobal.com).

Respectfully submitted,

**ALS Group USA, Corp. dba ALS Environmental**

Christopher Leavy  
Project Manager

ADDRESS 1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
PHONE +1 585 288 5380 | FAX +1 585 288 8475  
ALS Group USA, Corp.  
dba ALS Environmental



# Narrative Documents

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)



**Client:** Rush-Henrietta Central School District  
**Project:** Leary Elementary  
**Sample Matrix:** Drinking Water

**Service Request:** R2504405  
**Date Received:** 04/24/2025

**CASE NARRATIVE**

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

**Sample Receipt:**

Fifteen drinking water samples were received for analysis at ALS Environmental on 04/24/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

**Metals:**

No significant anomalies were noted with this analysis.

A handwritten signature in black ink, appearing to be 'WZ', is written over a horizontal line.

Approved by \_\_\_\_\_

Date 04/30/2025



### SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: Leary-1 60-Kitchen Island Sink Faucet		Lab ID: R2504405-001				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	3.7			1.0	ug/L	200.8
CLIENT ID: Leary-2 60-Braising Pan Faucet		Lab ID: R2504405-002				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	13.7			1.0	ug/L	200.8
CLIENT ID: Leary-3 60-Kitchen Island Sink Faucet (5Min Flush)		Lab ID: R2504405-003				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.3			1.0	ug/L	200.8
CLIENT ID: Leary-4 60-Braising Pan Faucet (5Min Flush)		Lab ID: R2504405-004				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	4.1			1.0	ug/L	200.8
CLIENT ID: Leary-5 Cafeteria - Drinking Fountain		Lab ID: R2504405-005				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	48.1			1.0	ug/L	200.8
CLIENT ID: Leary-8 30-Faculty Break Room Sink Faucet		Lab ID: R2504405-008				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	4.2			1.0	ug/L	200.8
CLIENT ID: Leary-9 30-Faculty Break Room Instant Hot Water		Lab ID: R2504405-009				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	3.9			1.0	ug/L	200.8
CLIENT ID: Leary-10 27-Health Office Sink Faucet Hallway Wall		Lab ID: R2504405-010				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	6.7			1.0	ug/L	200.8
CLIENT ID: Leary-11 27-Health Office Porcelain Wall Sink Faucet		Lab ID: R2504405-011				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	6.3			1.0	ug/L	200.8
CLIENT ID: Leary-12 Adj. to Main Office - Drinking Fountain		Lab ID: R2504405-012				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.6			1.0	ug/L	200.8
CLIENT ID: Leary-14 Adj. to Room 67 - Drinking Fountain		Lab ID: R2504405-014				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.1			1.0	ug/L	200.8



## Sample Receipt Information

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)

**Client:** Rush-Henrietta Central School District  
**Project:** Leary Elementary

**Service Request:**R2504405

**SAMPLE CROSS-REFERENCE**

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2504405-001	Leary-1 60-Kitchen Island Sink Faucet	4/24/2025	0450
R2504405-002	Leary-2 60-Braising Pan Faucet	4/24/2025	0450
R2504405-003	Leary-3 60-Kitchen Island Sink Faucet (5Min Flush)	4/24/2025	0455
R2504405-004	Leary-4 60-Braising Pan Faucet (5Min Flush)	4/24/2025	0456
R2504405-005	Leary-5 Cafeteria - Drinking Fountain	4/24/2025	0500
R2504405-006	Leary-6 43-Drinking Fountain Girl's Gym	4/24/2025	0517
R2504405-007	Leary-7 43-Drinking Fountain Boy's Gym	4/24/2025	0519
R2504405-008	Leary-8 30-Faculty Break Room Sink Faucet	4/24/2025	0522
R2504405-009	Leary-9 30-Faculty Break Room Instant Hot Water	4/24/2025	0524
R2504405-010	Leary-10 27-Health Office Sink Faucet Hallway Wall	4/24/2025	0505
R2504405-011	Leary-11 27-Health Office Porcelain Wall Sink Faucet	4/24/2025	0504
R2504405-012	Leary-12 Adj. to Main Office - Drinking Fountain	4/24/2025	0508
R2504405-013	Leary-13 Adj. to Room 40 - Drinking Fountain	4/24/2025	0515
R2504405-014	Leary-14 Adj. to Room 67 - Drinking Fountain	4/24/2025	0511
R2504405-015	Leary-15 Adj. to Room 50 - Drinking Fountain	4/24/2025	0528





Chain of Custody / Analytical Request Form

1565 Jefferson Road, Building 300, Suite 360 • Rochester, NY 14623 • +1 585 288 5380 • alsglobal.com

SR#:
Page of

Report To: ALL SHADED AREAS MUST BE COMPLETED BY THE CLIENT / SAMPLER
Company: Rush-Henrietta CSD
Project Name: Leary Elementary
Contact: Ken Nelson
Project Number:
Email: knelson@rhnet.org
ALS Quote #: 38456
Phone: 585-738-8070
Sampler's Signature:
Address: 2034 Lehigh Station Road
Henrietta NY 14467
Email CC: slacey@rhnet.org
jlschultz@rhnet.org
State Samples Collected NY

Table with columns: Lab ID (ALS), Sample Collection Information (Sample ID, Date, Time), Matrix, Number of Containers, MS/MSD?, 200.8 Lead, and Notes. Rows 11-15 contain data for drinking fountains.

Special Instructions / Comments:
Turnaround Requirements: Rush (Surcharges Apply), Subject to Availability, Please Check with your PM, Standard (10 Business Days)
Report Requirements: Tier II/Cat A - Results/QC, Tier IV/Cat B - Data Validation Report w/. Data
Metals: RCRA 8•PP 13•TAL 23•TCLP•Other (Ust)
VOA/SVOA Report List: TCL • BTEX • TCLP • CP-51/Stars • THM • Other:
Invoice To: ( Same as Report To)
PO #: 7225-01793
Company: Rush-Henrietta CSD

Signature and Date/Time table with columns: Relinquished By, Received By, Relinquished By, Received By, Relinquished By, Received By. Includes signatures of James Schultz and Abbie Austin.



R2504405 5

Rush-Henrietta Central School District  
Leary Elementary



### Cooler Receipt and Preservation C

Project/Client Rush-Henrietta CSD Folder Number \_\_\_\_\_

Cooler received on 4/24/25 by: JE COURIER: ALS UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	Y <u>(N)</u>	5a	Did VOA vials have sig* bubbles?	Y N <u>(NA)</u>
2	Custody papers properly completed (ink, signed)?	<u>(Y)</u> N	5b	Sig* bubbles: Alk? Y N <u>(NA)</u> Sulfide? Y N <u>(NA)</u>	
3	Did all bottles arrive in good condition (unbroken)?	Y N	6	Where did the bottles originate?	<u>ALS/ROC</u> CLIENT
4	Circle: Wet Ice Dry Ice Gel packs present?	Y <u>(N)</u>	7	Soil VOA received as: Bulk Encore 5035set	<u>(NA)</u>

8. Temperature Readings Date: 4/24/25 Time: 08:45 ID: IR#12 (IR#11) From: Temp Blank (Sample Bottle)

Temp (°C)	<u>19.3</u>						
Within 0-6°C?	Y <u>(N)</u>	Y N	Y N	Y N	Y N	Y N	Y N
If <0°C, were samples frozen?	Y N	Y N	Y N	Y N	Y N	Y N	Y N

If out of Temperature, note packing/ice condition: \_\_\_\_\_ Ice melted Poorly Packed (described below) Same Day Rule  
& Client Approval to Run Samples: \_\_\_\_\_ Standing Approval Client aware at drop-off Client notified by: \_\_\_\_\_

All samples held in storage location: SMD by JE on 4/24/25 at 08:50  
5035 samples placed in storage location: \_\_\_\_\_ by \_\_\_\_\_ on \_\_\_\_\_ at \_\_\_\_\_ within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check\*\*: Date: 4/24/25 Time: 10:27 by: JE

- 9. Were all bottle labels complete (i.e. analysis/preservation, etc.)? YES (NO)
- 10. Did all bottle labels and tags agree with custody papers? YES (NO)
- 11. Were correct containers used for the tests indicated? YES (NO)
- 12. Were 5035 vials acceptable (no extra labels, not leaking)? YES NO (N/A)
- 13. Were dissolved metals filtered in the field? YES NO (N/A)
- 14. Air Samples: Cassettes / Tubes Intact Y/N with MS Y/N Canisters Pressurized Tedlar® Bags Inflated (N/A)

pH	Lot of test paper	Reagent	Preserved?		Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
			Yes	No						
≥12		NaOH								
≤2	<u>226322</u>	HNO <sub>3</sub>		<u>X</u>	<u>None</u>		<u>All</u>	<u>4ml each</u>	<u>239258</u>	<u>All 2</u>
≤2		H <sub>2</sub> SO <sub>4</sub>								
<4		NaHSO <sub>4</sub>								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> (625, 608, CN), ascorbic (phenol).					
		Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub>								
		ZnAcetate	-	-						
		HCl	**	**						

\*\*VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers: 86419-05  
Explain all Discrepancies/ Other Comments: \_\_\_\_\_

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: JE \*significant air bubbles: VOA > 5-6 mm : WC > 1 in. diameter



## Miscellaneous Forms

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)



## REPORT QUALIFIERS AND DEFINITIONS

- U Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.
- J Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Aroclors).
- B Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.
- E Inorganics- Concentration is estimated due to the serial dilution was outside control limits.
- E Organics- Concentration has exceeded the calibration range for that specific analysis.
- D Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.
- \* Indicates that a quality control parameter has exceeded laboratory limits. Under the "Notes" column of the Form I, this qualifier denotes analysis was performed out of Holding Time.
- H Analysis was performed out of hold time for tests that have an "immediate" hold time criteria.
- # Spike was diluted out.
- + Correlation coefficient for MSA is <0.995.
- N Inorganics- Matrix spike recovery was outside laboratory limits.
- N Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.
- S Concentration has been determined using Method of Standard Additions (MSA).
- W Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.
- P Concentration >40% difference between the two GC columns.
- C Confirmed by GC/MS
- Q DoD reports: indicates a pesticide/Aroclor is not confirmed ( $\geq 100\%$  Difference between two GC columns).
- X See Case Narrative for discussion.
- MRL Method Reporting Limit. Also known as:
- LOQ Limit of Quantitation (LOQ)  
The lowest concentration at which the method analyte may be reliably quantified under the method conditions.
- MDL Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).
- LOD Limit of Detection. A value at or above the MDL which has been verified to be detectable.
- ND Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.

### Rochester Lab ID # for State Accreditations<sup>1</sup>



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

<sup>1</sup> Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

# ALS Laboratory Group

---

## Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Rush-Henrietta Central School District  
**Project:** Leary Elementary/

**Service Request:** R2504405

**Sample Name:** Leary-1 60-Kitchen Island Sink Faucet  
**Lab Code:** R2504405-001  
**Sample Matrix:** Drinking Water

**Date Collected:** 04/24/25  
**Date Received:** 04/24/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** Leary-2 60-Braising Pan Faucet  
**Lab Code:** R2504405-002  
**Sample Matrix:** Drinking Water

**Date Collected:** 04/24/25  
**Date Received:** 04/24/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** Leary-3 60-Kitchen Island Sink Faucet  
**Lab Code:** R2504405-003  
**Sample Matrix:** Drinking Water

**Date Collected:** 04/24/25  
**Date Received:** 04/24/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** Leary-4 60-Braising Pan Faucet (5Min  
**Lab Code:** R2504405-004  
**Sample Matrix:** Drinking Water

**Date Collected:** 04/24/25  
**Date Received:** 04/24/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** Leary-5 Cafeteria - Drinking Fountain  
**Lab Code:** R2504405-005  
**Sample Matrix:** Drinking Water

**Date Collected:** 04/24/25  
**Date Received:** 04/24/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Rush-Henrietta Central School District  
**Project:** Leary Elementary/

**Service Request:** R2504405

**Sample Name:** Leary-6 43-Drinking Fountain Girl's Gym  
**Lab Code:** R2504405-006  
**Sample Matrix:** Drinking Water

**Date Collected:** 04/24/25  
**Date Received:** 04/24/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** Leary-7 43-Drinking Fountain Boy's Gym  
**Lab Code:** R2504405-007  
**Sample Matrix:** Drinking Water

**Date Collected:** 04/24/25  
**Date Received:** 04/24/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** Leary-8 30-Faculty Break Room Sink  
**Lab Code:** R2504405-008  
**Sample Matrix:** Drinking Water

**Date Collected:** 04/24/25  
**Date Received:** 04/24/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** Leary-9 30-Faculty Break Room Instant  
**Lab Code:** R2504405-009  
**Sample Matrix:** Drinking Water

**Date Collected:** 04/24/25  
**Date Received:** 04/24/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** Leary-10 27-Health Office Sink Faucet  
**Lab Code:** R2504405-010  
**Sample Matrix:** Drinking Water

**Date Collected:** 04/24/25  
**Date Received:** 04/24/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Rush-Henrietta Central School District  
**Project:** Leary Elementary/

**Service Request:** R2504405

**Sample Name:** Leary-11 27-Health Office Porcelain Wall  
**Lab Code:** R2504405-011  
**Sample Matrix:** Drinking Water

**Date Collected:** 04/24/25  
**Date Received:** 04/24/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** Leary-12 Adj. to Main Office - Drinking  
**Lab Code:** R2504405-012  
**Sample Matrix:** Drinking Water

**Date Collected:** 04/24/25  
**Date Received:** 04/24/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** Leary-13 Adj. to Room 40 - Drinking  
**Lab Code:** R2504405-013  
**Sample Matrix:** Drinking Water

**Date Collected:** 04/24/25  
**Date Received:** 04/24/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** Leary-14 Adj. to Room 67 - Drinking  
**Lab Code:** R2504405-014  
**Sample Matrix:** Drinking Water

**Date Collected:** 04/24/25  
**Date Received:** 04/24/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** Leary-15 Adj. to Room 50 - Drinking  
**Lab Code:** R2504405-015  
**Sample Matrix:** Drinking Water

**Date Collected:** 04/24/25  
**Date Received:** 04/24/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN



## PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

### INORGANIC

#### Water/Liquid Matrix

Analytical Method	Preparation Method
200.7	200.2
200.8	200.2
6010C or 6010D	3005A/3010A
6020A or 6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

#### Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010C or 6010D	3050B
6020A or 6020B	3050B
6010C or 6010D TCLP (1311) extract	3005A/3010A
6010C or 6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

### ORGANIC

**Preparation Methods for Organic methods are listed in the header of the Results pages.**

#### Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



# Sample Results

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)



# Metals

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Rush-Henrietta Central School District  
**Project:** Leary Elementary  
**Sample Matrix:** Drinking Water  
**Sample Name:** Leary-1 60-Kitchen Island Sink Faucet  
**Lab Code:** R2504405-001

**Service Request:** R2504405  
**Date Collected:** 04/24/25 04:50  
**Date Received:** 04/24/25 08:38  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.7	ug/L	1.0	1	04/28/25 15:42	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Rush-Henrietta Central School District  
**Project:** Leary Elementary  
**Sample Matrix:** Drinking Water  
**Sample Name:** Leary-2 60-Braising Pan Faucet  
**Lab Code:** R2504405-002

**Service Request:** R2504405  
**Date Collected:** 04/24/25 04:50  
**Date Received:** 04/24/25 08:38  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	13.7	ug/L	1.0	1	04/28/25 15:44	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Rush-Henrietta Central School District  
**Project:** Leary Elementary  
**Sample Matrix:** Drinking Water  
**Sample Name:** Leary-3 60-Kitchen Island Sink Faucet (5Min Flush)  
**Lab Code:** R2504405-003

**Service Request:** R2504405  
**Date Collected:** 04/24/25 04:55  
**Date Received:** 04/24/25 08:38  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.3	ug/L	1.0	1	04/28/25 15:46	

**ALS Group USA, Corp.**  
dba ALS Environmental

Analytical Report

**Client:** Rush-Henrietta Central School District  
**Project:** Leary Elementary  
**Sample Matrix:** Drinking Water  
**Sample Name:** Leary-4 60-Braising Pan Faucet (5Min Flush)  
**Lab Code:** R2504405-004

**Service Request:** R2504405  
**Date Collected:** 04/24/25 04:56  
**Date Received:** 04/24/25 08:38

**Basis:** NA

**Inorganic Parameters**

<b>Analyte Name</b>	<b>Analysis Method</b>	<b>Result</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Date Analyzed</b>	<b>Q</b>
Lead, Total	200.8	<b>4.1</b>	ug/L	1.0	1	04/28/25 15:48	

**ALS Group USA, Corp.**  
dba ALS Environmental

Analytical Report

**Client:** Rush-Henrietta Central School District  
**Project:** Leary Elementary  
**Sample Matrix:** Drinking Water  
**Sample Name:** Leary-5 Cafeteria - Drinking Fountain  
**Lab Code:** R2504405-005

**Service Request:** R2504405  
**Date Collected:** 04/24/25 05:00  
**Date Received:** 04/24/25 08:38  
**Basis:** NA

**Inorganic Parameters**

<b>Analyte Name</b>	<b>Analysis Method</b>	<b>Result</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Date Analyzed</b>	<b>Q</b>
Lead, Total	200.8	<b>48.1</b>	ug/L	1.0	1	04/28/25 15:49	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Rush-Henrietta Central School District  
**Project:** Leary Elementary  
**Sample Matrix:** Drinking Water  
**Sample Name:** Leary-6 43-Drinking Fountain Girl's Gym  
**Lab Code:** R2504405-006

**Service Request:** R2504405  
**Date Collected:** 04/24/25 05:17  
**Date Received:** 04/24/25 08:38  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	04/28/25 15:55	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Rush-Henrietta Central School District  
**Project:** Leary Elementary  
**Sample Matrix:** Drinking Water  
**Sample Name:** Leary-7 43-Drinking Fountain Boy's Gym  
**Lab Code:** R2504405-007

**Service Request:** R2504405  
**Date Collected:** 04/24/25 05:19  
**Date Received:** 04/24/25 08:38  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	04/28/25 15:57	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Rush-Henrietta Central School District  
**Project:** Leary Elementary  
**Sample Matrix:** Drinking Water  
**Sample Name:** Leary-8 30-Faculty Break Room Sink Faucet  
**Lab Code:** R2504405-008

**Service Request:** R2504405  
**Date Collected:** 04/24/25 05:22  
**Date Received:** 04/24/25 08:38

**Basis:** NA

**Inorganic Parameters**

<b>Analyte Name</b>	<b>Analysis Method</b>	<b>Result</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Date Analyzed</b>	<b>Q</b>
Lead, Total	200.8	4.2	ug/L	1.0	1	04/28/25 15:59	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Rush-Henrietta Central School District  
**Project:** Leary Elementary  
**Sample Matrix:** Drinking Water  
**Sample Name:** Leary-9 30-Faculty Break Room Instant Hot Water Dispenser  
**Lab Code:** R2504405-009

**Service Request:** R2504405  
**Date Collected:** 04/24/25 05:24  
**Date Received:** 04/24/25 08:38  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.9	ug/L	1.0	1	04/28/25 16:01	

**ALS Group USA, Corp.**  
dba ALS Environmental

Analytical Report

**Client:** Rush-Henrietta Central School District  
**Project:** Leary Elementary  
**Sample Matrix:** Drinking Water

**Service Request:** R2504405  
**Date Collected:** 04/24/25 05:05  
**Date Received:** 04/24/25 08:38

**Sample Name:** Leary-10 27-Health Office Sink Faucet Hallway Wall  
**Lab Code:** R2504405-010

**Basis:** NA

**Inorganic Parameters**

<b>Analyte Name</b>	<b>Analysis Method</b>	<b>Result</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Date Analyzed</b>	<b>Q</b>
Lead, Total	200.8	6.7	ug/L	1.0	1	04/28/25 16:14	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Rush-Henrietta Central School District  
**Project:** Leary Elementary  
**Sample Matrix:** Drinking Water

**Service Request:** R2504405  
**Date Collected:** 04/24/25 05:04  
**Date Received:** 04/24/25 08:38

**Sample Name:** Leary-11 27-Health Office Porcelain Wall Sink Faucet  
**Lab Code:** R2504405-011

**Basis:** NA

**Inorganic Parameters**

<b>Analyte Name</b>	<b>Analysis Method</b>	<b>Result</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Date Analyzed</b>	<b>Q</b>
Lead, Total	200.8	<b>6.3</b>	ug/L	1.0	1	04/28/25 16:19	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Rush-Henrietta Central School District  
**Project:** Leary Elementary  
**Sample Matrix:** Drinking Water

**Service Request:** R2504405  
**Date Collected:** 04/24/25 05:08  
**Date Received:** 04/24/25 08:38

**Sample Name:** Leary-12 Adj. to Main Office - Drinking Fountain  
**Lab Code:** R2504405-012

**Basis:** NA

**Inorganic Parameters**

<b>Analyte Name</b>	<b>Analysis Method</b>	<b>Result</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Date Analyzed</b>	<b>Q</b>
Lead, Total	200.8	1.6	ug/L	1.0	1	04/28/25 16:21	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Rush-Henrietta Central School District  
**Project:** Leary Elementary  
**Sample Matrix:** Drinking Water

**Service Request:** R2504405  
**Date Collected:** 04/24/25 05:15  
**Date Received:** 04/24/25 08:38

**Sample Name:** Leary-13 Adj. to Room 40 - Drinking Fountain  
**Lab Code:** R2504405-013

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	04/28/25 16:23	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Rush-Henrietta Central School District  
**Project:** Leary Elementary  
**Sample Matrix:** Drinking Water  
**Sample Name:** Leary-14 Adj. to Room 67 - Drinking Fountain  
**Lab Code:** R2504405-014

**Service Request:** R2504405  
**Date Collected:** 04/24/25 05:11  
**Date Received:** 04/24/25 08:38  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.1	ug/L	1.0	1	04/28/25 16:25	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Rush-Henrietta Central School District  
**Project:** Leary Elementary  
**Sample Matrix:** Drinking Water

**Service Request:** R2504405  
**Date Collected:** 04/24/25 05:28  
**Date Received:** 04/24/25 08:38

**Sample Name:** Leary-15 Adj. to Room 50 - Drinking Fountain  
**Lab Code:** R2504405-015

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	04/28/25 16:27	



# QC Summary Forms

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)



# Metals

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Rush-Henrietta Central School District  
**Project:** Leary Elementary  
**Sample Matrix:** Drinking Water  
**Sample Name:** Method Blank  
**Lab Code:** R2504405-MB1

**Service Request:** R2504405  
**Date Collected:** NA  
**Date Received:** NA  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	04/28/25 15:11	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Rush-Henrietta Central School District  
**Project:** Leary Elementary  
**Sample Matrix:** Drinking Water  
**Sample Name:** Method Blank  
**Lab Code:** R2504405-MB2

**Service Request:** R2504405  
**Date Collected:** NA  
**Date Received:** NA  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	04/28/25 16:10	

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Rush-Henrietta Central School District  
**Project:** Leary Elementary  
**Sample Matrix:** Drinking Water

**Service Request:** R2504405  
**Date Collected:** 04/24/25  
**Date Received:** 04/24/25  
**Date Analyzed:** 04/28/25

**Duplicate Matrix Spike Summary**  
**Inorganic Parameters**

**Sample Name:** Leary-9 30-Faculty Break Room Instant Hot Water Dispenser  
**Lab Code:** R2504405-009  
**Analysis Method:** 200.8

**Units:** ug/L  
**Basis:** NA

Analyte Name	Sample Result	Result	Matrix Spike R2504405-009MS		Duplicate Matrix Spike R2504405-009DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	3.9	23.5	20.0	98	23.3	20.0	97	70-130	<1	20

Results flagged with an asterisk (\*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Rush-Henrietta Central School District  
**Project:** Leary Elementary  
**Sample Matrix:** Drinking Water

**Service Request:** R2504405  
**Date Collected:** 04/24/25  
**Date Received:** 04/24/25  
**Date Analyzed:** 04/28/25

**Duplicate Matrix Spike Summary**  
**Inorganic Parameters**

**Sample Name:** Leary-10 27-Health Office Sink Faucet Hallway Wall  
**Lab Code:** R2504405-010  
**Analysis Method:** 200.8  
**Units:** ug/L  
**Basis:** NA

Analyte Name	Sample Result	Result	Matrix Spike R2504405-010MS		Duplicate Matrix Spike R2504405-010DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	6.7	25.5	20.0	94	26.0	20.0	97	70-130	2	20

Results flagged with an asterisk (\*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Rush-Henrietta Central School District  
**Project:** Leary Elementary  
**Sample Matrix:** Drinking Water

**Service Request:** R2504405  
**Date Analyzed:** 04/28/25

**Lab Control Sample Summary**  
**Inorganic Parameters**

**Units:**ug/L  
**Basis:**NA

**Lab Control Sample**  
R2504405-LCS1

<b>Analyte Name</b>	<b>Analytical Method</b>	<b>Result</b>	<b>Spike Amount</b>	<b>% Rec</b>	<b>% Rec Limits</b>
Lead, Total	200.8	20.2	20.0	101	85-115

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Rush-Henrietta Central School District  
**Project:** Leary Elementary  
**Sample Matrix:** Drinking Water

**Service Request:** R2504405  
**Date Analyzed:** 04/28/25

**Lab Control Sample Summary**  
**Inorganic Parameters**

**Units:**ug/L  
**Basis:**NA

**Lab Control Sample**  
R2504405-LCS2

<b>Analyte Name</b>	<b>Analytical Method</b>	<b>Result</b>	<b>Spike Amount</b>	<b>% Rec</b>	<b>% Rec Limits</b>
Lead, Total	200.8	19.2	20.0	96	85-115