



May 05, 2025

Service Request No:R2504526

Mr. Ken Nelson  
Rush-Henrietta Central School District  
2034 Lehigh Station Road  
Henrietta, NY 14467

**Laboratory Results for: TOC**

Dear Mr.Nelson,

Enclosed are the results of the sample(s) submitted to our laboratory April 29, 2025  
For your reference, these analyses have been assigned our service request number **R2504526**.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7476. You may also contact me via email at [Chris.Leavy@alsglobal.com](mailto:Chris.Leavy@alsglobal.com).

Respectfully submitted,

**ALS Group USA, Corp. dba ALS Environmental**

Christopher Leavy  
Project Manager

ADDRESS 1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
PHONE +1 585 288 5380 | FAX +1 585 288 8475  
ALS Group USA, Corp.  
dba ALS Environmental



# Narrative Documents

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)



**Client:** Rush-Henrietta Central School District  
**Project:** TOC  
**Sample Matrix:** Drinking Water

**Service Request:** R2504526  
**Date Received:** 04/29/2025

**CASE NARRATIVE**

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

**Sample Receipt:**

Sixteen drinking water samples were received for analysis at ALS Environmental on 04/29/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

**Metals:**

No significant anomalies were noted with this analysis.

A handwritten signature in black ink, appearing to be "WZ", is written over a horizontal line.

Approved by \_\_\_\_\_

Date 05/05/2025



### SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

<b>CLIENT ID: TOC-3 Rm. 42-Conference Room A Sink Faucet</b>	<b>Lab ID: R2504526-003</b>
--	-----------------------------

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.8			1.0	ug/L	200.8

<b>CLIENT ID: TOC-8 Rm. 13-Bus Mechanics Break Room Sink</b>	<b>Lab ID: R2504526-008</b>
--	-----------------------------

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.4			1.0	ug/L	200.8



## Sample Receipt Information

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)

**Client:** Rush-Henrietta Central School District  
**Project:** TOC

**Service Request:**R2504526

**SAMPLE CROSS-REFERENCE**

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2504526-001	TOC-1 Rm. 39-Drinking Fountain Left	4/29/2025	0440
R2504526-002	TOC-2 Rm. 39-Drinking Fountain Right	4/29/2025	0441
R2504526-003	TOC-3 Rm. 42-Conference Room A Sink Faucet WEST	4/29/2025	0457
R2504526-004	TOC-4 Rm. 49-Prep Room Sink Faucet	4/29/2025	0455
R2504526-005	TOC-5 Rm. 57-Bus Driver's Break Room Slnk Faucet	4/29/2025	0445
R2504526-006	TOC-6 Rm. 57-Bus Driver's Break Room Instant Hot Water	4/29/2025	0447
R2504526-007	TOC-7 Rm. 13-Bus Driver's Break Room Keurig	4/29/2025	0450
R2504526-008	TOC-8 Rm. 13-Bus Mechanics Break Room Sink Faucet	4/29/2025	0500
R2504526-009	TOC-9 Rm. 42-Conference Room A Sink Faucet EAST	4/29/2025	0458
R2504526-010	TOC-10 Rm. 42-Conference Room A Refrigerator Ice Maker	4/29/2025	0505
R2504526-011	TOC-11 Rm. 36-Facilities Conference Room Sink Faucet	4/29/2025	0502
R2504526-012	TOC-12 Rm. 36-Facilities Conference Room Instant Hot	4/29/2025	0510
R2504526-013	TOC-13 Rm. 31-Copy Room Sink Faucet	4/29/2025	0504
R2504526-014	TOC-14 Rm. 20-Work Room Drinking Fountain	4/29/2025	0425
R2504526-015	TOC-15 Rm. 11-Bus Parts Storage Drinking Fountain	4/29/2025	0430
R2504526-016	TOC-16 Rm. 8-Grounds Drinking Fountain	4/29/2025	0432







R2504526

5

Rush-Henrietta Central School District  
TOC



### Cooler Receipt and Preservation Check Form

Project/Client Rush Henrietta CSD Folder Number \_\_\_\_\_

Cooler received on 4/29/25 by: KE

COURIER: ALS UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	Y <input checked="" type="radio"/> N <input type="radio"/>
2	Custody papers properly completed (ink, signed)?	Y <input checked="" type="radio"/> N <input type="radio"/>
3	Did all bottles arrive in good condition (unbroken)?	Y <input checked="" type="radio"/> N <input type="radio"/>
4	Circle: Wet Ice Dry Ice Gel packs present?	Y <input checked="" type="radio"/> N <input type="radio"/>

5a	Did VOA vials have sig* bubbles?	Y N <input checked="" type="radio"/> NA
5b	Sig* bubbles: Alk? Y N <input checked="" type="radio"/> NA Sulfide? Y N <input checked="" type="radio"/> NA	
6	Where did the bottles originate?	<u>ALS/ROC</u> CLIENT
7	Soil VOA received as: Bulk Encore 5035set	<input checked="" type="radio"/> NA

8. Temperature Readings Date: 4/29/25 Time: 08:20 ID: IR#12 IR#11 From: Temp Blank Sample Bottle

Temp (°C)	<u>8.1</u>							
Within 0-6°C?	Y <input checked="" type="radio"/> N <input type="radio"/>	Y N	Y N	Y N	Y N	Y N	Y N	Y N
If <0°C, were samples frozen?	Y N	Y N	Y N	Y N	Y N	Y N	Y N	Y N

If out of Temperature, note packing/ice condition: \_\_\_\_\_ Ice melted Poorly Packed (described below) Same Day Rule  
& Client Approval to Run Samples: \_\_\_\_\_ Standing Approval Client aware at drop-off Client notified by: \_\_\_\_\_

All samples held in storage location: SMO by KE on 4/29/25 at 08:27  
5035 samples placed in storage location: \_\_\_\_\_ by \_\_\_\_\_ on \_\_\_\_\_ at \_\_\_\_\_ within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check\*\*: Date: 4/29/25 Time: 9:28 by: AA

- 9. Were all bottle labels complete (i.e. analysis, preservation, etc.)? YES  NO  no date or time
- 10. Did all bottle labels and tags agree with custody papers? YES  NO
- 11. Were correct containers used for the tests indicated? YES  NO
- 12. Were 5035 vials acceptable (no extra labels, not leaking)? YES  NO  N/A
- 13. Were dissolved metals filtered in the field? YES  NO  N/A
- 14. Air Samples: Cassettes / Tubes Intact Y / N with MS Y / N Canisters Pressurized Tedlar® Bags Inflated N/A

pH	Lot of test paper	Reagent	Preserved?		Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
			Yes	No						
≥12		NaOH								
≤2		HNO <sub>3</sub>		<input checked="" type="checkbox"/>			<u>all</u>	<u>4mL</u>	<u>239258</u>	<u>≤2</u>
≤2		H <sub>2</sub> SO <sub>4</sub>								
<4		NaHSO <sub>4</sub>								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> (625, 608, CN), ascorbic (phenol).					
		Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub>								
		ZnAcetate	-	-						
		HCl	**	**						

\*\*VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers: 80419-05  
Explain all Discrepancies/ Other Comments: \_\_\_\_\_

Labels secondary reviewed by: AA

\*significant air bubbles: VOA > 5-6 mm : WC > 1 in. diameter

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541



## Miscellaneous Forms

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)



## REPORT QUALIFIERS AND DEFINITIONS

- |   |  |
|---|--|
| <p><b>U</b> Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.</p> <p><b>J</b> Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration &gt;40% difference between two GC columns (pesticides/Aroclors).</p> <p><b>B</b> Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.</p> <p><b>E</b> Inorganics- Concentration is estimated due to the serial dilution was outside control limits.</p> <p><b>E</b> Organics- Concentration has exceeded the calibration range for that specific analysis.</p> <p><b>D</b> Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.</p> <p><b>*</b> Indicates that a quality control parameter has exceeded laboratory limits. Under the “Notes” column of the Form I, this qualifier denotes analysis was performed out of Holding Time.</p> <p><b>H</b> Analysis was performed out of hold time for tests that have an “immediate” hold time criteria.</p> <p><b>#</b> Spike was diluted out.</p> | <p><b>+</b> Correlation coefficient for MSA is &lt;0.995.</p> <p><b>N</b> Inorganics- Matrix spike recovery was outside laboratory limits.</p> <p><b>N</b> Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.</p> <p><b>S</b> Concentration has been determined using Method of Standard Additions (MSA).</p> <p><b>W</b> Post-Digestion Spike recovery is outside control limits and the sample absorbance is &lt;50% of the spike absorbance.</p> <p><b>P</b> Concentration &gt;40% difference between the two GC columns.</p> <p><b>C</b> Confirmed by GC/MS</p> <p><b>Q</b> DoD reports: indicates a pesticide/Aroclor is not confirmed (<math>\geq 100\%</math> Difference between two GC columns).</p> <p><b>X</b> See Case Narrative for discussion.</p> <p><b>MRL</b> Method Reporting Limit. Also known as:</p> <p><b>LOQ</b> Limit of Quantitation (LOQ)<br/>The lowest concentration at which the method analyte may be reliably quantified under the method conditions.</p> <p><b>MDL</b> Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).</p> <p><b>LOD</b> Limit of Detection. A value at or above the MDL which has been verified to be detectable.</p> <p><b>ND</b> Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.</p> |
|---|--|

### Rochester Lab ID # for State Accreditations<sup>1</sup>



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

<sup>1</sup> Analyses were performed according to our laboratory’s NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

# ALS Laboratory Group

---

## Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Rush-Henrietta Central School District  
**Project:** TOC/

**Service Request:** R2504526

**Sample Name:** TOC-1 Rm. 39-Drinking Fountain Left  
**Lab Code:** R2504526-001  
**Sample Matrix:** Drinking Water

**Date Collected:** 04/29/25  
**Date Received:** 04/29/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** TOC-2 Rm. 39-Drinking Fountain Right  
**Lab Code:** R2504526-002  
**Sample Matrix:** Drinking Water

**Date Collected:** 04/29/25  
**Date Received:** 04/29/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** TOC-3 Rm. 42-Conference Room A Sink  
**Lab Code:** R2504526-003  
**Sample Matrix:** Drinking Water

**Date Collected:** 04/29/25  
**Date Received:** 04/29/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** TOC-4 Rm. 49-Prep Room Sink Faucet  
**Lab Code:** R2504526-004  
**Sample Matrix:** Drinking Water

**Date Collected:** 04/29/25  
**Date Received:** 04/29/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** TOC-5 Rm. 57-Bus Driver's Break Room  
**Lab Code:** R2504526-005  
**Sample Matrix:** Drinking Water

**Date Collected:** 04/29/25  
**Date Received:** 04/29/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Rush-Henrietta Central School District  
**Project:** TOC/

**Service Request:** R2504526

**Sample Name:** TOC-6 Rm. 57-Bus Driver's Break Room  
**Lab Code:** R2504526-006  
**Sample Matrix:** Drinking Water

**Date Collected:** 04/29/25  
**Date Received:** 04/29/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** TOC-7 Rm. 13-Bus Driver's Break Room  
**Lab Code:** R2504526-007  
**Sample Matrix:** Drinking Water

**Date Collected:** 04/29/25  
**Date Received:** 04/29/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** TOC-8 Rm. 13-Bus Mechanics Break  
**Lab Code:** R2504526-008  
**Sample Matrix:** Drinking Water

**Date Collected:** 04/29/25  
**Date Received:** 04/29/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** TOC-9 Rm. 42-Conference Room A Sink  
**Lab Code:** R2504526-009  
**Sample Matrix:** Drinking Water

**Date Collected:** 04/29/25  
**Date Received:** 04/29/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** TOC-10 Rm. 42-Conference Room A  
**Lab Code:** R2504526-010  
**Sample Matrix:** Drinking Water

**Date Collected:** 04/29/25  
**Date Received:** 04/29/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

ALS Group USA, Corp.  
dba ALS Environmental

Analyst Summary report

**Client:** Rush-Henrietta Central School District  
**Project:** TOC/

**Service Request:** R2504526

**Sample Name:** TOC-11 Rm. 36-Facilities Conference  
**Lab Code:** R2504526-011  
**Sample Matrix:** Drinking Water

**Date Collected:** 04/29/25  
**Date Received:** 04/29/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** TOC-12 Rm. 36-Facilities Conference  
**Lab Code:** R2504526-012  
**Sample Matrix:** Drinking Water

**Date Collected:** 04/29/25  
**Date Received:** 04/29/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** TOC-13 Rm. 31-Copy Room Sink Faucet  
**Lab Code:** R2504526-013  
**Sample Matrix:** Drinking Water

**Date Collected:** 04/29/25  
**Date Received:** 04/29/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** TOC-14 Rm. 20-Work Room Drinking  
**Lab Code:** R2504526-014  
**Sample Matrix:** Drinking Water

**Date Collected:** 04/29/25  
**Date Received:** 04/29/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**Sample Name:** TOC-15 Rm. 11-Bus Parts Storage  
**Lab Code:** R2504526-015  
**Sample Matrix:** Drinking Water

**Date Collected:** 04/29/25  
**Date Received:** 04/29/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN

**ALS Group USA, Corp.**

dba ALS Environmental

Analyst Summary report

**Client:** Rush-Henrietta Central School District  
**Project:** TOC/

**Service Request:** R2504526

**Sample Name:** TOC-16 Rm. 8-Grounds Drinking  
**Lab Code:** R2504526-016  
**Sample Matrix:** Drinking Water

**Date Collected:** 04/29/25

**Date Received:** 04/29/25

**Analysis Method**  
200.8

**Extracted/Digested By**

**Analyzed By**  
MKASTAN



## PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

### INORGANIC

#### Water/Liquid Matrix

Analytical Method	Preparation Method
200.7	200.2
200.8	200.2
6010C or 6010D	3005A/3010A
6020A or 6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

#### Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010C or 6010D	3050B
6020A or 6020B	3050B
6010C or 6010D TCLP (1311) extract	3005A/3010A
6010C or 6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

### ORGANIC

**Preparation Methods for Organic methods are listed in the header of the Results pages.**

#### Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



# Sample Results

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)



# Metals

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Rush-Henrietta Central School District  
**Project:** TOC  
**Sample Matrix:** Drinking Water  
**Sample Name:** TOC-1 Rm. 39-Drinking Fountain Left  
**Lab Code:** R2504526-001

**Service Request:** R2504526  
**Date Collected:** 04/29/25 04:40  
**Date Received:** 04/29/25 08:17  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	05/02/25 14:42	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Rush-Henrietta Central School District  
**Project:** TOC  
**Sample Matrix:** Drinking Water  
**Sample Name:** TOC-2 Rm. 39-Drinking Fountain Right  
**Lab Code:** R2504526-002

**Service Request:** R2504526  
**Date Collected:** 04/29/25 04:41  
**Date Received:** 04/29/25 08:17  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	05/02/25 14:44	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Rush-Henrietta Central School District  
**Project:** TOC  
**Sample Matrix:** Drinking Water

**Service Request:** R2504526  
**Date Collected:** 04/29/25 04:57  
**Date Received:** 04/29/25 08:17

**Sample Name:** TOC-3 Rm. 42-Conference Room A Sink Faucet WEST  
**Lab Code:** R2504526-003

**Basis:** NA

**Inorganic Parameters**

<b>Analyte Name</b>	<b>Analysis Method</b>	<b>Result</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Date Analyzed</b>	<b>Q</b>
Lead, Total	200.8	1.8	ug/L	1.0	1	05/02/25 14:45	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Rush-Henrietta Central School District  
**Project:** TOC  
**Sample Matrix:** Drinking Water  
**Sample Name:** TOC-4 Rm. 49-Prep Room Sink Faucet  
**Lab Code:** R2504526-004

**Service Request:** R2504526  
**Date Collected:** 04/29/25 04:55  
**Date Received:** 04/29/25 08:17  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	05/02/25 14:49	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Rush-Henrietta Central School District  
**Project:** TOC  
**Sample Matrix:** Drinking Water  
**Sample Name:** TOC-5 Rm. 57-Bus Driver's Break Room SInk Faucet  
**Lab Code:** R2504526-005

**Service Request:** R2504526  
**Date Collected:** 04/29/25 04:45  
**Date Received:** 04/29/25 08:17  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	05/02/25 14:51	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Rush-Henrietta Central School District  
**Project:** TOC  
**Sample Matrix:** Drinking Water  
**Sample Name:** TOC-6 Rm. 57-Bus Driver's Break Room Instant Hot Water Dispe  
**Lab Code:** R2504526-006

**Service Request:** R2504526  
**Date Collected:** 04/29/25 04:47  
**Date Received:** 04/29/25 08:17

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	05/02/25 14:52	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Rush-Henrietta Central School District  
**Project:** TOC  
**Sample Matrix:** Drinking Water  
**Sample Name:** TOC-7 Rm. 13-Bus Driver's Break Room Keurig  
**Lab Code:** R2504526-007

**Service Request:** R2504526  
**Date Collected:** 04/29/25 04:50  
**Date Received:** 04/29/25 08:17  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	05/02/25 14:54	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Rush-Henrietta Central School District  
**Project:** TOC  
**Sample Matrix:** Drinking Water

**Service Request:** R2504526  
**Date Collected:** 04/29/25 05:00  
**Date Received:** 04/29/25 08:17

**Sample Name:** TOC-8 Rm. 13-Bus Mechanics Break Room Sink Faucet  
**Lab Code:** R2504526-008

**Basis:** NA

**Inorganic Parameters**

<b>Analyte Name</b>	<b>Analysis Method</b>	<b>Result</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Date Analyzed</b>	<b>Q</b>
Lead, Total	200.8	1.4	ug/L	1.0	1	05/02/25 15:04	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Rush-Henrietta Central School District  
**Project:** TOC  
**Sample Matrix:** Drinking Water  
**Sample Name:** TOC-9 Rm. 42-Conference Room A Sink Faucet EAST  
**Lab Code:** R2504526-009

**Service Request:** R2504526  
**Date Collected:** 04/29/25 04:58  
**Date Received:** 04/29/25 08:17  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	05/02/25 15:08	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Rush-Henrietta Central School District  
**Project:** TOC  
**Sample Matrix:** Drinking Water  
**Sample Name:** TOC-10 Rm. 42-Conference Room A Refrigerator Ice Maker  
**Lab Code:** R2504526-010

**Service Request:** R2504526  
**Date Collected:** 04/29/25 05:05  
**Date Received:** 04/29/25 08:17  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	05/02/25 15:10	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Rush-Henrietta Central School District  
**Project:** TOC  
**Sample Matrix:** Drinking Water

**Service Request:** R2504526  
**Date Collected:** 04/29/25 05:02  
**Date Received:** 04/29/25 08:17

**Sample Name:** TOC-11 Rm. 36-Facilities Conference Room Sink Faucet  
**Lab Code:** R2504526-011

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	05/02/25 15:11	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Rush-Henrietta Central School District  
**Project:** TOC  
**Sample Matrix:** Drinking Water

**Service Request:** R2504526  
**Date Collected:** 04/29/25 05:10  
**Date Received:** 04/29/25 08:17

**Sample Name:** TOC-12 Rm. 36-Facilities Conference Room Instant Hot Water D  
**Lab Code:** R2504526-012

**Basis:** NA

**Inorganic Parameters**

<b>Analyte Name</b>	<b>Analysis Method</b>	<b>Result</b>	<b>Units</b>	<b>MRL</b>	<b>Dil.</b>	<b>Date Analyzed</b>	<b>Q</b>
Lead, Total	200.8	1.0 U	ug/L	1.0	1	05/02/25 15:22	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Rush-Henrietta Central School District  
**Project:** TOC  
**Sample Matrix:** Drinking Water  
**Sample Name:** TOC-13 Rm. 31-Copy Room Sink Faucet  
**Lab Code:** R2504526-013

**Service Request:** R2504526  
**Date Collected:** 04/29/25 05:04  
**Date Received:** 04/29/25 08:17  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	05/02/25 15:24	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Rush-Henrietta Central School District  
**Project:** TOC  
**Sample Matrix:** Drinking Water

**Service Request:** R2504526  
**Date Collected:** 04/29/25 04:25  
**Date Received:** 04/29/25 08:17

**Sample Name:** TOC-14 Rm. 20-Work Room Drinking Fountain  
**Lab Code:** R2504526-014

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	05/02/25 15:28	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Rush-Henrietta Central School District  
**Project:** TOC  
**Sample Matrix:** Drinking Water  
**Sample Name:** TOC-15 Rm. 11-Bus Parts Storage Drinking Fountain  
**Lab Code:** R2504526-015

**Service Request:** R2504526  
**Date Collected:** 04/29/25 04:30  
**Date Received:** 04/29/25 08:17  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	05/02/25 15:30	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Rush-Henrietta Central School District  
**Project:** TOC  
**Sample Matrix:** Drinking Water  
**Sample Name:** TOC-16 Rm. 8-Grounds Drinking Fountain  
**Lab Code:** R2504526-016

**Service Request:** R2504526  
**Date Collected:** 04/29/25 04:32  
**Date Received:** 04/29/25 08:17  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	05/02/25 15:31	



## QC Summary Forms

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)



# Metals

**ALS Environmental—Rochester Laboratory**  
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623  
Phone (585) 288-5380 Fax (585) 288-8475  
[www.alsglobal.com](http://www.alsglobal.com)

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Rush-Henrietta Central School District  
**Project:** TOC  
**Sample Matrix:** Drinking Water  
**Sample Name:** Method Blank  
**Lab Code:** R2504526-MB1

**Service Request:** R2504526  
**Date Collected:** NA  
**Date Received:** NA  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	05/02/25 14:14	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Rush-Henrietta Central School District  
**Project:** TOC  
**Sample Matrix:** Drinking Water  
**Sample Name:** Method Blank  
**Lab Code:** R2504526-MB2

**Service Request:** R2504526  
**Date Collected:** NA  
**Date Received:** NA  
**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0 U	ug/L	1.0	1	05/02/25 15:01	

**Client:** Rush-Henrietta Central School District  
**Project:** TOC  
**Sample Matrix:** Drinking Water

**Service Request:** R2504526  
**Date Collected:** 04/29/25  
**Date Received:** 04/29/25  
**Date Analyzed:** 05/2/25

**Duplicate Matrix Spike Summary  
Inorganic Parameters**

**Sample Name:** TOC-7 Rm. 13-Bus Driver's Break Room Keurig  
**Lab Code:** R2504526-007  
**Analysis Method:** 200.8

**Units:** ug/L  
**Basis:** NA

Analyte Name	Sample Result	Result	Matrix Spike R2504526-007MS		Result	Duplicate Matrix Spike R2504526-007DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	1.0 U	17.7	20.0	88	17.5	20.0	88	70-130	<1	20

Results flagged with an asterisk (\*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Rush-Henrietta Central School District  
**Project:** TOC  
**Sample Matrix:** Drinking Water

**Service Request:** R2504526  
**Date Collected:** 04/29/25  
**Date Received:** 04/29/25  
**Date Analyzed:** 05/2/25

**Duplicate Matrix Spike Summary**  
**Inorganic Parameters**

**Sample Name:** TOC-8 Rm. 13-Bus Mechanics Break Room Sink  
Faucet  
**Units:** ug/L  
**Lab Code:** R2504526-008  
**Basis:** NA  
**Analysis Method:** 200.8

Analyte Name	Sample Result	Result	Matrix Spike R2504526-008MS		Result	Duplicate Matrix Spike R2504526-008DMS		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	1.4	19.0	20.0	88	19.3	20.0	90	70-130	2	20

Results flagged with an asterisk (\*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Rush-Henrietta Central School District  
**Project:** TOC  
**Sample Matrix:** Drinking Water

**Service Request:** R2504526  
**Date Analyzed:** 05/02/25

**Lab Control Sample Summary**  
**Inorganic Parameters**

**Units:**ug/L  
**Basis:**NA

**Lab Control Sample**  
R2504526-LCS1

<b>Analyte Name</b>	<b>Analytical Method</b>	<b>Result</b>	<b>Spike Amount</b>	<b>% Rec</b>	<b>% Rec Limits</b>
Lead, Total	200.8	18.2	20.0	91	85-115

ALS Group USA, Corp.  
dba ALS Environmental

QA/QC Report

**Client:** Rush-Henrietta Central School District  
**Project:** TOC  
**Sample Matrix:** Drinking Water

**Service Request:** R2504526  
**Date Analyzed:** 05/02/25

**Lab Control Sample Summary**  
**Inorganic Parameters**

**Units:**ug/L  
**Basis:**NA

**Lab Control Sample**  
R2504526-LCS2

<b>Analyte Name</b>	<b>Analytical Method</b>	<b>Result</b>	<b>Spike Amount</b>	<b>% Rec</b>	<b>% Rec Limits</b>
Lead, Total	200.8	17.7	20.0	89	85-115