



6320 LA PAS TRAIL, INDIANAPOLIS, INDIANA 46268
TELEPHONE: (317) 293-1533 FAX: (317) 290-3566

E-MAIL: microair@microair.com
WEB SITE: <http://www.microair.com>

Indoor Air Quality
Catastrophe Services
Microbiology
Asbestos Surveys
Air Monitoring
Industrial Hygiene
Epidemiology
Radon Testing
Water Testing
Lead Testing

October 29, 2025

Catherine Odindo
Westfield Washington Schools
1143 E. 181st St.
Westfield, IN 46074

**RE: Carbon Monoxide Sampling Report
Westfield Intermediate School
17710 Shamrock Boulevard – Westfield, Indiana
Micro Air, Inc. Project #50-20669-H**

Dear Ms. Odindo,

Micro Air, Inc. conducted sampling to measure the carbon monoxide levels present within select areas of Westfield Intermediate School located at the above-referenced address. Request for services was in response to concerns regarding exhaust from vehicles traveling on a roadway adjacent to the school potentially entering the building through the air handling system intakes. April Nelson, Industrial Hygienist, conducted the testing on October 28, 2025.

Sampling to measure carbon monoxide levels was conducted using a TSI Model 7545 IAQ-CALC™ handheld direct-reading instrument. Carbon monoxide levels were measured using an Electro-Chemical sensor and are reported in units of parts per million (ppm).

Three samples were collected inside the school building during the evaluation:

The carbon monoxide concentration measured inside the Air Handler #5 fresh-air intake chamber was **zero (0) ppm**.

The carbon monoxide concentration measured inside the Air Handler #8 fresh-air intake chamber was **zero (0) ppm**.

The carbon monoxide concentration measured inside the Air Handler #16 fresh-air intake chamber was **zero (0) ppm**.

Based on the results of the current study, Micro Air, Inc. has no recommendations to offer at this time.

Thank you for allowing Micro Air, Inc. the opportunity to provide our services. If you have any questions or require additional information, please contact me at your convenience.

Respectfully submitted by,

A handwritten signature in black ink, appearing to read "April Nelson". The signature is fluid and cursive, with the first name "April" written in a larger, more prominent script than the last name "Nelson".

April Nelson, OHST
Sr. Industrial Hygienist
Director of IH & IAQ Services
Micro Air, Inc.