

ID 15689	Problem Heating/Cooling			Date Completed				
Desc.	Office is cold							
Bldg.	Westfield Intermediate School			Request	10/13/2025			
Space	Main Office - 0114			Status	Completed			
Area	0114			Priority	3-High			
Assigns	Frank Woten			Purpose	General Maintenance			
User	Frank Woten			Budget				
Notes	; Labor:							
Labor			To Date: 1.00 h		Purchases			To Date: \$0.00
Date	Name	Hrs	Date	PO	Description	Supplier	Qty	Cost Each
			Inventory		To Date: \$0.00			
			Date	Item No	Description	Qty	Pool	

Action Taken:

Technician/Supervisor

Date

ID 15760	Problem Heating/Cooling	Date Completed	
Desc.	This office is hot again.		
Bldg.	Westfield Intermediate School	Request	10/15/2025
Space	Main Office - 0115	Status	Completed
Area	0115	Priority	2-Medium
Assigns	Frank Woten	Purpose	General Maintenance
User	Frank Woten	Budget	
Notes	; Labor:		

Labor			To Date: 4.50 h		Purchases				To Date: \$0.00	
Date	Name	Hrs	Date	PO	Description	Supplier	Qty	Cost Each		
			Inventory		To Date: \$0.00					
			Date	Item No	Description		Qty	Pool		

Action Taken:

Technician/Supervisor

Date

ID 15712	Problem Heating/Cooling		Date Completed					
Desc.	Another office is cold							
Bldg.	Westfield Intermediate School		Request	10/14/2025				
Space	Main Office		Status	Completed				
Area			Priority	2-Medium				
Assigns	Frank Woten		Purpose	General Maintenance				
User	Frank Woten		Budget					
Notes	; Labor:							
Labor			To Date: 1.00 h					
Purchases			To Date: \$0.00					
Date	Name	Hrs	Date	PO	Description	Supplier	Qty	Cost Each
			Inventory		To Date: \$0.00			
			Date	Item No	Description	Qty	Pool	

Action Taken:

Technician/Supervisor

Date

ID 15270	Problem Heating/Cooling			Date Completed				
Desc.	Please clean the chiller water coil on AH4. This will assist the unit cool the office better							
Bldg.	Westfield Intermediate School			Request	9/23/2025			
Space	Main Office - AH 4			Status	Completed			
Area	AH 4			Priority	2-Medium			
Assigns	Wes Harouff			Purpose	General Maintenance			
User	Cat Odindo			Budget				
Notes	10/21 Cleaned coil with water. ; Labor:							
Labor			To Date: 2.00 h		Purchases			To Date: \$0.00
Date	Name	Hrs	Date	PO	Description	Supplier	Qty	Cost Each
			Inventory		To Date: \$0.00			
			Date	Item No	Description	Qty	Pool	

Action Taken:

Technician/Supervisor

Date

ID 15656	Problem Heating/Cooling		Date Completed					
Desc.	Coil pump #8. The bearings on the motor have gone bad. Motor needs replaced.							
Bldg.	Westfield Intermediate School		Request	10/10/2025				
Space	mech		Status	Completed				
Area			Priority	1-Low				
Assigns	Wes Harouff		Purpose	General Maintenance				
User	Wes Harouff		Budget					
Notes	Replaced seal and tested. ; Labor:							
Labor		To Date: 3.50 h	Purchases		To Date: \$0.00			
Date	Name	Hrs	Date	PO	Description	Supplier	Qty	Cost Each
			Inventory		To Date: \$0.00			
			Date	Item No	Description	Qty	Pool	

Action Taken:

Technician/Supervisor

Date

ID 16253	Problem Heating/Cooling			Date Completed				
Desc.	Replace broken coupler on AH #9 coil pump.							
Bldg.	Westfield Intermediate School			Request	11/5/2025			
Space	mech - Mechanical room by door 6.			Status	Completed			
Area	Mechanical room by door 6.			Priority	1-Low			
Assigns	Wes Harouff			Purpose	General Maintenance			
User	Wes Harouff			Budget				
Notes	Replaced broken coupler on AH #9 coil pump. ; Labor:							
Labor		To Date: 2.50 h		Purchases				To Date: \$0.00
Date	Name	Hrs	Date	PO	Description	Supplier	Qty	Cost Each
			Inventory		To Date: \$0.00			
			Date	Item No	Description	Qty	Pool	

Action Taken:

Technician/Supervisor

Date