



ADDENDUM NO. 01

Tokay High School Fire Alarm Panel Project No. 8150-5830-600-051

Issued November 21, 2025

This addendum issued on the above date sets forth additional answers for this project. Questions regarding the following listed changes should be directed to: Aaron Stroud; astroud@lodiUSD.net.

Questions/Answers:

- Document 00 11 16, section 1, 4th bullet point states: "The contractor shall obtain and submit DSA-approved drawings and secure final DSA approval prior to installation." Will this project be subject to DSA submittal approval?
Yes, DSA submittal and approval. The district will provide and retain an Electrical Engineer for this project.
- Document 00 72 13, section 3 clarifies the role of the Architect for this project. If DSA submittal and approval is required, will the Architect be submitting to DSA as the Design Professional in General Responsible Charge as described in DSA PR 13-0? **Yes**
- If no DSA submittal drawings are required, will panel interconnection drawings and battery calculation serve as complete submittal drawings? **Yes, if DSA will accept.**
- The project manual, notice to bidders, call for a 10% test of all installed devices. 2025 NFPA 72, section 14.4.2.4 states "All functions known to be affected by the change, or identified by a means that indicates changes, shall be 100 percent tested." As the scope of this project would be a complete change of executive software and programming, all devices would be affected by the change. Is it still the intent of the district to require a 10% test of the system?
Contractor is to test 100% of the devices