

Sample Location	Fixture Type	App or N/A	1 <sup>st</sup> Draw Results (ppb)	1st Draw Sampling Date	Remarks
<b>Charles E. Walters Primary School</b>					
Room 428	WF	App	7.0	10/28/25	Removed from service pending remediation
Room 426	WF	App	7.0	10/28/25	Removed from service pending remediation
<b>Charles E. Walters Intermediate School</b>					
No Exceedances					
<b>Coram Primary School</b>					
No Exceedances					
<b>Coram Intermediate School</b>					
No Exceedances					
<b>Ridge Primary School</b>					
Hallway by Room B113 (left)	WF	App	9.0	10/31/2025	Removed from service pending remediation
Hallway by Room B113 (right)	WF	App	6.0	10/31/2025	Removed from service pending remediation
Hallway by Serving Room	WF	App	40.0	10/31/2025	Removed from service pending remediation
<b>Ridge Intermediate School</b>					
No Exceedances					
<b>West Middle Island Primary School</b>					
Boys Locker Room	WF	App	12.0	10/29/2025	Removed from service pending remediation
<b>West Middle Island Intermediate School</b>					
No Exceedances					
<b>Longwood Middle School</b>					
Kitchen Counter by Cooler	SK	App	7.0	10/30/2025	Removed from service pending remediation
1 North by Room 310	BF	App	54.0	10/30/2025	Removed from service pending remediation
<b>Longwood Junior High School</b>					
No Exceedances					
<b>Longwood Career Center</b>					
No Exceedances					
<b>Longwood High School</b>					
Hall by 1107	WF	App	8.0	6/18/25	Removed from service pending fixture replacement
Room 1711 Station 4	SK	App	14.0	6/18/25	Removed from service pending remediation
Room 1711 Station 4	SPY	App	12.0	6/18/25	Removed from service pending remediation
Shop Room 1803	WF	App	23.0	6/18/25	Removed from service pending fixture replacement
Hall by 1614	WF	App	22.0	6/18/25	Removed from service pending fixture replacement
Field Concession Stand Kitchen	SK	App	7.0	6/18/25	Removed from service pending remediation
<b>Legend</b>					
SK-Sink					
WF-Water Fountain					
BF-Bottle Filler					
SPY-Spray					
App-currently considered an applicable/potable source					