J.C. Broderick & Associates, Inc.
Environmental / Construction Consulting & Testing

1775 Expressway Drive North
Hauppauge, NY 11788
631.584.5492
Fax: 631.584.3395
www.jcbroderick.com

November 24, 2025

Mr. Steve Jacob
Safety Coordinator
Nassau BOCES
George Farber Administrative Center
Garden City, New York 11530

Re: **Lead Testing in School Drinking Water**
Remedial Action Plan
2023-25 Compliance 10 NYCRR Subpart 67-4

JCB#: **23-56115**

Dear Mr. Jacob:

J.C. Broderick & Associates, Inc. (JCB) was retained to perform lead testing and analysis of the outlets which service the above referenced school district in accordance with 10 NYCRR Subpart 67-4 (Subpart 67-4).

The outlets servicing each of the school buildings were inventoried and assigned unique identification numbers. The use and location of each outlet was reviewed to determine its applicability for testing under Subpart 67-4.

An initial first-draw sample was collected from each applicable outlet after the minimum 8-hour stagnation period. Samples were logged into a chain of custody document and delivered to an Environmental Laboratory Approval Program (ELAP) accredited laboratory for analysis.

Results from the laboratory analysis were compared with the Action Level as defined by Subpart 67-4 of 5 parts per billion (ppb). Any outlet which exceeded this level requires a remediation action plan be implemented (i.e. removal from service, placarding for non-drinking uses). Outlets which did not exceed the action level do not require further testing or remediation.

Please see the following attachments which detail the sampling and analysis performed and remediation actions taken to date.

Attachment 1: Lead in Water Remediation Plan
Attachment 2: Outlet Inventory and Lead Testing Results
Attachment 3: Laboratory Analytical Reports
Attachment 4: Laboratory Certifications

If you have any questions, or if more information is needed, please contact our office.

Sincerely,
Paul J. Fazio
J C Broderick & Associates, Inc.

Attachment 1:

Lead in Water Remediation Plan



J.C. Broderick & Associates, Inc.
Environmental Consulting & Testing
1775 Expressway Drive North
Hauppauge, New York 11788
631.584.5492 fax 631.584.3395

Lead in Water Remediation Plan

Section 67-4.4 Response of the New York State Department of Health (NYS DOH) Title 10 of the Official Compilation of the Codes, Rules and Regulations of the State of New York requires:

If the lead concentration of water at an outlet exceeds the action level, the school shall:
(a) prohibit use of the outlet until:
(1) a lead remediation plan is implemented to mitigate the lead level of such outlet; and
(2) test results indicate that the lead levels are at or below the action level;

As historical sampling results have indicated, the concentrations of lead are more likely attributable to the individual fixtures and/or their immediately adjoining plumbing, and not with the building-wide plumbing. Based upon this information, the following remedial steps are recommended:

Step 1A: Potable Outlets (Outlets intended to be used for drinking/cooking)


Immediately remove the fixture from service. If necessary, provide an adequate supply of potable water for drinking/cooking to this location at no cost to the occupants. If an outlet is seldomly used or is unnecessary, the district may consider permanent removal of the outlet and capping of its supply line.

Step 1B: Non-Potable Outlets (Outlets not intended for drinking/cooking)

See Step 1A OR Placard the outlet for non-drinking use. Signs must be clearly visible and in close proximity to the affected outlet. Example signage is provided at: https://www.health.ny.gov/environmental/water/drinking/lead/docs/donotdrinksigns_lead .pdf.









Step 2: Service & Repair or Outlet Replacement

The school district's plumber should evaluate the outlet to determine if any components require service or repair. Depending on the extent of service/repair necessary, age of the fixture, and or overall costs, the district may consider replacing the outlet entirely. Any newly installed components shall be certified lead free. (i.e. NSF/ANSI 61, NSF/ANSI-273). If servicing involves installing/replacing a point-of-use filtration system, this filter shall be certified for its lead reduction capability (i.e. NSF/ANSI 53). Follow all manufacturer's instructions for all component installations. OUTLET RESTRICTIONS MUST REMAIN IN PLACE UNTIL SATISFACTORY TEST RESULTS ARE RECEIVED. See Step 3.

Step 3: Retesting & Return to Service

Schedule a retest of the outlet. Outlet restrictions must remain in place until lead testing results at or below the action level are received. Once satisfactory results are received, the outlet may be returned to normal service. Note: It is recommended that "Do Not Drink" signage remain in place for all non-potable and non-applicable outlet types.

Attachment 2:

Outlet Inventory and Lead Testing Results



J.C. Broderick & Associates, Inc.
Environmental Consulting & Testing
1775 Expressway Drive North
Hauppauge, New York 11788
631.584.5492 fax 631.584.3395

Laboratory Lead in Water Results

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-56115

Nassau BOCES

Rosemary Kennedy Center

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-0001	**Room 614**	2000	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0002	**Room 612**	2002	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0003	**Room 609**	2003	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0004	**Room 610**	2004	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0005	**Room 608**	2005	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0006	**Room 607**	2006	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0007	**Room 606**	2008	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0008	**Room 604**	2010	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0009	**Room 602**	2011	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0010	**Room 600**	2013	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0011	**Room 601**	2014	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0012	**Room 521**	2018	Classroom Faucet	Potable	**10/25/2025**	**1.1**			Result Below Action Level Continue O&M
NASS-0013	**Boys Bathroom 520**	2020	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0016	**Boys Bathroom 520**	2020	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0018	**Girls Bathroom 518**	2022	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0019	**Girls Bathroom 518**	2022	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service RFI = Removed from Inventory

Rosemary Kennedy Center

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-0020	**Girls Bathroom 518**	2022	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0021	**Girls Bathroom 518**	2022	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0022	**Girls Bathroom 518**	2022	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0023	**Room 516**	2023	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0024	**Room 515 & Inner Offices**	2024	Classroom Faucet	Potable	**10/25/2025**	**5.9**			Removed From Service, Pending Remediation
NASS-0025	**Room 515 & Inner Offices**	2024	Classroom Faucet	Potable	**10/25/2025**	**1.4**			Result Below Action Level Continue O&M
NASS-0026	**Room 514**	2025	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0027	**Room 513**	2026	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
NASS-0028	**Room 512**	2028	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0029	**Room 510**	2029	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0030	**Room 509**	2030	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0031	**Room 509**	2030	Ice Machine	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0033	**Room 506**	2033	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0037	**Room 505 Kitchen/Laundry Room**	2035	Home Economics Faucet (Cold)	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0038	**Room 505 Kitchen/Laundry Room**	2035	Home Economics Faucet (Cold)	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0044	**Room 504**	2037	Classroom Faucet	Potable	**10/25/2025**	**OOS**			Testing Required Before Return to Service
NASS-0045	**Room 502 School Store**	2038	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0053	**Room 406**	2046	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0054	**Room 405 Bathroom**	2049A	Bathroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0055	**Room 405 Bathroom**	2049A	Bathroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

Rosemary Kennedy Center

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-0056	**Room 410**	2050	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0057	**Room 408**	2048	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0058	**Room 405 Bathroom**	2049A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0059	**Room 103**	2104	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0060	**Room 105**	2105	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0061	**Room 107A Bathroom 2**	2107B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0062	**Room 107A (Space Reconstructed)**	2107	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0063	**Room 109**	2111	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0064	**Room 114**	2110	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0065	**Room 116 Health Office**	2114	Nurse's Office Sink	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0066	**Room 116 Health Office**	2114	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0067	**Room 116 Health Office**	2114	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0069	**Room 109A Bathroom**	2112A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0070	**Room 111**	2113	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0071	**Room 303**	2054	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0072	**Room 305**	2055	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0073	**Room 307**	2056	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0074	**Room 309**	2057	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0075	**Room 311**	2060	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0078	**Room 308**	2063	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

Rosemary Kennedy Center

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-0079	**Room 315**	2064	Classroom Faucet	Potable	**10/25/2025**	**1.1**			Result Below Action Level Continue O&M
NASS-0080	**Room 317**	2065	Classroom Faucet	Potable	**10/25/2025**	**1.4**			Result Below Action Level Continue O&M
NASS-0081	**Room 310**	2066	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0082	**Room 312**	2067	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0083	**Slop Sink Room o/s Room 301**	2052	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
NASS-0085	**Room 201**	2096	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0086	**Room 201A**	2095	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0087	**Room 203**	2093	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0089	**Room 204 Bathroom**	2091A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0090	**Room 205**	2090	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0091	**Room 205A**	2089	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0092	**Room 206**	2088	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0093	**Room 207**	2087	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0094	**Room 206A**	2086	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0095	**Room 207A**	2085	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0096	**Room 208**	2084	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0097	**Room 209**	2083	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0098	**Room 209A**	2082	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0099	**Bathroom 210B**	2076	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0100	**Bathroom 210B**	2076	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Rosemary Kennedy Center

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-0101	**Bathroom 210A**	2074	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0102	**Bathroom 210A**	2074	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0103	**Room 211A**	2075B	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0104	**Room 211 Bathroom**	2075E	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0105	**Room 212**	2073	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0106	**Room 213**	2072	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0107	**Room 212A**	2071	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0108	**Room 214**	2070	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0109	**Room 215**	2069	Bathroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0110	**Faculty Lounge Room 1202**	1016	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0112	**Men's Bathroom Room 1201**	1018	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0113	**Men's Bathroom Room 1201**	1018	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0114	**Men's Bathroom Room 1201**	1018	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0115	**Women's Bathroom 1200**	1019	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0116	**Women's Bathroom 1200**	1019	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0117	**Women's Bathroom 1200**	1019	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0118	**Room 1105**	1023	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0119	**Room 1107**	1025	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0121	**Room 1109**	1030	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0122	**Room 1111**	1032	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M

Rosemary Kennedy Center

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-0123	**Unisex Bathroom**	1034	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0124	**Room 1114 Bathroom**	1036A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0125	**Room 1114 Sink Area**	1036C	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0126	**Room 1113**	1037	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0127	**Room 914**	1040	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0128	**Room 910**	1045	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0129	**Room 906**	1049	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0130	**Girls Bathroom 904**	1051	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0131	**Girls Bathroom 904**	1051	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0132	**Girls Bathroom 904**	1051	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0133	**Girls Bathroom 904**	1051	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0134	**Girls Bathroom 904**	1051	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0135	**Boys Bathroom 900**	1053	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
NASS-0136	**Boys Bathroom 900**	1053	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0137	**Boys Bathroom 900**	1053	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0138	**Boys Bathroom 900**	1053	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0140	**Boys Bathroom 900**	1053	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0141	**Art Room 1001**	1055	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0142	**Art Room 1001**	1055	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0144	**Room 1002**	1057	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

Rosemary Kennedy Center

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-0145	**Room 1004**	1058	Water Fountain-No Chiller	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0146	**Room 1004**	1058	Classroom Faucet	Potable	**10/25/2025**	**1.4**			Result Below Action Level Continue O&M
NASS-0147	**Room 1006**	1060	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0148	**Room 1003**	1059	Classroom Faucet	Potable	**10/25/2025**	**2.3**			Result Below Action Level Continue O&M
NASS-0149	**Room 1003**	1059	Classroom Faucet	Potable	**10/25/2025**	**1.2**			Result Below Action Level Continue O&M
NASS-0150	**Room 1007**	1062	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0151	**Room 1006A**	1063	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0152	**Room 1008**	1064	Classroom Faucet	Potable	**10/25/2025**	**OOS**			Testing Required Before Return to Service
NASS-0155	**School Store Room 701**	1066	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0156	**700 Corridor**	1082	Water Fountain-No Chiller	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0157	**Room 703 Bathroom**	1068A	Bathroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0158	**Room 705 Large Sink Closet**	1070E	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0159	**Room 707**	1072	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0160	**Room 707A Bathroom**	1073A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0161	**Nurses Office Room 706**	1074	Nurse's Office Sink	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0162	**Medication Room**	1075	Nurse's Office Sink	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0163	**Room 708A Bathroom**	1079A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0164	**Room 711**	1080	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0165	**Room 801 Conference Room Sink Closet**	1083C	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0166	**Room 802 Small Closet**	1085A	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

Rosemary Kennedy Center

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-0167	**Room 803**	1086	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0168	**Kitchen 1300 Office Vestibule**	1012C	Kitchen Faucet (Cold)	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0169	**Kitchen 1300**	1012	Kitchen Faucet (Cold)	Potable	**10/25/2025**	**OOS**			Testing Required Before Return to Service
NASS-0170	**Kitchen 1300**	1012	Kitchen Faucet (Cold)	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0171	**Kitchen 1300**	1012	Kitchen Faucet (Cold)	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0172	**Kitchen 1300**	1012	Kitchen Faucet (Cold)	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0173	**Kitchen 1300**	1012	Kitchen Faucet (Cold)	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0174	**Kitchen 1300**	1012	Kitchen Faucet (Cold)	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0175	**Kitchen 1300**	1012	Hand Wash Only	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0176	**Kitchen 1300**	1012	Kitchen Faucet (Cold)	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0178	**Kitchen 1300**	1012	Pasta Pot/Steam Kettle	Potable	**10/25/2025**	**953**			Removed From Service, Pending Remediation
NASS-0179	**Kitchen 1300**	1012	Pasta Pot/Steam Kettle	Potable	**10/25/2025**	**3.0**			Result Below Action Level Continue O&M
NASS-0180	**Kitchen 1300**	1012	Ice Machine	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0181	**Kitchen 1300 Washer/Dryer Room**	1012H	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0182	**Kitchen 1300 Washer/Dryer Room**	1012H	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0184	**Room 1204 Custodial Office**	1015	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0185	**Room 1302 Custodial Closet**	1009	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
NASS-0188	**Corridor o/s Room 1400**	1006	Water Fountain-No Chiller	Potable	**10/25/2025**	**1.2**			Result Below Action Level Continue O&M
NASS-0193	**Room 1514 Bathroom**	1102A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0194	**Room 1514 Office**	1102B	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

Rosemary Kennedy Center

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-0195	**Men's Bathroom 1520**	1105	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0196	**Men's Bathroom 1520**	1105	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0197	**Women's Bathroom 1522**	1106	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0198	**Women's Bathroom 1522**	1106	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0199	**Room 1517**	1110	Classroom Faucet	Potable	**10/25/2025**	**4.9**			Result Below Action Level Continue O&M
NASS-0201	**Room 1803**	1148	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0202	**Room 1801**	1147	Kitchen Faucet (Cold)	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0203	**Room 1805**	1150	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0204	**Room 1805**	1150	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0205	**Room 1802 Bathroom**	1149A1	Bathroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0206	**Room 1802 Bathroom**	1149A1	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0207	**Room 1804**	1151	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
NASS-0208	**Room 1806**	1152	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0209	**Room Adjacent Room 1807**	1154	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0210	**Room 1807**	1153	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0212	**Room 1808/1808A**	1155	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0213	**Room 1809**	1156	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0214	**Room 1700/1702**	1133	Classroom Faucet	Potable	**10/25/2025**	**1.5**			Result Below Action Level Continue O&M
NASS-0215	**Room 1700/1702**	1133	Water Fountain-No Chiller	Potable	**10/25/2025**	**1.9**			Result Below Action Level Continue O&M
NASS-0216	**Room 1704**	1136	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

Rosemary Kennedy Center

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-0217	**Room 1705/1705A**	1137	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0218	**Room 1705/1705A**	1137	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0220	**Room 1705/1705A**	1137	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0221	**Room 1705/1705A**	1137	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0223	**Room 1706**	1138	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0224	**Room 1706**	1138	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0226	**Room 1708**	1141	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0227	**Room 1711**	1142	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0228	**Room 1711**	1142	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0229	**Girls Bathroom 1603**	1117	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0230	**Girls Bathroom 1603**	1117	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0231	**Girls Bathroom 1603**	1117	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0232	**Girls Bathroom 1603**	1117	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0233	**Boys Bathroom 1605**	1118	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0234	**Boys Bathroom 1605**	1118	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0235	**Boys Bathroom 1605**	1118	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0236	**Boys Bathroom 1605**	1118	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0237	**Room 1608**	1121	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0240	**Room 1609A**	1124	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0241	**Room 1610**	1126	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

Rosemary Kennedy Center

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-0242	**Room 1611A**	1128	Classroom Faucet	Potable	**10/25/2025**	**1.6**			Result Below Action Level Continue O&M
NASS-0243	**Room 1614**	1129	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0244	**Room 1613**	1130	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0245	**Room 1613**	1130	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0255	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0256	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0257	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0258	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0259	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0260	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0261	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0262	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0263	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0264	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0265	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0266	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0267	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0268	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0269	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0270	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

Rosemary Kennedy Center

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-0271	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0272	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0273	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0274	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0275	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0276	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0277	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0279	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0280	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0281	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0282	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0283	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0284	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0285	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1245	**Room 313**	2061	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1284	**1000 Corridor**	1065	Bottle Fill Station	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1285	**1000 Corridor**	1065	Water Cooler	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1286	**Room 1507/1509**	1097	Classroom Faucet	Potable	**10/25/2025**	**OOS**			Testing Required Before Return to Service
NASS-1754	**Room 404**	2045	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1755	**Room 204**	2091	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

Rosemary Kennedy Center

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-1785	**Boys Bathroom 900**	1053	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1786	**Kitchen Room 1000**	1056	Kitchen Faucet (Cold)	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1787	**Kitchen Room 1000**	1056	Kitchen Faucet (Cold)	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1788	**Kitchen Room 1000**	1056	Kitchen Faucet (Cold)	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1789	**Staff Bathroom 1304**	1008	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1790	**Staff Bathroom 1304**	1008	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1791	**Staff Bathroom 1306**	1007	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1792	**Staff Bathroom 1306**	1007	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1793	**Room 1204 Custodial Office Bathroom**	1015	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1794	**Room 1204 Custodial Office Bathroom**	1015	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1795	**Kitchen 1300 Laundry Room**	1012H	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
NASS-1796	**Kitchen 1300 Bathroom**	1012A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1797	**Kitchen 1300 Bathroom**	1012A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1798	**Kitchen 1300**	1012	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-1799	**Kitchen 1300**	1012	Coffe Pot	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1800	**Kitchen 1300**	1012	Coffe Pot	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1801	**Kitchen 1300**	1012	Coffe Pot	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1802	**Kitchen 1300**	1012	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-1803	**Room 1614**	1129	Ice Machine	Potable	**10/25/2025**	**OOS**			Testing Required Before Return to Service
NASS-1804	**Kitchen 200**	2094	Kitchen Faucet (Cold)	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

Rosemary Kennedy Center

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-1805	**Room 204**	2091	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1806	**Room 204**	2091	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1807	**Room 609**	2003	Dish Washer	Non-Applicable					Placarded for Non-Drinking Use
NASS-1808	**Room 609**	2003	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1809	**Room 609**	2003	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1810	**Boys Bathroom 520**	2020	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1811	**Boys Bathroom 520**	2020	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1812	**Boys Bathroom 520**	2020	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1813	**Room 509**	2030	Bottle Fill Station	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1814	**Room 509**	2030	Water Cooler	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1815	**Room 505 Home Economics**	2034	Dish Washer	Non-Applicable					Placarded for Non-Drinking Use
NASS-1816	**Room 505 Home Economics**	2034	Dish Washer	Non-Applicable					Placarded for Non-Drinking Use
NASS-1817	**Room 505 Home Economics**	2034	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1818	**Room 505 Home Economics**	2034	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1819	**Room 505 Home Economics**	2034	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1820	**Room 505 Home Economics**	2034	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1821	**Room 505 Home Economics**	2034	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-1822	**Room 505 Bathroom/Shower**	2034B	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-1823	**Room 505 Bathroom/Shower**	2034B	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-1824	**Room 505 Bathroom/Bath**	2034A	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use

Rosemary Kennedy Center

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-1825	**Room 505 Bathroom/Bath**	2034A	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-1826	**Room 505 Bathroom/Bath**	2034A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1828	**Room 505 Bathroom/Sinks**	2034	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1829	**Room 505 Bathroom/Sinks**	2034	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1830	**Girl's Bathroom 503**	2036	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1831	**Girl's Bathroom 503**	2036	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1832	**Girl's Bathroom 503**	2036	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1833	**Girl's Bathroom 503**	2036	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1834	**Girl's Bathroom 503**	2036	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1835	**Boys Bathroom 501**	2039	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1836	**Boys Bathroom 501**	2039	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1837	**Boys Bathroom 501**	2039	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1838	**Boys Bathroom 501**	2039	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1839	**Bathroom 400**	2042	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1840	**Bathroom 400**	2042	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1841	**Bathroom 402**	2043	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1842	**Bathroom 402**	2043	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1843	**Room 405 Bathroom**	2049A	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-1844	**Room 408**	2048	Dish Washer	Non-Applicable					Placarded for Non-Drinking Use
NASS-1846	**Main Office 102**	2102	Bottled Water Dispenser	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

Rosemary Kennedy Center

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-1847	**Main Office 102**	2102	Bottled Water Dispenser	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1848	**Main Office 102**	2102	Bottled Water Dispenser	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1849	**Nurse's Office 116 Bathroom**	2114	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1850	**Nurse's Office 116 Bathroom**	2114	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1851	**Corridor o/s Room 301**	2068	Bottle Fill Station	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1861	**Hygiene Center**	2059A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1862	**Hygiene Center**	2059A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1863	**Hygiene Center**	2059A	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-1977	**Room 708A**	1079	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1978	**Room 1808/1808A**	1155	Classroom Faucet	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1979	**All Purpose Room**	1112	Bottle Fill Station	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1980	**All Purpose Room**	1112	Bottle Fill Station	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1981	**Bathroom o/s 1106**	1028	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Haskett Drive Complex-Building A

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-0254	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1028	**Automotive Garage**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
NASS-1029	**Automotive Garage**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
NASS-1030	**Automotive Garage**	N/A	Water Fountain-No Chiller	Potable	**10/24/2025**	**77.6**			Removed From Service, Pending Remediation
NASS-1031	**Automotive Garage**	N/A	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
NASS-1032	**Automotive Garage**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1033	**Automotive Garage**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1034	**Men's Restroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1035	**Women's Restroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1036	**Transportation Lunch Room**	N/A	Kitchen Faucet (Cold)	Potable	**10/24/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1037	**Graphics Lunch Room**	N/A	Kitchen Faucet (Cold)	Potable	**10/24/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1038	**Electrical Room**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
NASS-1039	**Men's Restroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1040	**Women's Restroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1041	**Women's Restroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1042	**Printing Room**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
NASS-1045	**Printing Room**	N/A	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
NASS-1050	**Automotive Garage**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1054	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1055	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Haskett Drive Complex-Building A

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-1056	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1608	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1609	**Printing Room**	N/A	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
NASS-1610	**Printing Room**	N/A	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use

Robert E. Lupinskie Center for Curriculum, Instr

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-0278	**2001**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1193	**Women's Restroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1194	**Women's Restroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1195	**Women's Restroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1196	**Men's Restroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1197	**Men's Restroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1198	**Men's Restroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1199	**Corridor o/s Conference Room 3**	N/A	Water Cooler	Potable	**10/24/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1200	**Corridor o/s Conference Room 3**	N/A	Water Cooler	Potable	**10/24/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1201	**Pantry**	N/A	Tempered Water Outlet	Potable	**10/24/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1202	**Custodial Closet 1**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
NASS-1203	**Fire Sprinkler Room**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1204	**Custodial Closet 2**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
NASS-1205	**Men's Restroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1206	**Men's Restroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1207	**Men's Restroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1208	**Women's Restroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1209	**Women's Restroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1210	**Women's Restroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1211	**Corridor o/s Electrical Room 130**	N/A	Water Cooler	Potable	**10/24/2025**	**OOS**			Testing Required Before Return to Service

OOS= Out of Service **RFI = Removed from Inventory**

Robert E. Lupinskie Center for Curriculum, Instr

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-1212	**Women's Restroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1213	**Women's Restroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1214	**Unisex Bathroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1215	**Custodial Closet 3**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
NASS-1216	**Men's Restroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1217	**Men's Restroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1219	**Women's Restroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1220	**Storage 142A**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
NASS-1221	**Men's Restroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1222	**Employee Lounge 142**	N/A	Water Cooler	Potable	**10/24/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1223	**Employee Lounge 142**	N/A	Kitchen Faucet (Cold)	Potable	**10/24/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1224	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1225	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1226	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1617	**Office o/s Room 121**	N/A	Bottle Fill Station	Potable	**10/24/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1618	**Office o/s Room 121**	N/A	Water Cooler	Potable	**10/24/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1619	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1712	**Employee Lounge 142**	N/A	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-1713	**Employee Lounge 142**	N/A	Coffe Pot	Potable	**10/24/2025**	**OOS**			Testing Required Before Return to Service

OOS= Out of Service **RFI = Removed from Inventory**

Jerusalem Avenue School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-0286	**Room 101**	1000A	Classroom Faucet	Potable	**10/23/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0287	**Room 100**	1001	Classroom Faucet	Potable	**10/23/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0288	**Room 103**	1002A	Classroom Faucet	Potable	**10/23/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0289	**Room 102**	1003A	Classroom Faucet	Potable	**10/23/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0290	**Room 105**	1004	Classroom Faucet	Potable	**10/23/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0291	**Room 107**	1007A	Classroom Faucet	Potable	**10/23/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0292	**Room 106**	1006A	Classroom Faucet	Potable	**10/23/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0293	**Room 108**	1008A	Classroom Faucet	Potable	**10/23/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0294	**Room 109**	1009A	Classroom Faucet	Potable	**10/23/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0295	**Room 111**	1010A	Classroom Faucet	Potable	**10/23/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0300	**Boy's Bathroom 110**	1011	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0301	**Boy's Bathroom 110**	1011	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0302	**Boy's Bathroom 110**	1011	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0303	**Boy's Bathroom 110**	1011	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0304	**Custodial Closet 112**	1012	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
NASS-0310	**Girl's Bathroom 113**	1013	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0311	**Girl's Bathroom 113**	1013	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0312	**Girl's Bathroom 113**	1013	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0313	**Girl's Bathroom 113**	1013	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0314	**Girl's Bathroom 113**	1013	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Jerusalem Avenue School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-0315	**Girl's Bathroom 113**	1013	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0317	**Boiler Room Vestibule Bathroom**	1014A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0318	**Boiler Room**	0013	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
NASS-0319	**Room 116**	1016A	Classroom Faucet	Potable	**10/23/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0331	**Custodial Closet**	2014	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
NASS-0350	**Room 225**	2029	Classroom Faucet	Potable	**10/23/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0351	**Room 229 Suite**	2033	Classroom Faucet	Potable	**10/23/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0362	**Custodial Closet 237**	2041	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
NASS-0373	**Room 243**	2047	Classroom Faucet	Potable	**10/23/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0374	**Room 245**	2049	Classroom Faucet	Potable	**10/23/2025**	**2.8**			Result Below Action Level Continue O&M
NASS-0380	**Women's Bathroom 126**	1029	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0381	**Women's Bathroom 126**	1029	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0382	**Room 117**	1018	Classroom Faucet	Potable	**10/23/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0391	**Principal's Office Bathroom**	1026B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0393	**Room 131**	1032A	Classroom Faucet	Potable	**10/23/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0394	**Kitchen**	1037A	Kitchen Faucet (Cold)	Potable	**10/23/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0395	**Kitchen**	1037A	Kitchen Faucet (Cold)	Potable	**10/23/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0396	**Kitchen**	1037A	Kitchen Faucet (Cold)	Potable	**10/23/2025**	**5.3**			Removed From Service, Pending Remediation
NASS-0397	**Kitchen**	1037A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0398	**Kitchen**	1037A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Jerusalem Avenue School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-0399	**Kitchen**	1037A	Kitchen Faucet (Cold)	Potable	**10/23/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0400	**Kitchen**	1037A	Kitchen Faucet (Cold)	Potable	**10/23/2025**	**1.2**			Result Below Action Level Continue O&M
NASS-0401	**Kitchen**	1037A	Hand Wash Only	Potable	**10/23/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0402	**Kitchen Bathroom**	1037A1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0403	**West Cafeteria 141**	1039	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
NASS-0405	**Room 173 Classroom**	1071B	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0412	**Custodial Closet 174**	1072	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
NASS-0428	**Room 180**	1080	Classroom Faucet	Potable	**10/23/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0429	**Room 180**	1080	Classroom Faucet	Potable	**10/23/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0430	**Room 166 Kitchenette**	1047C	Classroom Faucet	Potable	**10/23/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0431	**Room 166 Kitchenette**	1047C	Classroom Faucet	Potable	**10/23/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0432	**Custodial Closet 163**	1052	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
NASS-0433	**Faculty Room 159**	1065	Classroom Faucet	Potable	**10/23/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0440	**Room 148**	1057	Classroom Faucet	Potable	**10/23/2025**	**1.7**			Result Below Action Level Continue O&M
NASS-0441	**Room 145**	1055	Classroom Faucet	Potable	**10/23/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0442	**Room 144**	1054	Classroom Faucet	Potable	**10/23/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0443	**Crawlspace (Pump Room)**	0007	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1289	**Corridor o/s Room 130**	1044	Bottle Fill Station	Potable	**10/23/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1290	**Corridor o/s Room 130**	1044	Water Cooler	Potable	**10/23/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1291	**Room 141**	1041B	Classroom Faucet	Potable	**10/23/2025**	**<1.00 ND**			Result Below Action Level Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

Jerusalem Avenue School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-1292	**Corridor o/s Room 245**	2052	Bottle Fill Station	Potable	**10/23/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1293	**Corridor o/s Room 245**	2052	Water Cooler	Potable	**10/23/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1294	**Corridor o/s Room 222**	2052	Bottle Fill Station	Potable	**10/23/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1295	**Corridor o/s Room 222**	2052	Water Cooler	Potable	**10/23/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1296	**Corridor o/s Room 235**	2052	Bottle Fill Station	Potable	**10/23/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1297	**Corridor o/s Room 235**	2052	Water Cooler	Potable	**10/23/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1298	**Corridor o/s Room 238**	2052	Bottle Fill Station	Potable	**10/23/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1299	**Corridor o/s Room 238**	2052	Water Cooler	Potable	**10/23/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1513	**Corridor o/s Room 111**	1017	Bottle Fill Station	Potable	**10/23/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1514	**Corridor o/s Room 111**	1017	Water Cooler	Potable	**10/23/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1515	**Corridor o/s Cafeteria**	1044	Bottle Fill Station	Potable	**10/23/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1516	**Corridor o/s Cafeteria**	1044	Water Cooler	Potable	**10/23/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1517	**Gym Corridor**	1082	Bottle Fill Station	Potable	**10/23/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1518	**Gym Corridor**	1082	Water Cooler	Potable	**10/23/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1629	**Girls Bathroom 238**	2042	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1630	**Girls Bathroom 238**	2042	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1631	**Girls Bathroom 238**	2042	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1632	**Girls Bathroom 238**	2042	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1633	**Boys Bathroom 236**	2040	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1634	**Boys Bathroom 236**	2040	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Jerusalem Avenue School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-1635	**Boys Bathroom 236**	2040	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1636	**Library Suite Vestibule Bathroom**	2024A2	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1637	**Womens Bathroom 220**	2022	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1638	**Womens Bathroom 220**	2022	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1639	**Womens Bathroom 220**	2022	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1640	**Womens Bathroom 220**	2022	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1641	**Corridor o/s Room 215**	2023	Bottle Fill Station	Potable	**10/23/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1642	**Corridor o/s Room 215**	2023	Water Cooler	Potable	**10/23/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1643	**Girls Bathroom 213**	2015	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1644	**Girls Bathroom 213**	2015	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1645	**Girls Bathroom 213**	2015	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1646	**Girls Bathroom 213**	2015	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1647	**Boys Bathroom 210**	2012	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1648	**Boys Bathroom 210**	2012	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1649	**Boys Bathroom 210**	2012	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1650	**Boys Bathroom 210**	2012	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1651	**Corridor o/s Room 200**	2023	Bottle Fill Station	Potable	**10/23/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1652	**Corridor o/s Room 200**	2023	Water Cooler	Potable	**10/23/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1653	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1654	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

Jerusalem Avenue School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-1655	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1656	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1657	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1658	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1659	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1660	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1661	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1709	**Kitchen Serving**	1037	Hand Wash Only	Potable	**10/23/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1710	**Room 242**	2046	Classroom Faucet	Potable	**10/23/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1711	**Room 234**	2038A	Classroom Faucet	Potable	**10/23/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1864	**Corridor o/s Room 103**	1017	Bottle Fill Station	Potable	**10/23/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1865	**Corridor o/s Room 103**	1017	Water Cooler	Potable	**10/23/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1866	**Boys Bathroom 110**	1011	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1867	**Boys Bathroom 110**	1011	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1868	**Boys Bathroom 110**	1011	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1869	**Boys Bathroom 110**	1011	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1870	**Boys Bathroom 110**	1011	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1871	**Girls Bathroom**	1013	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1872	**Girls Bathroom**	1013	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1873	**Girls Bathroom**	1013	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Jerusalem Avenue School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-1874	**Girls Bathroom**	1013	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1875	**Girls Bathroom**	1013	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1876	**Corridor o/s Room 115**	1017	Bottle Fill Station	Potable	**10/23/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1877	**Corridor o/s Room 115**	1017	Water Cooler	Potable	**10/23/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1878	**Nurse's Office**	1019	Nurse's Office Sink	Potable	**10/23/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1879	**Nurse's Office**	1020	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
NASS-1880	**Nurse's Office Bathroom**	1019B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1881	**Nurse's Office Bathroom**	1019B	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1882	**Womens Bathroom 119**	1020A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1883	**Womens Bathroom 119**	1020A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1884	**Womens Bathroom 119**	1020A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1885	**Womens Bathroom 119**	1020A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1886	**Womens Bathroom 119**	1020A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1887	**Corridor**	1027	Bottle Fill Station	Potable	**10/23/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1888	**Corridor**	1027	Water Cooler	Potable	**10/23/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1889	**Mens Bathroom 121**	1021	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1890	**Mens Bathroom 121**	1021	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1891	**Mens Bathroom 121**	1021	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1892	**Mens Bathroom 121**	1021	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1893	**Mens Bathroom 121**	1021	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

Jerusalem Avenue School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-1894	**Room 133**	1035	Home Economics Faucet (Cold)	Non-Applicable					Placarded for Non-Drinking Use
NASS-1895	**Room 133**	1035	Dish Washer	Non-Applicable					Placarded for Non-Drinking Use
NASS-1896	**Corridor 144 to 151**	1060	Bottle Fill Station	Potable	**10/23/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1897	**Corridor 144 to 151**	1060	Water Cooler	Potable	**10/23/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1898	**Bathroom 156**	1064A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1899	**Bathroom 156**	1064A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1900	**Bathroom 156**	1064A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1901	**Faculty Lounge**	1065	Dish Washer	Non-Applicable					Placarded for Non-Drinking Use
NASS-1902	**Girls Bathroom 172**	1070	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1903	**Girls Bathroom 172**	1070	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1904	**Girls Bathroom 172**	1070	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1905	**Boys Bathroom 175**	1073	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1906	**Boys Bathroom 175**	1073	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1907	**Boys Bathroom 175**	1073	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1908	**Custodial 183 Vestibule Bathroom**	1077A2	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1909	**Custodial 183 Vestibule Bathroom**	1077A2	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1910	**Custodial 183 Vestibule Bathroom**	1077A2	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-1911	**Storage Vestibule**	1077B	Water Fountain-No Chiller	Potable	**10/23/2025**	**OOS**			Testing Required Before Return to Service
NASS-1912	**Room 179 Bathroom**	1081A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1913	**Room 179 Bathroom**	1081A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Jerusalem Avenue School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-1914	**Room 179 Bathroom**	1081A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1915	**Gym Girls Bathroom Vestibule**	1078A1A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1916	**Gym Girls Bathroom Vestibule**	1078A1A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1917	**Gym Girls Bathroom Vestibule**	1078A1A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1918	**Gym Girls Bathroom Vestibule**	1078A1A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Carman Road School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-0459	**Health Office**	1001	Nurse's Office Sink	Potable	**10/22/2025**	**1.3**			Result Below Action Level Continue O&M
NASS-0461	**Nurse Office**	1002	Nurse's Office Sink	Potable	**10/22/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0462	**Kitchen**	1007	Kitchen Service Area	Potable	**10/22/2025**	**OOS**			Testing Required Before Return to Service
NASS-0463	**Kitchen**	1007	Pasta Pot/Steam Kettle	Potable	**10/22/2025**	**OOS**			Testing Required Before Return to Service
NASS-0464	**Kitchen**	1007	Kitchen Faucet (Cold)	Potable	**10/22/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0465	**Kitchen**	1007	Kitchen Faucet (Cold)	Potable	**10/22/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0466	**Kitchen**	1007	Kitchen Faucet (Cold)	Potable	**10/22/2025**	**13.4**			Removed From Service, Pending Remediation
NASS-0467	**Kitchen**	1007	Kitchen Faucet (Cold)	Potable	**10/22/2025**	**27.3**			Removed From Service, Pending Remediation
NASS-0468	**Kitchen Custodial Closet**	1007C	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
NASS-0470	**Boys Bathroom**	1015	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0471	**Boys Bathroom**	1015	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0472	**Boys Bathroom**	1015	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
NASS-0473	**Custodial Closet**	1016	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
NASS-0474	**Room 8**	1018	Classroom Faucet	Potable	**10/22/2025**	**1.3**			Result Below Action Level Continue O&M
NASS-0478	**Room 9**	1019	Classroom Faucet	Potable	**10/22/2025**	**2.1**			Result Below Action Level Continue O&M
NASS-0479	**Room 10**	1020	Classroom Faucet	Potable	**10/22/2025**	**1.4**			Result Below Action Level Continue O&M
NASS-0480	**Room 11**	1021	Classroom Faucet	Potable	**10/22/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0482	**Room 12**	1022	Classroom Faucet	Potable	**10/22/2025**	**1.8**			Result Below Action Level Continue O&M
NASS-0483	**Room 13**	1023	Classroom Faucet	Potable	**10/22/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0484	**Room 14**	1024	Classroom Faucet	Potable	**10/22/2025**	**<1.00 ND**			Result Below Action Level Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

Carman Road School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-0485	**Room 15**	1025	Classroom Faucet	Potable	**10/22/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0486	**Room 16**	1026	Classroom Faucet	Potable	**10/22/2025**	**1.3**			Result Below Action Level Continue O&M
NASS-0487	**Room 17**	1027	Classroom Faucet	Potable	**10/22/2025**	**1.4**			Result Below Action Level Continue O&M
NASS-0488	**Room 18**	1028	Classroom Faucet	Potable	**10/22/2025**	**2.3**			Result Below Action Level Continue O&M
NASS-0493	**Room 7**	1035	Classroom Faucet	Potable	**10/22/2025**	**1.0**			Result Below Action Level Continue O&M
NASS-0494	**Room 7 Bathroom/Closet**	1035A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0495	**Room 6**	1036	Classroom Faucet	Potable	**10/22/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0496	**Room 6 Bathroom/Closet**	1036A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0497	**Room 4**	1037	Classroom Faucet	Potable	**10/22/2025**	**2.5**			Result Below Action Level Continue O&M
NASS-0498	**Room 4 Bathroom/Closet**	1037A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0500	**Room 5 Bathroom/Closet**	1038A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0501	**Room 3**	1039	Classroom Faucet	Potable	**10/22/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0502	**Room 3 Bathroom/Closet**	1039A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0503	**Room 1**	1041	Classroom Faucet	Potable	**10/22/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0504	**Room 1 Changing Room/Bathroom**	1041A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0505	**Room 2 Changing Room/Bathroom**	1042A	Bathroom Faucet	Potable	**10/22/2025**	**1.5**			Result Below Action Level Continue O&M
NASS-0506	**Physical Therapy Room Changing Room/Bathroom**	1043A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0507	**Physical Therapy Room**	1043	Classroom Faucet	Potable	**10/22/2025**	**138**			Removed From Service, Pending Remediation
NASS-0509	**Greenhouse**	1048	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
NASS-0511	**Faculty Room**	1051	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Carman Road School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-0512	**Custodial Closet**	1052	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
NASS-0513	**Room 20**	1056	Classroom Faucet	Potable	**10/22/2025**	**1.6**			Result Below Action Level Continue O&M
NASS-0515	**Room 22**	1060	Classroom Faucet	Potable	**10/22/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0516	**Room 21**	1062	Home Economics Faucet (Cold)	Potable	**10/22/2025**	**1.1**			Result Below Action Level Continue O&M
NASS-0517	**Room 21**	1062	Bottle Fill Station	Potable	**10/22/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0520	**Room 24**	1063	Classroom Faucet	Potable	**10/22/2025**	**3.7**			Result Below Action Level Continue O&M
NASS-0521	**Room 23**	1064	Classroom Faucet	Potable	**10/22/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0523	**Learning Center**	1065	Classroom Faucet	Potable	**10/22/2025**	**4.7**			Result Below Action Level Continue O&M
NASS-0527	**Custodial Closet**	1069	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
NASS-0528	**Boys Bathroom**	1070	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0529	**Room 26**	1071	Classroom Faucet	Potable	**10/22/2025**	**2.5**			Result Below Action Level Continue O&M
NASS-0530	**Room 25**	1072	Classroom Faucet	Potable	**10/22/2025**	**1.4**			Result Below Action Level Continue O&M
NASS-0531	**Room 28 / School store**	1073	Classroom Faucet	Potable	**10/22/2025**	**2.0**			Result Below Action Level Continue O&M
NASS-0532	**Room 27**	1074	Classroom Faucet	Potable	**10/22/2025**	**1.4**			Result Below Action Level Continue O&M
NASS-0533	**Room 30**	1075	Classroom Faucet	Potable	**10/22/2025**	**3.3**			Result Below Action Level Continue O&M
NASS-0534	**Room 29**	1076	Classroom Faucet	Potable	**10/22/2025**	**2.7**			Result Below Action Level Continue O&M
NASS-0535	**PT Room 32**	1077	Classroom Faucet	Potable	**10/22/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0536	**OT Room 34**	1079	Classroom Faucet	Potable	**10/22/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0537	**Room 31**	1078	Classroom Faucet	Potable	**10/22/2025**	**1.1**			Result Below Action Level Continue O&M
NASS-0550	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Carman Road School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-1305	**Entrance Lobby**	1004	Bottle Fill Station	Potable	**10/22/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1306	**Entrance Lobby**	1004	Water Cooler	Potable	**10/22/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1307	**Corridor o/s Room 7**	1040	Bottle Fill Station	Potable	**10/22/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1308	**Corridor o/s Room 7**	1040	Water Cooler	Potable	**10/22/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1309	**Corridor o/s Assitant Principal Room**	1083	Bottle Fill Station	Potable	**10/22/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1310	**Corridor o/s Assitant Principal Room**	1083	Water Cooler	Potable	**10/22/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1311	**Corridor o/s Room 26**	1083	Bottle Fill Station	Potable	**10/22/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1312	**Corridor o/s Room 26**	1083	Water Cooler	Potable	**10/22/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1313	**Corridor o/s Room 11**	1029	Bottle Fill Station	Potable	**10/22/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1314	**Corridor o/s Room 11**	1029	Water Cooler	Potable	**10/22/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1554	**Health Office**	1001	Nurse's Office Sink	Potable	**10/22/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1555	**Health Office**	1002	Nurse's Office Sink	Potable	**10/22/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1556	**Nurse Office Bathroom**	1001A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1557	**Principal Bathroom**	1000D	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1558	**Girls Bathroom**	1017	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1559	**Girls Bathroom**	1017	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1560	**Girls Bathroom**	1017	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1561	**Custodial Office Shower**	1045A2	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-1562	**Custodial Office Bathroom**	1045A1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1563	**Bathroom**	1031	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Carman Road School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-1564	**Bathroom**	1032	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1565	**Womens Bathroom**	1050A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1566	**Room 21**	1062	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-1567	**Room 23 Bathroom**	1064A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1568	**Room 23 Bathroom**	1064A	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-1569	**Room 23 Bathroom**	1064A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1570	**Room 23**	1064	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1571	**Room 23**	1064	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1572	**Girls Bathroom**	1065	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1573	**Girls Bathroom**	1065	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1574	**Girls Bathroom**	1065	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1575	**Bathroom o/s PT**	1082	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1576	**Bathroom**	1084	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1577	**Boys Bathroom**	1070	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1578	**Boys Bathroom**	1070	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1579	**Boys Bathroom**	1070	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1580	**Bathroom**	1051A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1581	**Boys Bathroom**	1015	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1582	**Boys Bathroom**	1015	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1583	**Boys Bathroom**	1015	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Carman Road School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-1584	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1585	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1586	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1587	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1588	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1593	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1594	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1595	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1747	**Room 5**	1038	Classroom Faucet	Potable	**10/22/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1748	**Gymanasium Volunteer Room Bathroom**	1006B2	Bathroom Faucet	Potable	**10/22/2025**	**1.4**			Result Below Action Level Continue O&M

OOS= Out of Service RFI = Removed from Inventory

Joseph M. Barry Career & Technical Education

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-0551	**E-133**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0552	**E-125**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0553	**E-124**	N/A	Nurse's Office Sink	Potable	**10/21/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0554	**E-124**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0555	**E-119**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0556	**E-119**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0557	**E-116**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0558	**E-115**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0559	**E-115**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0560	**BR NEAR E-115**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0561	**E-113**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0562	**E-113**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0563	**E-113**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0564	**MENS BR**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0565	**MENS BR**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0566	**MENS BR**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0567	**MENS BR**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0568	**CC**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
NASS-0569	**WOMENS BR**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0570	**WOMENS BR**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Joseph M. Barry Career & Technical Education

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-0571	**WOMENS BR**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0572	**WOMENS BR**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0573	**E-112**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0574	**E-112**	N/A	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-0575	**E-112**	N/A	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-0576	**E-112**	N/A	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-0577	**E-112**	N/A	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-0578	**E-112**	N/A	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-0579	**CC**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
NASS-0580	**BOYS BR**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0581	**BOYS BR**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0582	**BOYS BR**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0583	**BOYS BR**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0584	**GIRLS BR**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0585	**GIRLS BR**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0586	**GIRLS BR**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0587	**GIRLS BR**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0588	**MENS BR**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0589	**MENS BR**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0590	**MENS BR**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Joseph M. Barry Career & Technical Education

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-0591	**WOMENS BR**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0592	**WOMENS BR**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0593	**WOMENS BR**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0594	**HA NEAR WOMENS**	N/A	Water Cooler	Potable	**10/21/2025**	**1.9**			Result Below Action Level Continue O&M
NASS-0595	**HA NEAR WOMENS**	N/A	Water Cooler	Potable	**10/21/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0596	**Culinary E-117**	N/A	Ice Machine	Potable	**10/21/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0598	**Culinary E-117**	N/A	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-0599	**Culinary E-117**	N/A	Hand Wash Only	Potable	**10/21/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0600	**Culinary E-117**	N/A	Pasta Pot/Steam Kettle	Potable	**10/21/2025**	**1.6**			Result Below Action Level Continue O&M
NASS-0601	**Culinary E-117**	N/A	Hand Wash Only	Potable	**10/21/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0603	**Culinary E-117**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
NASS-0604	**Culinary E-117**	N/A	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-0605	**Culinary E-117**	N/A	Kitchen Faucet (Cold)	Potable	**10/21/2025**	**1.2**			Result Below Action Level Continue O&M
NASS-0606	**Culinary E-117**	N/A	Hand Wash Only	Potable	**10/21/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0607	**Culinary E-117**	N/A	Hand Wash Only	Potable	**10/21/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0608	**Culinary E-117**	N/A	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-0610	**Culinary E-117**	N/A	Hand Wash Only	Potable	**10/21/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0611	**Culinary E-117**	N/A	Hand Wash Only	Potable	**10/21/2025**	**1**			Result Below Action Level Continue O&M
NASS-0613	**E-111**	N/A	Water Cooler	Potable	**10/21/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0614	**E-111 WOMENS**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Joseph M. Barry Career & Technical Education

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-0615	**E-111 WOMENS**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0616	**E-111 WOMENS**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0617	**E-111 WOMENS**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0618	**E-111 MENS**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0619	**E-111 MENS**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0620	**E-111 MENS**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0621	**E-111 MENS**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0622	**HA NEAR E-111**	N/A	Water Cooler	Potable	**10/21/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0623	**HA NEAR E-111**	N/A	Water Cooler	Potable	**10/21/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0624	**E-108**	N/A	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-0625	**E-108**	N/A	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-0626	**E-108**	N/A	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-0627	**E-108**	N/A	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-0628	**E-108 BR**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0629	**E-108 LAUDRY**	N/A	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
NASS-0630	**BOILER ROOM**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
NASS-0631	**E-106**	N/A	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-0632	**E-106**	N/A	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-0633	**E-106**	N/A	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-0634	**E-106**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Joseph M. Barry Career & Technical Education

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-0635	**E-106**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0636	**E-106**	N/A	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-0637	**Kitchen E-105**	N/A	Kitchen Faucet (Cold)	Potable	**10/21/2025**	**4.6**			Result Below Action Level Continue O&M
NASS-0638	**Kitchen E-105**	N/A	Hand Wash Only	Potable	**10/21/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0639	**Kitchen E-105**	N/A	Hand Wash Only	Potable	**10/21/2025**	**1.2**			Result Below Action Level Continue O&M
NASS-0640	**Kitchen E-105**	N/A	Hand Wash Only	Potable	**10/21/2025**	**3.7**			Result Below Action Level Continue O&M
NASS-0641	**Kitchen E-105**	N/A	Hand Wash Only	Potable	**10/21/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0642	**Kitchen E-105**	N/A	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-0643	**Kitchen E-105**	N/A	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-0644	**Kitchen E-105**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
NASS-0645	**Kitchen E-105**	N/A	Hand Wash Only	Potable	**10/21/2025**	**3**			Result Below Action Level Continue O&M
NASS-0646	**Kitchen E-105**	N/A	Hand Wash Only	Potable	**10/21/2025**	**1.1**			Result Below Action Level Continue O&M
NASS-0647	**Kitchen E-105**	N/A	Kitchen Faucet (Cold)	Potable	**10/21/2025**	**2.6**			Result Below Action Level Continue O&M
NASS-0649	**E104**	N/A	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-0650	**E103**	N/A	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-0651	**E103**	N/A	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-0652	**E103**	N/A	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-0653	**E103**	N/A	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-0654	**E103**	N/A	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-0655	**E103 LAUDRY**	N/A	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Joseph M. Barry Career & Technical Education

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-0656	**E103 BR**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0657	**CC NEAR C231**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
NASS-0658	**C231**	N/A	Kitchen Faucet (Cold)	Potable	**10/21/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0661	**C230**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0662	**C230**	N/A	Nurse's Office Sink	Potable	**10/21/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0663	**BOYS BR**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0664	**BOYS BR**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0665	**BOYS BR**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0666	**CC**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
NASS-0667	**GIRLS BR**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0668	**GIRLS BR**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0669	**GIRLS BR**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0670	**GIRLS BR**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0671	**HA NEAR C223**	N/A	Water Cooler	Potable	**10/21/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0672	**HA NEAR C223**	N/A	Water Cooler	Potable	**10/21/2025**	**19.6**			Removed From Service, Pending Remediation
NASS-0673	**C225 WOMEN**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0674	**C225 WOMEN**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0675	**C225 WOMEN**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0676	**C225 WOMEN**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0677	**C225 MEN**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use

Joseph M. Barry Career & Technical Education

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-0678	**C225 MEN**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0679	**C225 MEN**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0680	**C225 MEN**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0681	**C225 MEN**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0682	**C217**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0685	**C216**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0688	**C212**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0689	**C210**	N/A	Kitchen Faucet (Cold)	Potable	**10/21/2025**	**3.1**			Result Below Action Level Continue O&M
NASS-0690	**C210**	N/A	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
NASS-0691	**C201**	N/A	Kitchen Faucet (Cold)	Potable	**10/21/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0692	**C202**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0693	**C202**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0694	**C204**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0695	**C207 DENTAL**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0696	**C207 DENTAL**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0697	**C207 DENTAL**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0698	**C207 DENTAL**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0699	**C207 DENTAL**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0700	**C207 DENTAL**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0701	**C207 DARK RM**	N/A	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Joseph M. Barry Career & Technical Education

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-0704	**W317**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0705	**W317**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0706	**W317**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0707	**W317 CAGE WASHING**	N/A	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-0708	**W317 CAGE WASHING**	N/A	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-0709	**W317**	N/A	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-0710	**W317**	N/A	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-0711	**W318**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0712	**W318**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0713	**W318**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0714	**W318**	N/A	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-0715	**W318**	N/A	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-0716	**W327**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0717	**W327**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0718	**W327**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0719	**W319 TRADE**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0720	**W319 TRADE**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0721	**W319 TRADE**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0722	**W328 TRADE**	N/A	Water Cooler	Potable	**10/21/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0723	**W328 TRADE**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Joseph M. Barry Career & Technical Education

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-0724	**W328 TRADE**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0725	**W328 TRADE**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0726	**W328 TRADE**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0727	**W320**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0728	**W320**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0729	**W320**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0731	**W323**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0733	**C200F**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0734	**C205**	N/A	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
NASS-0735	**C205**	N/A	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
NASS-0736	**C205**	N/A	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
NASS-0737	**C205**	N/A	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
NASS-0738	**C206**	N/A	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
NASS-0739	**C206**	N/A	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
NASS-0740	**Faculty Lounge W336**	N/A	Kitchen Faucet (Cold)	Potable	**10/21/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0741	**W336B**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0742	**W336B**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0743	**W336B**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0744	**W336B**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0745	**W336C**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use

Joseph M. Barry Career & Technical Education

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-0746	**HA NEAR C209**	N/A	Water Cooler	Potable	**10/21/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0747	**HA NEAR C209**	N/A	Water Cooler	Potable	**10/21/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0748	**W334**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
NASS-0749	**Mens Bathroom W335**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0750	**Mens Bathroom W335**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0751	**Mens Bathroom W335**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0752	**Mens Bathroom W335**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0753	**Mens Bathroom W335**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0754	**Mens Bathroom W335**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0755	**W333**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0756	**W333**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0757	**W333**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0758	**W333**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0759	**W333**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0760	**W333**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0762	**W312**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0766	**W310**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0770	**W305**	N/A	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
NASS-0771	**W305**	N/A	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
NASS-0772	**W305**	N/A	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use

Joseph M. Barry Career & Technical Education

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-0773	**W305**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0774	**W303**	N/A	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
NASS-0775	**W303**	N/A	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
NASS-0776	**W303**	N/A	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
NASS-0777	**W303**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0778	**W302**	N/A	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
NASS-0779	**W302**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0780	**W301**	N/A	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
NASS-0781	**W301**	N/A	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
NASS-0782	**W301**	N/A	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
NASS-0783	**W324**	N/A	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
NASS-0784	**W324**	N/A	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
NASS-0785	**W324**	N/A	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
NASS-0786	**CC BY W323A**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
NASS-0787	**BOYS BR BY W323A**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0788	**BOYS BR BY W323A**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0789	**BOYS BR BY W323A**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0790	**BOYS BR BY W323A**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0791	**BOYS BR BY W323A**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0794	**GIRLS BR BY W323A**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use

Joseph M. Barry Career & Technical Education

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-0795	**GIRLS BR BY W323A**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0796	**GIRLS BR BY W323A**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0797	**GIRLS BR BY W323A**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0798	**GIRLS BR BY W323A**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0799	**W316**	N/A	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
NASS-0802	**W316 SCRUB RM**	N/A	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
NASS-0803	**C220**	N/A	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
NASS-0804	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0805	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0806	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0807	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0808	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0809	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0810	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0811	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0812	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0813	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1300	**Corridor o/s Room W316**	N/A	Bottle Fill Station	Potable	**10/21/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1301	**Corridor o/s Room W316**	N/A	Water Cooler	Potable	**10/21/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1302	**Corridor o/s Room W306**	N/A	Bottle Fill Station	Potable	**10/21/2025**	**<1.00 ND**			Result Below Action Level Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

Joseph M. Barry Career & Technical Education

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-1303	**Corridor o/s Room W306**	N/A	Water Cooler	Potable	**10/21/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1304	**Corridor o/s Room W306**	N/A	Water Cooler	Potable	**10/21/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1521	**W-303**	N/A	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
NASS-1522	**W-305**	N/A	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
NASS-1523	**W-302**	N/A	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
NASS-1524	**W-301**	N/A	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
NASS-1525	**W-324**	N/A	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
NASS-1745	**Culinary E-117**	N/A	Coffe Pot	Potable	**10/21/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1746	**Kitchen E-105**	N/A	Coffe Pot	Potable	**10/21/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1933	**E-113**	N/A	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-1934	**E-113**	N/A	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-1935	**E-133**	N/A	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-1936	**Culinary E-117**	N/A	Kitchen Faucet (Cold)	Potable	**10/21/2025**	**1.6**			Result Below Action Level Continue O&M
NASS-1937	**Culinary E-117**	N/A	Kitchen Faucet (Cold)	Potable	**10/21/2025**	**1.1**			Result Below Action Level Continue O&M
NASS-1938	**E-124**	N/A	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-1939	**E-125 Gym**	N/A	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-1940	**E-119**	N/A	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-1941	**E-119**	N/A	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-1942	**E-116**	N/A	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-1943	**E-115**	N/A	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Joseph M. Barry Career & Technical Education

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-1944	**E-115**	N/A	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-1945	**E-112**	N/A	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-1946	**E-112**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1947	**E-112**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1948	**Culinary E-117**	N/A	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
NASS-1949	**Culinary E-117**	N/A	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-1950	**Culinary E-117**	N/A	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
NASS-1951	**E-108**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1952	**E-108**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1953	**E-108**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1954	**E-108**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1955	**E-106**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1956	**E-106**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1957	**E-106**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1958	**E-106**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1959	**Kitchen E-105**	N/A	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-1960	**Kitchen E-105**	N/A	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-1961	**E-103**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1962	**E-103**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1963	**Hallway o/s C231**	N/A	Water Cooler	Potable	**10/21/2025**	**<1.00 ND**			Result Below Action Level Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

Joseph M. Barry Career & Technical Education

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-1964	**Hallway o/s C231**	N/A	Bottle Fill Station	Potable	**10/21/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1965	**Hallway o/s C231**	N/A	Water Cooler	Potable	**10/21/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1966	**Nurse Office**	N/A	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
NASS-1967	**Nursing C-206**	N/A	Nurse's Office Sink	Non-Applicable					Placarded for Non-Drinking Use
NASS-1968	**Nursing C-206**	N/A	Nurse's Office Sink	Non-Applicable					Placarded for Non-Drinking Use
NASS-1969	**C-216**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1970	**C-213**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1971	**C-214**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1972	**Room C-207 Dark**	N/A	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-1973	**Room C-207 Dark**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1974	**C-207**	N/A	Dental Chair Spit Drain	Potable	**10/21/2025**	**4.5**			Result Below Action Level Continue O&M
NASS-1975	**C-207**	N/A	Dental Chair Spit Drain	Potable	**10/21/2025**	**5.5**			Removed From Service, Pending Remediation
NASS-1976	**C-207**	N/A	Dental Chair Spit Drain	Potable	**10/21/2025**	**11**			Removed From Service, Pending Remediation
NASS-1982	**W-317**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1983	**W-317**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1984	**W-319**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1985	**W-319**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1986	**W-327**	N/A	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
NASS-1987	**W-328**	N/A	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
NASS-1988	**W-320**	N/A	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Joseph M. Barry Career & Technical Education

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-1989	**W-320**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1990	**Hallway o/s W-323A**	N/A	Bottle Fill Station	Potable	**10/21/2025**	**OOS**			Testing Required Before Return to Service
NASS-1991	**Hallway o/s W-323A**	N/A	Water Cooler	Potable	**10/21/2025**	**OOS**			Testing Required Before Return to Service
NASS-1992	**Hallway o/s W-323A**	N/A	Water Cooler	Potable	**10/21/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1993	**W-323**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1994	**W-323**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1995	**W-323**	N/A	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
NASS-1996	**W-323**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1997	**W-323**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1998	**W-326**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1999	**W-326**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-2000	**W-305**	N/A	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service RFI = Removed from Inventory

Career Preparatory High School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-0814	**PE OFFICE BATHROOM**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0815	**GYM 127**	N/A	Water Fountain-No Chiller	Potable	**10/21/2025**	**OOS**			Testing Required Before Return to Service
NASS-0817	**GYM GIRLS BR**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0818	**GYM GIRLS BR**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0819	**GYM GIRLS BR**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0820	**GYM BOYS BR**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0821	**GYM BOYS BR**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0822	**GYM BOYS BR**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0823	**CC NEAR GYM**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
NASS-0824	**WEIGHT ROOM 128**	N/A	Water Cooler	Potable	**10/21/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0825	**WOMENS BR BY GUIDANCE**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0826	**WOMENS BR BY GUIDANCE**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0827	**WOMENS BR BY GUIDANCE**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0828	**STUDENTS CAFETERIA**	N/A	Water Cooler	Potable	**10/21/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0829	**STUDENTS CAFETERIA**	N/A	Water Cooler	Potable	**10/21/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0830	**INDUSTIAL ARTS RM131**	N/A	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
NASS-0831	**AUTO MECHANICS RM132**	N/A	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
NASS-0832	**AUTO MECHANICS RM132**	N/A	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
NASS-0833	**AUTO MECHANICS RM132**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0834	**Room 136**	N/A	Hand Wash Only	Non-Potable	**10/21/2025**	**<1.00 ND**			Result Below Action Level Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

Career Preparatory High School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-0835	**CULINARY ARTS RM115**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
NASS-0836	**CULINARY ARTS RM115**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0837	**CULINARY ARTS RM115**	N/A	Hand Wash Only	Potable	**10/21/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0838	**CULINARY ARTS RM115**	N/A	Kitchen Faucet (Cold)	Potable	**10/21/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0839	**CULINARY ARTS RM115**	N/A	Kitchen Faucet (Cold)	Potable	**10/21/2025**	**1.4**			Result Below Action Level Continue O&M
NASS-0840	**CULINARY ARTS RM115**	N/A	Ice Machine	Potable	**10/21/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0841	**CULINARY ARTS RM115**	N/A	Hand Wash Only	Non-Potable	**10/21/2025**	**1.2**			Result Below Action Level Continue O&M
NASS-0842	**CULINARY ARTS RM115**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0843	**CULINARY ARTS RM115**	N/A	Hand Wash Only	Non-Potable	**10/21/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0844	**CULINARY ARTS RM115**	N/A	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-0845	**GIRLS BR BY RM115**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0846	**GIRLS BR BY RM115**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0847	**GIRLS BR BY RM115**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0848	**GIRLS BR BY RM115**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0849	**GIRLS BR BY RM115**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0850	**GIRLS BR BY RM115**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0851	**CC 138**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
NASS-0855	**BOYS BR BY RM139**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0856	**BOYS BR BY RM139**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0857	**BOYS BR BY RM139**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use

Career Preparatory High School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-0858	**BOYS BR BY RM139**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0859	**BOYS BR BY RM139**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0860	**PRINCIPLES OF 103 BR**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0861	**NURSE OFFICE 102**	N/A	Nurse's Office Sink	Potable	**10/21/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0862	**NURSE OFFICE 102**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0863	**NURSE OFFICE 102**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0865	**CC 107**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
NASS-0866	**Faculty Lounge 113**	N/A	Kitchen Faucet (Cold)	Potable	**10/21/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0867	**CUSTODIAL SHOP RM**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
NASS-0868	**MENS FACULTY BR BY 118**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0869	**MENS FACULTY BR BY 118**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0870	**MENS FACULTY BR BY 118**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0871	**HA o/s Room 119**	N/A	Water Cooler	Potable	**10/21/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0872	**HA o/s Room 119**	N/A	Water Cooler	Potable	**10/21/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0873	**RM 218**	N/A	Kitchen Faucet (Cold)	Potable	**10/21/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0874	**RM 218**	N/A	Water Cooler	Potable	**10/21/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0875	**RM 218**	N/A	Water Cooler	Potable	**10/21/2025**	**1.6**			Result Below Action Level Continue O&M
NASS-0876	**HA o/s Room 211**	N/A	Water Cooler	Potable	**10/21/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0877	**HA o/s Room 211**	N/A	Water Cooler	Potable	**10/21/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0878	**GIRLS BR BY 211**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Career Preparatory High School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-0879	**GIRLS BR BY 211**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0880	**GIRLS BR BY 211**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0881	**CC 210**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
NASS-0882	**BOYS BR BY 209**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0883	**BOYS BR BY 209**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0884	**BOYS BR BY 209**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0885	**MENS FACULTY BR BY 209**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0886	**MENS FACULTY BR BY 209**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0887	**WOMENS FACULTY BR BY 209**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0888	**WOMENS FACULTY BR BY 209**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0889	**2nd FLOOR HA BY ELEVATOR**	N/A	Water Cooler	Potable	**10/21/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0890	**ART RM 204**	N/A	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
NASS-0891	**SCIENCE RM**	N/A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0893	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0894	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0895	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1253	**HA**	N/A	Water Cooler	Potable	**10/21/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1254	**HA**	N/A	Water Cooler	Potable	**10/21/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1919	**Industrial Arts**	N/A	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
NASS-1920	**Auto Mechanic**	N/A	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Career Preparatory High School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-1921	**Culinary Arts Room 136**	N/A	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
NASS-1922	**Boy's Bathroom o/s Room 139**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1923	**Boy's Bathroom o/s Room 139**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1924	**Boy's Bathroom o/s Room 139**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1925	**Boy's Bathroom o/s Room 139**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1926	**Boy's Bathroom o/s Room 139**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1927	**Principal Bathroom**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1928	**Health Office**	N/A	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
NASS-1929	**HA o/s Room 106**	N/A	Water Cooler	Potable	**10/21/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1930	**Custodial Shop**	N/A	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
NASS-1931	**Art Room 204**	N/A	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
NASS-1932	**Science Room**	N/A	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use

Long Island High School for the Arts

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-0896	**Room A-11 (Previously Nursery)**	1053	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
NASS-0897	**Room A-11 (Previously Nursery)**	1053	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
NASS-0898	**Room A-11 (Previously Nursery)**	1053	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
NASS-0899	**Corridor A-8 to A-13**	1057	Water Cooler	Potable	**10/24/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0900	**Women's Bathroom**	1060	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0901	**Room A-9**	1054	Hand Wash Only	Potable	**10/24/2025**	**1.0**			Result Below Action Level Continue O&M
NASS-0902	**Room A-9**	1054	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0903	**Slop Sink Closet**	1059	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
NASS-0904	**Women's Bathroom**	1060	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0905	**Women's Bathroom**	1060	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0906	**Men's Bathroom**	1061	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0907	**Men's Bathroom**	1061	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0908	**Nurses Office Suite Exam Room Bathroom**	1062A1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0909	**Men's Faculty Bathroom (Interior Walls Removed, now**	1068	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0910	**Room A-8 & Fashion Sink Area (Previously Library)**	1056	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
NASS-0911	**Principal's Office**	1065G	Kitchen Faucet (Cold)	Potable	**10/24/2025**	**2.9**			Result Below Action Level Continue O&M
NASS-0913	**Room 27**	1013	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0914	**Boys Bathroom/Locker Room**	1042	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0915	**Boys Bathroom/Locker Room**	1042	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0916	**Girls Bathroom/Locker Room**	1041	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Long Island High School for the Arts

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-0917	**Girls Bathroom/Locker Room**	1041	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0918	**Custodial Closet**	1039	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
NASS-0919	**Custodial Closet**	1030	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
NASS-0920	**Corridor Theater Lobby to Custodial Closet**	1036	Water Cooler	Potable	**10/24/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-0922	**Women's Bathroom**	1023	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0923	**Women's Bathroom**	1023	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0924	**Men's Bathroom**	1021	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0925	**Men's Bathroom**	1021	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-0926	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0927	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0928	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-0929	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1315	**Dance Studio Corridor**	1049	Bottle Fill Station	Potable	**10/24/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1316	**Dance Studio Corridor**	1049	Water Cooler	Potable	**10/24/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1589	**Art Studio**	1052	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1590	**Art Studio**	1052	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1591	**A-9 Dark Room**	1054	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
NASS-1592	**Boys Locker Room**	1042	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-1596	**Boys Locker Room**	1042	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-1597	**Boys Locker Room**	1042	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use

Long Island High School for the Arts

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-1598	**Girls Locker Room**	1041	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-1599	**Girls Locker Room**	1041	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-1600	**Girls Locker Room**	1041	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-1601	**Girls Locker Room**	1041	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-1602	**Girls Locker Room**	1041	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-1603	**Girls Locker Room**	1041	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-1751	**Principal's Office**	1065G	Water Fountain-No Chiller	Potable	**10/24/2025**	**<1.00 ND**			Result Below Action Level Continue O&M

Haskett Drive Complex-Building F

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-1046	**Boiler Room**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
NASS-1047	**Warehouse**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1051	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1611	**Mens Bathroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1612	**Office Near Bathroom**	N/A	Bottle Fill Station	Potable	**10/24/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1613	**Office Near Bathroom**	N/A	Water Cooler	Potable	**10/24/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1614	**Mens Bathroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1615	**Hallway o/s Boiler Room**	N/A	Bottle Fill Station	Potable	**10/24/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1616	**Hallway o/s Boiler Room**	N/A	Water Cooler	Potable	**10/24/2025**	**<1.00 ND**			Result Below Action Level Continue O&M

OOS= Out of Service RFI = Removed from Inventory

Haskett Drive Complex-Building D

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-1016	**Equipment and Vehicle Storage**	N/A	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
NASS-1017	**Women's Restroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1018	**Men's Restroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1019	**Office**	N/A	Water Fountain-No Chiller	Potable	**10/24/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1048	**Boiler room**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1049	**Carpentry Room**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1052	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1604	**Equipment and Vehicle Storage**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1605	**Equipment and Vehicle Storage**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

Haskett Drive Complex-Building C

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-1020	**Office Bathroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1021	**Lunch Room**	N/A	Kitchen Faucet (Cold)	Potable	**10/24/2025**	**4.9**			Result Below Action Level Continue O&M
NASS-1023	**Men's Restroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1024	**Men's Restroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1025	**Women's Restroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1026	**Women's Restroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1027	**Custodial Closet**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
NASS-1053	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1606	**Lunch Room**	N/A	Bottled Water Dispenser	Potable	**10/24/2025**	**<1.00 ND**			Result Below Action Level Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

Iris Wolfson High School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-1057	**Janitor's Closet**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
NASS-1058	**Basement Corridor**	N/A	Water Cooler	Potable	**10/24/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1059	**Basement Corridor**	N/A	Water Cooler	Potable	**10/24/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1060	**Staff Restroom Unisex**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1061	**Basement Corridor**	N/A	Water Cooler	Potable	**10/24/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1062	**Basement Corridor**	N/A	Water Cooler	Potable	**10/24/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1063	**Art Room B2**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1064	**Girl's Restroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1066	**Boy's Restroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1067	**Boy's Restroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1068	**Girl's Restroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1069	**Girl's Restroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1070	**Boy's Restroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1072	**Staff Restoom Men**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1073	**Janitor's Closet**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
NASS-1074	**Office**	N/A	Classroom Faucet	Potable	**10/24/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1075	**Office**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1076	**Nurse's Office 107**	N/A	Nurse's Office Sink	Potable	**10/24/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1077	**Staff Restroom Women**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1080	**Warming Station 104B**	N/A	Kitchen Faucet (Cold)	Potable	**10/24/2025**	**<1.00 ND**			Result Below Action Level Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

Iris Wolfson High School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-1081	**Room 104B**	N/A	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
NASS-1082	**Janitor's Closet**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
NASS-1083	**Second Floor Corridor**	N/A	Water Cooler	Potable	**10/24/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1084	**Second Floor Corridor**	N/A	Water Cooler	Potable	**10/24/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1085	**Janitor's Closet**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
NASS-1086	**Staff Restroom Women**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1087	**Staff Restroom Men**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1088	**Boy's Restroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1089	**Boy's Restroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1090	**Girl's Restroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1091	**Girl's Restroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1093	**Student Activities 301**	N/A	Kitchen Faucet (Cold)	Potable	**10/24/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1094	**Staff Restroom Women**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1095	**Staff Restroom Men**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1096	**Boy's Restroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1097	**Boy's Restroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1098	**Girl's Restroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1099	**Girl's Restroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1100	**Third Floor Corridor**	N/A	Water Cooler	Potable	**10/24/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1101	**Third Floor Corridor**	N/A	Water Cooler	Potable	**10/24/2025**	**<1.00 ND**			Result Below Action Level Continue O&M

Iris Wolfson High School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-1102	**Janitor's Closet**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
NASS-1103	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1104	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1620	**Boys Bathroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1621	**Conference Room 105**	N/A	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-1622	**Nurse Office**	N/A	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
NASS-1623	**Girls Bathroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1624	**B4 Faculty Lounge**	N/A	Kitchen Faucet (Cold)	Potable	**10/24/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1625	**B4 Faculty Lounge**	N/A	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
NASS-1626	**B4 Faculty Lounge**	N/A	Bottled Water Dispenser	Potable	**10/24/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1627	**B4 Faculty Lounge**	N/A	Ice Machine	Potable	**10/24/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1628	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1752	**First Floor Corridor**	N/A	Bottle Fill Station	Potable	**10/24/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1753	**First Floor Corridor**	N/A	Water Cooler	Potable	**10/24/2025**	**<1.00 ND**			Result Below Action Level Continue O&M

North Shore Equestrian Center Indoor Arena

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-1105	**Faculty Bathroom**	1003	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1108	**Restroom**	1005	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1112	**Café**	1008	Kitchen Faucet (Cold)	Potable	**10/31/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1113	**Café**	1008	Kitchen Faucet (Cold)	Potable	**10/31/2025**	**1.2**			Result Below Action Level Continue O&M
NASS-1122	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1674	**Women's Bathroom**	1004	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1675	**Office Bathroom**	1006B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1676	**Office Bathroom**	1006B	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
NASS-1677	**Laundry Room**	1009	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
NASS-1678	**Laundry Room**	1009	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1679	**Laundry Room**	1009	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1680	**Laundry Room**	1009	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1681	**Laundry Room**	1009	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1683	**Stables**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1684	**Stables**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1685	**Stables**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1686	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1687	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1688	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1689	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

North Shore Equestrian Center Indoor Arena

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-1690	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

North Shore Equestrian Center Barn

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-1119	**Bathroom 1**	2004	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1120	**Bathroom 2**	2005	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1127	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1691	**Horse Stables**	1000	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1692	**Horse Stables**	1000	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
NASS-1693	**Bathroom 3**	2006	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
NASS-1694	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1695	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1696	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1697	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1698	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1699	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

Saint Bernard's Parish

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-1132	**Corridor**	2017	Water Fountain-No Chiller	Potable	**10/31/2025**	**OOS**			Testing Required Before Return to Service
NASS-1143	**Custodial Closet**	2007	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
NASS-1144	**Corridor**	2017	Water Fountain-No Chiller	Potable	**10/31/2025**	**OOS**			Testing Required Before Return to Service
NASS-1145	**Storage 200 Bathroom**	2000A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1146	**Corridor**	N/A	Water Fountain-No Chiller	Non-Applicable					Placarded for Non-Drinking Use
NASS-1147	**Basement Closet**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
NASS-1148	**Women's Restroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1149	**Women's Restroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1150	**Women's Restroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1151	**Women's Restroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1152	**Women's Restroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1153	**Men's Restroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1154	**Men's Restroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1155	**Men's Restroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1156	**Men's Restroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1157	**Men's Restroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1158	**Kitchen**	N/A	Kitchen Faucet (Cold)	Non-Applicable					Placarded for Non-Drinking Use
NASS-1159	**Kitchen**	N/A	Kitchen Faucet (Cold)	Non-Applicable					Placarded for Non-Drinking Use
NASS-1160	**Kitchen**	N/A	Kitchen Faucet (Cold)	Non-Applicable					Placarded for Non-Drinking Use
NASS-1161	**Bioler Room**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Saint Bernard's Parish

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-1162	**Office Bathroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1163	**Restroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1164	**Men's Restroom**	N/A		Non-Applicable					Placarded for Non-Drinking Use
NASS-1165	**Men's Restroom**	N/A		Non-Applicable					Placarded for Non-Drinking Use
NASS-1166	**Men's Restroom**	N/A		Non-Applicable					Placarded for Non-Drinking Use
NASS-1167	**Men's Restroom**	N/A		Non-Applicable					Placarded for Non-Drinking Use
NASS-1168	**Custodian's Closet**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
NASS-1169	**Women's Restroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1170	**Women's Restroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1171	**Women's Restroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1172	**Auditorium Kitchen**	N/A	Kitchen Faucet (Cold)	Non-Applicable					Placarded for Non-Drinking Use
NASS-1173	**Room 100**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1174	**Room 101 Bathroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1175	**Corridor**	N/A	Water Fountain-No Chiller	Non-Applicable					Placarded for Non-Drinking Use
NASS-1176	**Men's Restroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1177	**Men's Restroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1178	**Men's Restroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1179	**Men's Restroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1180	**Men's Restroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1181	**Custodial Closet**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use

Saint Bernard's Parish

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-1182	**Women's Restroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1183	**Women's Restroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1184	**Women's Restroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1185	**Women's Restroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1186	**Women's Restroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1187	**Women's Restroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1188	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1189	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1190	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1191	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1192	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1662	**Men's Restroom**	2006	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1663	**Men's Restroom**	2006	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1664	**Men's Restroom**	2006	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1665	**Men's Restroom**	2006	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1666	**Men's Restroom**	2006	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1667	**Women's Restroom**	2008	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1668	**Women's Restroom**	2008	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1669	**Women's Restroom**	2008	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1670	**Women's Restroom**	2008	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Saint Bernard’s Parish

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-1671	**Women's Restroom**	2008	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1672	**Room 213**	2014	Bottled Water Dispenser	Potable	**10/31/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1673	**Room 213**	2014	Bottled Water Dispenser	Potable	**10/31/2025**	**OOS**			Testing Required Before Return to Service

OOS= Out of Service **RFI = Removed from Inventory**

Brookville Outdoor Educational Center

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-1231	**Classroom Restroom**	1000B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1232	**Men's Restroom**	1003	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1233	**Women's Restroom**	1002	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1700	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1701	**Classroom**	1000	Bottle Fill Station	Potable	**10/31/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1702	**Classroom**	1000	Water Cooler	Potable	**10/31/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1703	**Classroom Bathroom 1**	1000A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1704	**Classroom**	1000	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1705	**Classroom**	1000	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Caumsett State Park Garage

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-1235	**Outdoor Education**	1006	Classroom Faucet	Potable	**10/31/2025**	**5.2**			Removed From Service, Pending Remediation
NASS-1236	**Nassau Boces Office/Storage**	1007A	Kitchen Faucet (Cold)	Potable	**10/31/2025**	**8.5**			Removed From Service, Pending Remediation
NASS-1239	**Public Women's Restroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1240	**Public Women's Restroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1241	**Public Men's Restroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1242	**Public Men's Restroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1243	**Public Family Restroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1706	**Public Entry**	1005	Bottle Fill Station	Potable	**10/31/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1707	**Public Entry**	1005	Water Cooler	Potable	**10/31/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1708	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

SESSC at Rosemary Kennedy Center

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-1246	**Kitchen**	N/A	Kitchen Faucet (Cold)	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1247	**Men's Bathroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1248	**Men's Bathroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1249	**Custodial Closet**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
NASS-1251	**Women's Bathroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1252	**Women's Bathroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1287	**O/S Women's Restroom**	N/A	Bottle Fill Station	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1288	**O/S Women's Restroom**	N/A	Water Cooler	Potable	**10/25/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1859	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
NASS-1860	**Exterior Hose Bib**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

North Annex (Endo) Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-1527	**Hallway o/s Room 208**	2022	Bottle Fill Station	Potable	**10/24/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1528	**Hallway o/s Room 208**	2022	Water Cooler	Potable	**10/24/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1529	**Hallway o/s Room 208**	2022	Water Cooler	Potable	**10/24/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1530	**Womens Bathrom 209**	2010	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1531	**Womens Bathrom 209**	2010	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1532	**Womens Bathrom 209**	2010	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1533	**Womens Bathrom 209**	2010	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1534	**Mens Bathroom 207**	2008	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1535	**Mens Bathroom 207**	2008	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1536	**Mens Bathroom 207**	2008	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1537	**Mens Bathroom 207**	2008	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1538	**Faculty Lounge 227**	2029	Kitchen Faucet (Cold)	Potable	**10/24/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1539	**Staff Room 210**	2011	Bottled Water Dispenser	Potable	**10/24/2025**	**OOS**			Testing Required Before Return to Service
NASS-1540	**Staff Room 210**	2011	Bottled Water Dispenser	Potable	**10/24/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1541	**Nurse Office 109**	1010	Nurse's Office Sink	Potable	**10/24/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1542	**Nurse Office 109**	1010	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
NASS-1543	**Womens Bathroom 111**	1008	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1544	**Womens Bathroom 111**	1008	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1545	**Womens Bathroom 111**	1008	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1546	**Womens Bathroom 111**	1008	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

North Annex (Endo) Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Potable/ Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
NASS-1547	**Hallway o/s Bathroom 111**	1020	Water Cooler	Potable	**10/24/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1548	**Hallway o/s Bathroom 111**	1020	Water Cooler	Potable	**10/24/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
NASS-1549	**Student Bathroom 113**	1007	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1550	**Student Bathroom 113**	1007	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1551	**Student Bathroom 113**	1007	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1552	**Student Bathroom 113**	1007	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
NASS-1553	**Custodial Closet 114**	1004	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use

Attachment 3:

Laboratory Analytical Reports



J.C. Broderick & Associates, Inc.
Environmental Consulting & Testing
1775 Expressway Drive North
Hauppauge, New York 11788
631.584.5492 fax 631.584.3395

Lead in Water: Chain of Custody for ED 56663

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-56115

Building: Joseph M. Barry Career & Technical Education Center
BARR

Client: Nassau BOCES

Walk In

Retest/New Install | |

Turn Around: Normal 1 wk / Rush_____

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
OCT 21 25, PM01:38

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
NASS-0553	NO	N/A	E-124	NS	10/21/2025	6:35:00 AM
NASS-0594	HA	N/A	HA NEAR WOMENS	WC	10/21/2025	6:33:00 AM
NASS-0595	HA	N/A	HA NEAR WOMENS	WC	10/21/2025	6:33:00 AM
NASS-0596	KI	N/A	Culinary E-117	IM	10/21/2025	6:52:00 AM
NASS-0599	KI	N/A	Culinary E-117	HW	10/21/2025	6:53:00 AM
NASS-0600	KI	N/A	Culinary E-117	PK	10/21/2025	6:49:00 AM
NASS-0601	KI	N/A	Culinary E-117	HW	10/21/2025	7:57:00 AM
NASS-0605	KI	N/A	Culinary E-117	KC	10/21/2025	6:42:00 AM
NASS-0606	KI	N/A	Culinary E-117	HW	10/21/2025	6:41:00 AM
NASS-0607	KI	N/A	Culinary E-117	HW	10/21/2025	6:41:00 AM
NASS-0610	KI	N/A	Culinary E-117	HW	10/21/2025	6:40:00 AM
NASS-0611	KI	N/A	Culinary E-117	HW	10/21/2025	6:38:00 AM
NASS-0613	CA	N/A	E-111	WC	10/21/2025	6:54:00 AM
NASS-0622	HA	N/A	HA NEAR E-111	WC	10/21/2025	6:30:00 AM
NASS-0623	HA	N/A	HA NEAR E-111	WC	10/21/2025	6:30:00 AM
NASS-0637	KI	N/A	Kitchen E-105	KC	10/21/2025	6:59:00 AM
NASS-0638	KI	N/A	Kitchen E-105	HW	10/21/2025	7:52:00 AM
NASS-0639	KI	N/A	Kitchen E-105	HW	10/21/2025	7:55:00 AM

Pb 200.8 Washington 10/23/25

Building Address
1196 Prospect Ave
Westbury , NY 11590

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WHARTON 10/21/25 1:38pm

Signature: David Wharton

Samplers Name: Maisha Yaseen

Samplers Signature: Maisha Yaseen

JCB Project Manager: Paul Fazio

Lead in Water: Chain of Custody for ED56663

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-56115

Building: Joseph M. Barry Career & Technical Education Center
BARR

Client: Nassau BOCES

Retest/New Install [ ]

Turn Around: Normal 1 wk / Rush_____

RECEIVED
ENSL ANALYTICAL, INC.
OCT 21 25, PM01:39

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
NASS-0640	KI	N/A	Kitchen E-105	HW	10/21/2025	7:52:00 AM
NASS-0641	KI	N/A	Kitchen E-105	HW	10/21/2025	7:53:00 AM
NASS-0645	KI	N/A	Kitchen E-105	HW	10/21/2025	7:54:00 AM
NASS-0646	KI	N/A	Kitchen E-105	HW	10/21/2025	7:54:00 AM
NASS-0647	KI	N/A	Kitchen E-105	KC	10/21/2025	6:58:00 AM
NASS-0658	FL	N/A	C231	KC	10/21/2025	7:05:00 AM
NASS-0662	NO	N/A	C230	NS	10/21/2025	7:08:00 AM
NASS-0671	HA	N/A	HA NEAR C223	WC	10/21/2025	7:11:00 AM
NASS-0672	HA	N/A	HA NEAR C223	WC	10/21/2025	7:11:00 AM
NASS-0689	CR	N/A	C210	KC	10/21/2025	7:16:00 AM
NASS-0691	CR	N/A	C201	KC	10/21/2025	7:13:00 AM
NASS-0722	CR	N/A	W328 TRADE	WC	10/21/2025	7:28:00 AM
NASS-0740	FL	N/A	Faculty Lounge W336	KC	10/21/2025	7:37:00 AM
NASS-0746	HA	N/A	HA NEAR C209	WC	10/21/2025	7:21:00 AM
NASS-0747	HA	N/A	HA NEAR C209	WC	10/21/2025	7:22:00 AM
NASS-1300	HA	N/A	Corridor o/s Room W316	WF	10/21/2025	7:35:00 AM
NASS-1301	HA	N/A	Corridor o/s Room W316	WC	10/21/2025	7:35:00 AM
NASS-1302	HA	N/A	Corridor o/s Room W306	WF	10/21/2025	7:25:00 AM

PB 200.8 10/23/25

Building Address
1196 Prospect Ave
Westbury , NY 11590

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WHARTON 10/21/25 1:38 pm

Signature: David Wharton

Samplers Name: Maisha Yaseen

Samplers Signature: Maisha Yaseen

JCB Project Manager: Paul Fazio

Lead in Water: Chain of Custody for ED56663

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-56115

Building: Joseph M. Barry Career & Technical Education Center
BARR

Client: Nassau BOCES

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
NASS-1303	HA	N/A	Corridor o/s Room W306	WC	10/21/2025	7:25:00 AM
NASS-1304	HA	N/A	Corridor o/s Room W306	WC	10/21/2025	7:25:00 AM
NASS-1745	KI	N/A	Culinary E-117	CP	10/21/2025	6:45:00 AM
NASS-1746	KI	N/A	Kitchen E-105	CP	10/21/2025	7:01:00 AM
NASS-1936	KI	N/A	Culinary E-117	KC	10/21/2025	6:47:00 AM
NASS-1937	KI	N/A	Culinary E-117	KC	10/21/2025	6:36:00 AM
NASS-1963	HA	N/A	Hallway o/s C231	WC	10/21/2025	7:07:00 AM
NASS-1964	HA	N/A	Hallway o/s C231	WF	10/21/2025	7:07:00 AM
NASS-1965	HA	N/A	Hallway o/s C231	WC	10/21/2025	7:07:00 AM
NASS-1974	CR	N/A	C-207	DC	10/21/2025	7:46:00 AM
NASS-1975	CR	N/A	C-207	DC	10/21/2025	7:46:00 AM
NASS-1976	CR	N/A	C-207	DC	10/21/2025	7:46:00 AM
NASS-1992	HA	N/A	Hallway o/s W-323A	WC	10/21/2025	7:30:00 AM

Samples Submitted 49

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
OCT 21 25, PM01:39

10/23/25

Building Address
1196 Prospect Ave
Westbury , NY 11590

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WHARTON 10/21/25 1:38 pm

Signature: Dave Wharton

Samplers Name: Maisha Yaseen

Samplers Signature: Maisha Yaseen

JCB Project Manager: Paul Fazio

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556663
LIMS Reference ID: ED56663
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: 23-56115 - Nassau BOCES - Joseph M. Barry Career & Technical Education Center BARR - 1196 Prospect Ave, Westbury, NY 11590
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/21/2025 13:38
Reported: 11/18/2025 08:55

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: NASS-0553		**Lims Reference ID:**		**ED56663-01**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/23/25 16:31	10/23/25 16:31	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0594		**Lims Reference ID:**		**ED56663-02**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									
Lead	1.9		1	1.0	µg/L	10/23/25 16:33	10/23/25 16:33	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0595		**Lims Reference ID:**		**ED56663-03**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/23/25 16:34	10/23/25 16:34	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0596		**Lims Reference ID:**		**ED56663-04**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/24/25 16:43	10/24/25 16:43	KT1	EPA 200.8 (Dig)/EPA 200.8
Sample: NASS-0599		**Lims Reference ID:**		**ED56663-05**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/23/25 16:38	10/23/25 16:38	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0600		**Lims Reference ID:**		**ED56663-06**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									
Lead	1.6		1	1.0	µg/L	10/23/25 16:39	10/23/25 16:39	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0601		**Lims Reference ID:**		**ED56663-07**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/23/25 16:40	10/23/25 16:40	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0605		**Lims Reference ID:**		**ED56663-08**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									
Lead	1.2		1	1.0	µg/L	10/23/25 16:42	10/23/25 16:42	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0606		**Lims Reference ID:**		**ED56663-09**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556663
LIMS Reference ID: ED56663
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: 23-56115 - Nassau BOCES - Joseph M. Barry Career & Technical Education Center BARR - 1196 Prospect Ave, Westbury, NY 11590
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/21/2025 13:38
Reported: 11/18/2025 08:55

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: NASS-0606 (Continued)		**Lims Reference ID:**		**ED56663-09**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	10/23/25 16:43	10/23/25 16:43	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0607		**Lims Reference ID:**		**ED56663-10**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/23/25 16:44	10/23/25 16:44	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0610		**Lims Reference ID:**		**ED56663-11**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/23/25 16:45	10/23/25 16:45	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0611		**Lims Reference ID:**		**ED56663-12**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									
Lead	1.0		1	1.0	µg/L	10/23/25 16:49	10/23/25 16:49	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0613		**Lims Reference ID:**		**ED56663-13**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/23/25 16:53	10/23/25 16:53	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0622		**Lims Reference ID:**		**ED56663-14**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/23/25 16:54	10/23/25 16:54	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0623		**Lims Reference ID:**		**ED56663-15**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/23/25 16:56	10/23/25 16:56	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0637		**Lims Reference ID:**		**ED56663-16**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									
Lead	4.6		1	1.0	µg/L	10/23/25 16:57	10/23/25 16:57	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0638		**Lims Reference ID:**		**ED56663-17**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556663
LIMS Reference ID: ED56663
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: 23-56115 - Nassau BOCES - Joseph M. Barry Career & Technical Education Center BARR - 1196 Prospect Ave, Westbury, NY 11590
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/21/2025 13:38
Reported: 11/18/2025 08:55

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: NASS-0638 (Continued)		**Lims Reference ID:**		**ED56663-17**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	10/23/25 16:58	10/23/25 16:58	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0639		**Lims Reference ID:**		**ED56663-18**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									
Lead	1.2		1	1.0	µg/L	10/23/25 17:00	10/23/25 17:00	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0640		**Lims Reference ID:**		**ED56663-19**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									
Lead	3.7		1	1.0	µg/L	10/23/25 17:01	10/23/25 17:01	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0641		**Lims Reference ID:**		**ED56663-20**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/23/25 17:02	10/23/25 17:02	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0645		**Lims Reference ID:**		**ED56663-21**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									
Lead	3.0		1	1.0	µg/L	10/23/25 17:18	10/23/25 17:18	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0646		**Lims Reference ID:**		**ED56663-22**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									
Lead	1.1		1	1.0	µg/L	10/23/25 17:21	10/23/25 17:21	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0647		**Lims Reference ID:**		**ED56663-23**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									
Lead	2.6		1	1.0	µg/L	10/23/25 17:23	10/23/25 17:23	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0658		**Lims Reference ID:**		**ED56663-24**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/23/25 17:24	10/23/25 17:24	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0662		**Lims Reference ID:**		**ED56663-25**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556663
LIMS Reference ID: ED56663
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: 23-56115 - Nassau BOCES - Joseph M. Barry Career & Technical Education Center BARR - 1196 Prospect Ave, Westbury, NY 11590
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/21/2025 13:38
Reported: 11/18/2025 08:55

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: NASS-0662 (Continued)		**Lims Reference ID:**		**ED56663-25**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	10/23/25 17:28	10/23/25 17:28	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0671		**Lims Reference ID:**		**ED56663-26**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/23/25 17:29	10/23/25 17:29	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0672		**Lims Reference ID:**		**ED56663-27**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									
Lead	19.6		1	1.0	µg/L	10/23/25 17:30	10/23/25 17:30	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0689		**Lims Reference ID:**		**ED56663-28**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									
Lead	3.1		1	1.0	µg/L	10/24/25 16:44	10/24/25 16:44	KT1	EPA 200.8 (Dig)/EPA 200.8
Sample: NASS-0691		**Lims Reference ID:**		**ED56663-29**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/23/25 17:32	10/23/25 17:32	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0722		**Lims Reference ID:**		**ED56663-30**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/23/25 17:33	10/23/25 17:33	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0740		**Lims Reference ID:**		**ED56663-31**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/23/25 17:34	10/23/25 17:34	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0746		**Lims Reference ID:**		**ED56663-32**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/23/25 17:35	10/23/25 17:35	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0747		**Lims Reference ID:**		**ED56663-33**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556663
LIMS Reference ID: ED56663
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: 23-56115 - Nassau BOCES - Joseph M. Barry Career & Technical Education Center BARR - 1196 Prospect Ave, Westbury, NY 11590
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/21/2025 13:38
Reported: 11/18/2025 08:55

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: NASS-0747 (Continued)		**Lims Reference ID:**		**ED56663-33**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	10/23/25 17:39	10/23/25 17:39	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1300		**Lims Reference ID:**		**ED56663-34**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/23/25 17:43	10/23/25 17:43	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1301		**Lims Reference ID:**		**ED56663-35**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/23/25 17:44	10/23/25 17:44	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1302		**Lims Reference ID:**		**ED56663-36**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/23/25 17:46	10/23/25 17:46	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1303		**Lims Reference ID:**		**ED56663-37**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/23/25 17:47	10/23/25 17:47	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1304		**Lims Reference ID:**		**ED56663-38**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/23/25 17:48	10/23/25 17:48	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1745		**Lims Reference ID:**		**ED56663-39**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/23/25 17:50	10/23/25 17:50	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1746		**Lims Reference ID:**		**ED56663-40**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/23/25 17:51	10/23/25 17:51	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1936		**Lims Reference ID:**		**ED56663-41**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556663
LIMS Reference ID: ED56663
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: 23-56115 - Nassau BOCES - Joseph M. Barry Career & Technical Education Center BARR - 1196 Prospect Ave, Westbury, NY 11590
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/21/2025 13:38
Reported: 11/18/2025 08:55

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: NASS-1936 (Continued)		**Lims Reference ID:**		**ED56663-41**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals (Continued)									
Lead	1.6		1	1.0	µg/L	10/23/25 17:52	10/23/25 17:52	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1937		**Lims Reference ID:**		**ED56663-42**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									
Lead	1.1		1	1.0	µg/L	10/23/25 18:19	10/23/25 18:19	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1963		**Lims Reference ID:**		**ED56663-43**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/23/25 18:23	10/23/25 18:23	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1964		**Lims Reference ID:**		**ED56663-44**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/23/25 18:24	10/23/25 18:24	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1965		**Lims Reference ID:**		**ED56663-45**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/23/25 18:25	10/23/25 18:25	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1974		**Lims Reference ID:**		**ED56663-46**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									
Lead	4.5		1	1.0	µg/L	10/23/25 18:29	10/23/25 18:29	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1975		**Lims Reference ID:**		**ED56663-47**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									
Lead	5.5		1	1.0	µg/L	10/23/25 18:31	10/23/25 18:31	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1976		**Lims Reference ID:**		**ED56663-48**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									
Lead	11.0		1	1.0	µg/L	10/23/25 18:32	10/23/25 18:32	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1992		**Lims Reference ID:**		**ED56663-49**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556663
LIMS Reference ID: ED56663
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: 23-56115 - Nassau BOCES - Joseph M. Barry Career & Technical Education Center BARR - 1196 Prospect Ave, Westbury, NY 11590
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/21/2025 13:38
Reported: 11/18/2025 08:55

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: NASS-1992 (Continued)			**Lims Reference ID:**	**ED56663-49**	**Matrix: Drinking Water**			**Sampled:**	**10/21/25 00:00:00**
Metals (Continued)									
Lead	**< 1.0**		1	1.0	µg/L	10/23/25 18:33	10/23/25 18:33	KT1	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556663
LIMS Reference ID: ED56663
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: 23-56115 - Nassau BOCES - Joseph M. Barry Career & Technical Education Center BARR - 1196 Prospect Ave, Westbury, NY 11590
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/21/2025 13:38
Reported: 11/18/2025 08:55

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556663
LIMS Reference ID: ED56663
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name:	23-56115 - Nassau BOCES - Joseph M. Barry Career & Technical Education Center BARR - 1196 Prospect Ave, Westbury, NY 11590
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	10/21/2025 13:38
Reported:	11/18/2025 08:55

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.



James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

ED56939

Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-56115

Building: Brookville Outdoor Educational Center

BOEC

Client: Nassau BOCES

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
NASS-1701	CR	1000	Classroom	WF	10/31/2025	10:00:00 AM
NASS-1702	CR	1000	Classroom	WC	10/31/2025	10:00:00 AM

Samples Submitted 2

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
NOV 03 25, PM02:05

Walk In

Building Address
195 Brookville Road
Glen Head , NY 11545

111705
200.8

Analysis Type: ELAP 200.5

Lab Recieved: Carle

Signature:

Samplers Name: Maisha Yaseen

Samplers Signature: Maisha Yaseen

JCB Project Manager: Paul Fazio

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556939

LIMS Reference ID: ED56939

EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: JCB#: 23-56115, Brookville Outdoor Educational Center, Nassau Boces, 195 Brookville Road, Glen Head, NY 11545

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 11/03/2025 14:05

Reported: 11/18/2025 09:19

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: NASS-1701		**Lims Reference ID:**		**ED56939-01**	**Matrix: Drinking Water**				**Sampled: 10/31/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	11/07/25 00:27	11/07/25 00:27	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1702		**Lims Reference ID:**		**ED56939-02**	**Matrix: Drinking Water**				**Sampled: 10/31/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	11/07/25 00:28	11/07/25 00:28	DAZ	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556939
LIMS Reference ID: ED56939
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: JCB#: 23-56115, Brookville Outdoor Educational Center, Nassau Boces, 195 Brookville Road, Glen Head, NY 11545
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 11/03/2025 14:05
Reported: 11/18/2025 09:19

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556939
LIMS Reference ID: ED56939
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name:	JCB#: 23-56115, Brookville Outdoor Educational Center, Nassau Boces, 195 Brookville Road, Glen Head, NY 11545
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	11/03/2025 14:05
Reported:	11/18/2025 09:19

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for

ED566662

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-56115

Building: Career Preparatory High School

CPHS

Client: Nassau BOCES

Walk In

Retest/New Install [ ]

Turn Around: (Normal 1 wk) Rush_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
NASS-0824	SP	N/A	WEIGHT ROOM 128	WC	10/21/2025	7:02:00 AM
NASS-0828	CA	N/A	STUDENTS CAFETERIA	WC	10/21/2025	6:59:00 AM
NASS-0829	CA	N/A	STUDENTS CAFETERIA	WC	10/21/2025	6:59:00 AM
NASS-0834	KI	N/A	Room 136	HW	10/21/2025	6:50:00 AM
NASS-0837	KI	N/A	CULINARY ARTS RM115	HW	10/21/2025	6:49:00 AM
NASS-0838	KI	N/A	CULINARY ARTS RM115	KC	10/21/2025	6:48:00 AM
NASS-0839	KI	N/A	CULINARY ARTS RM115	KC	10/21/2025	6:48:00 AM
NASS-0840	KI	N/A	CULINARY ARTS RM115	IM	10/21/2025	6:56:00 AM
NASS-0841	KI	N/A	CULINARY ARTS RM115	HW	10/21/2025	6:47:00 AM
NASS-0843	KI	N/A	CULINARY ARTS RM115	HW	10/21/2025	6:52:00 AM
NASS-0861	NO	N/A	NURSE OFFICE 102	NS	10/21/2025	7:08:00 AM
NASS-0866	FL	N/A	Faculty Lounge 113	KC	10/21/2025	7:06:00 AM
NASS-0871	HA	N/A	HA	WC	10/21/2025	7:04:00 AM
NASS-0872	HA	N/A	HA	WC	10/21/2025	7:04:00 AM
NASS-0873	CA	N/A	RM 218	KC	10/21/2025	7:16:00 AM
NASS-0874	CA	N/A	RM 218	WC	10/21/2025	7:17:00 AM
NASS-0875	CA	N/A	RM 218	WC	10/21/2025	7:17:00 AM
NASS-0876	HA	N/A	HA	WC	10/21/2025	7:14:00 AM

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
OCT 24 25 PM 2:37

Pb 200.8 10/24/25

Building Address
111 Cantiague Rock Rd
Westbury , NY 11590

Analysis Type: ELAP 200.5

Lab Recieved: 10/21/25 13:37

Signature: [signature]

Samplers Name: Olivia Sanfilippo

Samplers Signature: [signature]

JCB Project Manager: Paul Fa[illegible]

Lead in Water: Chain of Custody for ED56662

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-56115

Building: Career Preparatory High School

CPHS

Client: Nassau BOCES

Retest/New Install [ ]

Turn Around: ~~Normal~~ 1 wk Rush_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
NASS-0877	HA	N/A	HA	WC	10/21/2025	7:15:00 AM
NASS-0889	HA	N/A	HA BY ELEVATOR	WC	10/21/2025	7:13:00 AM
NASS-1253	HA	N/A	HA	WC	10/21/2025	7:09:00 AM
NASS-1254	HA	N/A	HA	WC	10/21/2025	7:09:00 AM
NASS-1929	HA	N/A	HA o/s Conference Room	WC	10/21/2025	7:07:00 AM

Samples Submitted 23

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
OCT 21 25, PM01:38

on hold 8-20-26

Building Address
111 Cantiague Rock Rd
Westbury , NY 11590

Analysis Type: ELAP 200.5

Lab Recieved: 10/21/25 13:38

Signature:

Samplers Name: Olivia Santilippo

Samplers Signature: Olivia

JCB Project Manager: Paul Fa...

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556662
LIMS Reference ID: ED56662
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: Career Preparatory High School: 111 Cantiague Rock Rd, Westbury, NY 11590: Nassau BOCES: Project# 23-56115
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/21/2025 13:37
Reported: 11/18/2025 08:54

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: NASS-0824		**Lims Reference ID:**		**ED56662-01**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	10/22/25 15:52	10/22/25 15:52	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0828		**Lims Reference ID:**		**ED56662-02**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	10/22/25 15:56	10/22/25 15:56	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0829		**Lims Reference ID:**		**ED56662-03**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	10/22/25 15:57	10/22/25 15:57	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0834		**Lims Reference ID:**		**ED56662-04**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	10/24/25 16:34	10/24/25 16:34	KT1	EPA 200.8 (Dig)/EPA 200.8
Sample: NASS-0837		**Lims Reference ID:**		**ED56662-05**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	10/22/25 15:58	10/22/25 15:58	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0838		**Lims Reference ID:**		**ED56662-06**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	10/22/25 16:02	10/22/25 16:02	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0839		**Lims Reference ID:**		**ED56662-07**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									
Lead	**1.4**		1	1.0	µg/L	10/24/25 16:35	10/24/25 16:35	KT1	EPA 200.8 (Dig)/EPA 200.8
Sample: NASS-0840		**Lims Reference ID:**		**ED56662-08**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	10/24/25 16:37	10/24/25 16:37	KT1	EPA 200.8 (Dig)/EPA 200.8
Sample: NASS-0841		**Lims Reference ID:**		**ED56662-09**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556662
LIMS Reference ID: ED56662
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: Career Preparatory High School: 111 Cantiague Rock Rd, Westbury, NY 11590: Nassau BOCES: Project# 23-56115
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/21/2025 13:37
Reported: 11/18/2025 08:54

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: NASS-0841 (Continued)		**Lims Reference ID:**		**ED56662-09**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals (Continued)									
Lead	1.2		1	1.0	µg/L	10/22/25 16:04	10/22/25 16:04	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0843		**Lims Reference ID:**		**ED56662-10**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/22/25 16:05	10/22/25 16:05	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0861		**Lims Reference ID:**		**ED56662-11**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/22/25 16:06	10/22/25 16:06	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0866		**Lims Reference ID:**		**ED56662-12**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/22/25 16:08	10/22/25 16:08	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0871		**Lims Reference ID:**		**ED56662-13**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/22/25 16:09	10/22/25 16:09	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0872		**Lims Reference ID:**		**ED56662-14**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/22/25 16:10	10/22/25 16:10	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0873		**Lims Reference ID:**		**ED56662-15**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/22/25 16:14	10/22/25 16:14	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0874		**Lims Reference ID:**		**ED56662-16**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/22/25 16:18	10/22/25 16:18	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0875		**Lims Reference ID:**		**ED56662-17**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556662
LIMS Reference ID: ED56662
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: Career Preparatory High School: 111 Cantiague Rock Rd, Westbury, NY 11590: Nassau BOCES: Project# 23-56115
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/21/2025 13:37
Reported: 11/18/2025 08:54

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: NASS-0875 (Continued)		**Lims Reference ID:**		**ED56662-17**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals (Continued)									
Lead	1.6		1	1.0	µg/L	10/24/25 16:41	10/24/25 16:41	KT1	EPA 200.8 (Dig)/EPA 200.8
Sample: NASS-0876		**Lims Reference ID:**		**ED56662-18**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/22/25 16:19	10/22/25 16:19	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0877		**Lims Reference ID:**		**ED56662-19**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/22/25 16:21	10/22/25 16:21	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0889		**Lims Reference ID:**		**ED56662-20**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/22/25 16:22	10/22/25 16:22	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1253		**Lims Reference ID:**		**ED56662-21**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/22/25 16:23	10/22/25 16:23	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1254		**Lims Reference ID:**		**ED56662-22**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/22/25 16:25	10/22/25 16:25	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1929		**Lims Reference ID:**		**ED56662-23**	**Matrix: Drinking Water**				**Sampled: 10/21/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/22/25 16:26	10/22/25 16:26	JH	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556662
LIMS Reference ID: ED56662
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: Career Preparatory High School: 111 Cantiague Rock Rd, Westbury, NY 11590: Nassau BOCES: Project# 23-56115
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/21/2025 13:37
Reported: 11/18/2025 08:54

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556662
LIMS Reference ID: ED56662
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name:	Career Preparatory High School: 111 Cantiague Rock Rd, Westbury, NY 11590: Nassau BOCES: Project# 23-56115
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	10/21/2025 13:37
Reported:	11/18/2025 08:54

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for

ED56722

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-56115

Building: Carman Road School

CRS

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
OCT 23 25, PM02:03

Walk In

Client: Nassau BOCES

Retest/New Install [ ]

Turn Around: (Normal 1 wk) Rush_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
NASS-0459	NO	1001	Health Office	NS	10/22/2025	6:05:00 AM
NASS-0461	NO	1002	Nurse Office	NS	10/22/2025	6:02:00 AM
NASS-0464	KI	1007	Kitchen	KC	10/22/2025	5:36:00 AM
NASS-0465	KI	1007	Kitchen	KC	10/22/2025	5:37:00 AM
NASS-0466	KI	1007	Kitchen	KC	10/22/2025	5:38:00 AM
NASS-0467	KI	1007	Kitchen	KC	10/22/2025	5:38:00 AM
NASS-0474	CR	1018	Room 8	CF	10/22/2025	5:44:00 AM
NASS-0478	CR	1019	Room 9	CF	10/22/2025	5:45:00 AM
NASS-0479	CR	1020	Room 10	CF	10/22/2025	5:47:00 AM
NASS-0480	CR	1021	Room 11	CF	10/22/2025	5:48:00 AM
NASS-0482	CR	1022	Room 12	CF	10/22/2025	5:49:00 AM
NASS-0483	CR	1023	Room 13	CF	10/22/2025	5:51:00 AM
NASS-0484	CR	1024	Room 14	CF	10/22/2025	5:52:00 AM
NASS-0485	CR	1025	Room 15	CF	10/22/2025	5:53:00 AM
NASS-0486	CR	1026	Room 16	CF	10/22/2025	5:54:00 AM
NASS-0487	CR	1027	Room 17	CF	10/22/2025	5:55:00 AM
NASS-0488	CR	1028	Room 18	CF	10/22/2025	5:56:00 AM
NASS-0493	CR	1035	Room 7	CF	10/22/2025	6:13:00 AM

Ab 2008 Kaufman 10/30/25

Building Address
Carmans Road
Massapequa Park , NY 11762

Analysis Type: ELAP 200.5

Lab Recieved: 10/23/25 14:03

Signature: Kay Wagner

Samplers Name: Olivia Santilippo

Samplers Signature: Olivia S

JCB Project Manager: Paul Faz

Lead in Water: Chain of Custody for

ED56722

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-56115

Building: Carman Road School

CRS

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
OCT 23 25, PM02:03

Client: Nassau BOCES

Retest/New Install:

Turn Around: Normal 1 wk Rush_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
NASS-0495	CR	1036	Room 6	CF	10/22/2025	6:13:00 AM
NASS-0497	CR	1037	Room 4	CF	10/22/2025	6:15:00 AM
NASS-0501	CR	1039	Room 3	CF	10/22/2025	6:19:00 AM
NASS-0503	CR	1041	Room 1	CF	10/22/2025	6:20:00 AM
NASS-0505	BR	1042A	Room 2 Changing Room/Bathroom	BF	10/22/2025	6:22:00 AM
NASS-0507	CR	1043	Physical Therapy Room	CF	10/22/2025	6:24:00 AM
NASS-0513	CR	1056	Room 20	CF	10/22/2025	6:42:00 AM
NASS-0515	OF	1060	Room 22	CF	10/22/2025	6:31:00 AM
NASS-0516	HE	1062	Room 21	EC	10/22/2025	6:33:00 AM
NASS-0517	HE	1062	Room 21	WF	10/22/2025	6:33:00 AM
NASS-0520	CR	1063	Room 24	CF	10/22/2025	6:35:00 AM
NASS-0521	CR	1064	Room 23	CF	10/22/2025	6:37:00 AM
NASS-0523	CR	1065	Learning Center	CF	10/22/2025	6:38:00 AM
NASS-0529	CR	1071	Room 26	CF	10/22/2025	6:45:00 AM
NASS-0530	CR	1072	Room 25	CF	10/22/2025	6:47:00 AM
NASS-0531	CR	1073	Room 28 / School store	CF	10/22/2025	6:49:00 AM
NASS-0532	CR	1074	Room 27	CF	10/22/2025	6:50:00 AM
NASS-0533	CR	1075	Room 30	CF	10/22/2025	6:51:00 AM

Pb 200.8 Analysis 10/30/25

Building Address
Carmans Road
Massapequa Park , NY 11762

Analysis Type: ELAP 200.5

Lab Recieved: 10/23/25 14:03

Signature:

Samplers Name: Olivia Sanfilippo

Samplers Signature:

JCB Project Manager: Paul Fa

Lead in Water: Chain of Custody for

ED 56722

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
OCT 23 25, PM02:03

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-56115

Client: Nassau BOCES

Building: Carman Road School

CRS

Retest/New Install

Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
NASS-0534	CR	1076	Room 29	CF	10/22/2025	6:52:00 AM
NASS-0535	CR	1077	PT Room 32	CF	10/22/2025	6:54:00 AM
NASS-0536	CR	1079	OT Room 34	CF	10/22/2025	6:57:00 AM
NASS-0537	CR	1078	Room 31	CF	10/22/2025	6:55:00 AM
NASS-1305	HA	1004	Entrance Lobby	WF	10/22/2025	6:08:00 AM
NASS-1306	HA	1004	Entrance Lobby	WC	10/22/2025	6:08:00 AM
NASS-1307	HA	1040	Corridor o/s Room 7	WF	10/22/2025	6:11:00 AM
NASS-1308	HA	1040	Corridor o/s Room 7	WC	10/22/2025	6:12:00 AM
NASS-1309	HA	1083	Corridor o/s Assitant Principal Room	WF	10/22/2025	6:26:00 AM
NASS-1310	HA	1083	Corridor o/s Assitant Principal Room	WC	10/22/2025	6:27:00 AM
NASS-1311	HA	1083	Corridor o/s Room 26	WF	10/22/2025	6:46:00 AM
NASS-1312	HA	1083	Corridor o/s Room 26	WC	10/22/2025	6:41:00 AM
NASS-1313	HA	1029	Corridor o/s Room 11	WF	10/22/2025	5:58:00 AM
NASS-1314	HA	1029	Corridor o/s Room 11	WC	10/22/2025	5:59:00 AM
NASS-1554	NO	1001	Health Office	NS	10/22/2025	6:06:00 AM
NASS-1555	NO	1002	Health Office	NS	10/22/2025	6:06:00 AM
NASS-1747	CR	1038	Room 5	CF	10/22/2025	6:17:00 AM
NASS-1748	BR	1006B2	Gymanasium Volunteer Room Bathroom	BF	10/22/2025	7:43:00 AM

Building Address
Carmans Road
Massapequa Park , NY 11762

Analysis Type: ELAP 200.5

Lab Recieved: 10/23/25 1403

Signature: MAY HANOVER

Samplers Name: Olivia Santilippo

Samplers Signature: Olivia S

JCB Project Manager: Paul F

Photo 8 Kaplan Duo 10/30/25

Lead in Water: Chain of Custody for ED56722

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-56115

Building: Carman Road School

CRS

Client: Nassau BOCES

Retest/New Install [ ]

Turn Around: ~~Normal 1 wk~~ **Rush**_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time

Samples Submitted 54

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
OCT 23 25, PM02:03

PB 200.8 Kathleen 10/30/25

Building Address
Carmans Road
Massapequa Park , NY 11762

Analysis Type: ELAP 200.5

Lab Recieved: 10/23/25 1403

Signature: MAY WAGNER

Samplers Name: Olivia Sanfilippo

Samplers Signature: Olivia

JCB Project Manager: Paul Fazi

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556722
LIMS Reference ID: ED56722
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: Carman Road School: Carmans Road, Massapequa Park, NY 11762: Nassau BOCES: Project# 23-56115
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/23/2025 14:03
Reported: 11/18/2025 08:59

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556722
LIMS Reference ID: ED56722
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: Carman Road School: Carmans Road, Massapequa Park, NY 11762: Nassau BOCES: Project# 23-56115
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/23/2025 14:03
Reported: 11/18/2025 08:59

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: NASS-0459		**Lims Reference ID:**		**ED56722-01**	**Matrix: Drinking Water**				**Sampled: 10/22/25 06:05:00**
Metals									
Lead	**1.3**		1	1.0	µg/L	10/31/25 12:59	10/31/25 12:59	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0461		**Lims Reference ID:**		**ED56722-02**	**Matrix: Drinking Water**				**Sampled: 10/22/25 06:02:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	10/31/25 13:03	10/31/25 13:03	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0464		**Lims Reference ID:**		**ED56722-03**	**Matrix: Drinking Water**				**Sampled: 10/22/25 05:36:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	10/31/25 13:05	10/31/25 13:05	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0465		**Lims Reference ID:**		**ED56722-04**	**Matrix: Drinking Water**				**Sampled: 10/22/25 05:37:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	10/31/25 13:08	10/31/25 13:08	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0466		**Lims Reference ID:**		**ED56722-05**	**Matrix: Drinking Water**				**Sampled: 10/22/25 05:38:00**
Metals									
Lead	**13.4**		1	1.0	µg/L	10/31/25 13:10	10/31/25 13:10	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0467		**Lims Reference ID:**		**ED56722-06**	**Matrix: Drinking Water**				**Sampled: 10/22/25 05:38:00**
Metals									
Lead	**27.3**		1	1.0	µg/L	10/31/25 13:11	10/31/25 13:11	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0474		**Lims Reference ID:**		**ED56722-07**	**Matrix: Drinking Water**				**Sampled: 10/22/25 05:44:00**
Metals									
Lead	**1.3**		1	1.0	µg/L	10/31/25 13:12	10/31/25 13:12	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0478		**Lims Reference ID:**		**ED56722-08**	**Matrix: Drinking Water**				**Sampled: 10/22/25 05:45:00**
Metals									
Lead	**2.1**		1	1.0	µg/L	10/31/25 13:14	10/31/25 13:14	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0479		**Lims Reference ID:**		**ED56722-09**	**Matrix: Drinking Water**				**Sampled: 10/22/25 05:47:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556722
LIMS Reference ID: ED56722
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: Carman Road School: Carmans Road, Massapequa Park, NY 11762: Nassau BOCES: Project# 23-56115
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/23/2025 14:03
Reported: 11/18/2025 08:59

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: NASS-0479 (Continued)			**Lims Reference ID:**	**ED56722-09**	**Matrix: Drinking Water**				**Sampled: 10/22/25 05:47:00**
Metals (Continued)									
Lead	1.4		1	1.0	µg/L	10/31/25 13:15	10/31/25 13:15	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0480			**Lims Reference ID:**	**ED56722-10**	**Matrix: Drinking Water**				**Sampled: 10/22/25 05:48:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/31/25 13:16	10/31/25 13:16	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0482			**Lims Reference ID:**	**ED56722-11**	**Matrix: Drinking Water**				**Sampled: 10/22/25 05:49:00**
Metals									
Lead	1.8		1	1.0	µg/L	10/31/25 13:17	10/31/25 13:17	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0483			**Lims Reference ID:**	**ED56722-12**	**Matrix: Drinking Water**				**Sampled: 10/22/25 05:51:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/31/25 13:24	10/31/25 13:24	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0484			**Lims Reference ID:**	**ED56722-13**	**Matrix: Drinking Water**				**Sampled: 10/22/25 05:52:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/31/25 13:25	10/31/25 13:25	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0485			**Lims Reference ID:**	**ED56722-14**	**Matrix: Drinking Water**				**Sampled: 10/22/25 05:53:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/31/25 00:00	10/31/25 14:23	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0486			**Lims Reference ID:**	**ED56722-15**	**Matrix: Drinking Water**				**Sampled: 10/22/25 05:54:00**
Metals									
Lead	1.3		1	1.0	µg/L	10/30/25 17:50	10/30/25 17:50	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0487			**Lims Reference ID:**	**ED56722-16**	**Matrix: Drinking Water**				**Sampled: 10/22/25 05:55:00**
Metals									
Lead	1.4		1	1.0	µg/L	10/30/25 17:53	10/30/25 17:53	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0488			**Lims Reference ID:**	**ED56722-17**	**Matrix: Drinking Water**				**Sampled: 10/22/25 05:56:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556722
LIMS Reference ID: ED56722
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: Carman Road School: Carmans Road, Massapequa Park, NY 11762: Nassau BOCES: Project# 23-56115
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/23/2025 14:03
Reported: 11/18/2025 08:59

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: NASS-0488 (Continued)			**Lims Reference ID:**	**ED56722-17**	**Matrix: Drinking Water**				**Sampled: 10/22/25 05:56:00**
Metals (Continued)									
Lead	**2.3**		1	1.0	µg/L	10/30/25 17:55	10/30/25 17:55	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0493			**Lims Reference ID:**	**ED56722-18**	**Matrix: Drinking Water**				**Sampled: 10/22/25 06:13:00**
Metals									
Lead	**1.0**		1	1.0	µg/L	10/30/25 17:56	10/30/25 17:56	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0495			**Lims Reference ID:**	**ED56722-19**	**Matrix: Drinking Water**				**Sampled: 10/22/25 06:13:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	10/30/25 17:57	10/30/25 17:57	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0497			**Lims Reference ID:**	**ED56722-20**	**Matrix: Drinking Water**				**Sampled: 10/22/25 06:15:00**
Metals									
Lead	**2.5**		1	1.0	µg/L	10/30/25 18:01	10/30/25 18:01	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0501			**Lims Reference ID:**	**ED56722-21**	**Matrix: Drinking Water**				**Sampled: 10/22/25 06:19:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	10/30/25 18:02	10/30/25 18:02	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0503			**Lims Reference ID:**	**ED56722-22**	**Matrix: Drinking Water**				**Sampled: 10/22/25 06:20:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	10/30/25 18:04	10/30/25 18:04	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0505			**Lims Reference ID:**	**ED56722-23**	**Matrix: Drinking Water**				**Sampled: 10/22/25 06:22:00**
Metals									
Lead	**1.5**		1	1.0	µg/L	10/30/25 18:05	10/30/25 18:05	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0507			**Lims Reference ID:**	**ED56722-24**	**Matrix: Drinking Water**				**Sampled: 10/22/25 06:24:00**
Metals									
Lead	**138**		2	2.0	µg/L	10/30/25 18:26	10/30/25 18:26	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0513			**Lims Reference ID:**	**ED56722-25**	**Matrix: Drinking Water**				**Sampled: 10/22/25 06:42:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556722
LIMS Reference ID: ED56722
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: Carman Road School: Carmans Road, Massapequa Park, NY 11762: Nassau BOCES: Project# 23-56115
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/23/2025 14:03
Reported: 11/18/2025 08:59

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: NASS-0513 (Continued)			**Lims Reference ID:**	**ED56722-25**	**Matrix: Drinking Water**				**Sampled: 10/22/25 06:42:00**
Metals (Continued)									
Lead	**1.6**		1	1.0	µg/L	10/30/25 18:08	10/30/25 18:08	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0515			**Lims Reference ID:**	**ED56722-26**	**Matrix: Drinking Water**				**Sampled: 10/22/25 06:31:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	10/30/25 18:11	10/30/25 18:11	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0516			**Lims Reference ID:**	**ED56722-27**	**Matrix: Drinking Water**				**Sampled: 10/22/25 06:33:00**
Metals									
Lead	**1.1**		1	1.0	µg/L	10/30/25 18:13	10/30/25 18:13	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0517			**Lims Reference ID:**	**ED56722-28**	**Matrix: Drinking Water**				**Sampled: 10/22/25 06:33:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	10/30/25 18:17	10/30/25 18:17	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0520			**Lims Reference ID:**	**ED56722-29**	**Matrix: Drinking Water**				**Sampled: 10/22/25 06:35:00**
Metals									
Lead	**3.7**		1	1.0	µg/L	10/30/25 18:18	10/30/25 18:18	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0521			**Lims Reference ID:**	**ED56722-30**	**Matrix: Drinking Water**				**Sampled: 10/22/25 06:37:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	10/30/25 18:19	10/30/25 18:19	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0523			**Lims Reference ID:**	**ED56722-31**	**Matrix: Drinking Water**				**Sampled: 10/22/25 06:38:00**
Metals									
Lead	**4.7**		1	1.0	µg/L	10/30/25 18:21	10/30/25 18:21	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0529			**Lims Reference ID:**	**ED56722-32**	**Matrix: Drinking Water**				**Sampled: 10/22/25 06:45:00**
Metals									
Lead	**2.5**		1	1.0	µg/L	10/30/25 18:22	10/30/25 18:22	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0530			**Lims Reference ID:**	**ED56722-33**	**Matrix: Drinking Water**				**Sampled: 10/22/25 06:47:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556722
LIMS Reference ID: ED56722
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: Carman Road School: Carmans Road, Massapequa Park, NY 11762: Nassau BOCES: Project# 23-56115
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/23/2025 14:03
Reported: 11/18/2025 08:59

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: NASS-0530 (Continued)			**Lims Reference ID:**	**ED56722-33**	**Matrix: Drinking Water**				**Sampled: 10/22/25 06:47:00**
Metals (Continued)									
Lead	1.4		1	1.0	µg/L	10/30/25 18:23	10/30/25 18:23	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0531			**Lims Reference ID:**	**ED56722-34**	**Matrix: Drinking Water**				**Sampled: 10/22/25 06:49:00**
Metals									
Lead	2.0		1	1.0	µg/L	10/30/25 18:24	10/30/25 18:24	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0532			**Lims Reference ID:**	**ED56722-35**	**Matrix: Drinking Water**				**Sampled: 10/22/25 06:50:00**
Metals									
Lead	1.4		1	1.0	µg/L	10/30/25 15:28	10/30/25 15:28	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0533			**Lims Reference ID:**	**ED56722-36**	**Matrix: Drinking Water**				**Sampled: 10/22/25 06:51:00**
Metals									
Lead	3.3		1	1.0	µg/L	10/30/25 15:31	10/30/25 15:31	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0534			**Lims Reference ID:**	**ED56722-37**	**Matrix: Drinking Water**				**Sampled: 10/22/25 06:52:00**
Metals									
Lead	2.7		1	1.0	µg/L	10/30/25 15:33	10/30/25 15:33	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0535			**Lims Reference ID:**	**ED56722-38**	**Matrix: Drinking Water**				**Sampled: 10/22/25 06:54:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/30/25 15:34	10/30/25 15:34	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0536			**Lims Reference ID:**	**ED56722-39**	**Matrix: Drinking Water**				**Sampled: 10/22/25 06:57:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/30/25 15:38	10/30/25 15:38	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0537			**Lims Reference ID:**	**ED56722-40**	**Matrix: Drinking Water**				**Sampled: 10/22/25 06:55:00**
Metals									
Lead	1.1		1	1.0	µg/L	10/30/25 15:39	10/30/25 15:39	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1305			**Lims Reference ID:**	**ED56722-41**	**Matrix: Drinking Water**				**Sampled: 10/22/25 06:08:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556722
LIMS Reference ID: ED56722
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: Carman Road School: Carmans Road, Massapequa Park, NY 11762: Nassau BOCES: Project# 23-56115
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/23/2025 14:03
Reported: 11/18/2025 08:59

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: NASS-1305 (Continued)		**Lims Reference ID:**		**ED56722-41**	**Matrix: Drinking Water**				**Sampled: 10/22/25 06:08:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	10/30/25 15:40	10/30/25 15:40	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1306		**Lims Reference ID:**		**ED56722-42**	**Matrix: Drinking Water**				**Sampled: 10/22/25 06:08:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/30/25 15:42	10/30/25 15:42	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1307		**Lims Reference ID:**		**ED56722-43**	**Matrix: Drinking Water**				**Sampled: 10/22/25 06:11:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/30/25 15:43	10/30/25 15:43	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1308		**Lims Reference ID:**		**ED56722-44**	**Matrix: Drinking Water**				**Sampled: 10/22/25 06:12:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/30/25 15:44	10/30/25 15:44	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1309		**Lims Reference ID:**		**ED56722-45**	**Matrix: Drinking Water**				**Sampled: 10/22/25 06:26:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/30/25 15:45	10/30/25 15:45	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1310		**Lims Reference ID:**		**ED56722-46**	**Matrix: Drinking Water**				**Sampled: 10/22/25 06:27:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/30/25 15:50	10/30/25 15:50	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1311		**Lims Reference ID:**		**ED56722-47**	**Matrix: Drinking Water**				**Sampled: 10/22/25 06:46:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/30/25 15:53	10/30/25 15:53	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1312		**Lims Reference ID:**		**ED56722-48**	**Matrix: Drinking Water**				**Sampled: 10/22/25 06:41:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/30/25 15:55	10/30/25 15:55	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1313		**Lims Reference ID:**		**ED56722-49**	**Matrix: Drinking Water**				**Sampled: 10/22/25 05:58:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556722
LIMS Reference ID: ED56722
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: Carman Road School: Carmans Road, Massapequa Park, NY 11762: Nassau BOCES: Project# 23-56115
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/23/2025 14:03
Reported: 11/18/2025 08:59

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: NASS-1313 (Continued)		**Lims Reference ID:**		**ED56722-49**	**Matrix: Drinking Water**				**Sampled: 10/22/25 05:58:00**
Metals (Continued)									
Lead	**< 1.0**		1	1.0	µg/L	10/30/25 15:56	10/30/25 15:56	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1314		**Lims Reference ID:**		**ED56722-50**	**Matrix: Drinking Water**				**Sampled: 10/22/25 05:59:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	10/30/25 15:57	10/30/25 15:57	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1554		**Lims Reference ID:**		**ED56722-51**	**Matrix: Drinking Water**				**Sampled: 10/22/25 06:06:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	10/30/25 15:58	10/30/25 15:58	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1555		**Lims Reference ID:**		**ED56722-52**	**Matrix: Drinking Water**				**Sampled: 10/22/25 06:06:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	10/30/25 16:00	10/30/25 16:00	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1747		**Lims Reference ID:**		**ED56722-53**	**Matrix: Drinking Water**				**Sampled: 10/22/25 06:17:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	10/30/25 16:01	10/30/25 16:01	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1748		**Lims Reference ID:**		**ED56722-54**	**Matrix: Drinking Water**				**Sampled: 10/22/25 07:43:00**
Metals									
Lead	**1.4**		1	1.0	µg/L	10/30/25 16:02	10/30/25 16:02	KT1	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556722
LIMS Reference ID: ED56722
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: Carman Road School: Carmans Road, Massapequa Park, NY 11762: Nassau BOCES: Project# 23-56115
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/23/2025 14:03
Reported: 11/18/2025 08:59

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

ED56949

Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-56115

Building: Caumsett State Park Garage

CSPMG

Client: Nassau BOCES

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
NASS-1235	CR	1006	Outdoor Education	CF	10/31/2025	10:43:00 AM
NASS-1236	KI	1007A	Nassau Boces Office/Storage	KC	10/31/2025	10:42:00 AM
NASS-1706	HA	1005	Public Entry	WF	10/31/2025	10:45:00 AM
NASS-1707	HA	1005	Public Entry	WC	10/31/2025	10:45:00 AM

Samples Submitted 4

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
NOV 03 25, PM02:04

Walk In

Building Address
29 Lloyd Harbor Road
Huntington , NY 11743

11/7/25
PO800.8

Analysis Type: ELAP 200.5

Lab Recieved: S. Cherofsky 11/3/25

Signature: S. Cherofsky 2:04PM

Samplers Name: Maisha Yaseen

Samplers Signature: Maisha Yaseen

JCB Project Manager: Paul Fazio

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556949
LIMS Reference ID: ED56949
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: 23-56115, Nassau BOCES, Caumsett State Park Garage, 29 Lloyd Harbor Road, Huntington, NY 11743
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 11/03/2025 14:04
Reported: 11/18/2025 09:22

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: NASS-1235		**Lims Reference ID:**		**ED56949-01**	**Matrix: Drinking Water**				**Sampled: 10/31/25 00:00:00**
Metals									
Lead	**5.2**		1	1.0	µg/L	11/07/25 00:33	11/07/25 00:33	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1236		**Lims Reference ID:**		**ED56949-02**	**Matrix: Drinking Water**				**Sampled: 10/31/25 00:00:00**
Metals									
Lead	**8.5**		1	1.0	µg/L	11/07/25 00:35	11/07/25 00:35	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1706		**Lims Reference ID:**		**ED56949-03**	**Matrix: Drinking Water**				**Sampled: 10/31/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	11/07/25 00:36	11/07/25 00:36	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1707		**Lims Reference ID:**		**ED56949-04**	**Matrix: Drinking Water**				**Sampled: 10/31/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	11/08/25 12:36	11/08/25 12:36	JH	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556949
LIMS Reference ID: ED56949
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: 23-56115, Nassau BOCES, Caumsett State Park Garage, 29 Lloyd Harbor Road, Huntington, NY 11743
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 11/03/2025 14:04
Reported: 11/18/2025 09:22

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556949
LIMS Reference ID: ED56949
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name:	23-56115, Nassau BOCES, Caumsett State Park Garage, 29 Lloyd Harbor Road, Huntington, NY 11743
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	11/03/2025 14:04
Reported:	11/18/2025 09:22

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

E056834

Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-56115
Building: Haskett Drive Complex-Building A
HDC-A

Client: Nassau BOCES
Courier
Retest/New Install [ ]
Turn Around: Normal 1 wk Rush_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
NASS-1030	SP		Automotive Garage	DW	10/24/2025	5:52:00 AM
NASS-1036	KI		Transportation Lunch Room	KC	10/24/2025	5:54:00 AM
NASS-1037	KI		Graphics Lunch Room	KC	10/24/2025	5:55:00 AM

Samples Submitted 3

B 200.8 Billing 11/6/25

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
OCT 28 25, PM12:49

Building Address
100 HaskettDrive
Syosset , NY 11791

Analysis Type: ELAP 200.5
Lab Recieved: S.Cherofsky 10/28/25
Signature: S. Cherofsky 12:49pm

Samplers Name: Olivia Sanfilippo
Samplers Signature: Olivia S
JCB Project Manager: Paul Faz

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556834
LIMS Reference ID: ED56834
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: 23-56115, Nassau BOCES, Haskett Drive Complex - Building A, 100 Haskett Diver, Syosset, NY 11791
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/28/2025 12:49
Reported: 11/18/2025 09:05

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: NASS-1030		**Lims Reference ID:**		**ED56834-01**	**Matrix: Drinking Water**				**Sampled: 10/24/25 00:00:00**
Metals									
Lead	**77.6**		1	1.0	µg/L	11/06/25 13:26	11/06/25 13:26	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1036		**Lims Reference ID:**		**ED56834-02**	**Matrix: Drinking Water**				**Sampled: 10/24/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	11/06/25 13:27	11/06/25 13:27	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1037		**Lims Reference ID:**		**ED56834-03**	**Matrix: Drinking Water**				**Sampled: 10/24/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	11/06/25 13:28	11/06/25 13:28	BP	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556834
LIMS Reference ID: ED56834
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: 23-56115, Nassau BOCES, Haskett Drive Complex - Building A, 100 Haskett Diver, Syosset, NY 11791
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/28/2025 12:49
Reported: 11/18/2025 09:05

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556834
LIMS Reference ID: ED56834
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: 23-56115, Nassau BOCES, Haskett Drive Complex - Building A, 100 Haskett Diver, Syosset, NY 11791
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/28/2025 12:49
Reported: 11/18/2025 09:05

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for ED56837

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-56115

Building: Haskett Drive Complex-Building C

HDC-C

Client: Nassau BOCES

Courier

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
NASS-1021	KI		Lunch Room	KC	10/24/2025	6:10:00 AM
NASS-1606	KI	N/A	Lunch Room	BW	10/24/2025	6:31:00 AM

Samples Submitted 2

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
OCT 28 25, PM12:50

Building Address
100 HaskettDrive
Syosset , NY 11791

11/7/25
PB200.8

Analysis Type: ELAP 200.5

Lab Recieved: S. Cherofsky 10/28/25

Signature: S. Cherofsky 12:50pm

Samplers Name: Olivia Santilippo

Samplers Signature: Olivia S

JCB Project Manager: Paul Faz

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556837
LIMS Reference ID: ED56837
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: 23-56115, Nassau BOCES, Haskett Drive Complex - Building C, 100 Haskett Drive, Syosset, NY 11791
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/28/2025 12:50
Reported: 11/18/2025 09:16

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: NASS-1021			**Lims Reference ID:**		**ED56837-01**	**Matrix: Drinking Water**			**Sampled: 10/24/25 00:00:00**
Metals									
Lead	**4.9**		1	1.0	µg/L	11/07/25 00:19	11/07/25 00:19	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1606			**Lims Reference ID:**		**ED56837-02**	**Matrix: Drinking Water**			**Sampled: 10/24/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	11/07/25 00:23	11/07/25 00:23	DAZ	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556837
LIMS Reference ID: ED56837
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: 23-56115, Nassau BOCES, Haskett Drive Complex - Building C, 100 Haskett Drive, Syosset, NY 11791
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/28/2025 12:50
Reported: 11/18/2025 09:16

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556837
LIMS Reference ID: ED56837
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: 23-56115, Nassau BOCES, Haskett Drive Complex - Building C, 100 Haskett Drive, Syosset, NY 11791
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/28/2025 12:50
Reported: 11/18/2025 09:16

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

ED56825

Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-56115

Building: Haskett Drive Complex-Building D

HDC-D

Client: Nassau BOCES

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
NASS-1019	OF		Office	DW	10/24/2025	6:05:00 AM

Samples Submitted 1

Courier

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
OCT 28 25, PM12:50

Rb 200.8 Kallus Lw 10/29/25

Building Address
100 HaskettDrive
Syosset , NY 11791

Analysis Type: ELAP 200.5

Lab Recieved: S. Cherofsky 10/28/25

Signature: S. Cherofsky 12:50pm

Samplers Name: Olivia Sanfilippo

Samplers Signature: Olivia

JCB Project Manager: Paul Fazzi

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556825
LIMS Reference ID: ED56825
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: 23-56115, Nassau BOCES, Haskett Drive Complex - Building D, 100 Haskett Drive, Syosset, NY 11791
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/28/2025 12:50
Reported: 11/18/2025 09:02

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: NASS-1019			**Lims Reference ID:**	**ED56825-01**	**Matrix: Drinking Water**			**Sampled:**	**10/24/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	10/29/25 15:16	10/29/25 15:16	KT1	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556825
LIMS Reference ID: ED56825
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: 23-56115, Nassau BOCES, Haskett Drive Complex - Building D, 100 Haskett Drive, Syosset, NY 11791
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/28/2025 12:50
Reported: 11/18/2025 09:02

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556825
LIMS Reference ID: ED56825
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: 23-56115, Nassau BOCES, Haskett Drive Complex - Building D, 100 Haskett Drive, Syosset, NY 11791
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/28/2025 12:50
Reported: 11/18/2025 09:02

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

ED56831

Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-56115

Building: Haskett Drive Complex-Building F

HDC-F

Client: Nassau BOCES

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
NASS-1612	OF	N/A	Office	WF	10/24/2025	6:20:00 AM
NASS-1613	OF	N/A	Office	WC	10/24/2025	6:20:00 AM
NASS-1615	HA	N/A	Hallway o/s Boiler Room	WF	10/24/2025	6:23:00 AM
NASS-1616	HA	N/A	Hallway o/s Boiler Room	WC	10/24/2025	6:23:00 AM

Samples Submitted 4

Courier

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
OCT 28 25, PM12:51

Building Address
100 HaskettDrive
Syosset , NY 11791

Analysis Type: ELAP 200.5

Lab Recieved: S. Cherofsky 10/28/25

Signature: S. Cherofsky 12:51 PM

Samplers Name: Olivia Santilippo

Samplers Signature: Olivia

JCB Project Manager: Paul Fa

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556831
LIMS Reference ID: ED56831
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: 23-56115, Nassau BOCES, Haskett Drive Complex - Building F, 100 Haskett Drive, Syosset, NY 11791
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/28/2025 12:51
Reported: 11/18/2025 09:03

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: NASS-1612		**Lims Reference ID:**		**ED56831-01**	**Matrix: Drinking Water**				**Sampled: 10/24/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	11/08/25 12:18	11/08/25 12:18	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1613		**Lims Reference ID:**		**ED56831-02**	**Matrix: Drinking Water**				**Sampled: 10/24/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	11/08/25 12:22	11/08/25 12:22	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1615		**Lims Reference ID:**		**ED56831-03**	**Matrix: Drinking Water**				**Sampled: 10/24/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	11/08/25 12:23	11/08/25 12:23	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1616		**Lims Reference ID:**		**ED56831-04**	**Matrix: Drinking Water**				**Sampled: 10/24/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	11/08/25 12:27	11/08/25 12:27	JH	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556831
LIMS Reference ID: ED56831
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: 23-56115, Nassau BOCES, Haskett Drive Complex - Building F, 100 Haskett Drive, Syosset, NY 11791
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/28/2025 12:51
Reported: 11/18/2025 09:03

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556831
LIMS Reference ID: ED56831
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: 23-56115, Nassau BOCES, Haskett Drive Complex - Building F, 100 Haskett Drive, Syosset, NY 11791
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/28/2025 12:51
Reported: 11/18/2025 09:03

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

ED56833

Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-56115
Building: Iris Wolfson High School
IWHS

Client: Nassau BOCES

Courier

Retest/New Install [ ]
Turn Around: Normal 1 wk Rush_____

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
OCT 28 25, PM12:53

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
NASS-1058	HA		Basement Corridor	WC	10/24/2025	7:52:00 AM
NASS-1059	HA		Basement Corridor	WC	10/24/2025	7:52:00 AM
NASS-1061	HA		Basement Corridor	WC	10/24/2025	7:50:00 AM
NASS-1062	HA		Basement Corridor	WC	10/24/2025	7:51:00 AM
NASS-1074	OF		Office	CF	10/24/2025	7:31:00 AM
NASS-1076	NO		Nurse's Office 107	NS	10/24/2025	7:34:00 AM
NASS-1080	KI		Warming Station 104B	KC	10/24/2025	7:25:00 AM
NASS-1083	HA		Second Floor Corridor	WC	10/24/2025	7:37:00 AM
NASS-1084	HA		Second Floor Corridor	WC	10/24/2025	7:37:00 AM
NASS-1093	HE		Student Activities 301	KC	10/24/2025	7:41:00 AM
NASS-1100	HA		Third Floor Corridor	WC	10/24/2025	7:39:00 AM
NASS-1101	HA		Third Floor Corridor	WC	10/24/2025	7:40:00 AM
NASS-1624	FL	N/A	B4 Faculty Lounge	KC	10/24/2025	7:45:00 AM
NASS-1626	FL	N/A	B4 Faculty Lounge	BW	10/24/2025	7:46:00 AM
NASS-1627	FL	N/A	B4 Faculty Lounge	IM	10/24/2025	7:49:00 AM
NASS-1752	HA	N/A	First Floor Corridor	WF	10/24/2025	7:28:00 AM
NASS-1753	HA	N/A	First Floor Corridor	WC	10/24/2025	7:29:00 AM

No 200.8 Bthy 11/6/25

Building Address
21 Chestnut Street
Greenvale , NY 11548

Analysis Type: ELAP 200.5
Lab Recieved: Rae
Signature:

Samplers Name: Olivia Santilippo
Samplers Signature: Olivia
JCB Project Manager: Paul Fazi

Lead in Water: Chain of Custody for EDS6833

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-56115

Building: Iris Wolfson High School
IWHS

Client: Nassau BOCES

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time

Samples Submitted 17

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
OCT 28 25, PM12:53

Building Address
21 Chestnut Street
Greenvale , NY 11548

Analysis Type: ELAP 200.5

Lab Recieved: Carle

Signature:

Samplers Name: Olivia Sanfilippo

Samplers Signature: Olivia S

JCB Project Manager: Paul Fazz

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556833
LIMS Reference ID: ED56833
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: JCB#: 23-56115, Iris Wolfson High School, Nassau BOCES, 21 Chestnut Street, Greenvale, NY 11548
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/28/2025 12:53
Reported: 11/18/2025 09:04

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: NASS-1058		**Lims Reference ID:**	**ED56833-01**	**Matrix: Drinking Water**					**Sampled: 10/24/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 12:51	11/06/25 12:51	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1059		**Lims Reference ID:**	**ED56833-02**	**Matrix: Drinking Water**					**Sampled: 10/24/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 12:55	11/06/25 12:55	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1061		**Lims Reference ID:**	**ED56833-03**	**Matrix: Drinking Water**					**Sampled: 10/24/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 12:56	11/06/25 12:56	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1062		**Lims Reference ID:**	**ED56833-04**	**Matrix: Drinking Water**					**Sampled: 10/24/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 12:58	11/06/25 12:58	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1074		**Lims Reference ID:**	**ED56833-05**	**Matrix: Drinking Water**					**Sampled: 10/24/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 13:03	11/06/25 13:03	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1076		**Lims Reference ID:**	**ED56833-06**	**Matrix: Drinking Water**					**Sampled: 10/24/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 13:05	11/06/25 13:05	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1080		**Lims Reference ID:**	**ED56833-07**	**Matrix: Drinking Water**					**Sampled: 10/24/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 13:06	11/06/25 13:06	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1083		**Lims Reference ID:**	**ED56833-08**	**Matrix: Drinking Water**					**Sampled: 10/24/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 13:07	11/06/25 13:07	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1084		**Lims Reference ID:**	**ED56833-09**	**Matrix: Drinking Water**					**Sampled: 10/24/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556833
LIMS Reference ID: ED56833
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: JCB#: 23-56115, Iris Wolfson High School, Nassau BOCES, 21 Chestnut Street, Greenvale, NY 11548
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/28/2025 12:53
Reported: 11/18/2025 09:04

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: NASS-1084 (Continued)		**Lims Reference ID:**		**ED56833-09**	**Matrix: Drinking Water**				**Sampled: 10/24/25 00:00:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	11/06/25 13:09	11/06/25 13:09	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1093		**Lims Reference ID:**		**ED56833-10**	**Matrix: Drinking Water**				**Sampled: 10/24/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 13:10	11/06/25 13:10	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1100		**Lims Reference ID:**		**ED56833-11**	**Matrix: Drinking Water**				**Sampled: 10/24/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 13:11	11/06/25 13:11	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1101		**Lims Reference ID:**		**ED56833-12**	**Matrix: Drinking Water**				**Sampled: 10/24/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 13:15	11/06/25 13:15	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1624		**Lims Reference ID:**		**ED56833-13**	**Matrix: Drinking Water**				**Sampled: 10/24/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 13:19	11/06/25 13:19	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1626		**Lims Reference ID:**		**ED56833-14**	**Matrix: Drinking Water**				**Sampled: 10/24/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 13:20	11/06/25 13:20	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1627		**Lims Reference ID:**		**ED56833-15**	**Matrix: Drinking Water**				**Sampled: 10/24/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 13:21	11/06/25 13:21	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1752		**Lims Reference ID:**		**ED56833-16**	**Matrix: Drinking Water**				**Sampled: 10/24/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 13:23	11/06/25 13:23	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1753		**Lims Reference ID:**		**ED56833-17**	**Matrix: Drinking Water**				**Sampled: 10/24/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556833
LIMS Reference ID: ED56833
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: JCB#: 23-56115, Iris Wolfson High School, Nassau BOCES, 21 Chestnut Street, Greenvale, NY 11548
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/28/2025 12:53
Reported: 11/18/2025 09:04

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: NASS-1753 (Continued)			**Lims Reference ID:**	**ED56833-17**	**Matrix: Drinking Water**			**Sampled:**	**10/24/25 00:00:00**
Metals (Continued)									
Lead	**< 1.0**		1	1.0	µg/L	11/06/25 13:24	11/06/25 13:24	BP	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556833
LIMS Reference ID: ED56833
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: JCB#: 23-56115, Iris Wolfson High School, Nassau BOCES, 21 Chestnut Street, Greenvale, NY 11548
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/28/2025 12:53
Reported: 11/18/2025 09:04

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556833
LIMS Reference ID: ED56833
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: JCB#: 23-56115, Iris Wolfson High School, Nassau BOCES, 21 Chestnut Street, Greenvale, NY 11548
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/28/2025 12:53
Reported: 11/18/2025 09:04

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for

ED56721

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

RECEIVED
OCT 23 25, PM02:01

Walk In

JCB #: 23-56115
Building: Jerusalem Avenue School
JAS

Client: EMSL ANALYTICAL, INC.
Nassau BOCES Carle Place, NY
Retest/New Install? [ ]
Turn Around: Normal 1 wk **Rush**_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
NASS-0286	CR	1000A	Room 101	CF	10/23/2025	6:20:00 AM
NASS-0287	CR	1001	Room 100	CF	10/23/2025	6:21:00 AM
NASS-0288	CR	1002A	Room 103	CF	10/23/2025	6:19:00 AM
NASS-0289	CR	1003A	Room 102	CF	10/23/2025	6:21:00 AM
NASS-0290	CR	1004	Room 105	CF	10/23/2025	6:18:00 AM
NASS-0291	CR	1007A	Room 107	CF	10/23/2025	6:18:00 AM
NASS-0292	CR	1006A	Room 106	CF	10/23/2025	6:22:00 AM
NASS-0293	CR	1008A	Room 108	CF	10/23/2025	6:24:00 AM
NASS-0294	CR	1009A	Room 109	CF	10/23/2025	6:16:00 AM
NASS-0295	CR	1010A	Room 111	CF	10/23/2025	6:16:00 AM
NASS-0319	CR	1016A	Room 116	CF	10/23/2025	6:14:00 AM
NASS-0350	CR	2029	Room 225	CF	10/23/2025	7:17:00 AM
NASS-0351	CR	2033	Room 229 Suite	CF	10/23/2025	7:18:00 AM
NASS-0373	CR	2047	Room 243	CF	10/23/2025	7:18:00 AM
NASS-0374	CR	2049	Room 245	CF	10/23/2025	7:17:00 AM
NASS-0382	CR	1018	Room 117	CF	10/23/2025	6:11:00 AM
NASS-0393	CR	1032A	Room 131	CF	10/23/2025	6:09:00 AM
NASS-0394	KI	1037A	Kitchen	KC	10/23/2025	6:05:00 AM

Pb 200.8 ICP-MS 10/28/25

Building Address
2351 Jerusalem Avenue
Bellmore , NY 11710

Analysis Type: ELAP 200.5
Lab Recieved: 10/23/25 14:01
Signature: [signature] MAY WARNER

Samplers Name: Maisha Yaseen
Samplers Signature: Maisha Yaseen
JCB Project Manager: Paul Fazio

Lead in Water: Chain of Custody for

ED56721

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-56115

Building: Jerusalem Avenue School

JAS

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
OCT 23 25, PM02:01

Client: Nassau BOCES

Retest/New Install | |

Turn Around: Normal 1 wk Rush_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
NASS-0395	KI	1037A	Kitchen	KC	10/23/2025	6:05:00 AM
NASS-0396	KI	1037A	Kitchen	KC	10/23/2025	6:05:00 AM
NASS-0399	KI	1037A	Kitchen	KC	10/23/2025	6:08:00 AM
NASS-0400	KI	1037A	Kitchen	KC	10/23/2025	6:07:00 AM
NASS-0401	KI	1037A	Kitchen	HW	10/23/2025	6:06:00 AM
NASS-0428	CR	1080	Room 180	CF	10/23/2025	6:32:00 AM
NASS-0429	CR	1080	Room 180	CF	10/23/2025	6:32:00 AM
NASS-0430	CR	1047C	Room 166 Kitchenette	CF	10/23/2025	6:46:00 AM
NASS-0431	CR	1047C	Room 166 Kitchenette	CF	10/23/2025	6:46:00 AM
NASS-0433	FL	1065	Faculty Room 159	CF	10/23/2025	6:44:00 AM
NASS-0440	CR	1057	Room 148	CF	10/23/2025	6:41:00 AM
NASS-0441	CR	1055	Room 145	CF	10/23/2025	6:39:00 AM
NASS-0442	CR	1054	Room 144	CF	10/23/2025	6:38:00 AM
NASS-1289	HA	1044	Corridor Room 129 to Room 143	WF	10/23/2025	6:04:00 AM
NASS-1290	HA	1044	Corridor Room 129 to Room 143	WC	10/23/2025	6:04:00 AM
NASS-1291	CR	1041B	Room 141	CF	10/23/2025	6:29:00 AM
NASS-1292	HA	2052	Corridor o/s Room 245	WF	10/23/2025	7:12:00 AM
NASS-1293	HA	2052	Corridor o/s Room 245	WC	10/23/2025	7:12:00 AM

Ob 200.8 10/28/25

Building Address
2351 Jerusalem Avenue
Bellmore , NY 11710

Analysis Type: ELAP 200.5

Lab Recieved: 10/23/25 14:01

Signature: KAY WALKER

Samplers Name: Maisha Yaseen

Samplers Signature: Maisha Yaseen

JCB Project Manager: Paul Fazio

Lead in Water: Chain of Custody for

G056721

RECEIVED
EMSL ANALYTICAL, INC.
OCT 23 25, PM02:01
Carle Place, NY

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-56115
Building: Jerusalem Avenue School
JAS

Client: Nassau BOCES
Retest/New Install [ ]
Turn Around: Normal 1 wk Rush_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
NASS-1294	HA	2052	Corridor o/s Room 222	WF	10/23/2025	7:05:00 AM
NASS-1295	HA	2052	Corridor o/s Room 222	WC	10/23/2025	7:05:00 AM
NASS-1296	HA	2052	Corridor o/s Room 235	WF	10/23/2025	7:08:00 AM
NASS-1297	HA	2052	Corridor o/s Room 235	WC	10/23/2025	7:08:00 AM
NASS-1298	HA	2052	Corridor o/s Room 238	WF	10/23/2025	7:09:00 AM
NASS-1299	HA	2052	Corridor o/s Room 238	WC	10/23/2025	7:09:00 AM
NASS-1513	HA	1017	Corridor Room 100 To Room 116	WF	10/23/2025	6:09:00 AM
NASS-1514	HA	1017	Corridor Room 100 To Room 116	WC	10/23/2025	6:09:00 AM
NASS-1515	HA	1044	Corridor Room 129 To Room 143	WF	10/23/2025	6:02:00 AM
NASS-1516	HA	1044	Corridor Room 129 To Room 143	WC	10/23/2025	6:02:00 AM
NASS-1517	HA	1082	Gym Corridor	WF	10/23/2025	6:00:00 AM
NASS-1518	HA	1082	Gym Corridor	WC	10/23/2025	5:59:00 AM
NASS-1641	HA	2023	Corridor o/s Room 215	WF	10/23/2025	7:01:00 AM
NASS-1642	HA	2023	Corridor o/s Room 215	WC	10/23/2025	7:01:00 AM
NASS-1651	HA	2023	Corridor o/s Room 200	WF	10/23/2025	6:59:00 AM
NASS-1652	HA	2023	Corridor o/s Room 200	WC	10/23/2025	6:59:00 AM
NASS-1709	KI	1037	Kitchen Serving	HW	10/23/2025	6:02:00 AM
NASS-1710	CR	2046	Room 242	CF	10/23/2025	7:25:00 AM

Pb 200.8 10/28/25

Building Address
2351 Jerusalem Avenue
Bellmore , NY 11710

Analysis Type: ELAP 200.5
Lab Recieved: 10/23/25 14:01
Signature:

Samplers Name: Maisha Yaseen
Samplers Signature: Maisha Yaseen
JCB Project Manager: Paul Fazio

Lead in Water: Chain of Custody for

E056721

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-56115

Building: Jerusalem Avenue School

JAS

Client: Nassau BOCES

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
NASS-1711	CR	2038A	Room 234	CF	10/23/2025	7:23:00 AM
NASS-1864	HA	1017	Corridor	WF	10/23/2025	6:11:00 AM
NASS-1865	HA	1017	Corridor	WC	10/23/2025	6:11:00 AM
NASS-1876	HA	1017	Corridor	WF	10/23/2025	6:07:00 AM
NASS-1877	HA	1017	Corridor	WC	10/23/2025	6:08:00 AM
NASS-1878	NO	1019	Nurse's Office	NS	10/23/2025	6:12:00 AM
NASS-1887	HA	1027	Corridor	WF	10/23/2025	6:06:00 AM
NASS-1888	HA	1027	Corridor	WC	10/23/2025	6:06:00 AM
NASS-1896	HA	1060	Corridor 144 to 151	WF	10/23/2025	6:42:00 AM
NASS-1897	HA	1060	Corridor 144 to 151	WC	10/23/2025	6:42:00 AM

Samples Submitted 64

Pb 200.8 [illegible] 10/28/25

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
OCT 23 25, PM02:02

Building Address
2351 Jerusalem Avenue
Bellmore , NY 11710

Analysis Type: ELAP 200.5

Lab Recieved: 10/23/25 14:01

Signature:

Samplers Name: Maisha Yaseen

Samplers Signature: Maisha Yaseen

JCB Project Manager: Paul Fazio

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556721
LIMS Reference ID: ED56721
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: Jerusalem Avenue School: 2351 Jerusalem Avenue, Bellmore, NY 11710: Nassau BOCES: Project# 23-56115
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/23/2025 14:01
Reported: 11/18/2025 08:58

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: NASS-0286		**Lims Reference ID:**	**ED56721-01**	**Matrix: Drinking Water**					**Sampled: 10/23/25 06:20:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/28/25 13:45	10/28/25 13:45	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0287		**Lims Reference ID:**	**ED56721-02**	**Matrix: Drinking Water**					**Sampled: 10/23/25 06:21:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/28/25 13:48	10/28/25 13:48	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0288		**Lims Reference ID:**	**ED56721-03**	**Matrix: Drinking Water**					**Sampled: 10/23/25 06:19:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/28/25 13:50	10/28/25 13:50	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0289		**Lims Reference ID:**	**ED56721-04**	**Matrix: Drinking Water**					**Sampled: 10/23/25 06:21:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/28/25 13:51	10/28/25 13:51	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0290		**Lims Reference ID:**	**ED56721-05**	**Matrix: Drinking Water**					**Sampled: 10/23/25 06:18:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/28/25 13:52	10/28/25 13:52	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0291		**Lims Reference ID:**	**ED56721-06**	**Matrix: Drinking Water**					**Sampled: 10/23/25 06:18:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/28/25 13:56	10/28/25 13:56	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0292		**Lims Reference ID:**	**ED56721-07**	**Matrix: Drinking Water**					**Sampled: 10/23/25 06:22:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/28/25 13:57	10/28/25 13:57	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0293		**Lims Reference ID:**	**ED56721-08**	**Matrix: Drinking Water**					**Sampled: 10/23/25 06:24:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/28/25 13:59	10/28/25 13:59	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0294		**Lims Reference ID:**	**ED56721-09**	**Matrix: Drinking Water**					**Sampled: 10/23/25 06:16:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556721
LIMS Reference ID: ED56721
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: Jerusalem Avenue School: 2351 Jerusalem Avenue, Bellmore, NY 11710: Nassau BOCES: Project# 23-56115
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/23/2025 14:01
Reported: 11/18/2025 08:58

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: NASS-0294 (Continued)		**Lims Reference ID:**		**ED56721-09**	**Matrix: Drinking Water**				**Sampled: 10/23/25 06:16:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	10/28/25 14:00	10/28/25 14:00	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0295		**Lims Reference ID:**		**ED56721-10**	**Matrix: Drinking Water**				**Sampled: 10/23/25 06:16:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/28/25 14:01	10/28/25 14:01	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0319		**Lims Reference ID:**		**ED56721-11**	**Matrix: Drinking Water**				**Sampled: 10/23/25 06:14:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/28/25 14:02	10/28/25 14:02	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0350		**Lims Reference ID:**		**ED56721-12**	**Matrix: Drinking Water**				**Sampled: 10/23/25 07:17:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/28/25 12:59	10/28/25 12:59	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0351		**Lims Reference ID:**		**ED56721-13**	**Matrix: Drinking Water**				**Sampled: 10/23/25 07:18:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/28/25 13:03	10/28/25 13:03	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0373		**Lims Reference ID:**		**ED56721-14**	**Matrix: Drinking Water**				**Sampled: 10/23/25 07:18:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/28/25 13:04	10/28/25 13:04	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0374		**Lims Reference ID:**		**ED56721-15**	**Matrix: Drinking Water**				**Sampled: 10/23/25 07:17:00**
Metals									
Lead	2.8		1	1.0	µg/L	10/28/25 13:06	10/28/25 13:06	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0382		**Lims Reference ID:**		**ED56721-16**	**Matrix: Drinking Water**				**Sampled: 10/23/25 06:11:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/28/25 13:10	10/28/25 13:10	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0393		**Lims Reference ID:**		**ED56721-17**	**Matrix: Drinking Water**				**Sampled: 10/23/25 06:09:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556721
LIMS Reference ID: ED56721
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: Jerusalem Avenue School: 2351 Jerusalem Avenue, Bellmore, NY 11710: Nassau BOCES: Project# 23-56115
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/23/2025 14:01
Reported: 11/18/2025 08:58

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: NASS-0393 (Continued)		**Lims Reference ID:**		**ED56721-17**	**Matrix: Drinking Water**				**Sampled: 10/23/25 06:09:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	10/28/25 13:11	10/28/25 13:11	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0394		**Lims Reference ID:**		**ED56721-18**	**Matrix: Drinking Water**				**Sampled: 10/23/25 06:05:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/28/25 13:12	10/28/25 13:12	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0395		**Lims Reference ID:**		**ED56721-19**	**Matrix: Drinking Water**				**Sampled: 10/23/25 06:05:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/28/25 13:13	10/28/25 13:13	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0396		**Lims Reference ID:**		**ED56721-20**	**Matrix: Drinking Water**				**Sampled: 10/23/25 06:05:00**
Metals									
Lead	5.3		1	1.0	µg/L	10/28/25 13:15	10/28/25 13:15	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0399		**Lims Reference ID:**		**ED56721-21**	**Matrix: Drinking Water**				**Sampled: 10/23/25 06:08:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/28/25 13:16	10/28/25 13:16	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0400		**Lims Reference ID:**		**ED56721-22**	**Matrix: Drinking Water**				**Sampled: 10/23/25 06:07:00**
Metals									
Lead	1.2		1	1.0	µg/L	10/28/25 13:17	10/28/25 13:17	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0401		**Lims Reference ID:**		**ED56721-23**	**Matrix: Drinking Water**				**Sampled: 10/23/25 06:06:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/28/25 13:21	10/28/25 13:21	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0428		**Lims Reference ID:**		**ED56721-24**	**Matrix: Drinking Water**				**Sampled: 10/23/25 06:32:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/28/25 13:25	10/28/25 13:25	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0429		**Lims Reference ID:**		**ED56721-25**	**Matrix: Drinking Water**				**Sampled: 10/23/25 06:32:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556721
LIMS Reference ID: ED56721
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: Jerusalem Avenue School: 2351 Jerusalem Avenue, Bellmore, NY 11710: Nassau BOCES: Project# 23-56115
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/23/2025 14:01
Reported: 11/18/2025 08:58

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: NASS-0429 (Continued)		**Lims Reference ID:**		**ED56721-25**	**Matrix: Drinking Water**				**Sampled: 10/23/25 06:32:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	10/28/25 13:26	10/28/25 13:26	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0430		**Lims Reference ID:**		**ED56721-26**	**Matrix: Drinking Water**				**Sampled: 10/23/25 06:46:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/28/25 13:27	10/28/25 13:27	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0431		**Lims Reference ID:**		**ED56721-27**	**Matrix: Drinking Water**				**Sampled: 10/23/25 06:46:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/28/25 13:29	10/28/25 13:29	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0433		**Lims Reference ID:**		**ED56721-28**	**Matrix: Drinking Water**				**Sampled: 10/23/25 06:44:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/28/25 13:30	10/28/25 13:30	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0440		**Lims Reference ID:**		**ED56721-29**	**Matrix: Drinking Water**				**Sampled: 10/23/25 06:41:00**
Metals									
Lead	1.7		1	1.0	µg/L	10/28/25 13:31	10/28/25 13:31	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0441		**Lims Reference ID:**		**ED56721-30**	**Matrix: Drinking Water**				**Sampled: 10/23/25 06:39:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/28/25 13:33	10/28/25 13:33	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0442		**Lims Reference ID:**		**ED56721-31**	**Matrix: Drinking Water**				**Sampled: 10/23/25 06:38:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/28/25 13:34	10/28/25 13:34	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1289		**Lims Reference ID:**		**ED56721-32**	**Matrix: Drinking Water**				**Sampled: 10/23/25 06:04:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/28/25 15:44	10/28/25 15:44	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1290		**Lims Reference ID:**		**ED56721-33**	**Matrix: Drinking Water**				**Sampled: 10/23/25 06:04:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556721
LIMS Reference ID: ED56721
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: Jerusalem Avenue School: 2351 Jerusalem Avenue, Bellmore, NY 11710: Nassau BOCES: Project# 23-56115
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/23/2025 14:01
Reported: 11/18/2025 08:58

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: NASS-1290 (Continued)		**Lims Reference ID:**		**ED56721-33**	**Matrix: Drinking Water**				**Sampled: 10/23/25 06:04:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	10/28/25 15:48	10/28/25 15:48	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1291		**Lims Reference ID:**		**ED56721-34**	**Matrix: Drinking Water**				**Sampled: 10/23/25 06:29:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/28/25 15:49	10/28/25 15:49	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1292		**Lims Reference ID:**		**ED56721-35**	**Matrix: Drinking Water**				**Sampled: 10/23/25 07:12:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/28/25 15:50	10/28/25 15:50	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1293		**Lims Reference ID:**		**ED56721-36**	**Matrix: Drinking Water**				**Sampled: 10/23/25 07:12:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/28/25 15:52	10/28/25 15:52	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1294		**Lims Reference ID:**		**ED56721-37**	**Matrix: Drinking Water**				**Sampled: 10/23/25 07:05:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/28/25 15:56	10/28/25 15:56	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1295		**Lims Reference ID:**		**ED56721-38**	**Matrix: Drinking Water**				**Sampled: 10/23/25 07:05:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/28/25 15:57	10/28/25 15:57	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1296		**Lims Reference ID:**		**ED56721-39**	**Matrix: Drinking Water**				**Sampled: 10/23/25 07:08:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/28/25 15:58	10/28/25 15:58	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1297		**Lims Reference ID:**		**ED56721-40**	**Matrix: Drinking Water**				**Sampled: 10/23/25 07:08:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/28/25 15:59	10/28/25 15:59	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1298		**Lims Reference ID:**		**ED56721-41**	**Matrix: Drinking Water**				**Sampled: 10/23/25 07:09:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556721
LIMS Reference ID: ED56721
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: Jerusalem Avenue School: 2351 Jerusalem Avenue, Bellmore, NY 11710: Nassau BOCES: Project# 23-56115
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/23/2025 14:01
Reported: 11/18/2025 08:58

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: NASS-1298 (Continued)		**Lims Reference ID:**		**ED56721-41**	**Matrix: Drinking Water**				**Sampled: 10/23/25 07:09:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	10/28/25 16:01	10/28/25 16:01	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1299		**Lims Reference ID:**		**ED56721-42**	**Matrix: Drinking Water**				**Sampled: 10/23/25 07:09:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/28/25 16:02	10/28/25 16:02	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1513		**Lims Reference ID:**		**ED56721-43**	**Matrix: Drinking Water**				**Sampled: 10/23/25 06:09:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/28/25 16:06	10/28/25 16:06	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1514		**Lims Reference ID:**		**ED56721-44**	**Matrix: Drinking Water**				**Sampled: 10/23/25 06:09:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/28/25 16:07	10/28/25 16:07	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1515		**Lims Reference ID:**		**ED56721-45**	**Matrix: Drinking Water**				**Sampled: 10/23/25 06:02:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/28/25 16:11	10/28/25 16:11	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1516		**Lims Reference ID:**		**ED56721-46**	**Matrix: Drinking Water**				**Sampled: 10/23/25 06:02:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/28/25 16:12	10/28/25 16:12	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1517		**Lims Reference ID:**		**ED56721-47**	**Matrix: Drinking Water**				**Sampled: 10/23/25 06:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/28/25 16:14	10/28/25 16:14	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1518		**Lims Reference ID:**		**ED56721-48**	**Matrix: Drinking Water**				**Sampled: 10/23/25 05:59:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/28/25 16:15	10/28/25 16:15	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1641		**Lims Reference ID:**		**ED56721-49**	**Matrix: Drinking Water**				**Sampled: 10/23/25 07:01:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556721
LIMS Reference ID: ED56721
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: Jerusalem Avenue School: 2351 Jerusalem Avenue, Bellmore, NY 11710: Nassau BOCES: Project# 23-56115
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/23/2025 14:01
Reported: 11/18/2025 08:58

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: NASS-1641 (Continued)		**Lims Reference ID:**		**ED56721-49**	**Matrix: Drinking Water**				**Sampled: 10/23/25 07:01:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	10/28/25 16:16	10/28/25 16:16	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1642		**Lims Reference ID:**		**ED56721-50**	**Matrix: Drinking Water**				**Sampled: 10/23/25 07:01:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/28/25 16:17	10/28/25 16:17	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1651		**Lims Reference ID:**		**ED56721-51**	**Matrix: Drinking Water**				**Sampled: 10/23/25 06:59:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/28/25 16:19	10/28/25 16:19	JH	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1652		**Lims Reference ID:**		**ED56721-52**	**Matrix: Drinking Water**				**Sampled: 10/23/25 06:59:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/28/25 17:21	10/28/25 17:21	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1709		**Lims Reference ID:**		**ED56721-53**	**Matrix: Drinking Water**				**Sampled: 10/23/25 06:02:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/28/25 17:23	10/28/25 17:23	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1710		**Lims Reference ID:**		**ED56721-54**	**Matrix: Drinking Water**				**Sampled: 10/23/25 07:25:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/28/25 17:24	10/28/25 17:24	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1711		**Lims Reference ID:**		**ED56721-55**	**Matrix: Drinking Water**				**Sampled: 10/23/25 07:23:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/28/25 17:25	10/28/25 17:25	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1864		**Lims Reference ID:**		**ED56721-56**	**Matrix: Drinking Water**				**Sampled: 10/23/25 06:11:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/28/25 17:29	10/28/25 17:29	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1865		**Lims Reference ID:**		**ED56721-57**	**Matrix: Drinking Water**				**Sampled: 10/23/25 06:11:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556721
LIMS Reference ID: ED56721
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: Jerusalem Avenue School: 2351 Jerusalem Avenue, Bellmore, NY 11710: Nassau BOCES: Project# 23-56115
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/23/2025 14:01
Reported: 11/18/2025 08:58

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: NASS-1865 (Continued)		**Lims Reference ID:**		**ED56721-57**	**Matrix: Drinking Water**				**Sampled: 10/23/25 06:11:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	10/28/25 17:30	10/28/25 17:30	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1876		**Lims Reference ID:**		**ED56721-58**	**Matrix: Drinking Water**				**Sampled: 10/23/25 06:07:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/28/25 17:34	10/28/25 17:34	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1877		**Lims Reference ID:**		**ED56721-59**	**Matrix: Drinking Water**				**Sampled: 10/23/25 06:08:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/28/25 17:35	10/28/25 17:35	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1878		**Lims Reference ID:**		**ED56721-60**	**Matrix: Drinking Water**				**Sampled: 10/23/25 06:12:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/28/25 17:37	10/28/25 17:37	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1887		**Lims Reference ID:**		**ED56721-61**	**Matrix: Drinking Water**				**Sampled: 10/23/25 06:06:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/28/25 17:38	10/28/25 17:38	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1888		**Lims Reference ID:**		**ED56721-62**	**Matrix: Drinking Water**				**Sampled: 10/23/25 06:06:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/28/25 17:39	10/28/25 17:39	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1896		**Lims Reference ID:**		**ED56721-63**	**Matrix: Drinking Water**				**Sampled: 10/23/25 06:42:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/28/25 17:41	10/28/25 17:41	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1897		**Lims Reference ID:**		**ED56721-64**	**Matrix: Drinking Water**				**Sampled: 10/23/25 06:42:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	10/28/25 17:42	10/28/25 17:42	KT1	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556721
LIMS Reference ID: ED56721
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: Jerusalem Avenue School: 2351 Jerusalem Avenue, Bellmore, NY 11710: Nassau BOCES: Project# 23-56115
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/23/2025 14:01
Reported: 11/18/2025 08:58

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556721
LIMS Reference ID: ED56721
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: Jerusalem Avenue School: 2351 Jerusalem Avenue, Bellmore, NY 11710: Nassau BOCES: Project# 23-56115
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/23/2025 14:01
Reported: 11/18/2025 08:58

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for

ED5 6835

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-56115

Building: Long Island High School for the Arts

SOA

Client: Nassau BOCES

Courier

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
NASS-0899	HA	1057	Corridor A-8 to A-13	WC	10/24/2025	6:53:00 AM
NASS-0901	SP	1054	Room A-9	HW	10/24/2025	6:55:00 AM
NASS-0911	OF	1065G	Principal's Office	KC	10/24/2025	6:50:00 AM
NASS-0920	HA	1036	Corridor Theater Lobby to Custodial Closet	WC	10/24/2025	6:59:00 AM
NASS-1315	HA	1049	Dance Studio Corridor	WF	10/24/2025	6:57:00 AM
NASS-1316	HA	1049	Dance Studio Corridor	WC	10/24/2025	6:57:00 AM
NASS-1751	OF	1065G	Principal's Office	DW	10/24/2025	6:55:00 AM

Samples Submitted 7

RECEIVED
ENSL ANALYTICAL, INC.
Carle Place, NY
OCT 28 25, PM12:52

Building Address
239 Cold Spring Road
Syosset , NY 11791

11/7/25
PB200.8

Analysis Type: ELAP 200.5

Lab Recieved: Carl

Signature:

Samplers Name: Olivia Santilippo

Samplers Signature: Olivia

JCB Project Manager: Paul Fazio

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556835

LIMS Reference ID: ED56835

EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: JCB#: 23-56115, Long Island High School for the Arts, Nassau BOCES, 239 Cold Spring Road, Syosset, NY 11791

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 10/28/2025 12:52

Reported: 11/18/2025 09:07

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: NASS-0899		**Lims Reference ID:**		**ED56835-01**	**Matrix: Drinking Water**				**Sampled: 10/24/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	11/07/25 00:01	11/07/25 00:01	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0901		**Lims Reference ID:**		**ED56835-02**	**Matrix: Drinking Water**				**Sampled: 10/24/25 00:00:00**
Metals									
Lead	**1.0**		1	1.0	µg/L	11/07/25 00:05	11/07/25 00:05	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0911		**Lims Reference ID:**		**ED56835-03**	**Matrix: Drinking Water**				**Sampled: 10/24/25 00:00:00**
Metals									
Lead	**2.9**		1	1.0	µg/L	11/07/25 00:06	11/07/25 00:06	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0920		**Lims Reference ID:**		**ED56835-04**	**Matrix: Drinking Water**				**Sampled: 10/24/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	11/07/25 00:08	11/07/25 00:08	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1315		**Lims Reference ID:**		**ED56835-05**	**Matrix: Drinking Water**				**Sampled: 10/24/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	11/07/25 00:11	11/07/25 00:11	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1316		**Lims Reference ID:**		**ED56835-06**	**Matrix: Drinking Water**				**Sampled: 10/24/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	11/07/25 00:13	11/07/25 00:13	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1751		**Lims Reference ID:**		**ED56835-07**	**Matrix: Drinking Water**				**Sampled: 10/24/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	11/07/25 00:14	11/07/25 00:14	DAZ	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556835
LIMS Reference ID: ED56835
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: JCB#: 23-56115, Long Island High School for the Arts, Nassau BOCES, 239 Cold Spring Road, Syosset, NY 11791
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/28/2025 12:52
Reported: 11/18/2025 09:07

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556835
LIMS Reference ID: ED56835
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name:	JCB#: 23-56115, Long Island High School for the Arts, Nassau BOCES, 239 Cold Spring Road, Syosset, NY 11791
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	10/28/2025 12:52
Reported:	11/18/2025 09:07

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for EDS 3839

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-56115

Building: North Annex (Endo) Elementary School

ENDO

Client: Nassau BOCES

Courier

Retest/New Install[ ]

Turn Around: Normal 1 wk Rush_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
NASS-1527	HA	2022	Hallway o/s Room 208	WF	10/24/2025	7:25:00 AM
NASS-1528	HA	2022	Hallway o/s Room 208	WC	10/24/2025	7:34:00 AM
NASS-1529	HA	2022	Hallway o/s Room 208	WC	10/24/2025	7:36:00 AM
NASS-1538	FL	2029	Faculty Lounge 227	KC	10/24/2025	7:36:00 AM
NASS-1540	ST	2011	Staff Room 210	BW	10/24/2025	7:30:00 AM
NASS-1541	NO	1010	Nurse Office 109	NS	10/24/2025	7:23:00 AM
NASS-1547	HA	1020	Hallway o/s Bathroom 111	WC	10/24/2025	7:22:00 AM
NASS-1548	HA	1020	Hallway o/s Bathroom 111	WC	10/24/2025	7:23:00 AM

Samples Submitted 8

Pb 200.8 Billing 11/5/25

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
OCT 28 25, PM12:52

Building Address
50 West White Street
Brentwood , NY 11717

Analysis Type: ELAP 200.5

Lab Recieved: Oracle

Signature:

Samplers Name: Maisha Yaseen

Samplers Signature: Maisha Yaseen

JCB Project Manager: Paul Fazio

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556839
LIMS Reference ID: ED56839
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: JCB#: 23-56115, North Annex (Endo) Elementary School, Nassau BOCES, 50 West White Street, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/28/2025 12:52
Reported: 11/18/2025 09:13

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: NASS-1527		**Lims Reference ID:**		**ED56839-01**	**Matrix: Drinking Water**				**Sampled: 10/24/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/05/25 13:30	11/05/25 13:30	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1528		**Lims Reference ID:**		**ED56839-02**	**Matrix: Drinking Water**				**Sampled: 10/24/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/05/25 13:34	11/05/25 13:34	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1529		**Lims Reference ID:**		**ED56839-03**	**Matrix: Drinking Water**				**Sampled: 10/24/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/05/25 13:35	11/05/25 13:35	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1538		**Lims Reference ID:**		**ED56839-04**	**Matrix: Drinking Water**				**Sampled: 10/24/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/05/25 13:36	11/05/25 13:36	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1540		**Lims Reference ID:**		**ED56839-05**	**Matrix: Drinking Water**				**Sampled: 10/24/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/05/25 13:40	11/05/25 13:40	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1541		**Lims Reference ID:**		**ED56839-06**	**Matrix: Drinking Water**				**Sampled: 10/24/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/05/25 13:42	11/05/25 13:42	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1547		**Lims Reference ID:**		**ED56839-07**	**Matrix: Drinking Water**				**Sampled: 10/24/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/05/25 13:43	11/05/25 13:43	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1548		**Lims Reference ID:**		**ED56839-08**	**Matrix: Drinking Water**				**Sampled: 10/24/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/05/25 13:44	11/05/25 13:44	BP	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556839
LIMS Reference ID: ED56839
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: JCB#: 23-56115, North Annex (Endo) Elementary School, Nassau BOCES, 50 West White Street, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/28/2025 12:52
Reported: 11/18/2025 09:13

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556839
LIMS Reference ID: ED56839
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: JCB#: 23-56115, North Annex (Endo) Elementary School, Nassau BOCES, 50 West White Street, Brentwood, NY 11717
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/28/2025 12:52
Reported: 11/18/2025 09:13

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for ED56947

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-56115

Building: North Shore Equestrian Center Indoor Arena
NSECIA

Client: Nassau BOCES

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
NASS-1112	KI	1008	Café	KC	10/31/2025	9:30:00 AM
NASS-1113	KI	1008	Café	KC	10/31/2025	9:32:00 AM
NASS-1114	KI	1008	Café	KC	10/31/2025	9:36:00 AM

Samples Submitted 3

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
NOV 03 25, PM02:04

Walk In

Building Address
C.W. Post Campus
Brookville , NY 11545

11/7/25
PB200.8

Analysis Type: ELAP 200.5

Lab Recieved: Abigail Minnfeld

Signature: A. Minnfeld
11/3/25 2:04pm

Samplers Name: Maisha Yaseen

Samplers Signature: Maisha Yaseen

JCB Project Manager: Paul Fazio

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556947
LIMS Reference ID: ED56947
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: 23-56115 , North Shore Equestrian Center Indoor Arena , NSECIA , Nassau BOCES, C.W. Post Campus Brookville, NY 11545
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 11/03/2025 14:04
Reported: 11/18/2025 09:20

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: NASS-1112		**Lims Reference ID:**		**ED56947-01**	**Matrix: Drinking Water**				**Sampled: 10/31/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	11/07/25 00:29	11/07/25 00:29	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1113		**Lims Reference ID:**		**ED56947-02**	**Matrix: Drinking Water**				**Sampled: 10/31/25 00:00:00**
Metals									
Lead	**1.2**		1	1.0	µg/L	11/07/25 00:31	11/07/25 00:31	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1114		**Lims Reference ID:**		**ED56947-03**	**Matrix: Drinking Water**				**Sampled: 10/31/25 00:00:00**
Metals									
Lead	**7.4**		1	1.0	µg/L	11/07/25 00:32	11/07/25 00:32	DAZ	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556947
LIMS Reference ID: ED56947
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: 23-56115 , North Shore Equestrian Center Indoor Arena , NSECIA , Nassau BOCES, C.W. Post Campus Brookville, NY 11545
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 11/03/2025 14:04
Reported: 11/18/2025 09:20

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556947
LIMS Reference ID: ED56947
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: 23-56115 , North Shore Equestrian Center Indoor Arena , NSECIA , Nassau BOCES, C.W. Post Campus Brookville, NY 11545
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 11/03/2025 14:04
Reported: 11/18/2025 09:20

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.



James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for

E056886

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-56115

Building: SESSC at Rosemary Kennedy Center

SESSC

Client: Nassau BOCES

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
NASS-1246	KI	N/A	Kitchen	KC	10/25/2025	10:32:00 AM
NASS-1287	HA	N/A	O/S Women's Restroom	WF	10/25/2025	10:31:00 AM
NASS-1288	HA	N/A	O/S Women's Restroom	WC	10/25/2025	10:31:00 AM

Samples Submitted 3

Courier

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
OCT 28 25, PM12:47

Building Address
850 N. Jerusalem Road
Wantagh , NY 11793

11/7/25

Analysis Type: ELAP 200.5

Lab Recieved: Carle

Signature:

Samplers Name: Haisha Yaseen

Samplers Signature: Haisha Yaseen

JCB Project Manager: Paul Fazio

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556836
LIMS Reference ID: ED56836
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: JCB#: 23-56115, SESSC at Rosemary Kennedy Center, Nassau BOCES, 850 N. Jerusalem Road, Wantagh, NY 11793
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/28/2025 12:47
Reported: 11/18/2025 09:14

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: NASS-1246		**Lims Reference ID:**		**ED56836-01**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	11/07/25 00:15	11/07/25 00:15	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1287		**Lims Reference ID:**		**ED56836-02**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	11/07/25 00:17	11/07/25 00:17	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1288		**Lims Reference ID:**		**ED56836-03**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	11/07/25 00:18	11/07/25 00:18	DAZ	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556836
LIMS Reference ID: ED56836
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name:	JCB#: 23-56115, SESSC at Rosemary Kennedy Center, Nassau BOCES, 850 N. Jerusalem Road, Wantagh, NY 11793
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	10/28/2025 12:47
Reported:	11/18/2025 09:14

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556836
LIMS Reference ID: ED56836
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name:	JCB#: 23-56115, SESSC at Rosemary Kennedy Center, Nassau BOCES, 850 N. Jerusalem Road, Wantagh, NY 11793
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	10/28/2025 12:47
Reported:	11/18/2025 09:14

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for E056822

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-56115

Building: Robert E. Lupinskie Center for Curriculum, Instruction and Technology
RLCCIT

Client: Nassau BOCES

Courier

Retest/New Install [ ]

Turn Around: Normal 1 wk) **Rush** _____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
NASS-1199	HA	N/A	Corridor o/s Conference Room 3	WC	10/24/2025	6:50:00 AM
NASS-1200	HA	N/A	Corridor o/s Conference Room 3	WC	10/24/2025	6:50:00 AM
NASS-1201	KI		Pantry	TM	10/24/2025	6:51:00 AM
NASS-1222	FL	N/A	Employee Lounge 142	WC	10/24/2025	6:56:00 AM
NASS-1223	FL	N/A	Employee Lounge 142	KC	10/24/2025	6:57:00 AM
NASS-1617	OF	N/A	Office o/s Room 121	WF	10/24/2025	6:54:00 AM
NASS-1618	OF	N/A	Office o/s Room 121	WC	10/24/2025	6:54:00 AM

Samples Submitted 7

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
OCT 28 25, PM12:51

Building Address
1 Merrick Avenue
Westbury , NY 11590

Analysis Type: ELAP 200.5

Lab Recieved: S. Cherofsky 10/28/25

Signature: S. Cherofsky 12:51PM

Samplers Name: Maisha Yaseen

Samplers Signature: Maisha Yaseen

JCB Project Manager: Paul Fazio

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556822

LIMS Reference ID: ED56822

EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: 23-56115, Nassau BOCES, Robert E. Lupinskie Center for Curriculum, Instruction and Technology, 1 Merrick Avenue, Westbury, NY 11590

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 10/28/2025 12:51

Reported: 11/18/2025 09:01

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: NASS-1199		**Lims Reference ID:**		**ED56822-01**	**Matrix: Drinking Water**				**Sampled: 10/24/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	11/01/25 14:20	11/01/25 14:20	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1200		**Lims Reference ID:**		**ED56822-02**	**Matrix: Drinking Water**				**Sampled: 10/24/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	11/01/25 14:22	11/01/25 14:22	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1201		**Lims Reference ID:**		**ED56822-03**	**Matrix: Drinking Water**				**Sampled: 10/24/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	11/01/25 14:23	11/01/25 14:23	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1222		**Lims Reference ID:**		**ED56822-04**	**Matrix: Drinking Water**				**Sampled: 10/24/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	11/01/25 14:24	11/01/25 14:24	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1223		**Lims Reference ID:**		**ED56822-05**	**Matrix: Drinking Water**				**Sampled: 10/24/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	11/01/25 14:25	11/01/25 14:25	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1617		**Lims Reference ID:**		**ED56822-06**	**Matrix: Drinking Water**				**Sampled: 10/24/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	11/01/25 14:27	11/01/25 14:27	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1618		**Lims Reference ID:**		**ED56822-07**	**Matrix: Drinking Water**				**Sampled: 10/24/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	11/01/25 14:28	11/01/25 14:28	DAZ	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556822

LIMS Reference ID: ED56822

EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: 23-56115, Nassau BOCES, Robert E. Lupinskie Center for Curriculum, Instruction and Technology, 1 Merrick Avenue, Westbury, NY 11590

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 10/28/2025 12:51

Reported: 11/18/2025 09:01

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556822
LIMS Reference ID: ED56822
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: 23-56115, Nassau BOCES, Robert E. Lupinskie Center for Curriculum, Instruction and Technology, 1 Merrick Avenue, Westbury, NY 11590
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/28/2025 12:51
Reported: 11/18/2025 09:01

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for ED56838

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-56115

Building: Rosemary Kennedy Center

RKC

Client: Nassau BOCES

Courier

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush _____

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
OCT 28 25, PM12:47

PB 200-8 Barry 11/5/25

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
NASS-0001	CR	2000	Room 614	CF	10/25/2025	7:40:00 AM
NASS-0002	CR	2002	Room 612	CF	10/25/2025	7:43:00 AM
NASS-0003	HE	2003	Room 609	CF	10/25/2025	7:42:00 AM
NASS-0004	CR	2004	Room 610	CF	10/25/2025	7:44:00 AM
NASS-0005	CR	2005	Room 608	CF	10/25/2025	7:45:00 AM
NASS-0006	CR	2006	Room 607	CF	10/25/2025	7:45:00 AM
NASS-0007	CR	2008	Room 606	CF	10/25/2025	7:46:00 AM
NASS-0008	CR	2010	Room 604	CF	10/25/2025	7:47:00 AM
NASS-0009	CR	2011	Room 602	CF	10/25/2025	7:49:00 AM
NASS-0010	CR	2013	Room 600	CF	10/25/2025	7:49:00 AM
NASS-0011	CR	2014	Room 601	CF	10/25/2025	7:50:00 AM
NASS-0012	CR	2018	Room 521	CF	10/25/2025	7:50:00 AM
NASS-0023	CR	2023	Room 516	CF	10/25/2025	7:52:00 AM
NASS-0024	CR	2024	Room 515 & Inner Offices	CF	10/25/2025	7:52:00 AM
NASS-0025	CR	2024	Room 515 & Inner Offices	CF	10/25/2025	7:53:00 AM
NASS-0026	CR	2025	Room 514	CF	10/25/2025	7:53:00 AM
NASS-0028	CR	2028	Room 512	CF	10/25/2025	7:55:00 AM
NASS-0029	CR	2029	Room 510	CF	10/25/2025	7:55:00 AM

Building Address
2850 N. Jerusalem Road
Wantagh , NY 11793

PB2008 Collected 11/4/25

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WHARTON 10/28/25 12:47 pm

Signature: Dave Wharton

Samplers Name: Maisha Yaseen

Samplers Signature: Maisha Yaseen

JCB Project Manager: Paul Fazio

Lead in Water: Chain of Custody for ED56838

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-56115

Building: Rosemary Kennedy Center
RKC

Client: Nassau BOCES

Retest/New Install [ ]

Turn Around: Normal 1 wk **Rush** _____

RECEIVED
MSL ANALYTICAL, INC.
Carle Place, NY
OCT 28 25, PM12:47

PB 200.8 Bkwy 11/6/25 11/5/25

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
NASS-0030	FL	2030	Room 509	CF	10/25/2025	7:57:00 AM
NASS-0031	FL	2030	Room 509	IM	10/25/2025	8:00:00 AM
NASS-0033	CR	2033	Room 506	CF	10/25/2025	8:02:00 AM
NASS-0037	HE	2035	Room 505 Kitchen/Laundry Room	EC	10/25/2025	8:02:00 AM
NASS-0038	HE	2035	Room 505 Kitchen/Laundry Room	EC	10/25/2025	8:02:00 AM
NASS-0045	CR	2038	Room 502 School Store	CF	10/25/2025	8:04:00 AM
NASS-0053	CR	2046	Room 406	CF	10/25/2025	7:39:00 AM
NASS-0054	BR	2049A	Room 405 Bathroom	BF	10/25/2025	7:44:00 AM
NASS-0055	BR	2049A	Room 405 Bathroom	BF	10/25/2025	7:44:00 AM
NASS-0056	CR	2050	Room 410	CF	10/25/2025	7:40:00 AM
NASS-0057	CR	2048	Room 408	CF	10/25/2025	7:42:00 AM
NASS-0059	CR	2104	Room 103	CF	10/25/2025	8:12:00 AM
NASS-0060	CR	2105	Room 105	CF	10/25/2025	8:12:00 AM
NASS-0062	CR	2107	Room 107A (Space Reconstructed)	CF	10/25/2025	8:14:00 AM
NASS-0063	CR	2111	Room 109	CF	10/25/2025	8:14:00 AM
NASS-0064	CR	2110	Room 114	CF	10/25/2025	8:15:00 AM
NASS-0065	NO	2114	Room 116 Health Office	NS	10/25/2025	8:10:00 AM
NASS-0070	CR	2113	Room 111	CF	10/25/2025	8:16:00 AM

Building Address
2850 N. Jerusalem Road
Wantagh, NY 11793

PB Kallodiew 11/4/25
200.8

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WHARTON 10/28/25 12:47 pm

Signature: Dave Wharton

Samplers Name: Maisha Yaseen

Samplers Signature: Maisha Yaseen

JCB Project Manager: Paul Fazio

Lead in Water: Chain of Custody for ED56838

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-56115

Building: Rosemary Kennedy Center
RKC

Client: Nassau BOCES

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush_____

RECEIVED
EMSL ANALYTICAL, INC.
Garla Place, NY
OCT 28 25, PM12:48

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
NASS-0071	CR	2054	Room 303	CF	10/25/2025	7:53:00 AM
NASS-0072	CR	2055	Room 305	CF	10/25/2025	7:53:00 AM
NASS-0073	CR	2056	Room 307	CF	10/25/2025	7:53:00 AM
NASS-0074	CR	2057	Room 309	CF	10/25/2025	7:53:00 AM
NASS-0075	CR	2060	Room 311	CF	10/25/2025	7:58:00 AM
NASS-0078	CR	2063	Room 308	CF	10/25/2025	7:56:00 AM
NASS-0079	CR	2064	Room 315	CF	10/25/2025	7:55:00 AM
NASS-0080	CR	2065	Room 317	CF	10/25/2025	7:53:00 AM
NASS-0081	CR	2066	Room 310	CF	10/25/2025	7:52:00 AM
NASS-0082	CR	2067	Room 312	CF	10/25/2025	7:51:00 AM
NASS-0085	CR	2096	Room 201	CF	10/25/2025	7:59:00 AM
NASS-0086	CR	2095	Room 201A	CF	10/25/2025	8:00:00 AM
NASS-0087	CR	2093	Room 203	CF	10/25/2025	8:01:00 AM
NASS-0090	CR	2090	Room 205	CF	10/25/2025	8:02:00 AM
NASS-0091	CR	2089	Room 205A	CF	10/25/2025	8:03:00 AM
NASS-0092	CR	2088	Room 206	CF	10/25/2025	8:07:00 AM
NASS-0093	CR	2087	Room 207	CF	10/25/2025	8:07:00 AM
NASS-0094	CR	2086	Room 206A	CF	10/25/2025	8:06:00 AM

Building Address
2850 N. Jerusalem Road
Wantagh, NY 11793

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WHARTON 10/28/25 12:47 pm

Signature:

Samplers Name: Maisha Yaseen

Samplers Signature: Maisha Yaseen

JCB Project Manager: Paul Fazio

Lead in Water: Chain of Custody for ED 56 838

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-56115

Building: Rosemary Kennedy Center

RKC

Client: Nassau BOCES

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush_____

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
OCT 28 25, PM12:48

Pb 200.8 Barry 11/5/25
Pb 200.8 Barry 11/6/25

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
NASS-0095	CR	2085	Room 207A	CF	10/25/2025	8:09:00 AM
NASS-0096	CR	2084	Room 208	CF	10/25/2025	8:11:00 AM
NASS-0097	CR	2083	Room 209	CF	10/25/2025	8:09:00 AM
NASS-0098	CR	2082	Room 209A	CF	10/25/2025	8:17:00 AM
NASS-0103	CR	2075B	Room 211A	CF	10/25/2025	8:14:00 AM
NASS-0105	CR	2073	Room 212	CF	10/25/2025	8:04:00 AM
NASS-0106	CR	2072	Room 213	CF	10/25/2025	8:03:00 AM
NASS-0107	OF	2071	Room 212A	CF	10/25/2025	8:03:00 AM
NASS-0108	CR	2070	Room 214	CF	10/25/2025	8:02:00 AM
NASS-0109	BR	2069	Room 215	BF	10/25/2025	8:01:00 AM
NASS-0110	FL	1016	Faculty Lounge Room 1202	CF	10/25/2025	9:11:00 AM
NASS-0118	CR	1023	Room 1105	CF	10/25/2025	9:06:00 AM
NASS-0119	CR	1025	Room 1107	CF	10/25/2025	9:07:00 AM
NASS-0121	CR	1030	Room 1109	CF	10/25/2025	9:08:00 AM
NASS-0122	CR	1032	Room 1111	CF	10/25/2025	9:09:00 AM
NASS-0125	OF	1036C	Room 1114 Sink Area	CF	10/25/2025	9:14:00 AM
NASS-0126	CR	1037	Room 1113	CF	10/25/2025	9:09:00 AM
NASS-0127	CR	1040	Room 914	CF	10/25/2025	9:07:00 AM

Building Address
2850 N. Jerusalem Road
Wantagh , NY 11793

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WHARTON 10/28/25 12:47 pm

Signature: Dave Wharton

Samplers Name: Maisha Yaseen

Samplers Signature: Maisha Yaseen

JCB Project Manager: Paul Fazio

Pb 200.8 Kathleen 11/4/25

Lead in Water: Chain of Custody for ED56838

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-56115

Building: Rosemary Kennedy Center

RKC

Client: Nassau BOCES

Retest/New Install [ ]

Turn Around: Normal 1 wk **Rush**_____

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
OCT 28 25, PM12:48

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
NASS-0128	CR	1045	Room 910	CF	10/25/2025	9:06:00 AM
NASS-0129	CR	1049	Room 906	CF	10/25/2025	9:05:00 AM
NASS-0144	CR	1057	Room 1002	CF	10/25/2025	8:56:00 AM
NASS-0145	CR	1058	Room 1004	DW	10/25/2025	8:57:00 AM
NASS-0146	CR	1058	Room 1004	CF	10/25/2025	8:59:00 AM
NASS-0147	CR	1060	Room 1006	CF	10/25/2025	8:58:00 AM
NASS-0148	CR	1059	Room 1003	CF	10/25/2025	9:31:00 AM
NASS-0149	CR	1059	Room 1003	CF	10/25/2025	9:31:00 AM
NASS-0150	CR	1062	Room 1007	CF	10/25/2025	9:20:00 AM
NASS-0151	CR	1063	Room 1006A	CF	10/25/2025	9:00:00 AM
NASS-0155	OF	1066	School Store Room 701	CF	10/25/2025	8:45:00 AM
NASS-0156	HA	1082	700 Corridor	DW	10/25/2025	8:45:00 AM
NASS-0157	BR	1068A	Room 703 Bathroom	BF	10/25/2025	9:35:00 AM
NASS-0159	CR	1072	Room 707	CF	10/25/2025	8:47:00 AM
NASS-0161	NO	1074	Nurses Office Room 706	NS	10/25/2025	8:47:00 AM
NASS-0162	NO	1075	Medication Room	NS	10/25/2025	8:50:00 AM
NASS-0164	CR	1080	Room 711	CF	10/25/2025	8:49:00 AM
NASS-0165	OF	1083C	Room 801 Conference Room Sink Closet	CF	10/25/2025	8:44:00 AM

PB 200-8 11/5/25

PB 200-8 11/4/25

Building Address
2850 N. Jerusalem Road
Wantagh , NY 11793

PB 200.8 11/4/25

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WHARTON 10/28/25 12:47 pm

Signature:

Samplers Name: Maisha Yaseen

Samplers Signature: Maisha Yaseen

JCB Project Manager: Paul Fazio

Lead in Water: Chain of Custody for ED56838

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-56115

Building: Rosemary Kennedy Center

RKC

Client: Nassau BOCES

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush_____

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
OCT 28 25, PM12:48

Pb 200.8 Body 11/4/25
Pb 200.8 Body 11/4/25

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
NASS-0166	OF	1085A	Room 802 Small Closet	CF	10/25/2025	8:46:00 AM
NASS-0167	OF	1086	Room 803	CF	10/25/2025	9:42:00 AM
NASS-0168	KI	1012C	Kitchen 1300 Office Vestibule	KC	10/25/2025	7:32:00 AM
NASS-0170	KI	1012	Kitchen 1300	KC	10/25/2025	7:30:00 AM
NASS-0171	KI	1012	Kitchen 1300	KC	10/25/2025	7:33:00 AM
NASS-0172	KI	1012	Kitchen 1300	KC	10/25/2025	7:24:00 AM
NASS-0173	KI	1012	Kitchen 1300	KC	10/25/2025	7:24:00 AM
NASS-0174	KI	1012	Kitchen 1300	KC	10/25/2025	7:25:00 AM
NASS-0175	KI	1012	Kitchen 1300	HW	10/25/2025	7:25:00 AM
NASS-0176	KI	1012	Kitchen 1300	KC	10/25/2025	7:26:00 AM
NASS-0178	KI	1012	Kitchen 1300	PK	10/25/2025	7:25:00 AM
NASS-0179	KI	1012	Kitchen 1300	PK	10/25/2025	7:29:00 AM
NASS-0180	KI	1012	Kitchen 1300	IM	10/25/2025	7:29:00 AM
NASS-0188	HA	1006	Corridor o/s Room 1400	DW	10/25/2025	8:43:00 AM
NASS-0194	OF	1102B	Room 1514 Office	CF	10/25/2025	9:39:00 AM
NASS-0199	CR	1110	Room 1517	CF	10/25/2025	9:37:00 AM
NASS-0201	CR	1148	Room 1803	CF	10/25/2025	9:17:00 AM
NASS-0202	KI	1147	Room 1801	KC	10/25/2025	9:17:00 AM

Building Address
2850 N. Jerusalem Road
Wantagh , NY 11793

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WHARTON 10/28/25 12:47 PM

Signature:

Samplers Name: Maisha Yaseen

Samplers Signature: Maisha Yaseen

JCB Project Manager: Paul Fazio

Pb 200.8 Kathleen 11/4/25

Lead in Water: Chain of Custody for ED56838

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-56115

Building: Rosemary Kennedy Center

RKC

Client: Nassau BOCES

Retest/New Install [ ]

Turn Around: (Normal 1 wk) / Rush_____

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
OCT 28 25, PM12:48

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
NASS-0203	CR	1150	Room 1805	CF	10/25/2025	9:16:00 AM
NASS-0204	CR	1150	Room 1805	CF	10/25/2025	9:16:00 AM
NASS-0205	BR	1149A1	Room 1802 Bathroom	BF	10/25/2025	9:12:00 AM
NASS-0208	CR	1152	Room 1806	CF	10/25/2025	9:13:00 AM
NASS-0209	CR	1154	Room Adjacent Room 1807	CF	10/25/2025	9:14:00 AM
NASS-0210	CR	1153	Room 1807	CF	10/25/2025	9:15:00 AM
NASS-0212	CR	1155	Room 1808/1808A	CF	10/25/2025	9:10:00 AM
NASS-0213	CR	1156	Room 1809	CF	10/25/2025	9:13:00 AM
NASS-0214	CR	1133	Room 1700/1702	CF	10/25/2025	9:33:00 AM
NASS-0215	CR	1133	Room 1700/1702	DW	10/25/2025	9:34:00 AM
NASS-0216	OF	1136	Room 1704	CF	10/25/2025	9:30:00 AM
NASS-0217	CR	1137	Room 1705/1705A	CF	10/25/2025	9:31:00 AM
NASS-0218	CR	1137	Room 1705/1705A	CF	10/25/2025	9:31:00 AM
NASS-0220	CR	1137	Room 1705/1705A	CF	10/25/2025	9:29:00 AM
NASS-0221	CR	1137	Room 1705/1705A	CF	10/25/2025	9:30:00 AM
NASS-0223	CR	1138	Room 1706	CF	10/25/2025	9:27:00 AM
NASS-0224	CR	1138	Room 1706	CF	10/25/2025	9:28:00 AM
NASS-0226	CR	1141	Room 1708	CF	10/25/2025	9:25:00 AM

Building Address
2850 N. Jerusalem Road
Wantagh , NY 11793

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WHARTON 10/28/25 12:47 pm

Signature: David Wharton

Samplers Name: Maisha Yaseen

Samplers Signature: Maisha Yaseen

JCB Project Manager: Paul Fazio

Lead in Water: Chain of Custody for ED56838

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-56115

Building: Rosemary Kennedy Center

RKC

Client: Nassau BOCES

Retest/New Install [ ]

Turn Around: Normal 1 wk **Rush**_____

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
OCT 28 25, PM12:48

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
NASS-0227	CR	1142	Room 1711	CF	10/25/2025	9:25:00 AM
NASS-0228	CR	1142	Room 1711	CF	10/25/2025	9:25:00 AM
NASS-0237	CR	1121	Room 1608	CF	10/25/2025	9:06:00 AM
NASS-0240	OF	1124	Room 1609A	CF	10/25/2025	9:03:00 AM
NASS-0241	CR	1126	Room 1610	CF	10/25/2025	9:03:00 AM
NASS-0242	OF	1128	Room 1611A	CF	10/25/2025	9:02:00 AM
NASS-0243	CR	1129	Room 1614	CF	10/25/2025	8:58:00 AM
NASS-0244	CR	1130	Room 1613	CF	10/25/2025	8:59:00 AM
NASS-0245	CR	1130	Room 1613	CF	10/25/2025	8:58:00 AM
NASS-1245	CR	2061	Room 313	CF.	10/25/2025	7:57:00 AM
NASS-1284	HA	1065	1000 Corridor	WF	10/25/2025	8:53:00 AM
NASS-1285	CR	1097	Room 1507/1509	CF	10/25/2025	8:56:00 AM
NASS-1754	CR	2045	Room 404	CF	10/25/2025	7:41:00 AM
NASS-1755	CR	2091	Room 204	CF	10/25/2025	8:10:00 AM
NASS-1786	KI	1056	Kitchen Room 1000	KC	10/25/2025	8:55:00 AM
NASS-1787	KI	1056	Kitchen Room 1000	KC	10/25/2025	8:55:00 AM
NASS-1788	KI	1056	Kitchen Room 1000	KC	10/25/2025	7:23:00 AM
NASS-1799	KI	1012	Kitchen 1300	CP	10/25/2025	7:23:00 AM

Building Address
2850 N. Jerusalem Road
Wantagh , NY 11793

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WHARTON 10/28/25 12:47 pm

Signature: Dave Wharton

Samplers Name: Maisha Yaseen

Samplers Signature: Maisha Yaseen

JCB Project Manager: Paul Fazio

Lead in Water: Chain of Custody for ED56838

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-56115

Building: Rosemary Kennedy Center

RKC

Client: Nassau BOCES

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
NASS-1800	KI	1012	Kitchen 1300	CP	10/25/2025	7:24:00 AM
NASS-1801	KI	1012	Kitchen 1300	CP	10/25/2025	7:24:00 AM
NASS-1804	KI	2094	Kitchen 200	KC	10/25/2025	7:59:00 AM
NASS-1813	CR	2030	Room 509	WF	10/25/2025	7:57:00 AM
NASS-1814	CR	2030	Room 509	WC	10/25/2025	7:57:00 AM
NASS-1846	OF	2102	Main Office 102	BW	10/25/2025	8:09:00 AM
NASS-1847	OF	2102	Main Office 102	BW	10/25/2025	8:09:00 AM
NASS-1848	OF	2102	Main Office 102	BW	10/25/2025	8:10:00 AM
NASS-1851	HA	2068	Corridor o/s Room 301	WF	10/25/2025	7:49:00 AM
NASS-1977	CR	1079	Room 708A	CF	10/25/2025	8:56:00 AM
NASS-1978	CR	1155	Room 1808/1808A	CF	10/25/2025	9:10:00 AM
NASS-1979	HA	1112	All Purpose Room	WF	10/25/2025	9:18:00 AM
NASS-1980	HA	1112	All Purpose Room	WF	10/25/2025	9:19:00 AM

Samples Submitted 157

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
OCT 28 25, PM12:49

Building Address
2850 N. Jerusalem Road
Wantagh , NY 11793

Analysis Type: ELAP 200.5

Lab Recieved: DAVID WHARTON 10/28/25 12:47 pm

Signature:

Samplers Name: Maisha Yaseen

Samplers Signature:

JCB Project Manager: Paul Facio

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556838
LIMS Reference ID: ED56838
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: 23-56115 - Nassau BOCES - Rosemary Kennedy Center RKC - 2850 N. Jerusalem Road, Wantagh, NY 11793
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/28/2025 12:47
Reported: 11/18/2025 09:10

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: NASS-0001		**Lims Reference ID:**		**ED56838-01**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/05/25 11:20	11/05/25 11:20	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0002		**Lims Reference ID:**		**ED56838-02**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/05/25 11:24	11/05/25 11:24	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0003		**Lims Reference ID:**		**ED56838-03**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/05/25 11:26	11/05/25 11:26	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0004		**Lims Reference ID:**		**ED56838-04**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/05/25 11:30	11/05/25 11:30	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0005		**Lims Reference ID:**		**ED56838-05**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/05/25 11:31	11/05/25 11:31	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0006		**Lims Reference ID:**		**ED56838-06**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/05/25 11:32	11/05/25 11:32	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0007		**Lims Reference ID:**		**ED56838-07**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/05/25 11:34	11/05/25 11:34	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0008		**Lims Reference ID:**		**ED56838-08**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/05/25 11:35	11/05/25 11:35	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0009		**Lims Reference ID:**		**ED56838-09**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556838
LIMS Reference ID: ED56838
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: 23-56115 - Nassau BOCES - Rosemary Kennedy Center RKC - 2850 N. Jerusalem Road, Wantagh, NY 11793
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/28/2025 12:47
Reported: 11/18/2025 09:10

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: NASS-0009 (Continued)		**Lims Reference ID:**		**ED56838-09**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	11/05/25 11:36	11/05/25 11:36	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0010		**Lims Reference ID:**		**ED56838-10**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/05/25 11:38	11/05/25 11:38	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0011		**Lims Reference ID:**		**ED56838-11**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/05/25 11:39	11/05/25 11:39	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0012		**Lims Reference ID:**		**ED56838-12**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	1.1		1	1.0	µg/L	11/05/25 11:45	11/05/25 11:45	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0023		**Lims Reference ID:**		**ED56838-13**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/05/25 11:47	11/05/25 11:47	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0024		**Lims Reference ID:**		**ED56838-14**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	5.9		1	1.0	µg/L	11/05/25 11:48	11/05/25 11:48	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0025		**Lims Reference ID:**		**ED56838-15**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	1.4		1	1.0	µg/L	11/05/25 11:49	11/05/25 11:49	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0026		**Lims Reference ID:**		**ED56838-16**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/05/25 11:51	11/05/25 11:51	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0028		**Lims Reference ID:**		**ED56838-17**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556838
LIMS Reference ID: ED56838
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: 23-56115 - Nassau BOCES - Rosemary Kennedy Center RKC - 2850 N. Jerusalem Road, Wantagh, NY 11793
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/28/2025 12:47
Reported: 11/18/2025 09:10

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: NASS-0028 (Continued)		**Lims Reference ID:**		**ED56838-17**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	11/05/25 11:52	11/05/25 11:52	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0029		**Lims Reference ID:**		**ED56838-18**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/05/25 11:53	11/05/25 11:53	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0030		**Lims Reference ID:**		**ED56838-19**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/05/25 11:55	11/05/25 11:55	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0031		**Lims Reference ID:**		**ED56838-20**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/05/25 11:56	11/05/25 11:56	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0033		**Lims Reference ID:**		**ED56838-21**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/05/25 15:33	11/05/25 15:33	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0037		**Lims Reference ID:**		**ED56838-22**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/05/25 15:37	11/05/25 15:37	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0038		**Lims Reference ID:**		**ED56838-23**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/05/25 15:39	11/05/25 15:39	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0045		**Lims Reference ID:**		**ED56838-24**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/05/25 15:40	11/05/25 15:40	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0053		**Lims Reference ID:**		**ED56838-25**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556838
LIMS Reference ID: ED56838
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: 23-56115 - Nassau BOCES - Rosemary Kennedy Center RKC - 2850 N. Jerusalem Road, Wantagh, NY 11793
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/28/2025 12:47
Reported: 11/18/2025 09:10

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: NASS-0053 (Continued)		**Lims Reference ID:**		**ED56838-25**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	11/05/25 15:44	11/05/25 15:44	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0054		**Lims Reference ID:**		**ED56838-26**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/05/25 15:45	11/05/25 15:45	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0055		**Lims Reference ID:**		**ED56838-27**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/05/25 15:46	11/05/25 15:46	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0056		**Lims Reference ID:**		**ED56838-28**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/05/25 15:48	11/05/25 15:48	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0057		**Lims Reference ID:**		**ED56838-29**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/05/25 15:49	11/05/25 15:49	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0059		**Lims Reference ID:**		**ED56838-30**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/05/25 15:50	11/05/25 15:50	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0060		**Lims Reference ID:**		**ED56838-31**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/05/25 15:51	11/05/25 15:51	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0062		**Lims Reference ID:**		**ED56838-32**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/05/25 15:55	11/05/25 15:55	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0063		**Lims Reference ID:**		**ED56838-33**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556838
LIMS Reference ID: ED56838
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: 23-56115 - Nassau BOCES - Rosemary Kennedy Center RKC - 2850 N. Jerusalem Road, Wantagh, NY 11793
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/28/2025 12:47
Reported: 11/18/2025 09:10

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: NASS-0063 (Continued)		**Lims Reference ID:**		**ED56838-33**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	11/05/25 15:59	11/05/25 15:59	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0064		**Lims Reference ID:**		**ED56838-34**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 16:00	11/06/25 16:00	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0065		**Lims Reference ID:**		**ED56838-35**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 16:04	11/06/25 16:04	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0070		**Lims Reference ID:**		**ED56838-36**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 16:05	11/06/25 16:05	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0071		**Lims Reference ID:**		**ED56838-37**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 16:06	11/06/25 16:06	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0072		**Lims Reference ID:**		**ED56838-38**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 16:10	11/06/25 16:10	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0073		**Lims Reference ID:**		**ED56838-39**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 16:11	11/06/25 16:11	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0074		**Lims Reference ID:**		**ED56838-40**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 16:13	11/06/25 16:13	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0075		**Lims Reference ID:**		**ED56838-41**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556838
LIMS Reference ID: ED56838
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: 23-56115 - Nassau BOCES - Rosemary Kennedy Center RKC - 2850 N. Jerusalem Road, Wantagh, NY 11793
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/28/2025 12:47
Reported: 11/18/2025 09:10

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: NASS-0075 (Continued)		**Lims Reference ID:**		**ED56838-41**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	11/06/25 16:14	11/06/25 16:14	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0078		**Lims Reference ID:**		**ED56838-42**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 16:15	11/06/25 16:15	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0079		**Lims Reference ID:**		**ED56838-43**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	1.1		1	1.0	µg/L	11/04/25 13:26	11/04/25 13:26	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0080		**Lims Reference ID:**		**ED56838-44**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	1.4		1	1.0	µg/L	11/04/25 13:27	11/04/25 13:27	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0081		**Lims Reference ID:**		**ED56838-45**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/04/25 13:29	11/04/25 13:29	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0082		**Lims Reference ID:**		**ED56838-46**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/04/25 13:30	11/04/25 13:30	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0085		**Lims Reference ID:**		**ED56838-47**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/04/25 13:31	11/04/25 13:31	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0086		**Lims Reference ID:**		**ED56838-48**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/04/25 13:32	11/04/25 13:32	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0087		**Lims Reference ID:**		**ED56838-49**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556838
LIMS Reference ID: ED56838
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: 23-56115 - Nassau BOCES - Rosemary Kennedy Center RKC - 2850 N. Jerusalem Road, Wantagh, NY 11793
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/28/2025 12:47
Reported: 11/18/2025 09:10

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: NASS-0087 (Continued)		**Lims Reference ID:**		**ED56838-49**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	11/04/25 15:05	11/04/25 15:05	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0090		**Lims Reference ID:**		**ED56838-50**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/04/25 15:09	11/04/25 15:09	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0091		**Lims Reference ID:**		**ED56838-51**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/04/25 15:10	11/04/25 15:10	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0092		**Lims Reference ID:**		**ED56838-52**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/04/25 15:12	11/04/25 15:12	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0093		**Lims Reference ID:**		**ED56838-53**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/04/25 15:16	11/04/25 15:16	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0094		**Lims Reference ID:**		**ED56838-54**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/04/25 15:17	11/04/25 15:17	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0095		**Lims Reference ID:**		**ED56838-55**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/04/25 15:18	11/04/25 15:18	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0096		**Lims Reference ID:**		**ED56838-56**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/04/25 15:19	11/04/25 15:19	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0097		**Lims Reference ID:**		**ED56838-57**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556838
LIMS Reference ID: ED56838
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: 23-56115 - Nassau BOCES - Rosemary Kennedy Center RKC - 2850 N. Jerusalem Road, Wantagh, NY 11793
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/28/2025 12:47
Reported: 11/18/2025 09:10

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: NASS-0097 (Continued)		**Lims Reference ID:**		**ED56838-57**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	11/04/25 15:21	11/04/25 15:21	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0098		**Lims Reference ID:**		**ED56838-58**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/04/25 15:22	11/04/25 15:22	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0103		**Lims Reference ID:**		**ED56838-59**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/04/25 15:23	11/04/25 15:23	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0105		**Lims Reference ID:**		**ED56838-60**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/04/25 15:27	11/04/25 15:27	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0106		**Lims Reference ID:**		**ED56838-61**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/04/25 15:31	11/04/25 15:31	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0107		**Lims Reference ID:**		**ED56838-62**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/04/25 15:32	11/04/25 15:32	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0108		**Lims Reference ID:**		**ED56838-63**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/04/25 15:34	11/04/25 15:34	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0109		**Lims Reference ID:**		**ED56838-64**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/04/25 15:35	11/04/25 15:35	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0110		**Lims Reference ID:**		**ED56838-65**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556838
LIMS Reference ID: ED56838
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: 23-56115 - Nassau BOCES - Rosemary Kennedy Center RKC - 2850 N. Jerusalem Road, Wantagh, NY 11793
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/28/2025 12:47
Reported: 11/18/2025 09:10

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: NASS-0110 (Continued)		**Lims Reference ID:**		**ED56838-65**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	11/04/25 15:36	11/04/25 15:36	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0118		**Lims Reference ID:**		**ED56838-66**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/04/25 15:38	11/04/25 15:38	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0119		**Lims Reference ID:**		**ED56838-67**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/04/25 15:39	11/04/25 15:39	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0121		**Lims Reference ID:**		**ED56838-68**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/04/25 15:40	11/04/25 15:40	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0122		**Lims Reference ID:**		**ED56838-69**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/05/25 09:54	11/05/25 09:54	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0125		**Lims Reference ID:**		**ED56838-70**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/05/25 09:58	11/05/25 09:58	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0126		**Lims Reference ID:**		**ED56838-71**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/05/25 09:59	11/05/25 09:59	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0127		**Lims Reference ID:**		**ED56838-72**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/05/25 10:00	11/05/25 10:00	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0128		**Lims Reference ID:**		**ED56838-73**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556838
LIMS Reference ID: ED56838
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: 23-56115 - Nassau BOCES - Rosemary Kennedy Center RKC - 2850 N. Jerusalem Road, Wantagh, NY 11793
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/28/2025 12:47
Reported: 11/18/2025 09:10

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: NASS-0128 (Continued)		**Lims Reference ID:**		**ED56838-73**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	11/05/25 10:04	11/05/25 10:04	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0129		**Lims Reference ID:**		**ED56838-74**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/05/25 10:06	11/05/25 10:06	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0144		**Lims Reference ID:**		**ED56838-75**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/05/25 10:07	11/05/25 10:07	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0145		**Lims Reference ID:**		**ED56838-76**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/05/25 10:08	11/05/25 10:08	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0146		**Lims Reference ID:**		**ED56838-77**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	1.4		1	1.0	µg/L	11/05/25 10:10	11/05/25 10:10	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0147		**Lims Reference ID:**		**ED56838-78**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/05/25 10:11	11/05/25 10:11	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0148		**Lims Reference ID:**		**ED56838-79**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	2.3		1	1.0	µg/L	11/05/25 10:12	11/05/25 10:12	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0149		**Lims Reference ID:**		**ED56838-80**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	1.2		1	1.0	µg/L	11/05/25 10:16	11/05/25 10:16	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0150		**Lims Reference ID:**		**ED56838-81**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556838
LIMS Reference ID: ED56838
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: 23-56115 - Nassau BOCES - Rosemary Kennedy Center RKC - 2850 N. Jerusalem Road, Wantagh, NY 11793
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/28/2025 12:47
Reported: 11/18/2025 09:10

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: NASS-0150 (Continued)		**Lims Reference ID:**		**ED56838-81**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	11/05/25 10:20	11/05/25 10:20	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0151		**Lims Reference ID:**		**ED56838-82**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/05/25 10:21	11/05/25 10:21	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0155		**Lims Reference ID:**		**ED56838-83**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/05/25 10:23	11/05/25 10:23	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0156		**Lims Reference ID:**		**ED56838-84**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/05/25 10:24	11/05/25 10:24	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0157		**Lims Reference ID:**		**ED56838-85**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/05/25 10:25	11/05/25 10:25	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0159		**Lims Reference ID:**		**ED56838-86**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/05/25 10:27	11/05/25 10:27	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0161		**Lims Reference ID:**		**ED56838-87**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/05/25 10:28	11/05/25 10:28	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0162		**Lims Reference ID:**		**ED56838-88**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/05/25 10:29	11/05/25 10:29	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0164		**Lims Reference ID:**		**ED56838-89**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556838
LIMS Reference ID: ED56838
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: 23-56115 - Nassau BOCES - Rosemary Kennedy Center RKC - 2850 N. Jerusalem Road, Wantagh, NY 11793
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/28/2025 12:47
Reported: 11/18/2025 09:10

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: NASS-0164 (Continued)		**Lims Reference ID:**		**ED56838-89**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	11/06/25 16:17	11/06/25 16:17	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0165		**Lims Reference ID:**		**ED56838-90**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 16:18	11/06/25 16:18	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0166		**Lims Reference ID:**		**ED56838-91**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 16:22	11/06/25 16:22	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0167		**Lims Reference ID:**		**ED56838-92**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 16:26	11/06/25 16:26	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0168		**Lims Reference ID:**		**ED56838-93**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 16:27	11/06/25 16:27	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0170		**Lims Reference ID:**		**ED56838-94**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 16:28	11/06/25 16:28	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0171		**Lims Reference ID:**		**ED56838-95**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 16:30	11/06/25 16:30	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0172		**Lims Reference ID:**		**ED56838-96**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 16:47	11/06/25 16:47	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0173		**Lims Reference ID:**		**ED56838-97**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556838
LIMS Reference ID: ED56838
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: 23-56115 - Nassau BOCES - Rosemary Kennedy Center RKC - 2850 N. Jerusalem Road, Wantagh, NY 11793
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/28/2025 12:47
Reported: 11/18/2025 09:10

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: NASS-0173 (Continued)		**Lims Reference ID:**		**ED56838-97**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	11/06/25 16:32	11/06/25 16:32	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0174		**Lims Reference ID:**		**ED56838-98**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 16:34	11/06/25 16:34	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0175		**Lims Reference ID:**		**ED56838-99**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 16:35	11/06/25 16:35	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0176		**Lims Reference ID:**		**ED56838-AA**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 17:08	11/06/25 17:08	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0178		**Lims Reference ID:**		**ED56838-AB**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	953		10	10.0	µg/L	11/06/25 17:51	11/06/25 17:51	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0179		**Lims Reference ID:**		**ED56838-AC**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	3.0		1	1.0	µg/L	11/06/25 17:13	11/06/25 17:13	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0180		**Lims Reference ID:**		**ED56838-AD**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 17:14	11/06/25 17:14	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0188		**Lims Reference ID:**		**ED56838-AE**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	1.2		1	1.0	µg/L	11/06/25 17:18	11/06/25 17:18	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0194		**Lims Reference ID:**		**ED56838-AF**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556838
LIMS Reference ID: ED56838
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: 23-56115 - Nassau BOCES - Rosemary Kennedy Center RKC - 2850 N. Jerusalem Road, Wantagh, NY 11793
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/28/2025 12:47
Reported: 11/18/2025 09:10

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: NASS-0194 (Continued)		**Lims Reference ID:**		**ED56838-AF**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	11/06/25 17:20	11/06/25 17:20	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0199		**Lims Reference ID:**		**ED56838-AG**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	4.9		1	1.0	µg/L	11/06/25 17:21	11/06/25 17:21	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0201		**Lims Reference ID:**		**ED56838-AH**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 17:22	11/06/25 17:22	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0202		**Lims Reference ID:**		**ED56838-AI**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 17:23	11/06/25 17:23	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0203		**Lims Reference ID:**		**ED56838-AJ**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 17:25	11/06/25 17:25	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0204		**Lims Reference ID:**		**ED56838-AK**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 17:26	11/06/25 17:26	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0205		**Lims Reference ID:**		**ED56838-AL**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 17:30	11/06/25 17:30	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0208		**Lims Reference ID:**		**ED56838-AM**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 17:34	11/06/25 17:34	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0209		**Lims Reference ID:**		**ED56838-AN**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556838
LIMS Reference ID: ED56838
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: 23-56115 - Nassau BOCES - Rosemary Kennedy Center RKC - 2850 N. Jerusalem Road, Wantagh, NY 11793
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/28/2025 12:47
Reported: 11/18/2025 09:10

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: NASS-0209 (Continued)		**Lims Reference ID:**		**ED56838-AN**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	11/06/25 17:35	11/06/25 17:35	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0210		**Lims Reference ID:**		**ED56838-AO**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 17:36	11/06/25 17:36	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0212		**Lims Reference ID:**		**ED56838-AP**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 17:38	11/06/25 17:38	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0213		**Lims Reference ID:**		**ED56838-AQ**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 17:39	11/06/25 17:39	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0214		**Lims Reference ID:**		**ED56838-AR**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	1.5		1	1.0	µg/L	11/06/25 17:40	11/06/25 17:40	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0215		**Lims Reference ID:**		**ED56838-AS**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	1.9		1	1.0	µg/L	11/06/25 17:42	11/06/25 17:42	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0216		**Lims Reference ID:**		**ED56838-AT**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 17:43	11/06/25 17:43	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0217		**Lims Reference ID:**		**ED56838-AU**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 15:07	11/06/25 15:07	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0218		**Lims Reference ID:**		**ED56838-AV**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556838
LIMS Reference ID: ED56838
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: 23-56115 - Nassau BOCES - Rosemary Kennedy Center RKC - 2850 N. Jerusalem Road, Wantagh, NY 11793
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/28/2025 12:47
Reported: 11/18/2025 09:10

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: NASS-0218 (Continued)		**Lims Reference ID:**		**ED56838-AV**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	11/06/25 15:11	11/06/25 15:11	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0220		**Lims Reference ID:**		**ED56838-AW**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 15:12	11/06/25 15:12	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0221		**Lims Reference ID:**		**ED56838-AX**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 15:16	11/06/25 15:16	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0223		**Lims Reference ID:**		**ED56838-AY**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 15:17	11/06/25 15:17	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0224		**Lims Reference ID:**		**ED56838-AZ**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 15:18	11/06/25 15:18	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0226		**Lims Reference ID:**		**ED56838-BA**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 15:20	11/06/25 15:20	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0227		**Lims Reference ID:**		**ED56838-BB**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 15:21	11/06/25 15:21	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0228		**Lims Reference ID:**		**ED56838-BC**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 15:22	11/06/25 15:22	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0237		**Lims Reference ID:**		**ED56838-BD**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556838
LIMS Reference ID: ED56838
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: 23-56115 - Nassau BOCES - Rosemary Kennedy Center RKC - 2850 N. Jerusalem Road, Wantagh, NY 11793
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/28/2025 12:47
Reported: 11/18/2025 09:10

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: NASS-0237 (Continued)		**Lims Reference ID:**		**ED56838-BD**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	11/06/25 15:24	11/06/25 15:24	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0240		**Lims Reference ID:**		**ED56838-BE**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 15:25	11/06/25 15:25	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0241		**Lims Reference ID:**		**ED56838-BF**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 15:31	11/06/25 15:31	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0242		**Lims Reference ID:**		**ED56838-BG**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	1.6		1	1.0	µg/L	11/06/25 15:33	11/06/25 15:33	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0243		**Lims Reference ID:**		**ED56838-BH**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 15:34	11/06/25 15:34	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0244		**Lims Reference ID:**		**ED56838-BI**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 15:35	11/06/25 15:35	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-0245		**Lims Reference ID:**		**ED56838-BJ**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 15:36	11/06/25 15:36	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1245		**Lims Reference ID:**		**ED56838-BK**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 15:38	11/06/25 15:38	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1284		**Lims Reference ID:**		**ED56838-BL**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556838
LIMS Reference ID: ED56838
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: 23-56115 - Nassau BOCES - Rosemary Kennedy Center RKC - 2850 N. Jerusalem Road, Wantagh, NY 11793
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/28/2025 12:47
Reported: 11/18/2025 09:10

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: NASS-1284 (Continued)		**Lims Reference ID:**		**ED56838-BL**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	11/06/25 15:39	11/06/25 15:39	BP	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1285		**Lims Reference ID:**		**ED56838-BM**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 18:04	11/06/25 18:04	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1754		**Lims Reference ID:**		**ED56838-BN**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 18:08	11/06/25 18:08	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1755		**Lims Reference ID:**		**ED56838-BO**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 18:09	11/06/25 18:09	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1786		**Lims Reference ID:**		**ED56838-BP**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 18:10	11/06/25 18:10	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1787		**Lims Reference ID:**		**ED56838-BQ**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 18:14	11/06/25 18:14	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1788		**Lims Reference ID:**		**ED56838-BR**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 18:15	11/06/25 18:15	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1799		**Lims Reference ID:**		**ED56838-BS**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 18:32	11/06/25 18:32	KT1	EPA 200.8 (Dig)/EPA 200.8
Sample: NASS-1800		**Lims Reference ID:**		**ED56838-BT**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556838
LIMS Reference ID: ED56838
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: 23-56115 - Nassau BOCES - Rosemary Kennedy Center RKC - 2850 N. Jerusalem Road, Wantagh, NY 11793
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/28/2025 12:47
Reported: 11/18/2025 09:10

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: NASS-1800 (Continued)		**Lims Reference ID:**		**ED56838-BT**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	11/06/25 18:17	11/06/25 18:17	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1801		**Lims Reference ID:**		**ED56838-BU**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 18:18	11/06/25 18:18	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1804		**Lims Reference ID:**		**ED56838-BV**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 18:19	11/06/25 18:19	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1813		**Lims Reference ID:**		**ED56838-BW**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 18:21	11/06/25 18:21	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1814		**Lims Reference ID:**		**ED56838-BX**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 18:22	11/06/25 18:22	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1846		**Lims Reference ID:**		**ED56838-BY**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 18:26	11/06/25 18:26	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1847		**Lims Reference ID:**		**ED56838-BZ**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 18:46	11/06/25 18:46	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1848		**Lims Reference ID:**		**ED56838-CA**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/06/25 18:47	11/06/25 18:47	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1851		**Lims Reference ID:**		**ED56838-CB**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556838
LIMS Reference ID: ED56838
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: 23-56115 - Nassau BOCES - Rosemary Kennedy Center RKC - 2850 N. Jerusalem Road, Wantagh, NY 11793
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/28/2025 12:47
Reported: 11/18/2025 09:10

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: NASS-1851 (Continued)		**Lims Reference ID:**		**ED56838-CB**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals (Continued)									
Lead	**< 1.0**		1	1.0	µg/L	11/06/25 18:48	11/06/25 18:48	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1977		**Lims Reference ID:**		**ED56838-CC**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	11/06/25 18:49	11/06/25 18:49	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1978		**Lims Reference ID:**		**ED56838-CD**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	11/06/25 18:51	11/06/25 18:51	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1979		**Lims Reference ID:**		**ED56838-CE**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	11/06/25 18:52	11/06/25 18:52	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: NASS-1980		**Lims Reference ID:**		**ED56838-CF**	**Matrix: Drinking Water**				**Sampled: 10/25/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	11/06/25 18:53	11/06/25 18:53	KT1	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556838
LIMS Reference ID: ED56838
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: 23-56115 - Nassau BOCES - Rosemary Kennedy Center RKC - 2850 N. Jerusalem Road, Wantagh, NY 11793
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 10/28/2025 12:47
Reported: 11/18/2025 09:10

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556838
LIMS Reference ID: ED56838
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name:	23-56115 - Nassau BOCES - Rosemary Kennedy Center RKC - 2850 N. Jerusalem Road, Wantagh, NY 11793
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	10/28/2025 12:47
Reported:	11/18/2025 09:10

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for ED56948

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-56115

Building: Saint Bernard's Parish
SBP

Client: Nassau BOCES

Walk In

Retest/New Install | |

Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
NASS-1672	OF	2014	Room 213	BW	10/31/2025	8:47:00 AM

Samples Submitted 1

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
NOV 03 25, PM02:05

Pb 200.8
Kathleen 11/6/25

Building Address
3100 Hempstead Turnpike
Levittown , NY 11756

Analysis Type: ELAP 200.5

Lab Recieved: Abigail Minnfield

Signature: A. Minnfield
11/3/25 2:05pm

Samplers Name: Misha Yaseen

Samplers Signature: Misha Yaseen

JCB Project Manager: Paul Fazio

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556948
LIMS Reference ID: ED56948
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: 23-56115, Saint Bernards Parish, SBP, Nassau BOCES, 3100 Hempstead Turnpike Levittown, NY 11756
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 11/03/2025 14:05
Reported: 11/18/2025 09:21

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: NASS-1672			**Lims Reference ID:**	**ED56948-01**	**Matrix: Drinking Water**			**Sampled:**	**10/31/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	11/06/25 18:55	11/06/25 18:55	KT1	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556948
LIMS Reference ID: ED56948
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: 23-56115, Saint Bernards Parish, SBP, Nassau BOCES, 3100 Hempstead Turnpike Levittown, NY 11756
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 11/03/2025 14:05
Reported: 11/18/2025 09:21

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556948
LIMS Reference ID: ED56948
EMSL Customer ID: JCBR50

Attention: Paul Fazio
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
PFazio@JCBroderick.com

Project Name: 23-56115, Saint Bernards Parish, SBP, Nassau BOCES, 3100 Hempstead Turnpike Levittown, NY 11756
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 11/03/2025 14:05
Reported: 11/18/2025 09:21

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Attachment 4:

Laboratory Certifications



J.C. Broderick & Associates, Inc.
Environmental Consulting & Testing
1775 Expressway Drive North
Hauppauge, New York 11788
631.584.5492 fax 631.584.3395

NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER

Expires 12:01 AM April 01, 2026
Issued April 01, 2025

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE

Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MR. DANIEL CLARKE
EMSL ANALYTICAL, INC.
528 MINEOLA AVE.
CARLE PLACE, NY 11514

NY Lab Id No: 11469

is hereby APPROVED as an Environmental Laboratory in conformance with the National Environmental Laboratory Accreditation Conference Standards (2016) for the category ENVIRONMENTAL ANALYSES POTABLE WATER
All approved analytes are listed below:

Bacteriology

Coliform, Total / E. coli (Qualitative)	SM 21, 23 9222A,B,C
	SM 20, 21-23 9223B (-04) (Colilert)
E. coli (Enumeration)	SM 21, 23 9222A,B,C
Heterotrophic Plate Count	SM 20, 21-23 9215B (-04)

Metals I

Copper, Total	EPA 200.8 Rev. 5.4
Lead, Total	EPA 200.8 Rev. 5.4
Silver, Total	EPA 200.8 Rev. 5.4

Miscellaneous

Asbestos	EPA 100.2

Serial No.: 70480

Property of the New York State Department of Health. Certificates are valid only at the address shown and must be conspicuously posted by the laboratory. Continued accreditation depends on the laboratory's successful ongoing participation in the Program. Consumers may verify a laboratory's accreditation status online at https://apps.health.ny.gov/pubdoh/applinks/wc/elappublicweb/, by phone (518) 485-5570 or by email to elap@health.ny.gov.