

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9220090

LRN : 0000324858

Auxiliary ID : Sample #1

Date Collected: 01/18/25

Date Received : 01/22/25

Requested by:

FINAL

Patient Name: CP/N/MLKDR, 1555

DOB:

Age:

Sex:

Ord. Comm: Golda Meir Lower Campus
Boys Bath Left Sink Ground Level

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	02/04/25 11:25
Test Method	*see below				02/04/25 11:25

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9220091

LRN : 0000324858

Auxiliary ID : Sample #2

Date Collected: 01/18/25

Date Received : 01/22/25

Requested by:

FINAL

Patient Name: CP/N/MLKDR, 1555

DOB:

Age:

Sex:

Ord. Comm: Golda Meir Lower Campus
Boys Bath Left Sink Ground Level
30 second

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	02/04/25 11:26
Test Method	*see below				02/04/25 11:26

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9220092

LRN : 0000324858

Auxiliary ID : Sample #3

Date Collected: 01/18/25

Date Received : 01/22/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/N/MLKDR, 1555

DOB:

Age:

Sex:

Ord. Comm: Golda Meir Lower Campus
Boys Bath Right Sink Ground Level

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	02/04/25 11:27
Test Method	*see below				02/04/25 11:27

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

[REDACTED]

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9220093

LRN : 0000324858

Auxiliary ID : Sample #4

Date Collected: 01/18/25

Date Received : 01/22/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/N/MLKDR, 1555

DOB:

Age:

Sex:

Ord. Comm: Golda Meir Lower Campus
Boys Bath Right Sink Ground Level
30 second

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	02/04/25 11:28
Test Method	*see below				02/04/25 11:28

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9220096

LRN : 0000324858

Auxiliary ID : Sample #5

Date Collected: 01/18/25

Date Received : 01/22/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/N/MLKDR, 1555

DOB:

Age:

Sex:

Ord. Comm: Golda Meir Lower Campus
Girls Bath Right Sink Ground Level

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	02/04/25 11:29
Test Method	*see below				02/04/25 11:29

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9220097

LRN : 0000324858

Auxiliary ID : Sample #6

Date Collected: 01/18/25

Date Received : 01/22/25

Requested by:

FINAL

Patient Name: CP/N/MLKDR, 1555

DOB:

Age:

Sex:

Ord. Comm: Golda Meir Lower Campus
Girls Bath Right Sink Ground Level
30 second

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	02/04/25 11:33
Test Method	*see below				02/04/25 11:33

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9220098

LRN : 0000324858

Auxiliary ID : Sample #7

Date Collected: 01/18/25

Date Received : 01/22/25

Requested by:

FINAL

Patient Name: CP/N/MLKDR, 1555

DOB:

Age:

Sex:

Ord. Comm: Golda Meir Lower Campus
Girls Bath Left Sink Ground Level

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	02/04/25 11:33
Test Method	*see below				02/04/25 11:33

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9220099

LRN : 0000324858

Auxiliary ID : Sample #8

Date Collected: 01/18/25

Date Received : 01/22/25

Requested by:

FINAL

Patient Name: CP/N/MLKDR, 1555

DOB:

Age:

Sex:

Ord. Comm: Golda Meir Lower Campus
Girls Bath Left Sink Ground Level
30 second

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*1.3			ug Pb/L	02/04/25 11:34
Test Method	*see below				02/04/25 11:34

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9220103

LRN : 0000324858

Auxiliary ID : Sample #9

Date Collected: 01/18/25

Date Received : 01/22/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/N/MLKDR, 1555

DOB:

Age:

Sex:

Ord. Comm: Golda Meir Lower Campus
Left Bubbler Ground Level

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	02/04/25 11:35
Test Method	*see below				02/04/25 11:35

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9220104

LRN : 0000324858

Auxiliary ID : Sample #10

Date Collected: 01/18/25

Date Received : 01/22/25

Requested by:

FINAL

Patient Name: CP/N/MLKDR, 1555

DOB:

Age:

Sex:

Ord. Comm: Golda Meir Lower Campus
Left Bubbler Ground Level
30 second

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	02/04/25 11:36
Test Method	*see below				02/04/25 11:36

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9220105

LRN : 0000324858

Auxiliary ID : Sample #11

Date Collected: 01/18/25

Date Received : 01/22/25

Requested by:

FINAL

Patient Name: CP/N/MLKDR, 1555

DOB:

Age:

Sex:

Ord. Comm: Golda Meir Lower Campus
Right Bubbler Ground Level

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	02/04/25 11:37
Test Method	*see below				02/04/25 11:37

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9220106

LRN : 0000324858

Auxiliary ID : Sample #12

Date Collected: 01/18/25

Date Received : 01/22/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/N/MLKDR, 1555

DOB:

Age:

Sex:

Ord. Comm: Golda Meir Lower Campus
Right Bubbler Ground Level
30 second

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	02/04/25 11:37
Test Method	*see below				02/04/25 11:37

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9220115

LRN : 0000324858

Auxiliary ID : Sample #13

Date Collected: 01/18/25

Date Received : 01/22/25

Requested by:

FINAL

Patient Name: CP/N/MLKDR, 1555

DOB:

Age:

Sex:

Ord. Comm: Golda Meir Lower Campus
Kitchen Sink Left

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	02/04/25 11:38
Test Method	*see below				02/04/25 11:38

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9220116

LRN : 0000324858

Auxiliary ID : Sample #14

Date Collected: 01/18/25

Date Received : 01/22/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/N/MLKDR, 1555

DOB:

Age:

Sex:

Ord. Comm: Golda Meir Lower Campus
Kitchen Sink Left
30 seconds

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	02/04/25 11:39
Test Method	*see below				02/04/25 11:39

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9220119

LRN : 0000324858

Auxiliary ID : Sample #15

Date Collected: 01/18/25

Date Received : 01/22/25

Requested by:

FINAL

Patient Name: CP/N/MLKDR, 1555

DOB:

Age:

Sex:

Ord. Comm: Golda Meir Lower Campus
Right Bubbler 1st Floor

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	02/04/25 11:39
Test Method	*see below				02/04/25 11:39

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9220122

LRN : 0000324858

Auxiliary ID : Sample #16

Date Collected: 01/18/25

Date Received : 01/22/25

Requested by:

FINAL

Patient Name: CP/N/MLKDR, 1555

DOB:

Age:

Sex:

Ord. Comm: Golda Meir Lower Campus
Right Bubbler 1st Floor
30 second

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	02/04/25 11:40
Test Method	*see below				02/04/25 11:40

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9220130

LRN : 0000324858

Auxiliary ID : Sample #17

Date Collected: 01/18/25

Date Received : 01/22/25

Requested by:

FINAL

Patient Name: CP/N/MLKDR, 1555

DOB:

Age:

Sex:

Ord. Comm: Golda Meir Lower Campus
Left Bubbler 1st Floor

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	02/04/25 11:40
Test Method	*see below				02/04/25 11:40

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9220131

LRN : 0000324858

Auxiliary ID : Sample #18

Date Collected: 01/18/25

Date Received : 01/22/25

Requested by:

FINAL

Patient Name: CP/N/MLKDR, 1555

DOB:

Age:

Sex:

Ord. Comm: Golda Meir Lower Campus
Left Bubbler 1st Floor
30 second

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	02/04/25 11:41
Test Method	*see below				02/04/25 11:41

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme



City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9220132
LRN : 0000324858
Auxiliary ID : Sample #19
Date Collected: 01/18/25
Date Received : 01/22/25

Requested by:

FINAL

Patient Name: CP/N/MLKDR, 1555 DOB: Age: Sex:

Ord. Comm: Golda Meir Lower Campus

Wash Sink 1st Floor

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*39.4			ug Pb/L	02/04/25 11:42
Test Method	*see below				02/04/25 11:42

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9220134

LRN : 0000324858

Auxiliary ID : Sample #20

Date Collected: 01/18/25

Date Received : 01/22/25

Requested by:

FINAL

Patient Name: CP/N/MLKDR, 1555

DOB:

Age:

Sex:

Ord. Comm: Golda Meir Lower Campus
Wash Sink 1st Floor
30 second

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*5.6			ug Pb/L	02/04/25 11:43
Test Method	*see below				02/04/25 11:43

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9220141

LRN : 0000324858

Auxiliary ID : Sample #21

Date Collected: 01/18/25

Date Received : 01/22/25

Requested by:

FINAL

Patient Name: CP/N/MLKDR, 1555

DOB:

Age:

Sex:

Ord. Comm: Golda Meir Lower Campus
Wash Sink 2nd Floor

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*6.1			ug Pb/L	02/06/25 09:20
Test Method	*see below				02/06/25 09:20

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9220142

LRN : 0000324858

Auxiliary ID : Sample #22

Date Collected: 01/18/25

Date Received : 01/22/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/N/MLKDR, 1555

DOB:

Age:

Sex:

Ord. Comm: Golda Meir Lower Campus
Wash Sink 2nd Floor
30 second

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*9.4			ug Pb/L	02/06/25 09:21
Test Method	*see below				02/06/25 09:21

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9220143

LRN : 0000324858

Auxiliary ID : Sample #23

Date Collected: 01/18/25

Date Received : 01/22/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/N/MLKDR, 1555

DOB:

Age:

Sex:

Ord. Comm: Golda Meir Lower Campus

Wash Sink 3rd Floor

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*28.8			ug Pb/L	02/06/25 09:22
Test Method	*see below				02/06/25 09:22

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9220145

LRN : 0000324858

Auxiliary ID : Sample #24

Date Collected: 01/18/25

Date Received : 01/22/25

Requested by:

FINAL

Patient Name: CP/N/MLKDR, 1555

DOB:

Age:

Sex:

Ord. Comm: Golda Meir Lower Campus
Wash Sink 3rd Floor
30 second

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*1.8			ug Pb/L	02/06/25 09:25
Test Method	*see below				02/06/25 09:25

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9220146

LRN : 0000324858

Auxiliary ID : Sample #25

Date Collected: 01/18/25

Date Received : 01/22/25

Requested by:

FINAL

Patient Name: CP/N/MLKDR, 1555

DOB:

Age:

Sex:

Ord. Comm: Golda Meir Lower Campus
Art Room Right Sink 3rd Floor

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*3.9			ug Pb/L	02/06/25 09:26
Test Method	*see below				02/06/25 09:26

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme



City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9220147
LRN : 0000324858
Auxiliary ID : Sample #26
Date Collected: 01/18/25
Date Received : 01/22/25

Requested by:



FINAL

Patient Name: CP/N/MLKDR, 1555	DOB:	Age:	Sex:
--------------------------------	------	------	------

Ord. Comm: Golda Meir Lower Campus
Art Room Right Sink 3rd Floor
30 second

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	02/06/25 09:27
Test Method	*see below				02/06/25 09:27

Reference Method of Analysis: SM 3113B


LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme



CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9220148

LRN : 0000324858

Auxiliary ID : Sample #27

Date Collected: 01/18/25

Date Received : 01/22/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/N/MLKDR, 1555

DOB:

Age:

Sex:

Ord. Comm: Golda Meir Lower Campus
Boys Bath 2nd Floor

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	02/06/25 09:28
Test Method	*see below				02/06/25 09:28

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9220149

LRN : 0000324858

Auxiliary ID : Sample #28

Date Collected: 01/18/25

Date Received : 01/22/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/N/MLKDR, 1555

DOB:

Age:

Sex:

Ord. Comm: Golda Meir Lower Campus
Boys Bath 2nd Floor
30 second

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	02/06/25 09:29
Test Method	*see below				02/06/25 09:29

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9220150
LRN : 0000324858
Auxiliary ID : Sample #29
Date Collected: 01/18/25
Date Received : 01/22/25

Requested by:

FINAL

Patient Name: CP/N/MLKDR, 1555

DOB:

Age:

Sex:

Ord. Comm: Golda Meir Lower Campus
Girls Bath 2nd Floor

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	02/06/25 09:30
Test Method	*see below				02/06/25 09:30

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9220151

LRN : 0000324858

Auxiliary ID : Sample #30

Date Collected: 01/18/25

Date Received : 01/22/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/N/MLKDR, 1555

DOB:

Age:

Sex:

Ord. Comm: Golda Meir Lower Campus
Girls Bath 2nd Floor
30 second

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	02/06/25 09:31
Test Method	*see below				02/06/25 09:31

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9220156
LRN : 0000324858
Auxiliary ID : Sample #31
Date Collected: 01/22/25
Date Received : 01/22/25

Requested by:

FINAL

Patient Name: CP/N/MLKDR, 1555

DOB:

Age:

Sex:

Ord. Comm: Golda Meir Lower Campus
Boys Bath 1st Floor

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE UNITS	DATE-TIME
<u>Lead in Water</u>				
Sample	*<1.0		ug Pb/L	02/06/25 09:32
Test Method	*see below			02/06/25 09:32

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9220157

LRN : 0000324858

Auxiliary ID : Sample #32

Date Collected: 01/22/25

Date Received : 01/22/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/N/MLKDR, 1555

DOB:

Age:

Sex:

Ord. Comm: Golda Meir Lower Campus
Boys Bath 1st Floor
30 second

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	02/06/25 09:33
Test Method	*see below				02/06/25 09:33

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9220158

LRN : 0000324858

Auxiliary ID : Sample #33

Date Collected: 01/22/25

Date Received : 01/22/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/N/MLKDR, 1555

DOB:

Age:

Sex:

Ord. Comm: Golda Meir Lower Campus
Girls Bath 1st Floor

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	02/06/25 09:33
Test Method	*see below				02/06/25 09:33

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9220159

LRN : 0000324858

Auxiliary ID : Sample #34

Date Collected: 01/22/25

Date Received : 01/22/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/N/MLKDR, 1555

DOB:

Age:

Sex:

Ord. Comm: Golda Meir Lower Campus
Girls Bath 1st Floor
30 second

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	02/06/25 09:35
Test Method	*see below				02/06/25 09:35

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9220160
LRN : 0000324858
Auxiliary ID : Sample #35
Date Collected: 01/22/25
Date Received : 01/22/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/N/MLKDR, 1555

DOB:

Age:

Sex:

Ord. Comm: Golda Meir Lower Campus
Kitchen Middle Sink

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*1.7			ug Pb/L	02/06/25 09:36
Test Method	*see below				02/06/25 09:36

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

[REDACTED]

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9220161
LRN : 0000324858
Auxiliary ID : Sample #36
Date Collected: 01/22/25
Date Received : 01/22/25

Requested by:

FINAL

Patient Name: CP/N/MLKDR, 1555

DOB:

Age:

Sex:

Ord. Comm: Golda Meir Lower Campus
Kitchen Middle Sink
30 second

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	02/06/25 09:37
Test Method	*see below				02/06/25 09:37

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

[REDACTED]

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9220162
LRN : 0000324858
Auxiliary ID : Sample #37
Date Collected: 01/22/25
Date Received : 01/22/25

Requested by:

FINAL

Patient Name: CP/N/MLKDR, 1555

DOB:

Age:

Sex:

Ord. Comm: Golda Meir Lower Campus
Kitchen Right Sink

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*4.9			ug Pb/L	02/06/25 09:38
Test Method	*see below				02/06/25 09:38

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

[REDACTED]

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9220163
LRN : 0000324858
Auxiliary ID : Sample #38
Date Collected: 01/22/25
Date Received : 01/22/25

Requested by:

FINAL

Patient Name: CP/N/MLKDR, 1555

DOB:

Age:

Sex:

Ord. Comm: Golda Meir Lower Campus
Kitchen Right Sink
30 second

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*4.8			ug Pb/L	02/06/25 09:38
Test Method	*see below				02/06/25 09:38

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9220164

LRN : 0000324858

Auxiliary ID : Sample #39

Date Collected: 01/22/25

Date Received : 01/22/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/N/MLKDR, 1555

DOB:

Age:

Sex:

Ord. Comm: Golda Meir Lower Campus
Left Bubbler 3rd Floor

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	02/06/25 09:40
Test Method	*see below				02/06/25 09:40

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9220165

LRN : 0000324858

Auxiliary ID : Sample #40

Date Collected: 01/22/25

Date Received : 01/22/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/N/MLKDR, 1555

DOB:

Age:

Sex:

Ord. Comm: Golda Meir Lower Campus
Left Bubbler 3rd Floor
30 second

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	02/06/25 09:41
Test Method	*see below				02/06/25 09:41

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9220166

LRN : 0000324858

Auxiliary ID : Sample #41

Date Collected: 01/22/25

Date Received : 01/22/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/N/MLKDR, 1555

DOB:

Age:

Sex:

Ord. Comm: Golda Meir Lower Campus

Wash Sink 3rd Floor

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*25.1			ug Pb/L	02/06/25 09:46
Test Method	*see below				02/06/25 09:46

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9220168

LRN : 0000324858

Auxiliary ID : Sample #42

Date Collected: 01/22/25

Date Received : 01/22/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/N/MLKDR, 1555

DOB:

Age:

Sex:

Ord. Comm: Golda Meir Lower Campus
Wash Sink 3rd Floor
30 second

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*9.0			ug Pb/L	02/06/25 09:53
Test Method	*see below				02/06/25 09:53

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme