

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9270044

LRN : 0000324913

Auxiliary ID : Sample #1

Date Collected: 01/25/25

Date Received : 01/27/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E Kagel School
Tall Porcelain Bubbler Basement

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	02/07/25 11:21
Test Method	*see below				02/07/25 11:21

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9270046

LRN : 0000324913

Auxiliary ID : Sample #2

Date Collected: 01/25/25

Date Received : 01/27/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E Kagel School
Tall Porcelain Bubbler Basement
30 second

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	* <1.0			ug Pb/L	02/07/25 11:21
Test Method	*see below				02/07/25 11:21

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

[REDACTED]

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9270047

LRN : 0000324913

Auxiliary ID : Sample #3

Date Collected: 01/25/25

Date Received : 01/27/25

Requested by:

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E Kagel School
New Bubbler Basement

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	02/07/25 11:22
Test Method	*see below				02/07/25 11:22

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

[REDACTED]

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9270050

LRN : 0000324913

Auxiliary ID : Sample #4

Date Collected: 01/25/25

Date Received : 01/27/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E Kagel School
New Bubbler Basement
30 second

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	02/07/25 11:23
Test Method	*see below				02/07/25 11:23

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9270051

LRN : 0000324913

Auxiliary ID : Sample #5

Date Collected: 01/25/25

Date Received : 01/27/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E Kagel School
Women Bathroom Sink Basement
(Most Right)

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	02/07/25 11:24
Test Method	*see below				02/07/25 11:24

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9270054

LRN : 0000324913

Auxiliary ID : Sample #6

Date Collected: 01/25/25

Date Received : 01/27/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E Kagel School
Women Bathroom Sink Basement
(Most Right) 30 second

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*1.2			ug Pb/L	02/07/25 11:26
Test Method	*see below				02/07/25 11:26

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9270055

LRN : 0000324913

Auxiliary ID : Sample #7

Date Collected: 01/25/25

Date Received : 01/27/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E Kagel School
Women Bathroom Sink Wall A Middle

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	02/07/25 11:27
Test Method	*see below				02/07/25 11:27

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

[REDACTED]

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9270056
LRN : 0000324913
Auxiliary ID : Sample #8
Date Collected: 01/25/25
Date Received : 01/27/25

Requested by:

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E Kagel School
Women Bathroom Sink Wall A Middle
30 second

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*2.1			ug Pb/L	02/07/25 11:27
Test Method	*see below				02/07/25 11:27

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9270093

LRN : 0000324913

Auxiliary ID : Sample #9

Date Collected: 01/25/25

Date Received : 01/27/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E Kagel School
Women's Bathroom Sink Wall A 2nd Middle

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*6.0			ug Pb/L	02/07/25 11:29
Test Method	*see below				02/07/25 11:29

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

[REDACTED]

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9270094

LRN : 0000324913

Auxiliary ID : Sample #10

Date Collected: 01/25/25

Date Received : 01/27/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E Kagel School
Women's Bathroom Sink Wall A 2nd Middle
30 second

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*3.9			ug Pb/L	02/07/25 11:39
Test Method	*see below				02/07/25 11:39

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9270096

LRN : 0000324913

Auxiliary ID : Sample #11

Date Collected: 01/25/25

Date Received : 01/27/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E Kagel School
Women's Bathroom Sink Wall A Left Most

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*7.3			ug Pb/L	02/07/25 11:44
Test Method	*see below				02/07/25 11:44

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9270097
LRN : 0000324913
Auxiliary ID : Sample #12
Date Collected: 01/25/25
Date Received : 01/27/25

Requested by:

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E Kagel School
Women's Bathroom Sink Wall A Left Most
30 second

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*4.8			ug Pb/L	02/07/25 11:52
Test Method	*see below				02/07/25 11:52

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

[REDACTED]

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9270098

LRN : 0000324913

Auxiliary ID : Sample #13

Date Collected: 01/25/25

Date Received : 01/27/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E Kagel School
Women's Bathroom Wall C Left Sink

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*4.0			ug Pb/L	02/07/25 11:46
Test Method	*see below				02/07/25 11:46

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9270099

LRN : 0000324913

Auxiliary ID : Sample #14

Date Collected: 01/25/25

Date Received : 01/27/25

Requested by:

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E Kagel School
Women's Bathroom Wall C Left Sink
30 second

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*4.1			ug Pb/L	02/07/25 11:47
Test Method	*see below				02/07/25 11:47

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9270104

LRN : 0000324913

Auxiliary ID : Sample #15

Date Collected: 01/25/25

Date Received : 01/27/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E Kagel School
Women's Bathroom Wall C Right Sink

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*4.3			ug Pb/L	02/07/25 11:52
Test Method	*see below				02/07/25 11:52

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

[REDACTED]

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9270115

LRN : 0000324913

Auxiliary ID : Sample #16

Date Collected: 01/25/25

Date Received : 01/27/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E Kagel School
Women's Bathroom Wall C Right Sink
30 second

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*1.9			ug Pb/L	02/07/25 11:53
Test Method	*see below				02/07/25 11:53

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9270120
LRN : 0000324913
Auxiliary ID : Sample #17
Date Collected: 01/25/25
Date Received : 01/27/25

Requested by:

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E Kagel School
Kitchen Basement Left Sink

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	02/07/25 11:54
Test Method	*see below				02/07/25 11:54

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9270121

LRN : 0000324913

Auxiliary ID : Sample #18

Date Collected: 01/25/25

Date Received : 01/27/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E Kagel School
Kitchen Basement Left Sink
30 second

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	02/07/25 11:54
Test Method	*see below				02/07/25 11:54

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9270122

LRN : 0000324913

Auxiliary ID : Sample #19

Date Collected: 01/25/25

Date Received : 01/27/25

Requested by:

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E Kagel School
Kitchen Basement Sink Right

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*2.6			ug Pb/L	02/07/25 11:55
Test Method	*see below				02/07/25 11:55

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9270123
LRN : 0000324913
Auxiliary ID : Sample #20
Date Collected: 01/25/25
Date Received : 01/27/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E Kagel School
Kitchen Basement Sink Right
30 second

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*1.2			ug Pb/L	02/07/25 11:56
Test Method	*see below				02/07/25 11:56

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9270131
LRN : 0000324913
Auxiliary ID : Sample #21
Date Collected: 01/25/25
Date Received : 01/27/25

Requested by:

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E Kagel School
Porcelain Basement Sink by Men's Restroom (Left)

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	02/07/25 11:57
Test Method	*see below				02/07/25 11:57

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9270132
LRN : 0000324913
Auxiliary ID : Sample #22
Date Collected: 01/25/25
Date Received : 01/27/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E Kagel School
Porcelain Basement Sink by Men's Restroom (Left)
30 second

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	02/07/25 11:57
Test Method	*see below				02/07/25 11:57

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

[REDACTED]

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9270133
LRN : 0000324913
Auxiliary ID : Sample #23
Date Collected: 01/25/25
Date Received : 01/27/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E Kagel School

Men's Bathroom Basement Sink Right Most (Wall C)

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*15.7			ug Pb/L	02/07/25 11:58
Test Method	*see below				02/07/25 11:58

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9270134

LRN : 0000324913

Auxiliary ID : Sample #24

Date Collected: 01/25/25

Date Received : 01/27/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E Kagel School

Men's Bathroom Basement Sink Right Most (Wall C)

30 second

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*8.5			ug Pb/L	02/07/25 11:59
Test Method	*see below				02/07/25 11:59

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9280089
LRN : 0000324913
Auxiliary ID : Sample #25
Date Collected: 01/25/25
Date Received : 01/27/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E Kagel School
Men's Bathroom Basement Wall C Sink Middle

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*19.4			ug Pb/L	02/07/25 12:00
Test Method	*see below				02/07/25 12:00

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

[REDACTED]

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9280090

LRN : 0000324913

Auxiliary ID : Sample #26

Date Collected: 01/25/25

Date Received : 01/27/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E Kagel School
Men's Bathroom Basement Wall C Sink Middle
30 second

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*7.2			ug Pb/L	02/07/25 12:01
Test Method	*see below				02/07/25 12:01

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

[REDACTED]

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9280091
LRN : 0000324913
Auxiliary ID : Sample #27
Date Collected: 01/25/25
Date Received : 01/27/25

Requested by:

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E Kagel School
Men's Restroom Sink Wall C 2nd Middle

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*6.4			ug Pb/L	02/07/25 12:02
Test Method	*see below				02/07/25 12:02

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

[REDACTED]

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9280092

LRN : 0000324913

Auxiliary ID : Sample #28

Date Collected: 01/25/25

Date Received : 01/27/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E Kagel School
Men's Restroom Sink Wall C 2nd Middle
30 second

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*4.4			ug Pb/L	02/07/25 12:03
Test Method	*see below				02/07/25 12:03

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9280093

LRN : 0000324913

Auxiliary ID : Sample #29

Date Collected: 01/25/25

Date Received : 01/27/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E Kagel School
Men's Basement Bathroom Wall B Left Most Sink

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*5.1			ug Pb/L	02/07/25 12:04
Test Method	*see below				02/07/25 12:04

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9280094

LRN : 0000324913

Auxiliary ID : Sample #30

Date Collected: 01/25/25

Date Received : 01/27/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E Kagel School
Men's Basement Bathroom Wall B Left Most Sink
30 second

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*1.7			ug Pb/L	02/07/25 12:05
Test Method	*see below				02/07/25 12:05

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

[REDACTED]

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9280097

LRN : 0000324913

Auxiliary ID : Sample #31

Date Collected: 01/25/25

Date Received : 01/27/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E Kagel School
Men's Bathroom Basement Wall B Middle Sink

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*9.5			ug Pb/L	02/07/25 12:06
Test Method	*see below				02/07/25 12:06

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9280099
LRN : 0000324913
Auxiliary ID : Sample #32
Date Collected: 01/25/25
Date Received : 01/27/25

Requested by:

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E Kagel School
Men's Bathroom Basement Wall B Middle Sink
30 second

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*1.4			ug Pb/L	02/07/25 12:07
Test Method	*see below				02/07/25 12:07

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9280100
LRN : 0000324913
Auxiliary ID : Sample #33
Date Collected: 01/25/25
Date Received : 01/27/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E Kagel School
Men's Bathroom Basement Wall B 2nd Middle

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*12.9			ug Pb/L	02/07/25 12:08
Test Method	*see below				02/07/25 12:08

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9280101
LRN : 0000324913
Auxiliary ID : Sample #34
Date Collected: 01/25/25
Date Received : 01/27/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E Kagel School
Men's Bathroom Basement Wall B 2nd Middle
30 second

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*2.3			ug Pb/L	02/07/25 12:09
Test Method	*see below				02/07/25 12:09

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9280110
LRN : 0000324913
Auxiliary ID : Sample #35
Date Collected: 01/25/25
Date Received : 01/27/25

Requested by:

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E Kagel School
1st Floor Hallway Sink Near RM 10

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*1.6			ug Pb/L	02/07/25 12:09
Test Method	*see below				02/07/25 12:09

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9280114
LRN : 0000324913
Auxiliary ID : Sample #36
Date Collected: 01/25/25
Date Received : 01/27/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E Kagel School
1st Floor Hallway Sink Near RM 10
30 second

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	02/07/25 12:10
Test Method	*see below				02/07/25 12:10

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9280119
LRN : 0000324913
Auxiliary ID : Sample #37
Date Collected: 01/25/25
Date Received : 01/27/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E Kagel School
10B Bathroom

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*12.0			ug Pb/L	02/07/25 12:12
Test Method	*see below				02/07/25 12:12

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9280120
LRN : 0000324913
Auxiliary ID : Sample #38
Date Collected: 01/25/25
Date Received : 01/27/25

Requested by:

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E Kagel School
10B Bathroom Basement

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*1.3			ug Pb/L	02/07/25 12:13
Test Method	*see below				02/07/25 12:13

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9280123
LRN : 0000324913
Auxiliary ID : Sample #39
Date Collected: 01/25/25
Date Received : 01/27/25

Requested by:

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E Kagel School
10C Bathroom Sink

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*3.7			ug Pb/L	02/07/25 12:14
Test Method	*see below				02/07/25 12:14

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Y9280124

LRN : 0000324913

Auxiliary ID : Sample #40

Date Collected: 01/25/25

Date Received : 01/27/25

Requested by:

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E Kagel School
10C Bathroom Sink
30 second

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*1.7			ug Pb/L	02/07/25 12:28
Test Method	*see below				02/07/25 12:28

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Z0030005
LRN : 0000324913
Auxiliary ID : Sample #41
Date Collected: 01/25/25
Date Received : 01/27/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E. Kagel School
015A Hall Sink

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE UNITS	DATE-TIME
<u>Lead in Water</u>				
Sample	*2.9		ug Pb/L	02/10/25 09:13
Test Method	*see below			02/10/25 09:13

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

[REDACTED]

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Z0030006
LRN : 0000324913
Auxiliary ID : Sample #42
Date Collected: 01/25/25
Date Received : 01/27/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E. Kagel School
015A Hall Sink 30 seconds

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*2.6			ug Pb/L	02/10/25 09:14
Test Method	*see below				02/10/25 09:14

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Z0030007
LRN : 0000324913
Auxiliary ID : Sample #43
Date Collected: 01/25/25
Date Received : 01/27/25

Requested by:

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E. Kagel School
RM 17 Teachers Lounge

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*5.3			ug Pb/L	02/10/25 09:14
Test Method	*see below				02/10/25 09:14

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Z0030008

LRN : 0000324913

Auxiliary ID : Sample #44

Date Collected: 01/25/25

Date Received : 01/27/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E. Kagel School
RM 17 Teachers Lounge
30 seconds

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*3.3			ug Pb/L	02/10/25 09:15
Test Method	*see below				02/10/25 09:15

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Z0030009
LRN : 0000324913
Auxiliary ID : Sample #45
Date Collected: 01/25/25
Date Received : 01/27/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E. Kagel School
Middle Hallway Bubbler
Next to RM 14

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*3.0			ug Pb/L	02/10/25 09:17
Test Method	*see below				02/10/25 09:17

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Z0030010

LRN : 0000324913

Auxiliary ID : Sample #46

Date Collected: 01/25/25

Date Received : 01/27/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E. Kagel School
Middle Hallway Bubbler
Next to RM 14 30 second

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	02/10/25 09:18
Test Method	*see below				02/10/25 09:18

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Z0030011

LRN : 0000324913

Auxiliary ID : Sample #47

Date Collected: 01/25/25

Date Received : 01/27/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E. Kagel School
Middle Hallway 1st Floor Bubbler 2
Next to RM 14

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	02/10/25 09:19
Test Method	*see below				02/10/25 09:19

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

[REDACTED]

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Z0030012
LRN : 0000324913
Auxiliary ID : Sample #48
Date Collected: 01/25/25
Date Received : 01/27/25

Requested by:

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E. Kagel School
Middle Hallway 1st Floor Bubbler 2
Next to RM 14 30 second

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	02/10/25 09:20
Test Method	*see below				02/10/25 09:20

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Z0030013

LRN : 0000324913

Auxiliary ID : Sample #49

Date Collected: 01/25/25

Date Received : 01/27/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E. Kagel School
New Bubbler 1st Floor Middle Hall

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	02/10/25 09:21
Test Method	*see below				02/10/25 09:21

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Z0030014
LRN : 0000324913
Auxiliary ID : Sample #50
Date Collected: 01/25/25
Date Received : 01/27/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E. Kagel School
New Bubbler 1st Floor Middle Hall
30 second

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	02/10/25 09:23
Test Method	*see below				02/10/25 09:23

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Z0030015

LRN : 0000324913

Auxiliary ID : Sample #51

Date Collected: 01/25/25

Date Received : 01/27/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E. Kagel School
1st Floor RM 11b Sink

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	02/10/25 09:24
Test Method	*see below				02/10/25 09:24

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Z0030016
LRN : 0000324913
Auxiliary ID : Sample #52
Date Collected: 01/25/25
Date Received : 01/27/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E. Kagel School
1st Floor RM 11b Sink
30 second

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	02/10/25 09:25
Test Method	*see below				02/10/25 09:25

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Z0030017
LRN : 0000324913
Auxiliary ID : Sample #53
Date Collected: 01/25/25
Date Received : 01/27/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E. Kagel School
Sink Near RM 20

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE UNITS	DATE-TIME
<u>Lead in Water</u>				
Sample	*<1.0		ug Pb/L	02/10/25 09:26
Test Method	*see below			02/10/25 09:26

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

[REDACTED]

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Z0030018
LRN : 0000324913
Auxiliary ID : Sample #54
Date Collected: 01/25/25
Date Received : 01/27/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E. Kagel School
Sink Near RM 20
30 second

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	02/10/25 09:26
Test Method	*see below				02/10/25 09:26

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Z0030019

LRN : 0000324913

Auxiliary ID : Sample #55

Date Collected: 01/25/25

Date Received : 01/27/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E. Kagel School
Principals Office 2nd Floor

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*7.9			ug Pb/L	02/10/25 09:27
Test Method	*see below				02/10/25 09:27

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Z0030020

LRN : 0000324913

Auxiliary ID : Sample #56

Date Collected: 01/25/25

Date Received : 01/27/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E. Kagel School
Principals Office 2nd Floor
30 second

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*14.7			ug Pb/L	02/10/25 09:28
Test Method	*see below				02/10/25 09:28

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

[REDACTED]

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Z0030041
LRN : 0000324913
Auxiliary ID : Sample #57
Date Collected: 01/25/25
Date Received : 01/27/25

Requested by:

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E Kagel School
Middle Hallway Near RM 24
Right Sink

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*2.4			ug Pb/L	02/10/25 09:29
Test Method	*see below				02/10/25 09:29

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Z0030042

LRN : 0000324913

Auxiliary ID : Sample #58

Date Collected: 01/25/25

Date Received : 01/27/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E Kagel School
Middle Hallway Near RM 24
Right Sink 30 second

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	02/10/25 09:30
Test Method	*see below				02/10/25 09:30

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Z0030043
LRN : 0000324913
Auxiliary ID : Sample #59
Date Collected: 01/25/25
Date Received : 01/27/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E Kagel School
Middle Bubbler Near RM 24

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	02/10/25 09:31
Test Method	*see below				02/10/25 09:31

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Z0030044
LRN : 0000324913
Auxiliary ID : Sample #60
Date Collected: 01/25/25
Date Received : 01/27/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E Kagel School
Middle Bubbler Near RM 24
30 second

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	02/10/25 09:32
Test Method	*see below				02/10/25 09:32

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Z0030045
LRN : 0000324913
Auxiliary ID : Sample #61
Date Collected: 01/25/25
Date Received : 01/27/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E Kagel School
New Bubbler Near RM 24
2nd Floor

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	02/10/25 09:34
Test Method	*see below				02/10/25 09:34

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Z0030046

LRN : 0000324913

Auxiliary ID : Sample #62

Date Collected: 01/25/25

Date Received : 01/27/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E Kagel School
New Bubbler Near RM 24
2nd Floor 30 second

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	02/10/25 09:34
Test Method	*see below				02/10/25 09:34

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Z0030050

LRN : 0000324913

Auxiliary ID : Sample #63

Date Collected: 01/25/25

Date Received : 01/27/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E Kagel School
Girl's Bathroom 2nd Floor
Left Sink

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*3.5			ug Pb/L	02/10/25 09:35
Test Method	*see below				02/10/25 09:35

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Z0030054

LRN : 0000324913

Auxiliary ID : Sample #64

Date Collected: 01/25/25

Date Received : 01/27/25

Requested by:

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E Kagel School
Girl's Bathroom 2nd Floor
Left Sink 30 second

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*4.2			ug Pb/L	02/10/25 09:37
Test Method	*see below				02/10/25 09:37

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Z0030055

LRN : 0000324913

Auxiliary ID : Sample #65

Date Collected: 01/25/25

Date Received : 01/27/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E Kagel School
Girl's Bathroom Right Sink

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*3.7			ug Pb/L	02/10/25 09:38
Test Method	*see below				02/10/25 09:38

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Z0030058
LRN : 0000324913
Auxiliary ID : Sample #66
Date Collected: 01/25/25
Date Received : 01/27/25

Requested by:

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E Kagel School
Girl's Bathroom Right Sink
30 second

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*4.3			ug Pb/L	02/10/25 09:40
Test Method	*see below				02/10/25 09:40

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Z0030062

LRN : 0000324913

Auxiliary ID : Sample #67

Date Collected: 01/25/25

Date Received : 01/27/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E Kagel School
Boy's Bathroom Left Sink

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*8.4			ug Pb/L	02/10/25 09:43
Test Method	*see below				02/10/25 09:43

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Z0030065

LRN : 0000324913

Auxiliary ID : Sample #68

Date Collected: 01/25/25

Date Received : 01/27/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E Kagel School
Boy's Bathroom Left Sink
30 second

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*8.4			ug Pb/L	02/10/25 09:44
Test Method	*see below				02/10/25 09:44

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Z0030097

LRN : 0000324913

Auxiliary ID : Sample #69

Date Collected: 01/25/25

Date Received : 01/27/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E. Kagel School
Boys Bathroom Right Sink

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*5.6			ug Pb/L	02/10/25 09:45
Test Method	*see below				02/10/25 09:45

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Z0030098

LRN : 0000324913

Auxiliary ID : Sample #70

Date Collected: 01/25/25

Date Received : 01/27/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E. Kagel School
Boys Bathroom Right Sink
30 seconds

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*2.6			ug Pb/L	02/10/25 09:46
Test Method	*see below				02/10/25 09:46

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Z0030099

LRN : 0000324913

Auxiliary ID : Sample #71

Date Collected: 01/25/25

Date Received : 01/27/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E. Kagel School
RM 33 Sink

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*2.1			ug Pb/L	02/10/25 09:46
Test Method	*see below				02/10/25 09:46

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

[REDACTED]

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Z0030100
LRN : 0000324913
Auxiliary ID : Sample #72
Date Collected: 01/25/25
Date Received : 01/27/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E. Kagel School
RM 33 Sink 30 seconds

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*3.4			ug Pb/L	02/10/25 09:47
Test Method	*see below				02/10/25 09:47

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Z0030101
LRN : 0000324913
Auxiliary ID : Sample #73
Date Collected: 01/25/25
Date Received : 01/27/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E. Kagel School
RM 33 3rd Floor

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	02/10/25 09:48
Test Method	*see below				02/10/25 09:48

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Z0030106

LRN : 0000324913

Auxiliary ID : Sample #74

Date Collected: 01/25/25

Date Received : 01/27/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E. Kagel School
RM 33 3rd Floor 30 seconds

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	02/10/25 09:48
Test Method	*see below				02/10/25 09:48

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

[REDACTED]

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Z0030107

LRN : 0000324913

Auxiliary ID : Sample #75

Date Collected: 01/25/25

Date Received : 01/27/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E. Kagel School
New Bubbler Near RM 30

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	02/10/25 09:49
Test Method	*see below				02/10/25 09:49

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

[REDACTED]

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Z0030109
LRN : 0000324913
Auxiliary ID : Sample #76
Date Collected: 01/25/25
Date Received : 01/27/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E. Kagel School
New Bubbler Near RM 30
30 seconds

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*1.4			ug Pb/L	02/10/25 09:50
Test Method	*see below				02/10/25 09:50

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

[REDACTED]

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Z0030110

LRN : 0000324913

Auxiliary ID : Sample #77

Date Collected: 01/25/25

Date Received : 01/27/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E. Kagel School
Sink Near RM 30 3rd Floor

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*2.2			ug Pb/L	02/10/25 09:51
Test Method	*see below				02/10/25 09:51

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

[REDACTED]

CITY OF MILWAUKEE
HEALTH DEPARTMENT

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
Autoreporting Lab

Submitter copy to:

HOME ENVIRONMENTAL HEALTH LEAD PROGRAM
841 N Broadway Ave
1st Floor
Milwaukee, WI 53202

Order ID : Z0030111
LRN : 0000324913
Auxiliary ID : Sample #78
Date Collected: 01/25/25
Date Received : 01/27/25

Requested by: [REDACTED]

FINAL

Patient Name: CP/W/MINERALST, 1210

DOB:

Age:

Sex:

Ord. Comm: Albert E. Kagel School
Sink Near RM 30 3rd Floor
30 second

Chemistry

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	02/10/25 09:52
Test Method	*see below				02/10/25 09:52

Reference Method of Analysis: SM 3113B

LOD: 0.769 ppb (ug/L)

LOQ: 2.562 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

[REDACTED]