

November 13, 2025

Mr. Jason Hamer
Belfast CSD
1 King Street
Belfast, New York 14711

Re: Lead Testing in School Drinking Water

Dear Mr. Hamer:

Included with this letter is Stohl Environmental LLC's report for the Lead in Drinking Water Sampling performed for Belfast Central School District, including:

- **Belfast Central School – 1 King St., Belfast, New York**

This report is prepared to assist school districts in complying with the requirements of 10 NYCRR Subpart 67-4: *Lead Testing in School Drinking Water*, by identifying the sources of potable water with lead concentrations greater than the NYS "Action Level of 5 parts per billion (ppb)".

Sampling was performed on October 23, 2025 As detailed in Section 1.2 (*Executive Summary*) of the accompanying report, based upon the sampling and analysis performed, 35 sources of potable water in the Belfast Central School have been identified as having lead concentrations in water above the NYS Action Level of 5 parts per billion. To comply with NYS regulations, response actions by the district are required. Response actions are outlined in Section 1.3 (*Response Actions Required Under NYS Regulations*).

Thank you for the opportunity to be of service to Belfast Central School District.

Sincerely,
Stohl Environmental, LLC.



Michael Scinta
EPA Lead Risk Assessor

Lead Testing in School Drinking Water

Prepared for:

Belfast Central School District

Prepared by:



**3860 California Road
Orchard Park, New York 14127**

Conditions as of October 23, 2025

Summary Tabulation

Lead in Drinking Water Investigation

- 1.1. Scope of Work and Sampling Protocol
- 1.2. Executive Summary of Sampling and Analysis
- 1.3. Response Actions Required Under NYS Regulations
- 1.4. Laboratory Analytical Reports and Chain of Custody Documents
- 1.5. Laboratory Certifications

1.1 Scope of Work and Sampling Protocol:

Stohl Environmental was retained by Belfast Central School District to perform sampling and analysis of potable water for lead concentrations. Sampling was performed in the following building:

- **Belfast Central School – 1 King St., Belfast, New York**

Scope of Work:

Stohl Environmental was charged with collecting first-draw water samples from outlets within the Belfast Central School. Outlets are defined in NYS regulations as: “a potable water fixture currently or potentially used for drinking or cooking purposes, including but not limited to a bubbler, drinking fountain, or faucets”.

Sampling Protocol:

In accordance with NYS regulations, ***Subpart 67-4: Lead Testing in School Drinking Water***, and the EPA guidance document, ***3Ts for Reducing Lead in Drinking Water in Schools***, Stohl Environmental’s protocol can be summarized as follows:

- **First-draw samples** of 250 milliliters (mL) were collected from cold water outlets before any water was used. Sampling was coordinated with District representatives to assure that water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours before sample collection.
- **Laboratory Analysis:** Samples were submitted following strict chain-of-custody protocols to an independent laboratory approved by the NYS Department of Health’s Environmental Laboratory Approval Program (ELAP).

1.2 Executive Summary of Sampling and Analysis:

Summary of Samples Collected at the Belfast Central School:

Building Name	Date of Sampling	Total Samples	At or Below Action Level*	Above Action Level*
Belfast Central School	10/23/25	88	53	35

**NYS Action Level is 5 parts per billion*

Listing of Outlets Requiring Remediation

The following outlets were analyzed above the NYS Action Level:

Sample #	Location	Fixture/Outlet type	Laboratory Analysis (in ppb)
218.1-1	Kitchen Back Corner Handwash	Sink	12.1
218.1-2	Kitchen Center 2 Bay	Sink	7.2
218.1-4	Kitchen 3 Bay Left	Sink	5.5
218.1-6	Kitchen 3 Bay Right	Sink	12.4
218.1-7	Kitchen Hand Wash by Cafe Entrance	Sink	6.9
218.1-8	Kitchen Lav	Sink	5.3
218.1-11	150 Kitchenette Sink	Sink	9.6
218.1-12	150 Left Lav	Sink	14.7
218.1-13	150 Left Low Sink	Sink	5.7
218.1-14	150 Right Low Sink	Sink	7.5
218.1-15	150 Right Lav	Sink	9.9
218.1-20	106D Faculty Room	Sink	7.0
218.1-21	100 Main	Sink	5.4
218.1-22	100 DF	Drinking Fountain	5.4
218.1-23	100 Lav	Sink	6.4
218.1-25	101 DF	Drinking Fountain	11.2
218.1-26	101 Lav	Sink	5.7
218.1-27	102 Main	Sink	6.9
218.1-29	103 Main	Sink	8.1
218.1-30	103 Lav	Sink	5.2

Sample #	Location	Fixture/Outlet type	Laboratory Analysis (in ppb)
218.1-31	104 Main	Sink	8.8
218.1-32	104 DF	Drinking Fountain	5.2
218.1-33	104 Lav	Sink	14.7
218.1-34	105 Main	Sink	8.0
218.1-35	105 Lav	Sink	7.1
218.1-37	Janitor Utility Sink Near 104	Sink	151
218.1-43	Room 109 Sink	Sink	58.7
218.1-48	Room 203	Sink	5.5
218.1-63	Girls Locker Room L	Sink	12.9
218.1-64	Girls Locker room R	Sink	9.7
218.1-65	116 Girls Phys Ed Office	Sink	8.8
218.1-66	122 Boys Phys Ed Office	Sink	8.3
218.1-67	Boys Locker Room L	Sink	13.9
218.1-68	Boys Locker Room R	Sink	38.9
218.1-81	HS Art Room 142 Right	Sink	36.4

1.3 Response Actions Required Under NYS Regulations, Section 67-4.4:

For outlets analyzed with a lead concentration more than the NYS Action Level, regulations require:

- (a) Prohibit use of the outlet until:
 - (1) a lead remediation plan is implemented to mitigate the lead level of such outlet; and
 - (2) test results indicate that the lead levels are at or below the action level;
- (b) Provide building occupants with an adequate supply of potable water for drinking and cooking until remediation is performed;
- (c) Report the test results to the local health department as soon as practicable, but no more than 1 business day after the school received the laboratory report; and
- (d) Notify all staff and all persons in parental relation to students of the test results, in writing, as soon as practicable but no more than 10 business days after the school received the laboratory report.

1.4 Laboratory Analytical Reports and Chain of Custody Documents



November 11, 2025

Service Request No:R2513915

Michael Scinta
Stohl Environmental
3860 California Road
Orchard Park, NY 14219

Laboratory Results for: Belfast CSD Elementary/Middle/High School

Dear Michael,

Enclosed are the results of the sample(s) submitted to our laboratory October 24, 2025
For your reference, these analyses have been assigned our service request number **R2513915**.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at Meghan.Pedro@alsglobal.com.

Respectfully submitted,

ALS Group USA, Corp. dba ALS Environmental

Meghan Pedro
Project Manager

CC: Rebecca
Franjoine

ADDRESS

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

PHONE

+1 585 288 5380

FAX

+1 585 288 8475

ALS Group USA, Corp.
dba ALS Environmental



Narrative Documents

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com



Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School
Sample Matrix: Drinking Water

Service Request: R2513915
Date Received: 10/24/2025

CASE NARRATIVE

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

Sample Receipt:

Thirty six drinking water samples were received for analysis at ALS Environmental on 10/24/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

Metals:

No significant anomalies were noted with this analysis.

Approved by

A handwritten signature in black ink, appearing to read 'Meghan Pedicini', is written over a horizontal line.

Date

11/11/2025



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 218.1-1		Lab ID: R2513915-001				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	12.1			1.0	ug/L	200.8
CLIENT ID: 218.1-2		Lab ID: R2513915-002				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	7.2			1.0	ug/L	200.8
CLIENT ID: 218.1-3		Lab ID: R2513915-003				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.7			1.0	ug/L	200.8
CLIENT ID: 218.1-4		Lab ID: R2513915-004				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	5.5			1.0	ug/L	200.8
CLIENT ID: 218.1-5		Lab ID: R2513915-005				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.5			1.0	ug/L	200.8
CLIENT ID: 218.1-6		Lab ID: R2513915-006				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	12.4			1.0	ug/L	200.8
CLIENT ID: 218.1-7		Lab ID: R2513915-007				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	6.9			1.0	ug/L	200.8
CLIENT ID: 218.1-8		Lab ID: R2513915-008				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	5.3			1.0	ug/L	200.8
CLIENT ID: 218.1-11		Lab ID: R2513915-011				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	9.6			1.0	ug/L	200.8
CLIENT ID: 218.1-12		Lab ID: R2513915-012				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	14.7			0.50	ug/L	200.8
CLIENT ID: 218.1-13		Lab ID: R2513915-013				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	5.7			1.0	ug/L	200.8
CLIENT ID: 218.1-14		Lab ID: R2513915-014				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	7.5			1.0	ug/L	200.8



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 218.1-15		Lab ID: R2513915-015				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	9.9			1.0	ug/L	200.8
CLIENT ID: 218.1-16		Lab ID: R2513915-016				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	3.8			1.0	ug/L	200.8
CLIENT ID: 218.1-17		Lab ID: R2513915-017				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.5			1.0	ug/L	200.8
CLIENT ID: 218.1-20		Lab ID: R2513915-021				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	7.0			1.0	ug/L	200.8
CLIENT ID: 218.1-21		Lab ID: R2513915-022				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	5.4			1.0	ug/L	200.8
CLIENT ID: 218.1-22		Lab ID: R2513915-023				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	5.4			1.0	ug/L	200.8
CLIENT ID: 218.1-23		Lab ID: R2513915-024				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	6.4			1.0	ug/L	200.8
CLIENT ID: 218.1-24		Lab ID: R2513915-025				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	3.0			1.0	ug/L	200.8
CLIENT ID: 218.1-25		Lab ID: R2513915-026				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	11.2			1.0	ug/L	200.8
CLIENT ID: 218.1-26		Lab ID: R2513915-027				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	5.7			1.0	ug/L	200.8
CLIENT ID: 218.1-27		Lab ID: R2513915-028				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	6.9			1.0	ug/L	200.8
CLIENT ID: 218.1-28		Lab ID: R2513915-029				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.9			1.0	ug/L	200.8



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 218.1-29		Lab ID: R2513915-030				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	8.1			1.0	ug/L	200.8
CLIENT ID: 218.1-30		Lab ID: R2513915-031				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	5.2			1.0	ug/L	200.8
CLIENT ID: 218.1-31		Lab ID: R2513915-032				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	8.8			1.0	ug/L	200.8
CLIENT ID: 218.1-32		Lab ID: R2513915-033				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	5.2			1.0	ug/L	200.8
CLIENT ID: 218.1-33		Lab ID: R2513915-034				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	14.7			1.0	ug/L	200.8
CLIENT ID: 218.1-34		Lab ID: R2513915-035				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	8.0			1.0	ug/L	200.8
CLIENT ID: 218.1-35		Lab ID: R2513915-036				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	7.1			1.0	ug/L	200.8



Sample Receipt Information

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1

Service Request:R2513915

SAMPLE CROSS-REFERENCE

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2513915-001	218.1-1	10/23/2025	
R2513915-002	218.1-2	10/23/2025	
R2513915-003	218.1-3	10/23/2025	
R2513915-004	218.1-4	10/23/2025	
R2513915-005	218.1-5	10/23/2025	
R2513915-006	218.1-6	10/23/2025	
R2513915-007	218.1-7	10/23/2025	
R2513915-008	218.1-8	10/23/2025	
R2513915-009	218.1-9	10/23/2025	
R2513915-010	218.1-10	10/23/2025	
R2513915-011	218.1-11	10/23/2025	
R2513915-012	218.1-12	10/23/2025	
R2513915-013	218.1-13	10/23/2025	
R2513915-014	218.1-14	10/23/2025	
R2513915-015	218.1-15	10/23/2025	
R2513915-016	218.1-16	10/23/2025	
R2513915-017	218.1-17	10/23/2025	
R2513915-018	218.1-18A	10/23/2025	
R2513915-019	218.1-18B	10/23/2025	
R2513915-020	218.1-19	10/23/2025	
R2513915-021	218.1-20	10/23/2025	
R2513915-022	218.1-21	10/23/2025	
R2513915-023	218.1-22	10/23/2025	
R2513915-024	218.1-23	10/23/2025	
R2513915-025	218.1-24	10/23/2025	
R2513915-026	218.1-25	10/23/2025	
R2513915-027	218.1-26	10/23/2025	
R2513915-028	218.1-27	10/23/2025	
R2513915-029	218.1-28	10/23/2025	
R2513915-030	218.1-29	10/23/2025	
R2513915-031	218.1-30	10/23/2025	
R2513915-032	218.1-31	10/23/2025	
R2513915-033	218.1-32	10/23/2025	
R2513915-034	218.1-33	10/23/2025	
R2513915-035	218.1-34	10/23/2025	
R2513915-036	218.1-35	10/23/2025	



3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Chain of Custody Document

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-218.1

Client: Belfast CSD

Contact: Jason Hamer

Building: Belfast Central Elementary/Middle/High School

Location: 1 King Street, Belfast, NY 14711

LEAD

Water by 200.8

X

Turnaround

10 Days

Sample #	Location	Outlet Type	Time
218.1-1	Kitchen Back Corner Handwash	Sink	5:05
218.1-2	Kitchen Center 2 Bay	Sink	5:06
218.1-3	Kitchen Center 2 Bay Sprayer	Sink	5:07
218.1-4	Kitchen 3 Bay Left	Sink	5:09
218.1-5	Kitchen 3 Bay Sprayer	Sink	5:10
218.1-6	Kitchen 3 Bay Right	Sink	5:11
218.1-7	Kitchnen Hand Wash by Cafe Entrance	Sink	5:13
218.1-8	Kitchen Lav	Sink	5:14
218.1-9	Auditorium Men's Lav Center	Sink	5:15
218.1-10	Auditorium Men's Lav Right	Sink	5:17
218.1-11	150 Kitchenette Sink	Sink	5:18
218.1-12	150 Left Lav	Sink	5:20
218.1-13	150 Left Low Sink	Sink	5:21
218.1-14	150 Right Low Sink	Sink	5:22
218.1-15	150 Right Lav	Sink	5:24
218.1-16	Auditorium Women's Lav Left	Sink	5:25
218.1-17	Auditorium Women's Lav Right	Sink	5:26
218.1-18A	Left DF Outside Auditorium	DF	5:28

Notes:

Please e-mail lab results to labs@stohlenvironmental.com

☒ If checked, also e-mail results to:

Mscinta@stohlenvironmental.com

Sampled By: <u>Jared Rider</u>	Print Name	Stohl Env: <u>Jared Rider</u>	Date: <u>10/23/2025</u>
Relinquished By: _____	Print Name	Stohl Env: <u>Connor Crilly</u>	Date: <u>10/23/2025</u>
Received (Name / Lab): <u>SPM 12/11/25</u>		Date: <u>10/24/25</u>	Time: <u>8:14</u>
Sample Login (Name / Lab): _____		Date: _____	Time: _____
Analysis (Name / Lab): _____		Date: _____	Time: _____
QA/QC Review (Name / Lab): _____		Date: _____	Time: _____
Archived / Released: _____	QA/QC InterLAB Use: _____	Date: _____	Time: _____

Page 1 of 5

R2513915

5

Stohl Environmental
Belfast CSD Elementary/Middle/High School





3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Chain of Custody Document

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-218.1

Client: Belfast CSD

Contact: Jason Hamer

Building: Belfast Central Elementary/Middle/High School

Location: 1 King Street, Belfast, NY 14711

LEAD

Water by 200.8

X

Turnaround

10 Days

Sample #	Location	Outlet Type	Time
218.1-18B	Left DFB outside Auditorium	DFB	5:29
218.1-19	Right DF Outside Auditorium	DF	5:30
218.1-20	106D Faculty Room	Sink	5:32
218.1-21	100 Main	Sink	5:33
218.1-22	100 DF	DF	5:35
218.1-23	100 Lav	Sink	5:36
218.1-24	101 Main	Sink	5:37
218.1-25	101 DF	DF	5:39
218.1-26	101 Lav	Sink	5:40
218.1-27	102 Main	Sink	5:41
218.1-28	102 Lav	Sink	5:43
218.1-29	103 Main	Sink	5:44
218.1-30	103 Lav	Sink	5:46
218.1-31	104 Main	Sink	5:47
218.1-32	104 DF	DF	5:48
218.1-33	104 Lav	Sink	5:50
218.1-34	105 Main	Sink	5:51
218.1-35	105 Lav	Sink	5:52

Notes:

Please e-mail lab results to labs@stohlenvironmental.com

Mscinta@stohlenvironmental.com

Sampled By: <u>Jared Rider</u>	Print Name	Stohl Env: <u>Jared Rider</u>	Date: <u>10/23/2025</u>
Relinquished By: _____	Print Name	Stohl Env: <u>Connor Crilly</u>	Date: <u>10/23/2025</u>
Received (Name / Lab): <u>Legion Mamm ALS</u>	Date: <u>10/24/25</u>	Time: <u>8:14</u>	
Sample Login (Name / Lab): _____	Date: _____	Time: _____	
Analysis (Name / Lab): _____	Date: _____	Time: _____	
QA/QC Review (Name / Lab): _____	Date: _____	Time: _____	
Archived / Released: _____	QA/QC InterLAB Use: _____	Date: _____	Time: _____



Cooler Receipt and Preservation

R2513915

5

Stohl Environmental
Belfast CSD Elementary/Middle/High School

Project/Client

Stohl

Folder Number

Cooler received on 10/24/25

by: RM

COURIER: ALS UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	Y N
2	Custody papers properly completed (ink, signed)?	Y N
3	Did all bottles arrive in good condition (unbroken)?	Y N
4	Circle: Wet Ice Dry Ice Gel packs present?	Y N

5a	Did VOA vials have sig* bubbles?	Y N NA
5b	Sig* bubbles: Alk? Y N NA Sulfide?	Y N NA
6	Where did the bottles originate?	ALS/ROC CLIENT
7	Soil VOA received as: Bulk Encore 5035set	NA

8. Temperature Readings

Date: 10/24/25

Time: 8:23

ID: IR#12 IR#11

From: Temp Blank

Sample Bottle

Temp (°C)	10.4						
Within 0-6°C?	Y N	Y N	Y N	Y N	Y N	Y N	Y N
If <0°C, were samples frozen?	Y N	Y N	Y N	Y N	Y N	Y N	Y N

If out of Temperature, note packing/ice condition: No ice Ice melted Poorly Packed (described below) Same Day Rule
& Client Approval to Run Samples: Standing Approval Client aware at drop-off Client notified by:

All samples held in storage location: SMO by RM on 10/24 at 8:30

5035 samples placed in storage location: by on at within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check**: Date: 10/27/25 Time: 1540 by: CC

- Were all bottle labels complete (i.e. analysis, preservation, etc.)? YES NO
- Did all bottle labels and tags agree with custody papers? YES NO
- Were correct containers used for the tests indicated? YES NO
- Were 5035 vials acceptable (no extra labels, not leaking)? YES NO N/A
- Were dissolved metals filtered in the field? YES NO N/A
- Air Samples: Cassettes / Tubes Intact Y / N with MS Y / N Canisters Pressurized Tedlar® Bags Inflated N/A

pH	Lot of test paper	Reagent	Preserved?		Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
≥12		NaOH	Yes	No						
≤2		HNO ₃ *	✓		244544	11/21/26	All	4ml	244544	✓
≤2		H ₂ SO ₄								
<4		NaHSO ₄								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add Na ₂ S ₂ O ₃ (625, 608, CN), ascorbic (phenol).					
		Na ₂ S ₂ O ₃								
		ZnAcetate	-	-						
		HCl	**	**						

**VOAs and 1664 Not to be tested before analysis.
Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers: 081125-2ADD

Explain all Discrepancies/ Other Comments:

* CC 10/27/2025

HPRD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: CC

*significant air bubbles: VOA > 5-6 mm : WC > 1 in. diameter



Miscellaneous Forms

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com



REPORT QUALIFIERS AND DEFINITIONS

U	Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.	+	Correlation coefficient for MSA is <0.995.
J	Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Aroclors).	N	Inorganics- Matrix spike recovery was outside laboratory limits.
B	Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.	N	Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.
E	Inorganics- Concentration is estimated due to the serial dilution was outside control limits.	S	Concentration has been determined using Method of Standard Additions (MSA).
E	Organics- Concentration has exceeded the calibration range for that specific analysis.	W	Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.
D	Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.	P	Concentration >40% difference between the two GC columns.
*	Indicates that a quality control parameter has exceeded laboratory limits. Under the "Notes" column of the Form I, this qualifier denotes analysis was performed out of Holding Time.	C	Confirmed by GC/MS
H	Analysis was performed out of hold time for tests that have an "immediate" hold time criteria.	Q	DoD reports: indicates a pesticide/Aroclor is not confirmed ($\geq 100\%$ Difference between two GC columns).
#	Spike was diluted out.	X	See Case Narrative for discussion.
		MRL	Method Reporting Limit. Also known as:
		LOQ	Limit of Quantitation (LOQ) The lowest concentration at which the method analyte may be reliably quantified under the method conditions.
		MDL	Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).
		LOD	Limit of Detection. A value at or above the MDL which has been verified to be detectable.
		ND	Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.

Rochester Lab ID # for State Accreditations¹



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

¹ Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

ALS Laboratory Group

Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental**Service Request:** R2513915**Project:** Belfast CSD Elementary/Middle/High School/2023L-218.1**Sample Name:** 218.1-1**Date Collected:** 10/23/25**Lab Code:** R2513915-001**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: 218.1-2**Date Collected:** 10/23/25**Lab Code:** R2513915-002**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: 218.1-3**Date Collected:** 10/23/25**Lab Code:** R2513915-003**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: 218.1-4**Date Collected:** 10/23/25**Lab Code:** R2513915-004**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: 218.1-5**Date Collected:** 10/23/25**Lab Code:** R2513915-005**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental**Service Request:** R2513915**Project:** Belfast CSD Elementary/Middle/High School/2023L-218.1**Sample Name:** 218.1-6**Date Collected:** 10/23/25**Lab Code:** R2513915-006**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: 218.1-7**Date Collected:** 10/23/25**Lab Code:** R2513915-007**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: 218.1-8**Date Collected:** 10/23/25**Lab Code:** R2513915-008**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: 218.1-9**Date Collected:** 10/23/25**Lab Code:** R2513915-009**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: 218.1-10**Date Collected:** 10/23/25**Lab Code:** R2513915-010**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental**Service Request:** R2513915**Project:** Belfast CSD Elementary/Middle/High School/2023L-218.1**Sample Name:** 218.1-11**Date Collected:** 10/23/25**Lab Code:** R2513915-011**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: 218.1-12**Date Collected:** 10/23/25**Lab Code:** R2513915-012**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

NMANSEN

NMANSEN

Sample Name: 218.1-13**Date Collected:** 10/23/25**Lab Code:** R2513915-013**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: 218.1-14**Date Collected:** 10/23/25**Lab Code:** R2513915-014**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: 218.1-15**Date Collected:** 10/23/25**Lab Code:** R2513915-015**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental**Service Request:** R2513915**Project:** Belfast CSD Elementary/Middle/High School/2023L-218.1**Sample Name:** 218.1-16**Date Collected:** 10/23/25**Lab Code:** R2513915-016**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: 218.1-17**Date Collected:** 10/23/25**Lab Code:** R2513915-017**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: 218.1-18A**Date Collected:** 10/23/25**Lab Code:** R2513915-018**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: 218.1-18B**Date Collected:** 10/23/25**Lab Code:** R2513915-019**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: 218.1-19**Date Collected:** 10/23/25**Lab Code:** R2513915-020**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental**Service Request:** R2513915**Project:** Belfast CSD Elementary/Middle/High School/2023L-218.1**Sample Name:** 218.1-20**Date Collected:** 10/23/25**Lab Code:** R2513915-021**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: 218.1-21**Date Collected:** 10/23/25**Lab Code:** R2513915-022**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: 218.1-22**Date Collected:** 10/23/25**Lab Code:** R2513915-023**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: 218.1-23**Date Collected:** 10/23/25**Lab Code:** R2513915-024**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: 218.1-24**Date Collected:** 10/23/25**Lab Code:** R2513915-025**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental**Service Request:** R2513915**Project:** Belfast CSD Elementary/Middle/High School/2023L-218.1**Sample Name:** 218.1-25**Date Collected:** 10/23/25**Lab Code:** R2513915-026**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: 218.1-26**Date Collected:** 10/23/25**Lab Code:** R2513915-027**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: 218.1-27**Date Collected:** 10/23/25**Lab Code:** R2513915-028**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: 218.1-28**Date Collected:** 10/23/25**Lab Code:** R2513915-029**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: 218.1-29**Date Collected:** 10/23/25**Lab Code:** R2513915-030**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental**Service Request:** R2513915**Project:** Belfast CSD Elementary/Middle/High School/2023L-218.1**Sample Name:** 218.1-30**Date Collected:** 10/23/25**Lab Code:** R2513915-031**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: 218.1-31**Date Collected:** 10/23/25**Lab Code:** R2513915-032**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: 218.1-32**Date Collected:** 10/23/25**Lab Code:** R2513915-033**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: 218.1-33**Date Collected:** 10/23/25**Lab Code:** R2513915-034**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: 218.1-34**Date Collected:** 10/23/25**Lab Code:** R2513915-035**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental

Service Request: R2513915

Project: Belfast CSD Elementary/Middle/High School/2023L-218.1

Sample Name: 218.1-35

Date Collected: 10/23/25

Lab Code: R2513915-036

Date Received: 10/24/25

Sample Matrix: Drinking Water

Analysis Method

Extracted/Digested By

Analyzed By

200.8

MKASTAN



PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

INORGANIC

Water/Liquid Matrix

Analytical Method	Preparation Method
200.7 / 200.8	200.2
6010D	3005A/3010A
6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010D	3050B
6010D TCLP (1311) extract	3005A/3010A
6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

ORGANIC

Preparation Methods for Organic methods are listed in the header of the Results pages.

Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



Sample Results

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-1
Lab Code: R2513915-001

Service Request: R2513915
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	12.1	ug/L	1.0	1	11/06/25 16:51	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-2
Lab Code: R2513915-002

Service Request: R2513915
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	7.2	ug/L	1.0	1	11/06/25 16:55	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-3
Lab Code: R2513915-003

Service Request: R2513915
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.7	ug/L	1.0	1	11/06/25 16:57	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-4
Lab Code: R2513915-004

Service Request: R2513915
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	5.5	ug/L	1.0	1	11/06/25 16:58	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-5
Lab Code: R2513915-005

Service Request: R2513915
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.5	ug/L	1.0	1	11/06/25 17:00	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-6
Lab Code: R2513915-006

Service Request: R2513915
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	12.4	ug/L	1.0	1	11/06/25 17:01	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-7
Lab Code: R2513915-007

Service Request: R2513915
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	6.9	ug/L	1.0	1	11/06/25 17:03	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-8
Lab Code: R2513915-008

Service Request: R2513915
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	5.3	ug/L	1.0	1	11/06/25 17:04	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-9
Lab Code: R2513915-009

Service Request: R2513915
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 17:06	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-10
Lab Code: R2513915-010

Service Request: R2513915
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 17:08	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-11
Lab Code: R2513915-011

Service Request: R2513915
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	9.6	ug/L	1.0	1	11/06/25 17:09	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-12
Lab Code: R2513915-012

Service Request: R2513915
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Date Extracted	Q
Lead, Total	200.8	14.7	ug/L	0.50	1	11/05/25 12:13	11/03/25	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-13
Lab Code: R2513915-013

Service Request: R2513915
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	5.7	ug/L	1.0	1	11/06/25 17:14	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-14
Lab Code: R2513915-014

Service Request: R2513915
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	7.5	ug/L	1.0	1	11/06/25 17:15	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-15
Lab Code: R2513915-015

Service Request: R2513915
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	9.9	ug/L	1.0	1	11/06/25 17:17	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-16
Lab Code: R2513915-016

Service Request: R2513915
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.8	ug/L	1.0	1	11/06/25 17:18	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-17
Lab Code: R2513915-017

Service Request: R2513915
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.5	ug/L	1.0	1	11/06/25 17:29	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-18A
Lab Code: R2513915-018

Service Request: R2513915
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 17:34	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-18B
Lab Code: R2513915-019

Service Request: R2513915
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 17:35	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-19
Lab Code: R2513915-020

Service Request: R2513915
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 17:37	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-20
Lab Code: R2513915-021

Service Request: R2513915
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	7.0	ug/L	1.0	1	11/06/25 17:38	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-21
Lab Code: R2513915-022

Service Request: R2513915
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	5.4	ug/L	1.0	1	11/06/25 17:40	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-22
Lab Code: R2513915-023

Service Request: R2513915
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	5.4	ug/L	1.0	1	11/06/25 17:44	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-23
Lab Code: R2513915-024

Service Request: R2513915
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	6.4	ug/L	1.0	1	11/06/25 17:46	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-24
Lab Code: R2513915-025

Service Request: R2513915
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.0	ug/L	1.0	1	11/06/25 17:47	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-25
Lab Code: R2513915-026

Service Request: R2513915
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	11.2	ug/L	1.0	1	11/06/25 17:49	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-26
Lab Code: R2513915-027

Service Request: R2513915
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	5.7	ug/L	1.0	1	11/06/25 17:50	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-27
Lab Code: R2513915-028

Service Request: R2513915
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	6.9	ug/L	1.0	1	11/06/25 17:52	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-28
Lab Code: R2513915-029

Service Request: R2513915
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.9	ug/L	1.0	1	11/06/25 17:54	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-29
Lab Code: R2513915-030

Service Request: R2513915
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	8.1	ug/L	1.0	1	11/06/25 17:55	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-30
Lab Code: R2513915-031

Service Request: R2513915
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	5.2	ug/L	1.0	1	11/06/25 17:57	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-31
Lab Code: R2513915-032

Service Request: R2513915
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	8.8	ug/L	1.0	1	11/06/25 17:58	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-32
Lab Code: R2513915-033

Service Request: R2513915
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	5.2	ug/L	1.0	1	11/06/25 18:03	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-33
Lab Code: R2513915-034

Service Request: R2513915
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	14.7	ug/L	1.0	1	11/06/25 18:04	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-34
Lab Code: R2513915-035

Service Request: R2513915
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	8.0	ug/L	1.0	1	11/06/25 18:06	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-35
Lab Code: R2513915-036

Service Request: R2513915
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	7.1	ug/L	1.0	1	11/06/25 18:07	



QC Summary Forms

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2513915-MB1

Service Request: R2513915
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Date Extracted	Q
Lead, Total	200.8	ND U	ug/L	0.50	1	11/05/25 11:58	11/03/25	
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 16:37	NA	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2513915-MB2

Service Request: R2513915
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 17:26	

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water

Service Request: R2513915
Date Collected: 10/23/25
Date Received: 10/24/25
Date Analyzed: 11/6/25

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name: 218.1-16
Lab Code: R2513915-016
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result		Matrix Spike		Duplicate Matrix Spike				RPD	RPD Limit
			Spike Amount	% Rec	Result	Spike Amount	% Rec	% Rec Limits		
Lead, Total	3.8	25.1	20.0	106	24.7	20.0	104	70-130	1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water

Service Request: R2513915
Date Collected: 10/23/25
Date Received: 10/24/25
Date Analyzed: 11/6/25

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name: 218.1-17
Lab Code: R2513915-017
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike		Result	Duplicate Matrix Spike		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	1.5	22.6	20.0	105	23.0	20.0	107	70-130	2	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water

Service Request: R2513915
Date Collected: 10/23/25
Date Received: 10/24/25
Date Analyzed: 11/6/25

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name: 218.1-35
Lab Code: R2513915-036
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike		Result	Duplicate Matrix Spike		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	7.1	27.7	20.0	103	27.7	20.0	103	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.

dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water

Service Request: R2513915
Date Analyzed: 11/05/25 - 11/06/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L**Basis:**NA**Lab Control Sample**

R2513915-LCS1

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	21.7	20.0	108	85-115
Lead, Total	200.8	20.9	20.0	104	85-115

ALS Group USA, Corp.

dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water

Service Request: R2513915

Date Analyzed: 11/06/25

Lab Control Sample Summary

Inorganic Parameters

Units:ug/L

Basis:NA

Lab Control Sample

R2513915-LCS2

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	21.8	20.0	109	85-115



November 11, 2025

Service Request No:R2513916

Michael Scinta
Stohl Environmental
3860 California Road
Orchard Park, NY 14219

Laboratory Results for: Belfast CSD Elementary/Middle/High School

Dear Michael,

Enclosed are the results of the sample(s) submitted to our laboratory October 24, 2025
For your reference, these analyses have been assigned our service request number **R2513916**.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at Meghan.Pedro@alsglobal.com.

Respectfully submitted,

ALS Group USA, Corp. dba ALS Environmental

Meghan Pedro
Project Manager

CC: Rebecca
Franjoine

ADDRESS

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

PHONE +1 585 288 5380 | **FAX** +1 585 288 8475

ALS Group USA, Corp.
dba ALS Environmental



Narrative Documents

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com



Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School
Sample Matrix: Drinking Water

Service Request: R2513916
Date Received: 10/24/2025

CASE NARRATIVE

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

Sample Receipt:

Thirty six drinking water samples were received for analysis at ALS Environmental on 10/24/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

Metals:

No significant anomalies were noted with this analysis.

Approved by Meghan Pedro

Date 11/11/2025



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 218.1-36		Lab ID: R2513916-001				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	3.9			1.0	ug/L	200.8
CLIENT ID: 218.1-37		Lab ID: R2513916-002				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	151			1.0	ug/L	200.8
CLIENT ID: 218.1-38		Lab ID: R2513916-003				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.1			1.0	ug/L	200.8
CLIENT ID: 218.1-39		Lab ID: R2513916-004				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.7			1.0	ug/L	200.8
CLIENT ID: 218.1-40		Lab ID: R2513916-005				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.5			1.0	ug/L	200.8
CLIENT ID: 218.1-43		Lab ID: R2513916-009				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	58.7			1.0	ug/L	200.8
CLIENT ID: 218.1-44		Lab ID: R2513916-010				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.7			1.0	ug/L	200.8
CLIENT ID: 218.1-45		Lab ID: R2513916-011				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.7			1.0	ug/L	200.8
CLIENT ID: 218.1-48		Lab ID: R2513916-015				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	5.5			1.0	ug/L	200.8
CLIENT ID: 218.1-50		Lab ID: R2513916-017				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.4			1.0	ug/L	200.8
CLIENT ID: 218.1-51		Lab ID: R2513916-018				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.6			1.0	ug/L	200.8
CLIENT ID: 218.1-52		Lab ID: R2513916-019				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.6			1.0	ug/L	200.8



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 218.1-53		Lab ID: R2513916-020				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.7			1.0	ug/L	200.8
CLIENT ID: 218.1-54		Lab ID: R2513916-021				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.4			1.0	ug/L	200.8
CLIENT ID: 218.1-55		Lab ID: R2513916-022				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.4			1.0	ug/L	200.8
CLIENT ID: 218.1-57		Lab ID: R2513916-025				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.1			1.0	ug/L	200.8
CLIENT ID: 218.1-58		Lab ID: R2513916-026				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.8			1.0	ug/L	200.8
CLIENT ID: 218.1-63		Lab ID: R2513916-033				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	12.9			1.0	ug/L	200.8
CLIENT ID: 218.1-64		Lab ID: R2513916-034				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	9.7			1.0	ug/L	200.8
CLIENT ID: 218.1-65		Lab ID: R2513916-035				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	8.8			1.0	ug/L	200.8
CLIENT ID: 218.1-66		Lab ID: R2513916-036				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	8.3			1.0	ug/L	200.8



Sample Receipt Information

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1

Service Request:R2513916

SAMPLE CROSS-REFERENCE

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2513916-001	218.1-36	10/23/2025	
R2513916-002	218.1-37	10/23/2025	
R2513916-003	218.1-38	10/23/2025	
R2513916-004	218.1-39	10/23/2025	
R2513916-005	218.1-40	10/23/2025	
R2513916-006	218.1-41	10/23/2025	
R2513916-007	218.1-42A	10/23/2025	
R2513916-008	218.1-42B	10/23/2025	
R2513916-009	218.1-43	10/23/2025	
R2513916-010	218.1-44	10/23/2025	
R2513916-011	218.1-45	10/23/2025	
R2513916-012	218.1-46	10/23/2025	
R2513916-013	218.1-47A	10/23/2025	
R2513916-014	218.1-47B	10/23/2025	
R2513916-015	218.1-48	10/23/2025	
R2513916-016	218.1-49	10/23/2025	
R2513916-017	218.1-50	10/23/2025	
R2513916-018	218.1-51	10/23/2025	
R2513916-019	218.1-52	10/23/2025	
R2513916-020	218.1-53	10/23/2025	
R2513916-021	218.1-54	10/23/2025	
R2513916-022	218.1-55	10/23/2025	
R2513916-023	218.1-56A	10/23/2025	
R2513916-024	218.1-56B	10/23/2025	
R2513916-025	218.1-57	10/23/2025	
R2513916-026	218.1-58	10/23/2025	
R2513916-027	218.1-59A	10/23/2025	
R2513916-028	218.1-59B	10/23/2025	
R2513916-029	218.1-60	10/23/2025	
R2513916-030	218.1-61	10/23/2025	
R2513916-031	218.1-62A	10/23/2025	
R2513916-032	218.1-62B	10/23/2025	
R2513916-033	218.1-63	10/23/2025	
R2513916-034	218.1-64	10/23/2025	
R2513916-035	218.1-65	10/23/2025	
R2513916-036	218.1-66	10/23/2025	



3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Chain of Custody Document

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-218.1

Client: Belfast CSD

Contact: Jason Hamer

Building: Belfast Central Elementary/Middle/High School

Location: 1 King Street, Belfast, NY 14711

LEAD

Water by 200.8

X

Turnaround

10 Days

Sample #	Location	Outlet Type	Time
218.1-36	105 DF	DF	5:54
218.1-37	Janitor Utility Sink Near 104	Sink	5:55
218.1-38	Boys Lav Next to 109 Maintenance	Sink	5:56
218.1-39	Fac Lav Across 108	Sink	5:58
218.1-40	Girls Lav Next to 108	Sink	5:59
218.1-41	207 Nurse Lav	Sink	6:01
218.1-42A	DF Near 109 Maintenance	DF	6:02
218.1-42B	DFB Near 109 maintenance	DFB	6:03
218.1-43	Room 109 Sink	Sink	6:05
218.1-44	207 Nurse Exam Room	Sink	6:06
218.1-45	Boys Lav Next to Nurse Right	Sink	6:07
218.1-46	Boys Lav Next to Nurse Left	Sink	6:09
218.1-47A	DF Next to 203	DF	6:10
218.1-47B	DFB Next to 203	DFB	6:11
218.1-48	Room 203	Sink	6:13
218.1-49	Girls Lav Across 202 Right	Sink	6:14
218.1-50	Girls Lav Across 202 Left	Sink	6:16
218.1-51	Room 201	Sink	6:17

Notes:

Please e-mail lab results to labs@stohlenvironmental.com

Mscinta@stohlenvironmental.com

Sampled By: <u>Jared Rider</u>	Print Name	Stohl Env: <u>Jared Rider</u>	Date: <u>10/23/2025</u>
Relinquished By: _____	Print Name	Stohl Env: <u>Connor Crilly</u>	Date: <u>10/23/2025</u>
Received (Name / Lab): <u>ALS</u>		Date: <u>10/24/25</u>	Time: <u>8:14</u>
Sample Login (Name / Lab): _____		Date: _____	Time: _____
Analysis (Name / Lab): _____		Date: _____	Time: _____
QA/QC Review (Name / Lab): _____		Date: _____	Time: _____
Archived / Released: _____	QA/QC InterLAB Use: _____	Date: _____	Time: _____

R2513916

5

Stohl Environmental
Belfast CSD Elementary/Middle/High School





Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-218.1

Client: Belfast CSD

Contact: Jason Hamer

Building: Belfast Central Elementary/Middle/High School

Location: 1 King Street, Belfast, NY 14711

LEAD

Water by 200.8 X

Turnaround

10 Days

Sample #	Location	Outlet Type	Time
218.1-52	Room 301 FL	Sink	6:18
218.1-53	Room 301 FR	Sink	6:20
218.1-54	Room 301 BL	Sink	6:21
218.1-55	Room 301 BR	Sink	6:22
218.1-56A	Next to Room 301 DF	DF	6:24
218.1-56B	Next to Room 301 DFB	DFB	6:25
218.1-57	Girls Lav Next to 303 Left	Sink	6:27
218.1-58	Girls Lav Next to 303 Right	Sink	6:28
218.1-59A	DF Next to 307	DF	6:29
218.1-59B	DFB next to 307	DFB	6:31
218.1-60	308 Boys Lav Left	Sink	6:32
218.1-61	308 Boys Lav Right	Sink	6:33
218.1-62A	DF Across From Locker Rooms	DF	6:35
218.1-62B	DFB Across From Locker Rooms	DFB	6:36
218.1-63	Girls Locker Room L	Sink	6:37
218.1-64	Girls Locker room R	Sink	6:39
218.1-65	116 Girls Phys Ed Office	Sink	6:40
218.1-66	122 Boys Phys Ed Office	Sink	6:42

Notes:

Please e-mail lab results to labs@stohlenvironmental.com

Mscinta@stohlenvironmental.com

Sampled By: <u>Jared Rider</u>	Print Name	Stohl Env: <u>Jared Rider</u>	Date: <u>10/23/2025</u>
Relinquished By: _____	Print Name	Stohl Env: <u>Connor Crilly</u>	Date: <u>10/23/2025</u>
Received (Name / Lab): <u>Kim [Signature] ALS</u>	Date: <u>10/24/25</u>	Time: <u>8:14</u>	
Sample Login (Name / Lab): _____	Date: _____	Time: _____	
Analysis (Name / Lab): _____	Date: _____	Time: _____	
QA/QC Review (Name / Lab): _____	Date: _____	Time: _____	
Archived / Released: _____	QA/QC InterLAB Use: _____	Date: _____	Time: _____



Cooler Receipt and Preservation

R2513916

5

Stohl Environmental
Belfast CSD Elementary/Middle/High SchoolProject/Client Stohl

Folder Number _____

Cooler received on 10/24/25by: RMCOURIER: ALS UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	Y <u>(N)</u>
2	Custody papers properly completed (ink, signed)?	<u>(Y)</u> N
3	Did all bottles arrive in good condition (unbroken)?	<u>(Y)</u> N
4	Circle: Wet Ice Dry Ice Gel packs present?	Y <u>(N)</u>

5a	Did VOA vials have sig* bubbles?	Y N <u>(NA)</u>
5b	Sig* bubbles: Alk?	Y N <u>(NA)</u>
	Sulfide?	Y N <u>(NA)</u>
6	Where did the bottles originate?	<u>ALS/ROC</u> CLIENT
7	Soil VOA received as: Bulk Encore 5035set	<u>(NA)</u>

8. Temperature Readings

Date: 10/24/25 Time: 8:23ID: IR#12 (IR#11)From: Temp Blank Sample Bottle

Temp (°C)	<u>10.4</u>						
Within 0-6°C?	Y <u>(N)</u>	Y N	Y N	Y N	Y N	Y N	Y N
If <0°C, were samples frozen?	Y N	Y N	Y N	Y N	Y N	Y N	Y N

If out of Temperature, note packing/ice condition: NO ICE Ice melted Poorly Packed (described below) Same Day Rule
& Client Approval to Run Samples: _____ Standing Approval Client aware at drop-off Client notified by: _____

All samples held in storage location: SMO by RM on 10/24 at 8:30

5035 samples placed in storage location: _____ by _____ on _____ at _____ within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check**: Date: 10/27/25 Time: 1558 by: CL

9. Were all bottle labels complete (i.e. analysis, preservation, etc.)? (YES) NO
 10. Did all bottle labels and tags agree with custody papers? (YES) NO
 11. Were correct containers used for the tests indicated? (YES) NO
 12. Were 5035 vials acceptable (no extra labels, not leaking)? YES NO (N/A)
 13. Were dissolved metals filtered in the field? YES NO (N/A)
 14. Air Samples: Cassettes / Tubes Intact Y / N with MS Y / N Canisters Pressurized Tedlar® Bags Inflated (N/A)

pH	Lot of test paper	Reagent	Preserved?		Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
			Yes	No						
≥12		NaOH								
≤2		HNO ₃					<u>All</u>	<u>4ml</u>	<u>244544</u>	<u>✓</u>
≤2		H ₂ SO ₄								
<4		NaHSO ₄								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add Na ₂ S ₂ O ₃ (625, 608, CN), ascorbic (phenol).					
		Na ₂ S ₂ O ₃								
		ZnAcetate	-	-						
		HCl	**	**						

**VOAs and 1664 Not to be tested before analysis.
Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers: 0 811 25 - 2 ADD

Explain all Discrepancies/ Other Comments: _____

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: CL

*significant air bubbles: VOA > 5-6 mm : WC > 1 in. diameter



Miscellaneous Forms

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com



REPORT QUALIFIERS AND DEFINITIONS

U	Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.	+	Correlation coefficient for MSA is <0.995.
J	Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Aroclors).	N	Inorganics- Matrix spike recovery was outside laboratory limits.
B	Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.	N	Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.
E	Inorganics- Concentration is estimated due to the serial dilution was outside control limits.	S	Concentration has been determined using Method of Standard Additions (MSA).
E	Organics- Concentration has exceeded the calibration range for that specific analysis.	W	Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.
D	Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.	P	Concentration >40% difference between the two GC columns.
*	Indicates that a quality control parameter has exceeded laboratory limits. Under the "Notes" column of the Form I, this qualifier denotes analysis was performed out of Holding Time.	C	Confirmed by GC/MS
H	Analysis was performed out of hold time for tests that have an "immediate" hold time criteria.	Q	DoD reports: indicates a pesticide/Aroclor is not confirmed ($\geq 100\%$ Difference between two GC columns).
#	Spike was diluted out.	X	See Case Narrative for discussion.
		MRL	Method Reporting Limit. Also known as:
		LOQ	Limit of Quantitation (LOQ) The lowest concentration at which the method analyte may be reliably quantified under the method conditions.
		MDL	Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).
		LOD	Limit of Detection. A value at or above the MDL which has been verified to be detectable.
		ND	Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.

Rochester Lab ID # for State Accreditations¹



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

¹ Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

ALS Laboratory Group

Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental**Service Request:** R2513916**Project:** Belfast CSD Elementary/Middle/High School/2023L-218.1**Sample Name:** 218.1-36**Date Collected:** 10/23/25**Lab Code:** R2513916-001**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: 218.1-37**Date Collected:** 10/23/25**Lab Code:** R2513916-002**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: 218.1-38**Date Collected:** 10/23/25**Lab Code:** R2513916-003**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: 218.1-39**Date Collected:** 10/23/25**Lab Code:** R2513916-004**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: 218.1-40**Date Collected:** 10/23/25**Lab Code:** R2513916-005**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental**Service Request:** R2513916**Project:** Belfast CSD Elementary/Middle/High School/2023L-218.1**Sample Name:** 218.1-41**Date Collected:** 10/23/25**Lab Code:** R2513916-006**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: 218.1-42A**Date Collected:** 10/23/25**Lab Code:** R2513916-007**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: 218.1-42B**Date Collected:** 10/23/25**Lab Code:** R2513916-008**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: 218.1-43**Date Collected:** 10/23/25**Lab Code:** R2513916-009**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: 218.1-44**Date Collected:** 10/23/25**Lab Code:** R2513916-010**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental**Service Request:** R2513916**Project:** Belfast CSD Elementary/Middle/High School/2023L-218.1**Sample Name:** 218.1-45**Date Collected:** 10/23/25**Lab Code:** R2513916-011**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: 218.1-46**Date Collected:** 10/23/25**Lab Code:** R2513916-012**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: 218.1-47A**Date Collected:** 10/23/25**Lab Code:** R2513916-013**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: 218.1-47B**Date Collected:** 10/23/25**Lab Code:** R2513916-014**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: 218.1-48**Date Collected:** 10/23/25**Lab Code:** R2513916-015**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental**Service Request:** R2513916**Project:** Belfast CSD Elementary/Middle/High School/2023L-218.1**Sample Name:** 218.1-49**Date Collected:** 10/23/25**Lab Code:** R2513916-016**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: 218.1-50**Date Collected:** 10/23/25**Lab Code:** R2513916-017**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: 218.1-51**Date Collected:** 10/23/25**Lab Code:** R2513916-018**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: 218.1-52**Date Collected:** 10/23/25**Lab Code:** R2513916-019**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: 218.1-53**Date Collected:** 10/23/25**Lab Code:** R2513916-020**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental**Service Request:** R2513916**Project:** Belfast CSD Elementary/Middle/High School/2023L-218.1**Sample Name:** 218.1-54**Date Collected:** 10/23/25**Lab Code:** R2513916-021**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

NMANSEN

Sample Name: 218.1-55**Date Collected:** 10/23/25**Lab Code:** R2513916-022**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

NMANSEN

Sample Name: 218.1-56A**Date Collected:** 10/23/25**Lab Code:** R2513916-023**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

NMANSEN

Sample Name: 218.1-56B**Date Collected:** 10/23/25**Lab Code:** R2513916-024**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

NMANSEN

Sample Name: 218.1-57**Date Collected:** 10/23/25**Lab Code:** R2513916-025**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

NMANSEN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental**Service Request:** R2513916**Project:** Belfast CSD Elementary/Middle/High School/2023L-218.1**Sample Name:** 218.1-58**Date Collected:** 10/23/25**Lab Code:** R2513916-026**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

NMANSEN

Sample Name: 218.1-59A**Date Collected:** 10/23/25**Lab Code:** R2513916-027**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

NMANSEN

Sample Name: 218.1-59B**Date Collected:** 10/23/25**Lab Code:** R2513916-028**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

NMANSEN

Sample Name: 218.1-60**Date Collected:** 10/23/25**Lab Code:** R2513916-029**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

NMANSEN

Sample Name: 218.1-61**Date Collected:** 10/23/25**Lab Code:** R2513916-030**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

NMANSEN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental**Service Request:** R2513916**Project:** Belfast CSD Elementary/Middle/High School/2023L-218.1**Sample Name:** 218.1-62A
Lab Code: R2513916-031
Sample Matrix: Drinking Water**Date Collected:** 10/23/25**Date Received:** 10/24/25**Analysis Method**

200.8

Extracted/Digested By**Analyzed By**

NMANSEN

Sample Name: 218.1-62B
Lab Code: R2513916-032
Sample Matrix: Drinking Water**Date Collected:** 10/23/25**Date Received:** 10/24/25**Analysis Method**

200.8

Extracted/Digested By**Analyzed By**

NMANSEN

Sample Name: 218.1-63
Lab Code: R2513916-033
Sample Matrix: Drinking Water**Date Collected:** 10/23/25**Date Received:** 10/24/25**Analysis Method**

200.8

Extracted/Digested By**Analyzed By**

NMANSEN

Sample Name: 218.1-64
Lab Code: R2513916-034
Sample Matrix: Drinking Water**Date Collected:** 10/23/25**Date Received:** 10/24/25**Analysis Method**

200.8

Extracted/Digested By**Analyzed By**

NMANSEN

Sample Name: 218.1-65
Lab Code: R2513916-035
Sample Matrix: Drinking Water**Date Collected:** 10/23/25**Date Received:** 10/24/25**Analysis Method**

200.8

Extracted/Digested By**Analyzed By**

NMANSEN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental

Service Request: R2513916

Project: Belfast CSD Elementary/Middle/High School/2023L-218.1

Sample Name: 218.1-66

Date Collected: 10/23/25

Lab Code: R2513916-036

Date Received: 10/24/25

Sample Matrix: Drinking Water

Analysis Method

Extracted/Digested By

Analyzed By

200.8

NMANSEN



PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

INORGANIC

Water/Liquid Matrix

Analytical Method	Preparation Method
200.7 / 200.8	200.2
6010D	3005A/3010A
6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010D	3050B
6010D TCLP (1311) extract	3005A/3010A
6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

ORGANIC

Preparation Methods for Organic methods are listed in the header of the Results pages.

Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



Sample Results

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-36
Lab Code: R2513916-001

Service Request: R2513916
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.9	ug/L	1.0	1	11/06/25 18:18	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-37
Lab Code: R2513916-002

Service Request: R2513916
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	151	ug/L	1.0	1	11/06/25 18:23	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-38
Lab Code: R2513916-003

Service Request: R2513916
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.1	ug/L	1.0	1	11/06/25 18:24	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-39
Lab Code: R2513916-004

Service Request: R2513916
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.7	ug/L	1.0	1	11/06/25 18:26	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-40
Lab Code: R2513916-005

Service Request: R2513916
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.5	ug/L	1.0	1	11/06/25 18:27	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-41
Lab Code: R2513916-006

Service Request: R2513916
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 18:29	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-42A
Lab Code: R2513916-007

Service Request: R2513916
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 18:33	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-42B
Lab Code: R2513916-008

Service Request: R2513916
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 18:35	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-43
Lab Code: R2513916-009

Service Request: R2513916
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	58.7	ug/L	1.0	1	11/06/25 18:36	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-44
Lab Code: R2513916-010

Service Request: R2513916
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.7	ug/L	1.0	1	11/06/25 18:38	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-45
Lab Code: R2513916-011

Service Request: R2513916
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.7	ug/L	1.0	1	11/06/25 18:40	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-46
Lab Code: R2513916-012

Service Request: R2513916
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 18:41	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-47A
Lab Code: R2513916-013

Service Request: R2513916
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 18:43	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-47B
Lab Code: R2513916-014

Service Request: R2513916
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 18:44	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-48
Lab Code: R2513916-015

Service Request: R2513916
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	5.5	ug/L	1.0	1	11/06/25 18:46	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-49
Lab Code: R2513916-016

Service Request: R2513916
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 18:47	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-50
Lab Code: R2513916-017

Service Request: R2513916
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.4	ug/L	1.0	1	11/06/25 18:52	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-51
Lab Code: R2513916-018

Service Request: R2513916
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.6	ug/L	1.0	1	11/06/25 18:53	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-52
Lab Code: R2513916-019

Service Request: R2513916
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.6	ug/L	1.0	1	11/06/25 18:55	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-53
Lab Code: R2513916-020

Service Request: R2513916
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.7	ug/L	1.0	1	11/06/25 18:56	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-54
Lab Code: R2513916-021

Service Request: R2513916
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.4	ug/L	1.0	1	11/07/25 13:51	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-55
Lab Code: R2513916-022

Service Request: R2513916
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.4	ug/L	1.0	1	11/07/25 13:52	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-56A
Lab Code: R2513916-023

Service Request: R2513916
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/07/25 13:53	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-56B
Lab Code: R2513916-024

Service Request: R2513916
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/07/25 13:55	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-57
Lab Code: R2513916-025

Service Request: R2513916
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.1	ug/L	1.0	1	11/07/25 13:56	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-58
Lab Code: R2513916-026

Service Request: R2513916
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.8	ug/L	1.0	1	11/07/25 13:57	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-59A
Lab Code: R2513916-027

Service Request: R2513916
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/07/25 13:58	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-59B
Lab Code: R2513916-028

Service Request: R2513916
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/07/25 14:02	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-60
Lab Code: R2513916-029

Service Request: R2513916
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/07/25 14:04	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-61
Lab Code: R2513916-030

Service Request: R2513916
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/07/25 14:05	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-62A
Lab Code: R2513916-031

Service Request: R2513916
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/07/25 14:06	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-62B
Lab Code: R2513916-032

Service Request: R2513916
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/07/25 14:16	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-63
Lab Code: R2513916-033

Service Request: R2513916
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	12.9	ug/L	1.0	1	11/07/25 14:19	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-64
Lab Code: R2513916-034

Service Request: R2513916
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	9.7	ug/L	1.0	1	11/07/25 14:21	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-65
Lab Code: R2513916-035

Service Request: R2513916
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	8.8	ug/L	1.0	1	11/07/25 14:22	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-66
Lab Code: R2513916-036

Service Request: R2513916
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	8.3	ug/L	1.0	1	11/07/25 14:23	



QC Summary Forms

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2513916-MB1

Service Request: R2513916
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/06/25 18:15	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2513916-MB2

Service Request: R2513916
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/07/25 13:31	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2513916-MB3

Service Request: R2513916
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/07/25 14:13	

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water

Service Request: R2513916
Date Collected: 10/23/25
Date Received: 10/24/25
Date Analyzed: 11/6/25

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name: 218.1-36
Lab Code: R2513916-001
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike		Result	Duplicate Matrix Spike		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	3.9	27.2	20.0	116	25.1	20.0	106	70-130	8	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water

Service Request: R2513916
Date Collected: 10/23/25
Date Received: 10/24/25
Date Analyzed: 11/6/25

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name: 218.1-53
Lab Code: R2513916-020
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike		Result	Duplicate Matrix Spike		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	1.7	22.7	20.0	105	22.5	20.0	104	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water

Service Request: R2513916
Date Collected: 10/23/25
Date Received: 10/24/25
Date Analyzed: 11/7/25

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name: 218.1-62A
Lab Code: R2513916-031
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike		Result	Duplicate Matrix Spike		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	ND U	18.6	20.0	93	19.1	20.0	95	70-130	3	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water

Service Request: R2513916
Date Collected: 10/23/25
Date Received: 10/24/25
Date Analyzed: 11/7/25

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name: 218.1-62B
Lab Code: R2513916-032
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike		Result	Duplicate Matrix Spike		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	ND U	18.3	20.0	91	18.2	20.0	91	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.

dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water

Service Request: R2513916

Date Analyzed: 11/06/25

Lab Control Sample Summary

Inorganic Parameters

Units:ug/L

Basis:NA

Lab Control Sample

R2513916-LCS1

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	21.1	20.0	105	85-115

ALS Group USA, Corp.

dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water

Service Request: R2513916

Date Analyzed: 11/07/25

Lab Control Sample Summary

Inorganic Parameters

Units:ug/L

Basis:NA

Lab Control Sample

R2513916-LCS2

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	19.7	20.0	98	85-115

ALS Group USA, Corp.

dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water

Service Request: R2513916

Date Analyzed: 11/07/25

Lab Control Sample Summary

Inorganic Parameters

Units:ug/L

Basis:NA

Lab Control Sample

R2513916-LCS3

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	19.3	20.0	97	85-115



November 12, 2025

Service Request No:R2513917

Michael Scinta
Stohl Environmental
3860 California Road
Orchard Park, NY 14219

Laboratory Results for: Belfast CSD Elementary/Middle/High School

Dear Michael,

Enclosed are the results of the sample(s) submitted to our laboratory October 24, 2025
For your reference, these analyses have been assigned our service request number **R2513917**.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at Meghan.Pedro@alsglobal.com.

Respectfully submitted,

ALS Group USA, Corp. dba ALS Environmental

Meghan Pedro
Project Manager

CC: Rebecca
Franjoine

ADDRESS

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

PHONE +1 585 288 5380 | **FAX** +1 585 288 8475

ALS Group USA, Corp.
dba ALS Environmental



Narrative Documents

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com



Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School
Sample Matrix: Drinking Water

Service Request: R2513917
Date Received: 10/24/2025

CASE NARRATIVE

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

Sample Receipt:

Sixteen drinking water samples were received for analysis at ALS Environmental on 10/24/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

Metals:

No significant anomalies were noted with this analysis.

Approved by

A handwritten signature in black ink, appearing to read 'Meghan Pedicini', is written over a horizontal line.

Date

11/12/2025



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 218.1-67		Lab ID: R2513917-001				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	13.9			1.0	ug/L	200.8
CLIENT ID: 218.1-68		Lab ID: R2513917-002				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	38.9			1.0	ug/L	200.8
CLIENT ID: 218.1-69		Lab ID: R2513917-003				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.3			1.0	ug/L	200.8
CLIENT ID: 218.1-71		Lab ID: R2513917-005				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.6			1.0	ug/L	200.8
CLIENT ID: 218.1-72		Lab ID: R2513917-006				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.1			1.0	ug/L	200.8
CLIENT ID: 218.1-73		Lab ID: R2513917-007				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.8			1.0	ug/L	200.8
CLIENT ID: 218.1-74		Lab ID: R2513917-008				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	2.7			1.0	ug/L	200.8
CLIENT ID: 218.1-75		Lab ID: R2513917-009				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.7			1.0	ug/L	200.8
CLIENT ID: 218.1-76		Lab ID: R2513917-010				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.4			1.0	ug/L	200.8
CLIENT ID: 218.1-77		Lab ID: R2513917-011				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.2			1.0	ug/L	200.8
CLIENT ID: 218.1-78		Lab ID: R2513917-012				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	5.0			1.0	ug/L	200.8
CLIENT ID: 218.1-79		Lab ID: R2513917-013				
Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	4.3			1.0	ug/L	200.8



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 218.1-80			Lab ID: R2513917-014			
----------------------------	--	--	-----------------------------	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	1.0			1.0	ug/L	200.8

CLIENT ID: 218.1-81			Lab ID: R2513917-015			
----------------------------	--	--	-----------------------------	--	--	--

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	36.4			1.0	ug/L	200.8



Sample Receipt Information

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1

Service Request:R2513917

SAMPLE CROSS-REFERENCE

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2513917-001	218.1-67	10/23/2025	
R2513917-002	218.1-68	10/23/2025	
R2513917-003	218.1-69	10/23/2025	
R2513917-004	218.1-70	10/23/2025	
R2513917-005	218.1-71	10/23/2025	
R2513917-006	218.1-72	10/23/2025	
R2513917-007	218.1-73	10/23/2025	
R2513917-008	218.1-74	10/23/2025	
R2513917-009	218.1-75	10/23/2025	
R2513917-010	218.1-76	10/23/2025	
R2513917-011	218.1-77	10/23/2025	
R2513917-012	218.1-78	10/23/2025	
R2513917-013	218.1-79	10/23/2025	
R2513917-014	218.1-80	10/23/2025	
R2513917-015	218.1-81	10/23/2025	
R2513917-016	218.1-82	10/23/2025	



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-218.1

Client: Belfast CSD

Contact: Jason Hamer

Building: Belfast Central Elementary/Middle/High School

Location: 1 King Street, Belfast, NY 14711

LEAD

Water by 200.8

X

Turnaround

10 Days

Sample #	Location	Outlet Type	Time
218.1-67	Boys Locker Room L	Sink	6:43
218.1-68	Boys Locker Room R	Sink	6:44
218.1-69	Single Fitness Room Lav	Sink	6:46
218.1-70	Single Lav Across From Gym Left	Sink	6:47
218.1-71	Single Lav Across From Gym Left Center	Sink	6:48
218.1-72	Single Lav Across From Gym Right Center	Sink	6:50
218.1-73	Single Lav Across From Gym Right	Sink	6:51
218.1-74	Main Office Kitchenette	Sink	6:52
218.1-75	Robotics Sink	Sink	6:54
218.1-76	Elementary Art Room 141 Left	Sink	6:55
218.1-77	Elementary Art Room 141 Right	Sink	6:57
218.1-78	Gender Neutral Left Lav	Sink	6:58
218.1-79	Gender Neutral Right Lav	Sink	6:59
218.1-80	HS Art Room 142 Left	Sink	7:01
218.1-81	HS Art Room 142 Right	Sink	7:02
218.1-82	Cafe Ice Water Machine	DFB/IM	7:03

Notes:

Please e-mail lab results to labs@stohlenvironmental.com

Mscinta@stohlenvironmental.com

Sampled By: <u>Jared Rider</u>	Print Name	Stohl Env: <u>Jared Rider</u>	Date: <u>10/23/2025</u>
Relinquished By: _____	Print Name	Stohl Env: <u>Connor Crilly</u>	Date: <u>10/23/2025</u>
Received (Name / Lab): <u>[Signature] ALS</u>		Date: <u>10/24/25</u>	Time: <u>8:14</u>
Sample Login (Name / Lab): _____		Date: _____	Time: _____
Analysis (Name / Lab): _____		Date: _____	Time: _____
QA/QC Review (Name / Lab): _____		Date: _____	Time: _____
Archived / Released: _____	QA/QC InterLAB Use: _____	Date: _____	Time: _____

Page 5 of 5

R2513917

5

Stohl Environmental
Belfast CSD Elementary/Middle/High School





Cooler Receipt and Preserva

R2513917

5

Stohl Environmental
Belfast CSD Elementary/Middle/High SchoolProject/Client Stohl

Folder Number

Cooler received on 10/24/25by: RMCOURIER: ALS UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	Y <u>N</u>
2	Custody papers properly completed (ink, signed)?	<u>Y</u> N
3	Did all bottles arrive in good condition (unbroken)?	<u>Y</u> N
4	Circle: Wet Ice Dry Ice Gel packs present?	Y <u>N</u>

5a	Did VOA vials have sig* bubbles?	Y N <u>NA</u>
5b	Sig* bubbles: Alk? Y N <u>NA</u> Sulfide? Y N <u>NA</u>	
6	Where did the bottles originate?	<u>ALS/ROC</u> CLIENT
7	Soil VOA received as: Bulk Encore 5035set	<u>NA</u>

8. Temperature Readings Date: 10/24/25 Time: 8:23 ID: IR#12 IR#11 From: Temp Blank Sample Bottle

Temp (°C)	<u>10.4</u>						
Within 0-6°C?	<u>Y</u> <u>N</u>	Y N	Y N	Y N	Y N	Y N	Y N
If <0°C, were samples frozen?	Y N	Y N	Y N	Y N	Y N	Y N	Y N

If out of Temperature, note packing/ice condition: NO ice Ice melted Poorly Packed (described below) Same Day Rule
& Client Approval to Run Samples: Standing Approval Client aware at drop-off Client notified by:All samples held in storage location: SMO by RM on 10/24 at 8:30

5035 samples placed in storage location: by on at within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check**: Date: 10/27/25 Time: 1620 by: CL

9. Were all bottle labels complete (i.e. analysis, preservation, etc.)? YES NO
10. Did all bottle labels and tags agree with custody papers? YES NO
11. Were correct containers used for the tests indicated? YES NO
12. Were 5035 vials acceptable (no extra labels, not leaking)? YES NO NA
13. Were dissolved metals filtered in the field? YES NO NA
14. Air Samples: Cassettes / Tubes Intact Y / N with MS Y / N Canisters Pressurized Tedlar® Bags Inflated NA

pH	Lot of test paper	Reagent	Preserved?		Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
≥12		NaOH	Yes	No						
≤2		HNO ₃					<u>All</u>	<u>4ml</u>	<u>244544</u>	<u>✓</u>
≤2		H ₂ SO ₄								
<4		NaHSO ₄								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add Na ₂ S ₂ O ₃ (625, 608, CN), ascorbic (phenol).					
		Na ₂ S ₂ O ₃								
		ZnAcetate	-	-						
		HCl	**	**						

**VOAs and 1664 Not to be tested before analysis.
Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers:

081125-2ADD

Explain all Discrepancies/ Other Comments:

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: CL

*significant air bubbles: VOA > 5-6 mm : WC > 1 in. diameter



Miscellaneous Forms

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com



REPORT QUALIFIERS AND DEFINITIONS

U	Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.	+	Correlation coefficient for MSA is <0.995.
J	Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Aroclors).	N	Inorganics- Matrix spike recovery was outside laboratory limits.
B	Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.	N	Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.
E	Inorganics- Concentration is estimated due to the serial dilution was outside control limits.	S	Concentration has been determined using Method of Standard Additions (MSA).
E	Organics- Concentration has exceeded the calibration range for that specific analysis.	W	Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.
D	Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.	P	Concentration >40% difference between the two GC columns.
*	Indicates that a quality control parameter has exceeded laboratory limits. Under the "Notes" column of the Form I, this qualifier denotes analysis was performed out of Holding Time.	C	Confirmed by GC/MS
H	Analysis was performed out of hold time for tests that have an "immediate" hold time criteria.	Q	DoD reports: indicates a pesticide/Aroclor is not confirmed ($\geq 100\%$ Difference between two GC columns).
#	Spike was diluted out.	X	See Case Narrative for discussion.
		MRL	Method Reporting Limit. Also known as:
		LOQ	Limit of Quantitation (LOQ) The lowest concentration at which the method analyte may be reliably quantified under the method conditions.
		MDL	Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).
		LOD	Limit of Detection. A value at or above the MDL which has been verified to be detectable.
		ND	Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.

Rochester Lab ID # for State Accreditations¹



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

¹ Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

ALS Laboratory Group

Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental**Service Request:** R2513917**Project:** Belfast CSD Elementary/Middle/High School/2023L-218.1**Sample Name:** 218.1-67**Date Collected:** 10/23/25**Lab Code:** R2513917-001**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

NMANSEN

Sample Name: 218.1-68**Date Collected:** 10/23/25**Lab Code:** R2513917-002**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: 218.1-69**Date Collected:** 10/23/25**Lab Code:** R2513917-003**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: 218.1-70**Date Collected:** 10/23/25**Lab Code:** R2513917-004**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: 218.1-71**Date Collected:** 10/23/25**Lab Code:** R2513917-005**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental**Service Request:** R2513917**Project:** Belfast CSD Elementary/Middle/High School/2023L-218.1**Sample Name:** 218.1-72**Date Collected:** 10/23/25**Lab Code:** R2513917-006**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: 218.1-73**Date Collected:** 10/23/25**Lab Code:** R2513917-007**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: 218.1-74**Date Collected:** 10/23/25**Lab Code:** R2513917-008**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: 218.1-75**Date Collected:** 10/23/25**Lab Code:** R2513917-009**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: 218.1-76**Date Collected:** 10/23/25**Lab Code:** R2513917-010**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

ALS Group USA, Corp.

dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental**Service Request:** R2513917**Project:** Belfast CSD Elementary/Middle/High School/2023L-218.1**Sample Name:** 218.1-77**Date Collected:** 10/23/25**Lab Code:** R2513917-011**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: 218.1-78**Date Collected:** 10/23/25**Lab Code:** R2513917-012**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: 218.1-79**Date Collected:** 10/23/25**Lab Code:** R2513917-013**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: 218.1-80**Date Collected:** 10/23/25**Lab Code:** R2513917-014**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

Sample Name: 218.1-81**Date Collected:** 10/23/25**Lab Code:** R2513917-015**Date Received:** 10/24/25**Sample Matrix:** Drinking Water**Analysis Method****Extracted/Digested By****Analyzed By**

200.8

MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental

Service Request: R2513917

Project: Belfast CSD Elementary/Middle/High School/2023L-218.1

Sample Name: 218.1-82

Date Collected: 10/23/25

Lab Code: R2513917-016

Date Received: 10/24/25

Sample Matrix: Drinking Water

Analysis Method

Extracted/Digested By

Analyzed By

200.8

NMANSEN



PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

INORGANIC

Water/Liquid Matrix

Analytical Method	Preparation Method
200.7 / 200.8	200.2
6010D	3005A/3010A
6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010D	3050B
6010D TCLP (1311) extract	3005A/3010A
6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

ORGANIC

Preparation Methods for Organic methods are listed in the header of the Results pages.

Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



Sample Results

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-67
Lab Code: R2513917-001

Service Request: R2513917
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	13.9	ug/L	1.0	1	11/07/25 14:25	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-68
Lab Code: R2513917-002

Service Request: R2513917
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	38.9	ug/L	1.0	1	11/11/25 11:02	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-69
Lab Code: R2513917-003

Service Request: R2513917
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.3	ug/L	1.0	1	11/11/25 11:03	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-70
Lab Code: R2513917-004

Service Request: R2513917
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/11/25 11:05	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-71
Lab Code: R2513917-005

Service Request: R2513917
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.6	ug/L	1.0	1	11/11/25 11:06	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-72
Lab Code: R2513917-006

Service Request: R2513917
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.1	ug/L	1.0	1	11/11/25 11:08	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-73
Lab Code: R2513917-007

Service Request: R2513917
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.8	ug/L	1.0	1	11/11/25 11:12	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-74
Lab Code: R2513917-008

Service Request: R2513917
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.7	ug/L	1.0	1	11/11/25 11:14	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-75
Lab Code: R2513917-009

Service Request: R2513917
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.7	ug/L	1.0	1	11/11/25 11:15	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-76
Lab Code: R2513917-010

Service Request: R2513917
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.4	ug/L	1.0	1	11/11/25 11:17	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-77
Lab Code: R2513917-011

Service Request: R2513917
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.2	ug/L	1.0	1	11/11/25 11:28	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-78
Lab Code: R2513917-012

Service Request: R2513917
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	5.0	ug/L	1.0	1	11/11/25 11:32	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-79
Lab Code: R2513917-013

Service Request: R2513917
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	4.3	ug/L	1.0	1	11/11/25 11:34	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-80
Lab Code: R2513917-014

Service Request: R2513917
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.0	ug/L	1.0	1	11/11/25 11:35	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-81
Lab Code: R2513917-015

Service Request: R2513917
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	36.4	ug/L	1.0	1	11/11/25 11:37	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: 218.1-82
Lab Code: R2513917-016

Service Request: R2513917
Date Collected: 10/23/25
Date Received: 10/24/25 08:14
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/07/25 14:57	



QC Summary Forms

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

Phone (585) 288-5380 Fax (585) 288-8475

www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2513917-MB1

Service Request: R2513917
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/07/25 14:13	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2513917-MB2

Service Request: R2513917
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/07/25 14:54	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2513917-MB3

Service Request: R2513917
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/11/25 11:25	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2513917-MB4

Service Request: R2513917
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	11/11/25 10:36	

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water

Service Request: R2513917
Date Collected: 10/23/25
Date Received: 10/24/25
Date Analyzed: 11/11/25

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name: 218.1-76
Lab Code: R2513917-010
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Matrix Spike				Duplicate Matrix Spike				% Rec Limits	RPD	RPD Limit
	Sample Result	Result	Spike Amount	% Rec	Result	Spike Amount	% Rec				
Lead, Total	1.4	20.9	20.0	97	20.9	20.0	97	70-130	<1		20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water

Service Request: R2513917
Date Collected: 10/23/25
Date Received: 10/24/25
Date Analyzed: 11/11/25

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name: 218.1-77
Lab Code: R2513917-011
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Matrix Spike				Duplicate Matrix Spike				RPD	RPD Limit
	Sample Result	Result	Spike Amount	% Rec	Result	Spike Amount	% Rec	% Rec Limits		
Lead, Total	1.2	21.5	20.0	101	21.2	20.0	100	70-130	1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water

Service Request: R2513917
Date Collected: 10/23/25
Date Received: 10/24/25
Date Analyzed: 11/7/25

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name: 218.1-82
Lab Code: R2513917-016
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike		Result	Duplicate Matrix Spike		% Rec Limits	RPD	RPD Limit
			Spike Amount	% Rec		Spike Amount	% Rec			
Lead, Total	ND U	19.4	20.0	97	19.2	20.0	96	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.

dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water

Service Request: R2513917**Date Analyzed:** 11/07/25**Lab Control Sample Summary
Inorganic Parameters****Units:**ug/L**Basis:**NA**Lab Control Sample**

R2513917-LCS1

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	19.3	20.0	97	85-115

ALS Group USA, Corp.

dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water

Service Request: R2513917

Date Analyzed: 11/07/25

Lab Control Sample Summary

Inorganic Parameters

Units:ug/L

Basis:NA

Lab Control Sample

R2513917-LCS2

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	20.8	20.0	104	85-115

ALS Group USA, Corp.

dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water

Service Request: R2513917
Date Analyzed: 11/11/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L**Basis:**NA**Lab Control Sample**

R2513917-LCS3

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	19.7	20.0	98	85-115

ALS Group USA, Corp.

dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: Belfast CSD Elementary/Middle/High School/2023L-218.1
Sample Matrix: Drinking Water

Service Request: R2513917

Date Analyzed: 11/11/25

Lab Control Sample Summary

Inorganic Parameters

Units:ug/L

Basis:NA

Lab Control Sample

R2513917-LCS4

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	20.5	20.0	103	85-115

1.5 Laboratory Certifications

**NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER**



Expires 12:01 AM April 01, 2026
Issued April 01, 2025

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE
Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MS. CHRISTINE KUTZER
ALS ENVIRONMENTAL - ROCHESTER
1565 JEFFERSON ROAD BUILDING 300, SUITE 360
ROCHESTER, NY 14623

NY Lab Id No: 10145

*is hereby APPROVED as an Environmental Laboratory in conformance with the
National Environmental Laboratory Accreditation Conference Standards (2016) for the category*
ENVIRONMENTAL ANALYSES POTABLE WATER
All approved analytes are listed below:

Bacteriology	
Coliform, Total / E. coli (Qualitative)	SM 20, 21-23 9223B (-04) (Colliert)
Dissolved Gases	
Acetylene	RSK-175
Ethane	RSK-175
Ethene (Ethylene)	RSK-175
Methane	RSK-175
Propane	RSK-175
Fuel Additives	
Methyl tert-butyl ether	EPA 524.2
Naphthalene	EPA 524.2
Metals I	
Arsenic, Total	EPA 200.8 Rev. 5.4
Barium, Total	EPA 200.8 Rev. 5.4
Cadmium, Total	EPA 200.8 Rev. 5.4
Chromium, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Copper, Total	EPA 200.8 Rev. 5.4
Iron, Total	EPA 200.7 Rev. 4.4
Lead, Total	EPA 200.8 Rev. 5.4
Manganese, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Mercury, Total	EPA 245.1 Rev. 3.0
Selenium, Total	EPA 200.8 Rev. 5.4
Silver, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Zinc, Total	EPA 200.7 Rev. 4.4

Serial No.: 70111

Property of the New York State Department of Health. Certificates are valid only at the address shown and must be conspicuously posted by the laboratory. Continued accreditation depends on the laboratory's successful ongoing participation in the Program. Consumers may verify a laboratory's accreditation status online at <https://appa.health.ny.gov/pubdoh/applinks/wc/elappublicweb/>, by phone (518) 485-5570 or by email to elap@health.ny.gov.

Page 1 of 5

