

December 1, 2025

Mr. Scott Christ
Holland CSD
103 Canada Street
Holland, New York 14080

Re: Lead Testing in School Drinking Water – Additional Initial Sampling

Dear Mr. Christ:

Included with this letter is Stohl Environmental LLC's report for the Lead in Drinking Water Sampling performed by Holland Central School District. Sampling was performed in the following buildings on November 20, 2025:

- **Holland High School – 103 Canada St., Holland, NY**
- **Holland Middle School – 11720 Partridge Rd., Holland, NY**
- **Holland Elementary School - 173 Canada St., Holland, NY**

Based upon the sampling and analysis performed, none of the additionally tested sources of potable have been identified as having lead concentrations in water above the NYS Action Level of 5 parts per billion. A summary of the results is as follows:

Sample #	Location	Fixture/Outlet type	Laboratory Analysis (in ppb)
133.1-100	High School – Kitchen Steamer	Steamer	< 1.00
133.2-100	Middle School – Kitchen Steamer	Steamer	2.54
133.3-100	Elementary School – Kitchen Steamer	Steamer	< 1.00

If after reviewing this letter you have any questions, or if we can be of assistance in any other way, please do not hesitate to call. Thank you for the opportunity to be of service to Holland Central School District.

Sincerely,
Stohl Environmental, LLC.



Michael Scinta
EPA Lead Risk Assessor

Enc.



7469 Whitepine Rd
 North Chesterfield, VA 23237
 Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Report Number: 25-11-03947

Client: Stohl Environmental
 3860 California Road
 Orchard Park, NY 14127

Received Date: 11/21/2025
 Reported Date: 11/25/2025
 Sampled By:
 Tech Certification #:

Project/Test Address: 2023L-133; Holland ES/MS/HS

Client Number:
 33-5980

Laboratory Results

Fax Number:
 716-312-8092

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
25-11-03947-001	133.1-100	11/20/2025	HS KITCHEN STEAMER	<1.00	11/24/2025	
25-11-03947-002	133.2-100	11/20/2025	MS KITCHEN STEAMER	2.54	11/24/2025	
25-11-03947-003	133-3-100	11/20/2025	ES KITCHEN STEAMER	<1.00	11/24/2025	

Method: EPA 200.8
 Analyst: Nicole Holloway
 Accreditation #: NY 11714

Reviewed By Authorized Signatory: *Melissa Kanode*

Melissa Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion

NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER



Expires 12:01 AM April 01, 2026
Issued April 01, 2025

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE

Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MS. JULIE DICKERSON
ENVIRONMENTAL HAZARDS SERVICES, LLC
7469 WHITEPINE ROAD
N. CHESTERFIELD, VA 23237

NY Lab Id No: 11714

*is hereby APPROVED as an Environmental Laboratory in conformance with the
National Environmental Laboratory Accreditation Conference Standards (2016) for the category
ENVIRONMENTAL ANALYSES POTABLE WATER
All approved analytes are listed below:*

Metals I

Arsenic, Total	EPA200.8 Rev. 5.4
Copper, Total	EPA200.8 Rev. 5.4
Lead, Total	EPA200.8 Rev. 5.4
Manganese, Total	EPA200.8 Rev. 5.4



Serial No.: 70597

Property of the New York State Department of Health. Certificates are valid only at the address shown and must be conspicuously posted by the laboratory. Continued accreditation depends on the laboratory's successful ongoing participation in the Program. Consumers may verify a laboratory's accreditation status online at <https://apps.health.ny.gov/pubdoh/applinks/wc/elappublicweb/>, by phone (518) 485-5570 or by email to elap@health.ny.gov.

