

Lead in School Drinking Water Report

Brier Terrace Middle School



EXPLANATION OF TESTING AND RESULTS

Results in this report represent sampling conducted by Washington State Department of Health (DOH). Per [RCW 28A.210.410](#) sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols.

[RCW 28A.210.410](#) does not require remediation for fixtures testing at 5 ppb and under. DOH offers post-remediation testing only for outlets that initially tested above 5 ppb. After a school completes remediation, DOH will provide up to two post-remediation sampling visits. If after the second post-remediation sampling, outlets test above 5 ppb, the district will be responsible for finding a contractor to conduct additional sampling and testing. For questions regarding sampling, testing, and results, please email: leadfreekids@doh.wa.gov.

DEFINITIONS

Fixture Housing
Location

Room/space where
fixture is located
(i.e. room number,
gym, playground)

Fixture Housing Type

Structure that contains
the individual fixtures
where water samples
were collected from.
Fixture housing may
contain one or more
individual fixture for
sampling.

Fixture Location
Details

Location within a
room or space where
fixture housing is
located, starting to the
left of the entrance and
rotating clockwise, of
the total number of
fixture housings in a
room or space
(e.g. 1/5, 2/5)

Fixture Type

Tap, Sprayer, Water
Fountain, Water Bottle
Filler, Ice maker

Fixture Position

Left, Center, Right

Date(s) collected: 2025-10-08

Date(s) analyzed: 2025-10-14

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
1	412175	Building C Cafeteria	Sink - Multi-Compartment	Kitchen	1 of 3 south wall	Tap	center	412
2	412214	Building B Shop	Fountain/Tap Combo	Rm31b	1 of 1	Tap	right	163
3	412187	Building A Main	Sink	South Conference Room	1 of 1	Tap	center	148
4	412189	Building A Main	Sink	Library Workroom	1 of 1	Tap	center	96
5	412198	Building A Main	Sink - Multi-Compartment	Rm28	1 of 7	Tap	center	95
6	412199	Building A Main	Sink - Multi-Compartment	Rm28	2 of 7	Tap	center	27
7	412213	Building B Shop	Fountain/Tap Combo	Rm31b	1 of 1	Tap	center	26
8	412200	Building A Main	Sink - Multi-Compartment	Rm28	3 of 7	Tap	center	21
9	412209	Building A Main	Sink	Rm26	1 of 3 left side of counter	Tap	center	16

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
10	412206	Building A Main	Sink	Rm27	2 of 3 center	Tap	center	11
11	412201	Building A Main	Sink - Multi-Compartment	Rm28	4 of 7	Tap	center	10
12	412207	Building A Main	Sink	Rm27	3 of 3 right	Tap	center	10
13	412210	Building A Main	Sink	Rm26	2 of 3 left on right side	Tap	center	10
14	412176	Building C Cafeteria	Sink	Kitchen	2 of 3 middle island	Tap	center	9
15	412204	Building A Main	Sink - Multi-Compartment	Rm28	7 of 7	Tap	center	8
16	412215	Building B Shop	Fountain/Tap Combo	Rm32	1 of 1	Water Fountain	left	8
17	412188	Building A Main	Sink	Planning A	1 of 1	Tap	center	6
18	412196	Building A Main	Sink	Rm30	1 of 1	Tap	center	6
19	412203	Building A Main	Sink - Multi-Compartment	Rm28	6 of 7	Tap	center	6
20	412211	Building A Main	Sink	Rm26	3 of 3 right on	Tap	center	6

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
					right side			
21	412178	Building C Cafeteria	Sink	Staff Lounge	1 of 1	Tap	center	5
22	412205	Building A Main	Sink	Rm27	1 of 3 left	Tap	center	5
23	412208	Building A Main	Fountain	Across Rm26	1 of 1	Water Fountain	center	5
24	412216	Building B Shop	Fountain/Tap Combo	Rm32	1 of 1	Tap	center	5
25	412182	Building A Main	Sink	Workroom	1 of 1	Tap	center	4
26	412195	Building D Gym	Sink	Music Storage	1 of 1	Tap	center	4
27	412212	Building B Shop	Fountain/Tap Combo	Rm31b	1 of 1	Water Fountain	left	4
28	412217	Building B Shop	Fountain/Tap Combo	Rm32	1 of 1	Tap	right	3
29	412177	Building C Cafeteria	Sink	Kitchen	3 of 3 west wall	Tap	center	2
30	412183	Building A Main	Fountain/Tap Combo	Health Room	1 of 1	Tap	left	2
31	412191	Building D Gym	Fountain	Boys Locker Room	1 of 2 left	Water Fountain	center	2

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
32	412194	Building D Gym	Fountain with Bottle Filler	Girls Locker Room	1 of 1	Water Bottle Filler	center	2
33	412202	Building A Main	Sink	Rm28	5 of 7	Tap	center	2
34	412179	Building C Cafeteria	Fountain with Bottle Filler	Cafeteria	1 of 1	Water Fountain	center	1
35	412184	Building A Main	Fountain/Tap Combo	Health Room	1 of 1	Water Fountain	right	1
36	412185	Building A Main	Fountain with Bottle Filler	Library Hallway	1 of 1	Water Fountain	center	1
37	412190	Building A Main	Fountain	Right Of Rm14	1 of 1	Water Fountain	center	1
38	412193	Building D Gym	Fountain with Bottle Filler	Girls Locker Room	1 of 1	Water Fountain	center	1
39	412180	Building C Cafeteria	Fountain with Bottle Filler	Cafeteria	1 of 1	Water Bottle Filler	center	<1
40	412181	Building A Main	Fountain	Left Of Rm15	1 of 1	Water Fountain	center	<1
41	412186	Building A Main	Fountain with Bottle Filler	Library Hallway	1 of 1	Water Bottle Filler	center	<1
42	412192	Building D Gym	Fountain	Boys Locker Room	2 of 2 right	Water Fountain	center	<1
43	412197	Building A Main	Fountain	Left Of Rm29	1 of 1	Water Fountain	center	<1