

DOH Result Line number	ICOS Building Name	Site Map Building Name	Fixture Location	 Fixture Type	Result - entered manually, check DOH report
1	Unit A	Main Bld	F101 NW corner - 4 of 6	Sink faucet	6
2	Unit A	Main Bld	c107	Sink faucet	5
3	Unit A	Main Bld	B120 - Career Center	Sink faucet	5
4	Unit A	Bld A	Rm A208 left	Sink faucet	3
5	Unit A	Main Bld	Health rm	Sink faucet	3
6	Unit A	Main Bld	D200 Pod/Unit	Sink faucet	3
7	Unit A	Main Bld	F100 pod/unit	Bubbler	3
8	Unit A	Main Bld	C106	Bubbler	3
9	Unit A	Bld A	Rm A208 Right	Sink faucet	2
10	Unit A	Main Bld	C201A - from hall	Bubbler	2
11	Unit A	Main Bld	Rm E201 - Left	Sink faucet	2
12	Unit A	Main Bld	Rm E201 - Right	Bubbler	2
13	Unit A	Main Bld	E200 Pod/Unit	Sink faucet	2
14	Unit A	Main Bld	Rm F201 - 2 of 2 (right)	Sink faucet	2
15	Unit A	Main Bld	F101 South of door to hall - 2 of 6	Sink faucet	2
16	Unit A	Main Bld	Hall across from G111 - left	Water fountain	2
17	Unit A	Main Bld	across from G103 storage - left	Water fountain	2
18	Unit A	Main Bld	Kitchen - 2 of 5 - south wall (cooler, freezer area)	Sink faucet	2
19	Unit A	Main Bld	E100d planning	Sink faucet	2
20	Unit A	Main Bld	D107 - From hall	Bubbler	2
21	Unit A	Main Bld	C100D planning	Sink faucet	2
22	Unit A	Main Bld	C101C - from hall	Sink faucet	2
23	Unit A	Main Bld	Health rm	Bubbler	1
24	Unit A	Main Bld	C201A - from hall	Sink faucet	1
25	Unit A	Main Bld	C200 Pod/Unit	Bubbler	1

EWH - Initial Water Testing Results

26	Unit A	Main Bld	C206 - from unit	Sink faucet	1
27	Unit A	Main Bld	C206 - from unit	Bubbler	1
28	Unit A	Main Bld	D206 from unit	Bubbler	1
29	Unit A	Main Bld	Rm D201	Bubbler	1
30	Unit A	Main Bld	F200 Pod/unit	Bubbler	1
31	Unit A	Main Bld	F200D planning	Sink faucet	1
32	Unit A	Main Bld	Rm F201 - 1 of 2 (Left)	Sink faucet	1
33	Unit A	Main Bld	F100D planning	Sink faucet	1
34	Unit A	Main Bld	F101 west on the north wall - 5 of 6	Sink faucet	1
35	Unit A	Main Bld	Kitchen 3 of 5	Sink faucet sprayer	1
36	Unit A	Main Bld	D101 - sink only	Sink faucet	1
37	Unit A	Main Bld	D100 Pod/Unit	Sink faucet	1
38	Unit A	Main Bld	D100 Pod/Unit	Bubbler	1
39	Unit A	Main Bld	C101C - from hall	Bubbler	1
40	Unit A	Bld A	theater bathroom left	Water fountain	<1
41	Unit A	Bld A	theater bathroom Right	Water fountain	<1
42	Unit A	Bld A	A200f Green room	Sink faucet	<1
43	Unit A	Bld A	Rm A207 Left	Sink faucet	<1
44	Unit A	Bld A	Rm A207 center	Sink faucet	<1
45	Unit A	Bld A	Rm A207 right	Sink faucet	<1
46	Unit A	Bld A	Rm A207 right	Bubbler	<1
47	Unit A	Bld A	Rm A 204 left	Sink faucet	<1
48	Unit A	Bld A	Rm A 204 right	Sink faucet	<1
49	Unit A	Bld A	Hall A111 short, left	Water fountain	<1
50	Unit A	Bld A	Hall A111, tall right	Water fountain	<1
51	Unit A	Bld A	Rm A111	Water fountain	<1

EWB - Initial Water Testing Results

52	Unit A	Bld A	Rm A112	Water fountain	<1
53	Unit A	Main Bld	Main Office Entry	Water fountain	<1
54	Unit A	Main Bld	B206 - Workroom in the Main office	Sink faucet	<1
55	Unit A	Main Bld	B223 - Counseling workroom	Sink faucet	<1
56	Unit A	Main Bld	C200 Pod/Unit	Sink faucet	<1
57	Unit A	Main Bld	C200D - Planning	Sink faucet	<1
58	Unit A	Main Bld	C201C - from unit	Sink faucet	<1
59	Unit A	Main Bld	Hall outside C200	Water fountain	<1
60	Unit A	Main Bld	D207 from hall	Sink faucet	<1
61	Unit A	Main Bld	D207 from hall	Bubbler	<1
62	Unit A	Main Bld	D206 from unit	Sink faucet	<1
63	Unit A	Main Bld	D200 Pod/Unit	Bubbler	<1
64	Unit A	Main Bld	D200D Planning	Sink faucet	<1
65	Unit A	Main Bld	Rm D201 - Left	Sink faucet	<1
66	Unit A	Main Bld	Rm D201 - Right	Sink faucet	<1
67	Unit A	Main Bld	Hall outside D200 unit	Water fountain	<1
68	Unit A	Main Bld	Rm E201 - Right	Sink faucet	<1
69	Unit A	Main Bld	E200 Pod/Unit	Bubbler	<1
70	Unit A	Main Bld	E200D planning	Sink faucet	<1
71	Unit A	Main Bld	Hall Outside E200 Pod/unit - Left	Water fountain	<1
72	Unit A	Main Bld	Hall Outside E200 Pod/unit - Right	Water fountain	<1
73	Unit A	Main Bld	F200 Pod/unit	Sink faucet	<1
74	Unit A	Main Bld	Rm F206 is a TYPO - Meant F201 - Norht/Right	Bubbler	<1
75	Unit A	Main Bld	Hall Outside F100 Pod/unit	Water fountain	<1
76	Unit A	Main Bld	F100 Pod/unit	Sink faucet	<1
77	Unit A	Main Bld	F101 closest to F101A - 1 of 6	Sink faucet	<1

EWB - Initial Water Testing Results

78	Unit A	Main Bld	F101 North of door to hall - 3 of 6	Sink faucet	<1
79	Unit A	Main Bld	F101 North of door to hall - 6 of 6	Sink faucet	<1
80	Unit A	Main Bld	Hall across from G108 - left	Water fountain	<1
81	Unit A	Main Bld	Hall across from G108 - right	Water fountain	<1
82	Unit A	Main Bld	Hall across from G111 - right	Water fountain	<1
83	Unit A	Main Bld	Weight rm G108	Water fountain	<1
84	Unit A	Main Bld	Training room G106 - counter top	Sink faucet	<1
85	Unit A	Main Bld	Training room G106 - wall	Sink faucet	<1
86	Unit A	Main Bld	G105 - Girls locker room	Water fountain	<1
87	Unit A	Main Bld	Hall across from G104 - boys locker - left	Water fountain	<1
88	Unit A	Main Bld	Hall across from G104 - boys locker - right	Water fountain	<1
89	Unit A	Main Bld	across from G103 storage - right	Water fountain	<1
90	Unit A	Main Bld	G104 - Boys locker room	Water fountain	<1
91	Unit A	Main Bld	serving area - Left	Water fountain	<1
92	Unit A	Main Bld	serving area - Right	Water fountain	<1
93	Unit A	Main Bld	Kitchen 1 of 5 - center Island (near kettles)	Sink faucet	<1
94	Unit A	Main Bld	Kitchen 4 of 5	Kettle filler	<1
95	Unit A	Main Bld	Kitchen 5 of 5	Ice Machine	<1
96	Unit A	Main Bld	Hall Outside E100 Pod/Unit	Water fountain	<1
97	Unit A	Main Bld	Hall Outside E100 Pod/Unit	Bottle filler	<1
98	Unit A	Main Bld	Rm E101	Sink faucet	<1
99	Unit A	Main Bld	E100 Pod/Unit	Sink faucet	<1
100	Unit A	Main Bld	E100 Pod/Unit	Bubbler	<1
101	Unit A	Main Bld	H100 hallway - Great Hall lobby	Water fountain	<1
102	Unit A	Main Bld	Hall Outside D100 Pod/Unit	Water fountain	<1
103	Unit A	Main Bld	D101 - sink combo	Sink faucet	<1

EWB - Initial Water Testing Results

104	Unit A	Main Bld	D100d Planning	Sink faucet	<1
105	Unit A	Main Bld	D106 - from unit	Sink faucet	<1
106	Unit A	Main Bld	D106 - from unit	Bubbler	<1
107	Unit A	Main Bld	D107 - From hall	Sink faucet	<1
108	Unit A	Main Bld	C106	Sink faucet	<1
109	Unit A	Main Bld	C100 Pod/unit	Sink faucet	<1
110	Unit A	Main Bld	C100 Pod/unit	Bubbler	<1
111	Unit A	Main Bld	Hall Outside C100 Pod/Unit	Water fountain	<1
112	Unit A	Main Bld	B102 - Library workroom	Sink faucet	<1
113	Unit A	Main Bld	B110 - Staff Lounge	Sink faucet	<1